


PRE-QUALIFYING (PQ) CRITERIA FOR VENDORS**PI NO. 241527350 REV.00****PROJECT – RAHUGHAT , KODYAR & KUTTIYADI HEP**


- 1) Vendor (OEM / Authorized dealer) should have supplied similar type Position feedback device (Magnetostrictive / Micro-pulse type) of offered make in Hydro Power Station / any other industry with following parameters in last 5 years (from tender opening date Part-1).


- (a) Active electric stroke: 120 mm
(b) Accuracy: 0.05% of FS

Vendor shall furnish unpriced PO copy and Delivery Challan / Invoice with Approved document (Drawing / Bill of Material / Data Sheet) or any other relevant documentary evidence as proof of supplying Position type feedback device (Magnetostrictive / Micro-pulse type) with above parameters.

- 2) The Vendor should be authorized dealer of offered Position type feedback device (Magnetostrictive / Micro-pulse type) and submit the authorization letter from OEM. It is not applicable for OEM.
- 3) The OEM of Position type feedback device (Magnetostrictive / Micro-pulse type) should have ISO certificate.


PRASHANT KUMAR
Dy. Manager
HPE Division
BHEL, Bhopal.


शिव प्रभात सिंह / SHIV PRABHAT SINGH
प्रबंधक / Manager
एच.पी.ई. विभाग/HPE Division
बी.एच.ई.एल., भोपाल/BHEL, Bhopal


अमित पाण्डेय/AMIT PANDEY
उप महाप्रबंधक / Dy. General Manager
एच.पी.ई. विभाग / H.P.E. Division
बी.एच.ई.एल., भोपाल/BHEL, BHOPAL