




Technical Pre-Qualification Requirement (PQR) for procurement of 20 Pin plug socket assembly from “local suppliers”.

Sl no.	Pre-Qualification Requirements	“BIDDER” to comment	
		Document to be submitted	Bidder Compliance Yes/No
1.0	Bidder should be “Local supplier” of circular aluminum body hard anodic coated multi-pin plug and socket with minimum current rating of 20 Amps. Bidder should have supplied minimum 10 Nos (Ten) 20 Pin or above such plug & socket in last five (05) years, for Oil & gas industry application (To be reckoned from the bid opening date).	Un priced PO copies/ Contract Copies issued by buyer. Along with copy of delivery challan/Store receipt etc.	Yes/no
2.0	Authorized dealer/ distributor/ agent of such “Local Supplier” meeting PQR requirement at Sl 1.0 can also participate in the tender.	Authorization certificate from Principal “Local supplier”.	Yes/No
3.0	Bidder should have adequate facility for circular aluminum body hard anodic coated multi-pin Plug and socket in India to meet the “Local Supplier” criteria. Incase Bidder is authorized dealer/distributor then bidder should submit such documents of their principal supplier.	Self-certified details of their facilities covering details of plant, machinery & product profile.	Yes/No

Notes:

- “Local supplier” is defined in BHEL tender enquiry.
- In absence of compliance above PQR, supplier offer is liable to be rejected.
- Information submitted by “local supplier” shall be correct in all respect. In case any deviation/false information is revealed later on, BHEL is free to initiate appropriate punitive proceeding as per prevalent processes and guidelines of company.




Prepared By	Checked By	Approved By
 Prateek kumar singh Sr engineer/TME	 30.12.20 S K Yadav Sr Manager/TME	 30/12/2020 S P Singh Sr DGM/TME

Technical Pre-Qualification Requirement (PQR) for procurement of 1000 Ampere single pole contact assembly from "local suppliers"

Sl no.	Pre-Qualification Requirements	"BIDDER" to comment	
		Document to be submitted	Bidder Compliance Yes/No
1.0	Bidder should be "Local supplier" of silver coated single pole contact assembly made from copper alloy with minimum current rating of 1000 Amps. Bidder should have supplied minimum 10 Nos (Ten) of such contact assembly in last five (05) years, for Oil & gas industry application (To be reckoned from the bid opening date).	Un priced PO copies/ Contract Copies issued by buyer. Along with copy of delivery challan/Store receipt etc.	Yes/no
2.0	Authorized dealer/ distributor/ agent of such "Local Supplier" meeting PQR requirement at Sl. 1.0 can also participate in the tender.	Authorization certificate from Principal "Local supplier".	Yes/No
3.0	Bidder should have adequate facility for silver coated single pole contact assembly made from copper alloy in India to meet the "Local Supplier" criteria. Incase Bidder is authorized dealer/distributor then bidder should submit such documents of their principal supplier.	Self-certified details of their facilities covering details of plant, machinery & product profile.	Yes/No

Notes:

- "Local supplier" is defined in BHEL tender enquiry.
- In absence of compliance above PQR, supplier offer is liable to be rejected.
- Information submitted by "local supplier" shall be correct in all respect. In case any deviation/false information is revealed later on, BHEL is free to initiate appropriate punitive proceeding as per prevalent processes and guidelines of company.

Prepared By	Checked By	Approved By
 Prateek kumar Singh Sr Engineer/ TME	 S K Yadav Sr manager/TME	 S P Singh Sr DGM/TME