

# BHARAT HEAVY ELECTRICALS LIMITED, JHANSI

## SUPPLY & FIXING OF CABLE TRAY IN NEW SHOPS/STORES

### NOTE :


- 1 VENDOR must submit complete information against clause No.9.0 The offer meeting this clause would only be processed.
- 2 The " offered" Column and where applicable, the " Deviations" Column of this format shall be filled in by the Vender and submitted along with the offer. Technical details also submitted with the offer. Inadequate / incomplete, ambiguous, or unsustainable information against any of the clauses of the specification / requirements shall be treated as non - compliance.
- 3 The offer and all documents enclosed with offer should be in English language only.


### SCOPE :


### SPECIFICATION CUM COMPLIANCE CERTIFICATE OF CABLE TRAY


S.NO.	DESCRIPTION FOR BHEL REQUIREMENT	SPECIFIED / TO BE CONFIRMED BY	OFFERED	DEVIATIONS
<b>1.0</b>	<b>SCOPE</b>			
1.1	This specification governs the quality requirements of supply & fixing of cable tray for new stores/Shops	VENDER TO CONFIRM		
<b>2.0</b>	<b>REQUIREMENT</b>			
2.1	Ladder type cable tray - 400 Meter	VENDER TO CONFIRM		
2.2	Perforated type cable tray - 270 meter	VENDER TO CONFIRM		
<b>3.0</b>	<b>SPECIFICATION</b>			
<b>3.1</b>	<b>TYPE - LADDER TYPE STEEL CABLE TRAY.</b>			
3.1.1	Material - Mild steel	VENDER TO CONFIRM		
3.1.2	Side fail - Formed channel,	VENDER TO CONFIRM		
3.1.3	Nominal height of rail channel - 3 Inch	VENDER TO CONFIRM		
3.1.4	Thickness of sheet - 2 mm	VENDER TO CONFIRM		
3.1.5	Ladder rung - Rounded corners with continuous slots size - 40x15 mm	VENDER TO SUBMIT		
3.1.6	Width - 200 mm	VENDER TO CONFIRM		
3.1.7	Length - 2.5 Meter	VENDER TO SUBMIT		
3.1.8	Finish - Painted	VENDER TO CONFIRM		
<b>3.2</b>	<b>PERFORATED TYPE STEEL CABLE TRAY.</b>			
3.2.1	Material - Mild steel	VENDER TO CONFIRM		
3.2.2	Thickness of sheet - 2 mm	VENDER TO CONFIRM		
3.2.3	Width - 200 mm	VENDER TO CONFIRM		
3.2.4	Depth - 25 mm	VENDER TO CONFIRM		
3.2.5	Length - 2.5 Meter	VENDER TO CONFIRM		
3.2.6	Finish - Painted	VENDER TO CONFIRM		
<b>4.0</b>	<b>FIXING</b>			
4.1	Supplied cable tray will be fixed in new store (drawing of the stores/shops will be provided by BHEL)	VENDER TO CONFIRM		
4.2	Items(accessories & hardware) required for the jointing, tightening etc will be included in the offer and supplied with the tray.	VENDER TO CONFIRM		
4.3	Support material if required will be provided by BHEL free of cost but fixing of support material will be included in the offer.	VENDER TO CONFIRM		
4.4	The supplier shall bring their own tools for the fixing of cable tray ( on returnable basis ).	VENDER TO CONFIRM		


SPECIFICATION CUM COMPLIANCE CERTIFICATE OF CABLE TRAY				
S.NO.	DESCRIPTION FOR BHEL REQUIREMENT	SPECIFIED / TO BE CONFIRMED BY	OFFERED	DEVIATIONS
5.0	<b>GUARANTEE</b>			
5.1	Guarantee for complete work shall be for 24 months from the date of installation (fixing).	VENDER TO CONFIRM		
6.0	<b>PACKING:</b>			
6.1	All components shall be suitably packed so that the material reaches BHEL without any damage/loss in transit.	VENDER TO CONFIRM		
7.0	<b>MISCELLANEOUS :</b>			
7.1	All material used should be of the best of their respective kinds and should of the appropriate I.S. Specification/ I S I mark & all workman ship should be of best quality.	VENDER TO CONFIRM		
7.2	Fixing of cable tray to be done by the supplier at site with their own labour, tools and tackles, winch etc.	VENDER TO CONFIRM		
7.3	Not with standing any thing the details in this specification, if any thing else is required for its functioning the same shall be specially brought and included in offer	VENDER TO CONFIRM		
8.0	<b>DOCUMENTATION :</b>			
8.1	Technical literature of the offered cable tray	VENDER TO SUBMIT		
9.0	<b>BHEL reserves the right to verify information submitted by vender. In case the information is found to be false/ incorrect, the offer shall be rejected.</b>	Vender to confirm		

  
Y.K Dhingra  
Sr. Engr(WEX)

  
Arjun Singh  
Mgr(WEX)

  
Inder Mathur  
Sr. Mgr(WEX)

  
A.K. Shivpuri  
Sr. Mgr(WEX)

  
S.J. Chakraborty  
Sr. DGM(WEX)