

**Specification against enquiry no- E7120483**

| <b>S.No</b> | <b>Item Description</b>  | <b>Quantity</b> | <b>Delivery</b> |
|-------------|--|-----------------|-----------------|
| 1           | <p>40 AH, 30 VOLT SUB-STATION TUBULAR BATTERY BANK WITH SUITABLE BATTERY CHARGER. BATTERY BANKCONSIST OF 15 NOS,2 VOLT, 40 AH CAPACITY BATTERY AT 10 HR RATE OF DISCHARGE. THE BATTERY BANK SHALL BE SUPPLIED COMPLETE WITH BATTERY, INTER CONNECTION COPPER STRIP, LEVEL INDICATOR, FUNNEL, CELL TESTER, HYDROMETER ETC. BATTERY SHALL BE IN CHARGED CONDITION.</p> <p>THE CHARGER SHALL BE SUITABLE TO CHARGE BATTERY BANK. CHARGER SHALL HAVE FACILITY TO CHARGING IN FLOAT AND BOOST. CHARGING MAX. D.C. CONTINUOUS OUT PUT SHALL 6 AMP, BATTERY CHARGER SHALL BE SUITABLE FOR INPUT SUPPLY OF 230 VOLT SINGLE PHASE AC SUPPLY MAKE OF BATTERY EXIDE / AMCO / STANDARD ONLY.</p> | 03 SETS         | Oct-12          |