



Form No. 2038

उत्पाद मानक

परिणामित्र

शाप / अभि / निर्देश

PRODUCT STANDARD

TRANSFORMER

SHOP / ENGG. INSTRUCTIONS

TR20038A


1 पृष्ठों में 1

PAGE 1 OF 1

REF

COMP. dng

COPYRIGHT AND CONFIDENTIAL
The Information on this document is the property of BHARAT HEAVY ELECTRICALS LIMITED. It must not be used directly or indirectly in any way detrimental to the interest of the Company.

TITLE : FLEXIBLE SEPARATOR FOR ATMOSEAL TYPE CONSERVATOR

W (WIDTH) = $11/2$ (CONSERVATOR DIA) + 40
L(LENGTH) = (CONSERVATOR LENGTH – DIA OF CONSERVATOR)
+ WIDTH OF FLEXIBLE SEPARATOR

G = (CONSERVATOR LENGTH – DIA OF CONSERVATOR – 200)

IT. NO.	STYLE NO. OF FLEXIBLE SEPARATOR	CONSERVATOR SIZE	W	L	G	REMARKS
01		Ø 800 X LENGTH	1297			CALL DIM. L & G ON INDENT
02	BP9096048172 ST604817	Ø 1000 X 4400	1610	5010	3200	
03		Ø 1300 X LENGTH	2082			CALL DIM. L & G ON INDENT
04		Ø 1600 X LENGTH	2553			CALL DIM. L & G ON INDENT

NOTE :
FLEXIBLE SEPARATOR SHALL MEET THE SPECIFICATION REQUIREMENT OF TR10150A.

TR20038A

PAGE 1 OF 1

पुनः Rev.
10
दि Dt.
04/11/23

SHEET REAFFIRMED

Rashmi Nitin NKM

वितरण

DISTRIBUTION

सं.

स्वीकृत किया :

APPROVED : sd/MCJ sd/SNA

पुनः Rev.
09
दि Dt
13/11/18

SHEET REAFFIRMED

Rashmi Nitin NKM

TRE/TRM/FTM
TRX/TTG/QC-TCB
/ QA-TCB /
JHANSI

तैयार किया PREPD.
D.T.K

जारी किया ISSUED
टीआरई/मानक TRE/STD.

दिनांक
DATE
30-12-83