

Enquiry



Bharat Heavy Electricals Limited
Transmission Business Group
Materials Management

Project : GSECL UKAI

Enquiry No	Enquiry Dt	Rev No	Rev Dt	PI No	Enquiry Type	Inspection by	Due Dt	Commercial Comments	Technical Comments	Signing Authority
429E134	24-Jul-09	0		342290198	Package		14-Aug-09	Enquiry is due on 14-August-09		Rajesh Kumar Engineer

Document Enclosed

- Technical Specifications
- Terms & Conditions for Indigenous Enquiry
- Activity Schedule
- Schedule of Information (checklist) to be furnished
- Schedule of Commercial Deviation
- Schedule of Technical Deviation

SN	Equipment	Phy Unit	Qty	Unit Exworks	% ED	% CST	% VAT	% ST	Unit F&I	Plan Dt	Comments
1	CABLE 420KV EHV CABLE	LOT	1							31-Jan-10	QUANTITIES AS PER TECHNICAL SPECIFICATION DOC. NO. TB-308-316-030 REV-01

You are requested to submit your most competitive offer so as to reach us positively by the tender opening date & time. THE TENDERS NOT RECEIVED WITHIN SCHEDULED DATE AND TIME ARE LIKELY TO BE IGNORED. BHEL shall not be responsible for any postal delay.

IN YOUR OWN INTEREST YOU ARE ADVISED TO CAREFULLY READ "THE INSTRUCTIONS TO BIDDERS". INCOMPLETE BIDS AND/OR BIDS NOT COMPLYING WITH TENDER CONDITIONS SHALL BE TREATED AS NON RESPONSIVE AND ARE LIKELY TO BE IGNORED.

In case Tender Documents are not received within 7 days of this E-mail message, intimate BHEL accordingly. If no intimation is received, it will be considered that you have received tender enquiry and delay in submission offer due to late receipt of tender documents will not be entertained.

OFFERS THROUGH E-MAIL / FAX:

WHOSOEVER DESIRES TO SEND OFFERS ON THEIR OWN RISK (COMPLETE IN ALL RESPECTS) VIA E-MAIL or FAX HAVE TO SEND THE OFFERS TO THE COMMON E-MAIL ADDRESS tenderbox@bhelindustry.com or 011-24365869 FAX .

THE RECEIVED EMAIL OFFERS WILL BE PRINTED BY PURCHASE COORDINATOR AND PUT THEM INTO COVERS AS PER CONVENTIONAL METHOD FOR TENDER OPENING I.E., TECHNO COMMERCIAL & PRICE OFFER SHALL BE PUT INTO TWO SEPARATE COVERS AND BOTH THE COVERS ARE KEPT IN THIRD COVER DULY SUPER SCRIBING ENQY. NO. AND DUE DATE.

OFFERS SENT TO ANY OTHER E-MAIL ID or FAX NO AND INCOMPLETE OFFERS SHALL NOT BE CONSIDERED FOR EVALUATION PURPOSE.

It is suggested that the bidders are advised to send the files with 'password protection', procedure for giving a password to a file has been given below:

For saving Excel file with password

Steps to be followed:

1. Click on the FILE option in XP system and Start sign in Vista system then go to SAVE AS option.
2. Select the location to save and Click on the TOOLS box and go to GENERAL OPTION.
3. It will ask for the password, type the password into open or modify box or both as required.
4. Then click on the OK button it will ask for recenter of the password.
5. After reentering the password click on the save box.

For saving Word file with password

Steps to be followed:

1. Click on the FILE option in XP and Start sign in Vista then go to SAVE AS option.
2. Select the location to save and Click on the TOOLS box and go to SECURITY OPTION in XP system and GENERAL OPTION in Vista system.
3. It will ask for the password, type the password into open or modify box or both as required.
4. Then click on the OK button it will ask for recenter of the password.
5. After reentering the password click on the save box.

The vendors who has sent offers with password, the passwords are to be forwarded to another email id: supplierinfo@bhelindustry.com

MSME STATUS

"THOSE INDUSTRIES WHO HAVE FILED A MEMORANDUM WITH THE CONCERNED AUTHORITIES AND REGISTERED AS MICRO & SMALL ENTERPRISE UNDER MICRO, SMALL AND MEDIUM ENTERPRISES DEVELOPMENT ACT 2006, HAVE TO SUBMIT A COPY OF SUCH REGISTRATION CERTIFICATE / MEMORANDUM TO BHEL FOR NECESSARY COMPLIANCES OF THE ABOVE ACT".

Please acknowledge the receipt of tender enquiry and fax back this letter by ticking the appropriate item below.

U 215

We acknowledge the receipt of tender.

- (a) The offer against subject enquiry shall be submitted by the scheduled date and time.
(b) We regret to quote. The item in reference is out of our manufacturing range.
(c) We regret because of our prior commitments.
(d) Any other reason.

To
Mr S S Chandi
SDGM (TBMM)
TBG, Industry Sector,
Integrated Office Complex,
Lodhi Road,
New Delhi-110003

Ph: 011-41793145 / 24302145
Fax: 011-24365869

Signature and Seal of Tenderer

Enquiry No : 429E134 Enquiry Dt : 24-Jul-09

TRANSMISSION BUSSINESS GROUP
MATERIAL MANGEMENT
BHEL LODI ROAD NEW DELHI

ACTIVITY SCHEDULE

Please submit this format duly filled in along with offer. Time indicated will be used for calculating contractual delivery period.

ENQUIRY NO. 429E134

Date: 24/07/09

PROJECT: 1 X 500 UNIT-6 UKAI

ITEM: CABLE

VENDOR :

OFFER REF.

SL. NO.	ACTIVITY	ACTIVITY TIME IN WEEKS	REMARKS IF ANY
1.	Receipt of P.O		
2.	P.O Acceptance	ONE WEEK	Vendor must Submit Po acceptance with in one week
3.	Submission of documents necessary for getting manufacturing clearance like Drawings, date sheet etc.		Documents complete in all respect are to be Submitted. Delay in approval on account of incomplete / inadequate information shall be the responsibility of supplier
4.	Review and Approval of documents and issue of manufacturing clearance	BHEL ACTIVITY	Vendor must ensure to reply all queries within 3 working days.
5.	Manufacturing Time		Manufacturing time be indicated considering all constrains & must include time required for internal inspections etc.
6	Raise inspection call	-VE 2 WEEKS TO SL NO 5	Call for inspection must be raised atleast two weeks in advance in the prescribed format. Non availability of offered material for inspection to the inspector will be viewed very seriously & may result in financial implications. The date of inspection must be with in the period indicated in 5 above.
7	Inspection	BHEL	
8	Issue of MICC, MDCC & other documents like EDEC , Road permits etc	BHEL	Vendor must indicate requirement well in advance.
9	Dispatch	ONE WEEK	Vendor must ensure to dispatch with in one Week of receiving all documents rquired
10	Installation Services(Laying/Erection/Testing /Commisioning		

Total time in vendor's scope.

Please mention constraints if any. For multiple lot delivery activity landmark for each lot should be mentioned. Multiple inspection calls for one lot are to be avoided & delay on this account shall be vendor's responsibility

SIGNATURE AND SEAL

ENQUIRY NO. 429E134

Date: 24/07/09

CHECKLIST**SCHEDULE OF INFORMATION TO BE FURNISHED WITH THE OFFER**

NOTE: This format is to be submitted in original only, duly filled in. Reproduction of this format on bidder's letter head or on other paper is not acceptable.

Put a tick mark on "YES" if the information is enclosed with the offer or put a tick mark on "NO" if the information is not enclosed or write "NOT APPLICABLE" if the information is not applicable.

1.	Technical offer with detailed schedule of equipment / material and spares enclosed.	YES / NO
2.	Guaranteed Technical Particulars as per Section – 4 enclosed.	YES / NO
3.	Schedule of deviation, if any, clause wise with respect to Technical Specification enclosed.	YES / NO
4.	Standard Manufacturing Quality Plan enclosed.	YES / NO
5.	GA Drawings with dimensions and weights & foundation / fixing details enclosed.	YES / NO
6.	Drawing and Data submission schedule enclosed.	YES / NO
7.	Type Test Reports enclosed.	YES / NO
8.	Bar Chart showing the schedule indicating time required for design, manufacture, test and inspection, transport, erection, site testing and commissioning enclosed.	YES / NO
9.	Makes of all components as per technical Specification enclosed.	YES / NO
10.	Schedule of commercial deviation exception from the General Terms and Conditions	YES / NO

The above checklist is verified for:-

Offer Ref. :
 Equipment :
 Submitted by : M/s
 Project Reference. :

Signed with Seal

Date

ENQUIRY NO. 429E134

Date: 24/07/09

SCHEDULE OF COMMERCIAL DEVIATION

The following are the deviations / variations exception from the General Terms and Conditions:-

SL. NO.	CLAUSE NO. OF GENERAL TERMS & CONDITIONS	STATEMENT OF DEVIATION

Incase, this schedule is not submitted, it will be presumed that the equipment / material to be supplied under this contract is deemed to be in compliance with the General terms and Conditions.

If there is NIL deviation, even then the format to be filled as NIL DEVIATION.

NOTE: Continuation sheets of like size and format may be used as per the Bidder's requirement and shall be annexed to this schedule.

Place

Signature of the authorized representative of

Date

Bidder's Name

Designation

Company seal

SCHEDULE OF TECHNICAL DEVIATION

The following are the deviations / variations exception from the Technical Specifications:-

SL. NO.	CLAUSE NO. OF TECHNICAL SPECIFICATIONS	STATEMENT OF DEVIATION

Incase, this schedule is not submitted, it will be presumed that the equipment / material to be supplied under this contract is deemed to be in compliance with the Technical Specifications.

If there is NIL deviation, even then the format to be filled as NIL DEVIATION.

NOTE: Continuation sheets of like size and format may be used as per the Bidder's requirement and shall be annexed to this schedule.

Place

Signature of the authorized representative of

Date

Bidder's Name

Designation

Company seal

SCHEDULE OF PRICE(Installation Services)

***(BIDDERS TO STRICTLY ENSURE SUBMITTING THE PRICE BIDS IN THIS FORMAT)**

Sl. No.	Item Description	QTY./Unit	Laying / Erection (A)	Supervision of Laying / Erection (B)	Testing and Commissioning (C)	Taxes and Duties (D)	Total sum of services (E=A+B+C+D)
	Cables						
6							

TOTAL

Mention currency of the rates quoted

SCHEDULE OF PRICE(Supply Items)

(BIDDERS TO STRICTLY ENSURE SUBMITTING THE PRICE BIDS IN THIS FORMAT)

TENDER ENQUIRY NO. : 429E134 , DATE 24/07/09

SL. NO.	DESCRIPTION OF ITEM	UNIT	QUANTITY	UNIT FOB/EX WORKS PRICE	TOTAL FOB/EX WORKS PRICE	UNIT FREIGHT AND INSURANCE UP TO PORT OF DISCHARGE (FOREIGN BIDDER)	UNIT FREIGHT AND INSURANCE FROM PORT OF DISCHARGE(FOREIGN BIDDER) EX WORKS (INDIAN BIDDER) UP TO SITE	TOTAL FREIGHT AND INSURANCE	TAXES AND DUTIES IF ANY	TOTAL F.O.R (DESTINATION) PRICE
3	2 As Per BOQ	M	4	5	6	7	7	8	9	10
		Nos								
		LOT								
		LOT								
		LOT								
		M								
		Nos								
		LOT								
		LOT								
		LOT								
TOTAL										

- NOTE: 1. PLEASE NOTE THAT UNPRICED COPY OF PRICE BID (i.e. WITH ALL PRICES BLANKED) SHALL BE FURNISHED ALONG WITH TECHNICAL BID.
 2. REQUIRED COPIES OF FORMAT BE MADE & DETAILS MAY BE ANNEXED.
 3. THE PRICES MUST BE QUOTED IN THE PRESCRIBED UNIT ONLY.
 4. SEAWORTHY PACKING CHARGES ARE INCLUSIVE
 5. MENTION PORT OF LOADING
 6. FOREIGN VENDORS TO QUOTE FOB PRICES AND INDIAN VENDORS TO QUOTE EX WORKS PRICES.
 7. INDIAN VENDORS TO MENTION ALL TAXES AND DUTIES SEPERATELY IN COL 9
 8. FOREIGN VENDORS TO QUOTE FREIGHT AND INSURANCE UP TO PORT OF DISCHARGE (MUMBAI) FREIGHT FROM MUMBAI TO SIGHT AS PER APPLICABLE BHTEL RATE CONTRACT WILL BE ADDED FOR ARRIVING AT TOTAL COST TO BHTEL ALTERNATIVELY FOREIGN VENDORS CAN ALSO QUOTE FREIGHT FROM PORT TO SITE IF THEY WISH TO MAKE THEIR OWN TRANSPORT ARRANGEMENT AFTER CUSTOM CLEARANCE BY BHTEL
- (*) 9. INDIAN VENDORS TO QUOTE FREIGHT AND INSURANCE FROM WORKS TO SITE.

SIGNATURE AND SEAL OF BIDDER

INTEGRITY PACT

Between

Bharat Heavy Electricals Ltd. (BHEL), a company registered under the Companies Act 1956 and having registered office at "BHEL House", Siri Fort, New Delhi -110049 (India) hereinafter referred to as "The Principal", which expression unless repugnant to the context or meaning hereof shall include its successors or assigns of the ONE PART

And

_____, (description of the party along with address), hereinafter referred to as "The Bidder/Contractor" which expression unless repugnant to the context or meaning hereof shall include its successors or assigns of the OTHER PART

Preamble

The Principal intends to award, under laid-down organizational procedures, contract/s for

_____. The Principal values full compliance with all relevant laws of the land, rules and regulations, and the principles of economic use of resources, and of fairness and transparency in its relations with its Bidder(s)/Contractor(s).

In order to achieve these goals, the Principal will appoint Independent External Monitor(s), who will monitor the tender process and the execution of the contract for compliance with the principles mentioned above.

Section 1- Commitments of the Principal

- 1.1 The Principal commits itself to take all measures necessary to prevent corruption and to observe the following principles:
 - 1.1.1 No employee of the Principal, personally or through family members, will in connection with the tender for, or the execution of a contract demand, take a promise for or accept, for self or third person, any material or immaterial benefit which the person is not legally entitled to.
 - 1.1.2 The Principal will, during the tender process treat all Bidder(s) with equity and reason. The Principal will in particular, before and during the tender process, provide to all Bidder(s) the same information and will not provide to any Bidder(s) confidential/additional information through which the Bidder(s) could obtain an advantage in relation to the tender process or the contract execution.
 - 1.1.3 The principal will exclude from the process all known prejudiced persons.
- 1.2 If the Principal obtains information on the conduct of any of its employees which is a penal offence under the Indian Penal Code 1860 and Prevention of Corruption Act 1988 or any other statutory penal enactment, or if there be a substantive suspicion in this regard, the Principal will inform its Vigilance Office and in addition can initiate disciplinary actions.

Section 2 – Commitments of the Bidder(s)/Contractor(s)

- 2.1 The Bidder(s)/Contractor(s) commit himself to take all measures necessary to prevent corruption. He commits himself to observe the following principles during his participation in the tender process and during the contract execution.
 - 2.1.1 The Bidder(s)/Contractor(s) will not, directly or through any other person or firm, offer, promise or give to the Principal or to any of the Principal's employees involved in the tender process or the execution of the contract or to any third person any material, immaterial or any other benefit which he/ she is not legally entitled to, in order to obtain in exchange any advantage of any kind whatsoever during the tender process or during the execution of the contract.

- 2.1.2 The Bidder(s)/ Contractor(s) will not enter with other Bidder(s) into any illegal or undisclosed agreement or understanding, whether formal or informal. This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to introduce cartelization in the bidding process.
- 2.1.3 The Bidder(s)/ Contractor(s) will not commit any penal offence under the relevant IPC/ PC Act; further the Bidder(s)/ Contractor(s) will not use improperly, for purpose of competition or personal gain, or pass on to others, any information or document provided by the Principal as part of the business relationship, regarding plans, technical proposals and business details, including information contained or transmitted electronically.
- 2.1.4 The Bidder(s)/ Contractor(s) will, when presenting his bid, disclose any and all payments he has made, and is committed to or intends to make to agents, brokers or any other intermediaries in connection with the award of the contract.
- 2.2 The Bidder(s)/ Contractor(s) will not instigate third persons to commit offences outlined above or be an accessory to such offences.

Section 3- Disqualification from tender process and exclusion from future contracts

If the Bidder(s)/ Contractor(s), before award or during execution has committed a transgression through a violation of Section 2 above, or acts in any other manner such as to put his reliability or credibility in question, the Principal is entitled to disqualify the Bidder(s) / Contractor(s) from the tender process or take action as per the separate “Guidelines for Suspension of Business Dealing with Suppliers/ Contractors” framed by the Principal.

Section 4 – Compensation for Damages

- 4.1 If the Principal has disqualified the Bidder(s) from the tender process prior to the award according to Section 3, the Principal is entitled to demand and recover the damages equivalent to Earnest Money Deposit/ Bid Security.
- 4.2 If the Principal has terminated the contract according to section 3, or if the Principal is entitled to terminate the contract according to section 3, the Principal shall be entitled to demand and recover from the Contractor liquidated damages equivalent to 5% of the contract value or the amount equivalent to Security Deposit/Performance Bank Guarantee, whichever is higher.

Section 5 – Previous Transgression

- 5.1 The Bidder declares that no previous transgressions occurred in the last 3 years with any other company in any country conforming to the anti-corruption approach or with any other Public Sector Enterprise in India that could justify his exclusion from the tender process.
- 5.2 If the Bidder makes incorrect statement on this subject, he can be disqualified from the tender process of the contract, if already awarded, can be terminated for such reason.

Section 6 – Equal treatment of all Bidders/Contractors/ Sub-contractors

- 6.1 The Bidder(s)/ Contractor(s) undertake(s) to demand from his sub-contractors a commitment consistent with this Integrity Pact. This commitment shall be taken only from those sub-contractors whose contract value is more than 20% of Bidder's/Contractor's contract value with the Principal.
- 6.2 The Principal will enter into agreements with identical conditions as this one with all Bidders and Contractors.
- 6.3 The Principal will disqualify from the tender process all bidders who do not sign this pact or violate its provisions.

Section 7 - Criminal Charges against violating Bidders / Contractors / Sub-Contractors

If the Principal obtains knowledge of conduct of a Bidder, Contractor or Subcontractor, or of an employee or a representative or an associate of a Bidder, Contractor or Subcontractor which constitutes corruption, or if the Principal has substantive suspicion in this regard, the Principal will inform the Vigilance Office.

Section 8 - Independent External Monitor(s)

- 8.1 The Principal appoints competent and credible Independent External Monitor for this pact. The task of the Monitor is to review independently and objectively, whether and to what extent the parties comply with the obligations under this agreement.
- 8.2 The Monitor is not subject to instructions by the representatives of the parties and performs his functions neutrally and independently. He reports to the CMD, BHEL.
- 8.3 The Bidder(s) / Contractor(s) accepts that the Monitor has the right to access without restriction to all contract documentation of the Principal including that provided by the Bidder(s) / contractor(s). The Bidder(s) /Contractor(s) will grant the monitor, upon his request and demonstration of a valid interest, unrestricted and unconditional access to his contract documentation. The same is applicable to Sub-contractor(s). The Monitor is under contractual obligation to treat the information and documents of the Bidder(s) /Contractor(s) / Sub-contractor(s) with confidentiality.
- 8.4 The Principal will provide to the Monitor sufficient information about all meetings among the parties related to the contract provided such meetings could have an impact on the contractual relations between the Principal and the contractor. The parties offer to the Monitor the option to participate in such meetings.
- 8.5 As soon as the Monitor notices or believes to notice, a violation of this Agreement, he will so inform the Management of the Principal and request the Management to discontinue or take corrective action, or heal the situation, or to take other relevant action. The Monitor can in this regard submit non-binding recommendations. Beyond this, the Monitor has no right to demand from the parties that they act in a specific manner, refrain from action or tolerate action.

- 8.6 The Monitor will submit a written report to the CMD, BHEL, within 8 to 10 weeks from the date of reference or intimation to him by the Principal and, should the occasion arise, submit proposals for correcting problematic situations.
- 8.7 The CMD, BHEL, shall decide the compensation to be paid to the Monitor and its terms and conditions.
- 8.8 If the Monitor has reported to the CMD, BHEL, a substantiated suspicion of an offence under relevant IPC / PC Act, and the CMD, BHEL, has not, within reasonable time, taken visible action to proceed against such offence or reported it to the Vigilance Office, the Monitor may also transmit this information directly to the Central Vigilance Commissioner, Government of India.
- 8.9 The number of Independent External Monitor(s) shall be decided by the CMD, BHEL.
- 8.10 The word 'Monitor' would include both singular and plural.

Section 9 – Pact Duration

- 9.1 This pact begins when both parties have legally signed it. It expires for the Contractor 12 months after the last payment under the respective contract and for all other Bidders 6 months after the contract has been awarded.
- 9.2 If any claim is made / lodged during this time, the same shall be binding and continue to be valid despite the lapse of this pact as specified as above, unless it is discharged / determined by the CMD, BHEL.

Section 10 – Other Provisions

- 10.1 This agreement is subject to Indian Laws and jurisdiction shall be registered Office of the Principal i.e. New Delhi.
- 10.2 Changes and supplements as well as termination notices need to be made in writing. Side agreements have not been made.
- 10.3 If the Contractor is a partnership or a consortium, this agreement must be signed by all partners or consortium members.
- 10.4 Should one or several provisions of this agreement turn out to be invalid, the remainder of this agreement remains valid. In this case, the parties will strive to come to an agreement to their original intentions.
- 10.5 Only those bidders/contractors who have entered into this agreement with the Principal would be competent to participate in the bidding. In other words, entering into this agreement would be a preliminary qualification.

For & On behalf of the Principal
(Office Seal)

For & On behalf of the Bidder/ Contractor
(Office Seal)

Place _____

Date _____

Witness: _____

(Name & Address) _____

Witness: _____

(Name & Address) _____

45

PRICE ADJUSTMENT FORMULA

(400/220KV XLPE CABLE)

The prices of cables shall be adjusted to the official LME (Cash) price ruling on following working day from the issue date of our Purchase Order.

The offered price of cable shall be increased or decreased by the following formula for rise or fall respectively in the basic cash price of Cu and Al :

$$P_1 = P_0 + [(Cu_1 - Cu_0) * VFc] + [(Al_1 - Al_0) * VFa]$$

Where :

P₁ = The final contract price of cable (USD/kM)

P₀ = The initial order price of Cable (USD/kM)

Cu₁ = The official LME Copper Cash price of the next LME working day of our Purchase Order issue date. (USD/MT)

Cu₀ = The base copper price (LME Rate of Enquiry floating Date).

VFc = Copper weight per cable KM (MT/kM) – To be Quoted

Al₁ = The official LME Aluminum price of the next LME working day of our Purchase Order issue date.

Al₀ = The base Aluminum price (LME Rate of Enquiry floating Date i.e.).

VF_a = Aluminum weight per cable KM (MT/kM) - To be Quoted

Initial Price (P₀) quoted in any currency will be converted to USD on the exchange rate of Bid opening date between currency of quotation and USD.

P₁ will be converted back to currency quoted on same exchange rate. However the VFc and VF_a (i.e. Cu and Al weight will be decided after bid opening depending upon the figure received in offer in consultation with TBEM.

In case of variation one value of VFc and VF_a will be given to all the vendors to submit impact on submitted prices to bring all the vendors at par.

**BHARAT HEAVY ELECTRICALS LTD.
(TRANSMISSION BUSINESS GROUP)**

GENERAL TERMS AND CONDITIONS FOR ENQUIRY

Sr. No	ENQUIRY NO. <u>429E134</u>	DATE <u>24-7-09</u>
1.	<p>1. Sealed quotations are invited for the items mentioned in the enquiry. Quotations should be typed and free from over writing and erasures, corrections or additions must be clearly written both in words and figures and attested and otherwise offer may be rejected.</p> <p>2. Bidder must ensure that their quotation is received / dropped in the tender box on or before 10.15 AM of the due date of opening in Material Management Division, Transmission Business Group, BHEL, Integrated Office Complex, Lodhi Road, New Delhi – 110 003, India. Phone : 091-11- 41793289, Fax :091-11-24365869, Email: rky@bhelindustry.com deepakkant@bhelindustry.com</p> <p>3. The same shall be opened at 11.00 AM on the same day. Tenders received late shall be rejected. Bidders must ensure that tender documents are deposited on or before due date. Bidders are required to submit the credential along with Techno commercial bid to substantiate the qualifying requirement .</p> <p>4. Bids are to be submitted in Two parts: i) Techno-commercial bid (Part I) – To be submitted in duplicate. A copy of price bid (Part II) (without prices) is also to be enclosed in Part I bid. ii) Price bid (Part II) – To be submitted only in one copy in a separate sealed envelope. This should not contain any Technical or Commercial Terms. The rates should be quoted both in figures and words. In case of any difference between figures and words, the quoted rate in words will prevail over figure. If there is a calculation mistake in multiplication of unit rate with quantity, then the unit rate quoted will be considered for calculation.</p> <p>Both Part I and Part II bids are to be sealed in separate envelope and both envelopes to be kept in another common envelope. Each envelope should be sealed and super scribed with enquiry no., item / package name, project name and due date of opening. Note:1 Representative deputed to witness tender opening must produce an authority letter from the signatory of offer at the time of tender opening.</p> <p>5. For any Technical clarification, please contact Shri Saroj Kumar, Sr. Engineer / TBEM BHEL, Integrated Office Complex, Lodhi Road, New Delhi – 110 003, India Phone : 091-11- 41793480, Fax :091-11-24369509, Email: sarojkumar@bhelindustry.com</p> <p>For any commercial clarification please contact person issuing enquiry.</p> <p>6. Price bid should not contain any information / description / terms & condition other than given in Part-I of the bid except prices, otherwise bid is liable for rejection.</p> <p>7. Price bid submitted along with the bid shall remain valid up to validity of offer. Unsolicited Supplementary / Revised price bid submitted during validity period of offer, unless asked by BHEL, shall not be considered. Withdrawal of quotation by the bidder, at any stage after its opening, may entail blacklisting of vendor.</p>	

Sr. No	ENQUIRY NO. 429E134	DATE 24.07.09
	<p>8. Enquiry condition for where the scope against this tender includes Installation and Commissioning of the equipment / material</p> <p>9. Authorized signatory should authenticate tender documents.</p> <p>There will be separate contract awarded for Supply portion and Site execution portion. For Supply portion General Terms and Conditions mentioned here shall be applicable for Site execution portion, Terms and conditions for Installation services shall be applicable. However, any breach in either of the contract shall be deemed as the breach of other contract also.</p>	
2.	<p>PRICES:</p> <p>A. The prices as quoted in price schedule remain firm after adjustment by the PVC adjustment formula attached with the enquiry.</p> <p>B. The break-up of price shall be as under:-</p> <ul style="list-style-type: none"> • Ex-Works price for Indian vendors • FOB (mention port) / CIF- destination port (Mumbai) for foreign <p>ii) Freight & Insurance: Indian vendors to quote Freight and insurance from works to site. Foreign vendors to quote Freight and Insurance charges from port of loading to port of discharge .</p> <p>iii) Type Test charges is to be quoted separately for each Test along with taxes and duties if such test is specified .</p> <p>iii) Erection / Commissioning supervision charges to be quoted separately along with applicable taxes and duties .</p> <p>Note: i) The purchase order shall be placed on Ex-works/ FOB/ CIF basis. ii) Evaluation shall be on landed cost at site to buyer. For foreign vendor, BHEL transport contract rates / freight charges from port to site will be added for evaluation. However foreign vendor can also quote for inland transport.(from port to site)</p> <p>iii) Price offer should clearly mention breakup of FREIGHT and INSURANCE up to DISCHARGE PORT – MUMBAI</p> <p>(iv) BHEL reserves right to exercise option of “REVERSE AUCTION” to obtain best price. (v) Price expressed in any currency will be converted to Indian rupee at the sailing exchange rate in India on the date of Bid opening.</p>	
3.	<p>TERMS OF PAYMENT: -</p> <p>a) FOR SUPPLY PORTION:- By irrevocable LC which will be opened after placement of order and receipt of performance bank guarantee for 10% of order value. All bank charges to supplier's account.</p> <p>90% against original invoice, original bill of lading, packing list, MICC (dispatch clearance given by BHEL quality group), guarantee certificate, certificate of origin, Transit Insurance Certificate.</p> <p>10% against material receipt at site against material receipt certificate by BHEL Site Incharge.</p> <p>b) FOR INSTALLATION SERVICES:- 100% direct payment within 15 days after acceptance of the installation services work.</p> <p>INTEREST LIABILITY In case of any delay in payment due to any reason, BHEL shall not pay any interest on delayed payment.</p>	
4	<p>GUARANTEE: The equipment / material shall be guaranteed for 18 months from the date of delivery or 12 months from the date of commissioning, whichever is earlier. The defective material / component shall be replaced free of cost at site.</p>	

Sr. No	ENQUIRY NO. 429E134	DATE 24-7-09
5.	SECURITY CUM PERFORMANCE BANK GUARANTEE: In the event of an order, tenderer shall furnish BG towards Security Cum Performance for 10% of total value of P.O., within two weeks of placement of P.O. valid till 60 days beyond the guarantee period, from a reputed Bank of the bidder's country, subject to Purchaser's approval, in our prescribed format. The original BG shall be sent by issuing bank directly to AGM - FINANCE, INDUSTRY SECTOR, BHARAT HEAVY ELECTRICALS LIMITED, INTEGRATED OFFICE COMPLEX, LODHI ROAD, NEW DELHI - 110 003, (INDIA).	
6.	INSPECTION: BHEL and / or customer may inspect the Equipment/Material before dispatch. In the event BHEL / Customer waives off inspection, certified TEST REPORTS and RESULTS shall be submitted for approval. Supplier shall obtain approval on Test reports and MICC (Material Inspection Clearance Certificate), before dispatch of equipment. BHEL / Customer may also carry out stage inspection during manufacturing of the ordered item. Supplier shall send inspection call on prescribed format only, with an advance notice of 15 days.	
7.	DISPATCH DOCUMENTS: Dispatch documents (Negotiable documents) shall normally comprise Original Invoice, AWB / Bill of Lading, Shipping / Packing lists (case wise), Transit Insurance certificate, Certificate of country of origin, Material Inspection Clearance certificate (MICC), Test Certificates & approval of acceptance & routine test certificates and manufacturer's guarantee certificate.	
8.	DELIVERY PERIOD: Bidder to specify delivery period in weeks from the date of LOI / PO in the activity schedule format enclosed with enquiry. Time for conduction of type test, if required, is to be separately indicated. Note: BOL/AWB date or Invoice date whichever is later shall be considered as delivery date for supply portion and date of completion of installation work shall be considered as delivery date for installation work.	
9.	DELAYED DELIVERY: In case of delay in execution of order beyond the lot wise contractual delivery, an amount of ½ % of total Ex-Works Value per week or part there-of subject to maximum of 5% of total Ex-Works value of P.O. will be withheld.	
10.	VALIDITY: The offer shall be valid for 120 days from the due date of opening.	
11.	ACCEPTANCE / REJECTION OF TENDER: BHEL reserves the right to reject in full or part, any or all tender without assigning any reason thereof. BHEL also reserves right to vary the quantities mentioned in the tender.	
12.	EVALUATION: Comparative statement shall be prepared based on overall quantity basis unless otherwise indicated in the enquiry. Evaluation of offers shall be done on the basis of delivered cost to BHEL.	
13.	DEVIATION: The bids having deviation(s) w.r.to tender are liable for rejection. However, BHEL, at its discretion, may load the prices for evaluation of offer with prior intimation to bidder.	
14.	ARBITRATION: All cases of disputes emanating from and relating to this contract, the matter shall be referred to the sole arbitration of Unit Head / GM, BHEL or any other person (including an employee of BHEL, even though he had to deal with the matter relating to this contract in any manner) nominated by him to act as sole arbitrator. The arbitration shall be under 'The arbitration and conciliation act 1996' and the rules there under as amended from time to time. The arbitrator may from time to time with the consent of the parties enlarge the time for making and publishing the award. The venue of arbitration shall be any Indian city as decided by BHEL.	
15.	LEGAL SETTLEMENT: All suits/claims in respect of this contract shall be in the courts having jurisdiction at New Delhi.	

Sr. No	ENQUIRY NO. 429E134	DATE 24-7-09
16.	SUBCONTRACTING: In case further subcontracting of BHEL order or part thereof is envisaged by supplier, the same can be done after written permission is obtained from BHEL. However it shall not absolve the supplier of the responsibility of fulfilling BHEL purchase order requirements.	
17.	RISK PURCHASE: In case the successful bidder fails to supply or fails to comply with the terms & conditions of the purchase order, BHEL reserves the right to source such material/ component / equipment/ system from any other agency at the risk and cost of the successful bidder.	
18.	ADJUSTMENT OF RECOVERY: Any amount payable by the supplier under any of the condition of this contract shall be liable to be adjusted against any amount payable to the supplier under any other works/contract awarded to him by any BHEL unit. This is without prejudice to any other action as may be deemed fit by BHEL.	
19.	FORCE MAJEURE CONDITION: If by reason of war, civil commotion, act of god, Government restrictions, strike, lockout which are not in control of supplier the deliveries are delayed, supplier shall not be held responsible.	
20	Integrity Pact: Submit signed copy of integrity pact (copy enclosed). Name of Independent External monitor to be considered (IEM): Shri D P Bagchi, Address: Y-165, Regency Park-II, Phase - IV, DLF City, Gurgaon - 122 009, Ph: 0124 - 4040876.	
21	Demurrage/ Wharfage: For the reasons of delay in receipt of documents from suppliers or due to the same being found to be incomplete, and/or faulty, the suppliers shall be responsible to reimburse in all demurrages / wharfages, if any, paid by BHEL (for stated reasons).	
22	Indemnity (Against Patents / Trademarks etc) : The supplier shall at all times indemnify the purchaser against all claims which may be made in respect of the said supply from any rights protected by patent registration of design or trade mark; provided always that in the event of any claim in respect of an alleged breach of patents registered design or trademark being made against. The purchaser -the-latter shall notify the seller of same and the seller shall be at liberty, but entirely at their own expenses, to conduct negotiation for settlement of deal with any litigation that may arise there from.	
23	Procurement will be from manufacturers only. Manufacturers should submit offers directly. However in case of involvement of any representative the details of the same along with the copy of the agreement should be submitted in the first part of the offer. Principal manufactures must ensure that the nominated representative do not represent any other manufacture for the same item.	

Signature of Bidder

Seal

Enquiry No _____ Dtd _____ /07/09
BHEL/TBG/ETC/01-02

**BHARAT HEAVY ELECTRICALS LTD.
(TRANSMISSION BUSINESS GROUP)**

TERMS & CONDITIONS FOR SUPERVISION / INSTALLATION SERVICES

Sl. No.	Terms & Conditions
1.0	<u>SCOPE OF WORK:</u> As per our Technical Specification No. TB-308-316-030.
2.0	<u>COMMENCEMENT OF WORK:</u> Project start / zero date for this work shall be intimated by BHEL.
3.0	<u>COMPLETION SCHEDULE:</u> Bidder to specify delivery period in weeks from the date of Project start / zero date in the activity schedule format enclosed with enquiry.
4.0	<u>OVER RUN CHARGES:</u> No over run charges are payable.
5.0	<u>IDLE LABOUR CHARGES:</u> No idle labour charges will be admissible in the event of any stoppage of work resulting in the contractor's workmen being rendered idle due to any reason at any time.
6.0	<u>SECURITY-CUM-PERFORMANCE GUARANTEE:</u> The contractor shall furnish security-cum-performance BG for 10% of total contract value within two weeks of placement of work order valid till guarantee period from a reputed Bank of the bidder's country, subject to Purchaser's approval in the prescribed format. The BG should be sent directly by your banker to AGM - FINANCE, INDUSTRY SECTOR, BHARAT HEAVY ELECTRICALS LIMITED, INTEGRATED OFFICE COMPLEX, LODHI ROAD, NEW DELHI – 110 003, (INDIA).
7.0	<u>INSURANCE:</u> The Contractor shall take insurance cover(s) to cover his Tools and Plant assets, workman compensation and third party liability. The contractor shall make available the original insurance cover(s) to the Engineer for necessary verification before commencement of work.
8.0	<u>GUARANTEE:</u> Though the work will be carried out under the supervision of BHEL Engineers, the contractor shall be responsible for the quality of the workmanship and shall guarantee the work done for a period of 15 months from the date of putting the complete system into commercial operation or 18 months from the date the system is declared completely erected, duly tested and accepted by customer, whichever is later and shall rectify free of cost all defects due to faulty erection detected during the guarantee period starting from the date of the completion of rectification. In the event of the contractor failing to repair the defective works within the time specified by the engineer, BHEL may proceed to undertake the repairs of such defective works at the contractor's risk and cost without prejudice to any other rights under the contract and recover the same from security deposit/ other dues of this project or any other project executed by the contractor.
9.0	<u>TERMS OF PAYMENT:</u> The terms of payment shall be as specified under Clause 3 of General Terms and Conditions of Overseas Enquiry.

SL. No.	<u>Terms & Conditions</u>
10.0	ESCALATION / PRICE VARIATION: Prices shall be firm for total contract period and extended period, if any, and no price escalation / price variation will be applicable.
11.0	COMPENSATION FOR DELAY IN EXECUTION: In case the contractor fails to complete the work within the time specified or any extension thereof subject to force major condition, the contractor shall be liable to pay by way of compensation, a sum equal to half percent (½%) of the contract price, per calendar week or part thereof by which the commissioning is delayed, subject to a ceiling of 5% of the contract price.
12.0	ADDITIONAL EXPENDITURE: In case any additional expenditure is incurred in the works arising out of the faulty execution of the works by the contractor, such additional expenditure shall be borne by the contractor.
13.0	REGULATION OF LOCAL AUTHORITIES AND STATUS : The contractor shall adhere to the regulation of local authorities and status.
14.0	DISCIPLINE OF WORKMEN: The contractor shall adhere to the disciplinary procedure set by the owner in respect of his employees and workman at site.
15.0	FORCE MAJEURE: The force majeure shall be as specified under Clause 19 of General Terms and Conditions of Overseas Enquiry.
16.0	ARBITRATION: The arbitration shall be as specified under Clause 14 of General Terms and Conditions of Overseas Enquiry.

We understand that the bids having deviation (s) w.r.t tender are to be out rightly rejected. BHEL, however at their discretion, if consider the bid, have undisputable right to load the prices for price comparison as they deem fit.

Signature of Supplier
With seal



BHARAT HEAVY ELECTRICALS LIMITED

TRANSMISSION PROJECTS ENGINEERING MANAGEMENT

DOCUMENT No.	TB-308-316-030	Rev no.-01	Prepared	Checked	Approved
TYPE OF DOC.	TECHNICAL SPECIFICATION	NAME	SK	DS	SN
TITLE		SIGN	-sd-	-sd-	-sd-
SPECIFICATION FOR 420kV HT POWER CABLES		DATE	06.03.09		
		GROUP	TBEM	W.O. No	88004
CUSTOMER/ CONSULTANT	GUJRAT STATE ELECTRICITY CORPORATION LTD. VADODARA/ TCE CONSULTING ENGINEERS LTD. BANGALORE				
PROJECT	1X500MW Unit-6 TPS-400/220kV Substation Ukai				

CONTENTS

Sec. No.	Description	No. of Sheets
1.	Scope , Specific Technical requirement and Quantities	6
	Annexure -A (HT Cable trench route)	1
	Annexure-B(Proposed trench section)	1
2.	Equipment Specification	11
3.	General Technical Requirements	9
	Title block	1
4.	Guaranteed Technical Particulars	3
5.	Schedule of technical deviations	1

COPYRIGHT & CONFIDENTIAL
The Information in this document is the property of BHARAT HEAVY ELECTRICALS LIMITED
This must not be used directly or indirectly in any way detrimental to the interest of the Company.

01	15.07.09	SK <i>SK</i>	DS <i>DS</i>	SN <i>SN</i>	To includes other alternative size of cables			
Rev No.	Date	Alte red	Checked	Approved	REVISION DETAILS			
Distribution			To	TBT S	O/C	TBMM	TBQM	TBCM
			Copies	-	1	3	-	-

SECTION 1
SCOPE, SPECIFIC TECHNICAL REQUIREMENTS AND QUANTITIES

1.0 SCOPE

This technical specification covers the requirements of design, manufacturing, testing at works, packing and dispatch, transporting, laying of cable at site in BHEL provided trenches, testing and commissioning at site of 400kV XLPE Cables , termination etc complete in all respect along with accessories .

Name of customer : Gujrat State Electricity Corporation Ltd. Vadodara
Name of Consultant : TCE Consulting Engineers Ltd. Bangalore
Name of the project : 1X500MW Unit-6 TPS-400/220kV Substation at Ukai

The specification comprise of following sections:

Section-1: Scope & Bill of Quantities.
Section-2: Specific technical requirements for the equipment under scope of supplies.
Section-3: General technical requirements for all equipments under the project.
Section-4: Equipment Data Sheet

In case of any conflict between various sections, order of precedence shall be in the same order as listed above.

A. SUPPLIES

- I. Supply of power cable, single core, Copper conductor compacted circular stranded, XLPE-insulated, *Corrugated Aluminium sheathed* , HDPE outer sheathed with outer conductive layer.
- II. Supply of cable termination kit , straight through joint , accessories, essential spares, tools and tackles.

B. INSTALLATION SERVICES

Complete cable installation services including laying , supervision , termination, clamping , testing and commissioning of the cable system, point to point.

The Specification envisages turnkey execution of a COMPLETE, POINT TO POINT, 400 kV CABLE SYSTEM and the scope includes all materials and service necessary to execute the job to satisfaction of GSECL and BHEL. Any other item /service required for the execution for the complete job shall be included in the offer , Whether specifically mentioned in the specification or not, The Bill of quantities included in the offer shall clearly reflect such items along with their respective quantities.

The exact requirement shall also be decided by supplier after visiting site & making precise measurments.The Payment of cables length will be as per actual measurement at site jointly.

Bidder shall offer both Supplies and Installtion Services as per this Technical Specification. Bids in which only Supplies or only Installation Services are offered shall be rejected.

Saraj Umer

1.1 SPECIFIC TECHNICAL REQUIREMENTS-

Sl. no.	Particulars	Unit	400kV
1.	Rated System Voltage	kV	400
2.	Highest System Voltage	kV	420
3.	Number of phases	Nos.	3
4.	System Frequency	Hz	50
5.	System earthing		Effectively earthed (solidly grounded)
6.	Rated peak withstand current	kA	100
7.	System fault current for one second	kA	40
8.	One minute power frequency withstand voltage	kV	630
9.	Rated lightning impulse withstand voltage (1.2/50 μ s)	kVp	1425
10.	Conductor area	mm ²	1200 or 1600 for 400kV GT and 400 for 400kV ST
11.	Type of conductor		Copper
12.	Insulation		XLPE
13.	Transformer rating to which the cables are proposed to be connected		For 400kV GT- 3 X 1 Phase 200MVA, (420/ $\sqrt{3}$)/21kV, YNd11 For 400kV ST- 63/28/35MVAMVA, 400/11.5/6.9kV, YNyn0yn0
14.	Continuous Current rating considering 10% overloading of Transformer	A	953 for 400kV GT, 101 for 400kV ST
15.	Nos of core per circuit	Nos.	3 core for main circuit and 1 core spare for 400kV GT, 3 core for 400kV ST
16.	Metallic sheath		Corrugated Aluminium
17.	Outer sheath		HDPE with outer conductive layer
18.	Creepage distance for termination	mm/kV	31

Saraj Umer

19.	Maximum permissible operating temperature of the conductor under (a) Rated continuous current (b) Short circuit	°C °C	90 250
20.	Daily load	Hours	24
21.	Sheath voltage	V	Sheath voltage to ground under normal operating condition shall not exceed 65
22.	Laying method	-	In RCC trench supported on rack with removable cover
23.	Cable configuration	-	Trefoil for 3 phase and flat for spare cable
24.	Screen earthing method	-	Cross-bonding
25.	Design ambient temperature	°C	50
26.	Minimum ambient temperature	°C	8

1.2 QUANTITIES

Material and Services required for the execution of the job are listed below. All item listed in the following BOQs shall be offered. Any item not appearing herein but clearly mentioned in Section 2 shall be included in the offer. The BOQs included in the offer to be submitted by the Bidder shall be exhaustive in this respect and shall cover completely the requirements of Section 1 and Section 2.

SUPPLY ITEMS

(1) 400kV Cables: GT yard to GT bay in 400kV Switchyard

Sl. no.	Description	Unit	Main Quantities (A)	Spare quantities (B)	Total Qty. (C=A+B)
1.	400kV 1C X 1200mm ² Copper conductor corrugated Aluminium sheath, XLPE cable complete with necessary auxiliary equipment	m	3300	1100	4400
2.	400kV 1C X 1600mm ² Copper conductor corrugated Aluminium sheath, XLPE cable complete with necessary auxiliary equipment	m	3300	1100	4400
3.	400kV outdoor type cable termination kit complete with porcelain terminal bushing for 1C X 1200mm ² Cable	Nos.	06	02	8
4.	400kV outdoor type cable termination kit complete with porcelain terminal bushing for 1C X 1600mm ² Cable	Nos.	06	02	8
5.	Straight through joints for 1C X 1200mm ² Cable between GT and GT bays	Nos.	06	02	8

Sasj Uman

6.	Straight through joints for 1C X 1600mm ² Cable between GT and GT bays	Nos.	06	02	8
7.	Earthing of cable as per requirement	Lot	1	1	2
8.	Trefoil clamps for 400kV cables	Lot	1	0	1
9.	Single type cleats for 400kV	Lot	0	1	1

(2) 400kV Cables: ST yard to ST bay in 400kV Switchyard

Sl. no.	Description	Unit	Main Quantities (A)	Spare quantities (B)	Total Qty. (C=A+B)
1.	400kV 1C X 400mm ² Copper conductor corrugated Aluminium sheath, XLPE cable complete with necessary auxiliary equipment	m	3180	0	3180
2.	400kV outdoor type cable termination kit complete with porcelain terminal bushing for ST bay	Nos.	06	0	6
3.	Straight through joints for 400kV cable between ST and ST bays	Nos.	06	0	6
4.	Earthing of cable as per requirement	Lot	1	0	1
5.	Trefoil clamps for 400kV cables	Lot	1	0	1

Note

- (1) Manufacturing lengths and drum length shall be determined as per the joint route survey with GSECL/BHEL & the quantities of joints may increase /decrease as per requirement.
- (2) Refer Annexure -A for cable proposed trench route.
- (3) The exact length may vary by $\pm 20\%$.
- (4) Spare cables shall be laid as a spares run. Both the end of spare cable shall be terminated.
- (5) Bidder will submit short circuit current calculation, continuous current rating calculation and sheath standing voltage calculation for justifying the size of the 400kV cable. Please refer Annexure-B for proposed trench i.e there will be three circuit 400kV GT, 400kV ST, 220kV ST(normal current 182A, trefoil formation, single point bonding), one spare run of 400kV GT and one spare run of 220kV ST. Any other calculations which may be required during detailed engineering stage may also be submitted.
- (6) Supplier will submit detailed bar chart indicating all the milestones from Engineering till manufacturing/ testing, dispatch to site and commissioning.
- (7) Earthing of HT cables shall be in supplier scope. Earth mat grid is existing and interconnected at both end of transformer yard and switchyard end. The complete earthing BOQ items if required to be supplied by the supplier and shall be clearly mentioned in the offer. The accessories shall necessary include the following but not limited to:
SVL, Link box for earthing, Link box for cross bonding, Earthing cable, bonding cables etc as per the requirement.
- (8) The cable trench and support angles in the trenches will be supplied by BHEL as per supplier recommendation. The trench design will be given by supplier.

Singh

- (9) Support structure and foundation for cable sealing end shall be provided by BHEL based on the input provided by supplier.
- (10) The spare 400kV cable will be used to replace any one of the cables of 400kV GT.
- (11) The necessary power supply at site shall be provided by BHEL at one point only.
- (12) Terminal connector for overhead connection with cable sealing end shall be provided by BHEL.
- (13) Any other tools and tackles and accessories required to complete the cable laying, termination and ETC shall be included in your offer. Please note BHEL shall not provide any equipments, tool and tackles for carrying out any test /or laying of cables.
- (14) The un-price BOQ shall be strictly as per cl. No. 1.2 sl. No. (1), (2) & (3) of quantities.
- (15) BHEL reserves the right to order full or part quantities & also to delete any item/s.

(3) Other services for cables

Sl. no.	Item Description	Unit	Rates of followings			Total sum of services (D=A+B+C)
			Laying /Erection (A)	Supervision of Laying /Erection (B)	Testing and Commissioning (C)	
1.	400kV Cables					
(i)	For 1C X 1200mm ²	4400 m				
(ii)	For 1C X 1600mm ²	4400 m				
(iii)	For 1C X 400mm ²	3180m				
2.	400kV outdoor cable termination kit					
(i)	For 1C X 1200mm ²	8 Nos.				
(ii)	For 1C X 1600mm ²	8 Nos.				
(iii)	For 1C X 400mm ²	6 Nos.				
3.	Straight through joint for following cables					
(i)	For 1C X 1200mm ²	8 Nos.				
(ii)	For 1C X 1600mm ²	8 Nos.				
(iii)	For 1C X 400mm ²	6 Nos.				
4.	Earthing of 400kV GT cable	1 lot				
5.	Earthing of 400kV ST cable	1 lot				
6.	4 days Training at site	1 lot				

1.3 TYPE TESTS

The Bidder shall submit valid type test reports (as per relevant IEC 62067 standard) for the tests carried out within last five years from the date of LOA (i.e. 07.09.2007). In case valid type test reports are not available then type test shall be perform free of cost.

1.4 INSPECTION & TESTING

Before being fitted on the equipment, all components shall be subjected to routine tests at the Contractors factory, provided by the relevant IEC standards. A detailed test report proving the successful passing of such tests shall be provided. Prior to dispatch, the routine & acceptance tests shall be carried out on cables and accessories in accordance with the applicable IEC /IS and the material shall be offered for final inspection by BHEL and GSECL in accordance with agreed quality plan with 4 weeks advance information.

Type test reports on identical rating cables and accessories shall be submitted for approval. In event of non-acceptability of submitted test reports on technical grounds at the contract stage, the type tests shall be conducted at no additional cost.

1.5 QUALITY PLAN

The contractor shall carry out the works in accordance with sound quality management principles which shall include such as controls which are necessary to ensure full compliance to all requirements of the specification & applicable international standards. These quality management requirement shall apply to all activities during design, procurement, manufacturing, inspection, testing, packaging, shipping, inland transportation, storage, site erection & commissioning. Contractor shall submit detailed Quality Plan for BHEL / customer's approval.

1.6 QUALIFYING REQUIREMENT


1.6.1 Offered equipment should have been supplied to any public sector electricity utility viz . State electricity board/ Corporations, NTPC, PGCIL etc. Should have given two years proven trouble free operational service in tropical climate during last 10 years. However , in case of equipment being manufactured in India under valid foreign collaboration, operating experience in tropical climate of offered collaborator's equipment, shall also be acceptable provided copy of valid collaboration agreement for the equipment offered is submitted with the tender. Further , in case of offer of imported equipment, the two years operating experience will be considered in respect of those areas only which are similar to tropical conditions prevailing in India. The offered equipment should have already been supplied to atleast two projects.

1.6.2 Type test reports as called for in cl. no. 1.3 shall also be submitted.

1.6.3 The placement of order is subject to final acceptance of the bidder by M/s. BHEL, M/s TCE Consulting Engineers Ltd., and the ultimate customer. Complete documentation shall be provided with the offer to allow facilitate "vendor acceptance".

Saroj Kumar

ANNEXURE -A




202

Sand W

400KV AND 220KV PROPOSED HT CABLE TRENCH ROUTE

TRENCH COVER



PROPOSED CABLE TRENCH SECTION

Sraj'w

SECTION 2 EQUIPMENT SPECIFICATION

1.0 GENERAL

The section covers the broad technical specifications of 400kV single core Copper conductor XLPE insulated, Aluminium corrugated sheathed cable system complete with accessories and spares etc.,

2.0 GENERAL REQUIREMENTS

The design and workmanship of the cable and accessories covered under this specification shall be in accordance with the best engineering practices to ensure satisfactory performance and service life of 50 years. The cable accessories shall also be designed for maximum reliability and acceptability.

Unless brought out clearly, the offer shall be deemed to confirm to this specification. Any deviation between this specifications and bid offered, if not clearly brought out and accepted by BHEL/GSECL will not be considered as a valid deviation.

The vendor shall bring out clearly any additional feature which they deem to include to give a complete and comprehensive offer. The vendor shall, however sustain his reasons for offering such additional feature/item in his proposal.

3.0 STANDARDS:

The XLPE Cables and the associated accessories shall conform to the following International standards, as amended/ revised till date, as appropriate:

IEC 62067(2001)	Power cables with extruded insulation and their accessories for rated voltage above 150 kV up to 500kV – Test methods and requirements.
IEC 60060 Part-1	High voltage test techniques
IEC 60187	General definitions & test requirements
IEC 60068	Seismic test methods for the equipment
IEC 60183	Guide to the selection of High Voltage Cables
IEC 60228	Conductors for insulated cables
IEC 60229	Tests on cable over sheaths
IEC 60230	Impulse test on cables and their accessories
IEC 60270	Partial Discharge Measurements
IEC 60287	Calculation of continuous current carrying capacity & losses
IEC 60332 Part-1	Test on Electric Cables under fire conditions

IEC 60502	Power Cables with extruded insulation and their accessories
IEC 60506	Switching Impulse test on EHV Insulators
IEC 60540	Test methods for insulations and sheaths of electric cables and cords
IEC 60811 Part-1 to Part-4	Common test methods for insulating and sheathing materials of electric cables
IEC 60840	Tests for power cables with extruded insulation
IEC 60859	Cable connections for gas insulated metal enclosed switchgear
IEC -60885 Part-3	Electrical test methods for electric cables
IEC 62087	
CIGRE WG21.03 (Electra 151) (Dec 1993)	Recommendation for electrical tests on extruded cables and accessories
IEEE 48	Test procedures and requirements for high voltage cable terminations
IEEE 404	Joints for use with solid dielectric cables
IEEE 635	Guide for selection and design of aluminium sheath

4.0 TECHNICAL PARAMETERS OF CABLES:

The rating and electrical characteristics of the single core, XLPE cables shall be as follows:

- a) **TYPE OF CABLE:**
400kV single core, stranded, annealed, copper conductor, segmental compacted, circular, XLPE insulated, corrugated Aluminium sheath, High Density Polyethylene outer sheathed cable.

The tests shall be as per IEC-62067- 2001 with latest amendments.

Voltage Grade	As per section-1
Maximum operating conductor temperature	90° C
Maximum conductor temperature under short Circuit for 1 Sec.	250° C

- b) Construction
- Single core stranded, annealed, copper conductor, segmental, compacted, circular, conductor screen, cross linked polyethylene (XLPE) insulation, core screen of semi-conducting water swellable layer, Corrugated Aluminium sheathed, semi-conducting bedding tapes, helically applied plain round copper wire, plain copper tape in open helix, water swellable tape with overall extruded High-Density Polyethylene sheath coated with graphite along with outer conductive layer.
- c) Conductor :
- Plain, annealed, high conductivity copper wires stranded, segmental conductor
- d) Conductor Screen :
- Extruded semi-conducting layer with adequate capacity
- e) Insulation :
- Dry cured cross linked polyethylene. In any particular point, the thickness may differ from the nominal thickness, however, the measured thickness shall be within the limits.
- f) Core/Insulation Screen
- Extruded semi-conducting layer.
- g) Longitudinal Water barrier
- Semi-conducting water swellable tape/s
- h) Radial Moisture Barrier
- Corrugated Aluminium sheath
- i) Bedding
- Semi-conducting tape/s.
- j) Armour Screen
- Helically applied non-magnetic plain copper wires
- k) Contact Tape
- Annealed plain copper tape in open helix.
- l) Water swellable tape
- Non-conducting water swellable tape.
- m) Outer Sheath
- Extruded High Density Polyethylene type ST 7 (black), anti-termite treated. Extruded outer conducting layer coated with graphite.

5.0 GENERAL TECHNICAL REQUIREMENTS OF CABLE:

- 5.1 The cable and all its accessories shall conform in all respects, to the requirement of the latest standards of IEC except in so far as they are modified in these specifications. Whenever a standard is specifically mentioned in the specification, it is understood that the corresponding standard or standard from amongst the source mentioned above shall also apply. It is, however,

- understood that the cable and accessories etc., supplied shall conform to one consistent set of standards except in so far as they are modified by the requirement of these specifications.
- 5.2 Cables/Cable accessories satisfying the quality requirements of other International standards, which ensure equal or better quality than the standards mentioned above shall also be acceptable. Where the equipment offered by the supplier conforms to other standards, salient points of difference between the standards preferred and the specified standards shall be informed. Four (4) copies of the reference standards in English language shall be furnished for reference.
- 5.3 The general principle on which these specifications are drawn up, is to permit the adaptation of modern manufacturing standards. The Contractor shall supply his own standard equipment as far as possible, provided they comply with the requirements of these specifications. However, should the Contractor wish to depart from the provisions of these specifications either on account of manufacturing practice or for any other reasons, he shall draw the attention of the Corporation to the proposed items of departure and shall submit such full information, drawings and specifications, full justification as will enable the relative merits.
- 5.4 In the event of these specifications or part thereof and of the Contractor's drawings, specifications, forms, tables etc., being found to disagree during the execution of the contract, these specifications shall be held as binding unless, the departures have been duly approved in writing by the Corporation.
- 5.5 All similar component parts of similar equipment supplied shall be interchangeable with one another.
- 5.6 The size of the conductors of the cable shall be sufficient to carry continuously Current at a maximum temperature of 90° C under site conditions.
- 5.7 Insulation Curing: Dry curing process should be adopted in cross-linking the insulation.
- 5.8 Triple Extrusion:
The conductor screen, insulation and insulation screen shall be extruded in single process (triple extrusion) and cross linked by continuous vulcanization process or MDCV process (Mitsubishi Dainichi Continuous Vulcanization process) or any other equivalent process using dry curing technology to ensure homogeneity and absence of micro voids.
- 5.9 The cable shall be designed to have a minimum useful life of not less than fifty years.
- 5.10 Each cable length shall be provided with a pulling socket, pulling eye, which shall be fitted to pulling end to withstand the maximum pulling force.

21

- 5.11 The contractor shall furnish the details of any specific construction features which will be provided to ensure specific water tightness of cable both transversely and longitudinally.

6.0 MECHANICAL CHARACTERISTICS OF CABLE:

The cable shall withstand the electro-mechanical forces due to short circuit current of 40 kA and shall withstand the stresses in the insulation due to faults. The cable shall withstand the mechanical stress during installation.

6.1 TEMPERATURE RISE:

The maximum conductor temperature shall not exceed 90°C during continuous operation of current. The temperature after a short circuit for one second shall not exceed 250° C, with initial conductor temperature of 90° C.

6.2 CABLE MATERIAL:

a) **Conductor** :The conductor shall be of plain annealed high conductivity copper wires, stranded, segmental conductor conforming to IEC-60228. The Copper used for the conductor shall be of highest purity. The minimum number of wires and conductors and DC resistance of conductor shall be as per IEC-60228.

b) **Conductor Screen** :The conductor screen shall be provided over the conductor by extrusion of semi-conducting compound or by a combination of semi-conducting tape/s and extruded semi-conducting compound.

c) **Insulation** :Cross-linked polyethylene insulation by dry curing process shall be provided over the conductor screen. The insulation shall be of high quality and shall be as far as possible free from contaminants, moisture and voids. The size of voids and contaminants shall be within limits of recognised Standards.

The insulation shall be suitable for operation in wet or dry locations at conductor temperature not exceeding 90° C for normal operation and 250° C for short circuit conditions.

d) **Insulation Screen**: Shall be by extruded semi-conducting compound. The semi-conducting screen shall be suitable for the operating temperatures of the cable and compatible with the insulation.

e) **Moisture Barrier (Longitudinal)**: This shall be semi-conducting synthetic non-woven tape with suitable swellable absorbent for longitudinal water sealing covering the whole surface area of the non-metallic part of insulation screening. This barrier shall restrict longitudinal water penetration under the metallic sheath.

f) **Metal Sheath/Moisture Barrier (Radial)**: This shall be Corrugated Aluminium sheath. The nominal thickness of sheath shall meet the Electrical and Mechanical properties as per standards. The minimum thickness shall be as per IEC-62067.

g) **Bedding Tapes**: Suitable semi-conducting bedding tapes shall be used under metallic screen .

h) **Metallic Screen (Armour)**: The metallic screen shall be of non-magnetic SS316 stainless steel tapes or 1% bronze tapes/ plain copper round wires, helically applied over the semi-



conducting bedding tape/s.

A binder tape of suitable material/annealed plain copper shall be applied in the form of an open helix, over the metallic screen.

Note: Requirement of Metallic Sheath/Screen:

The cross section of the metallic sheath that is corrugated Aluminium sheath in combination with stainless steel tapes/bronze tapes/plain copper round wire screen shall be designed to meet the following requirements:

- i) Sustaining the system short circuit rating of 40 KA for 1 Sec. The temperature of metallic sheath at the time of short circuit (cable operating at maximum conductor temperature) shall be indicated in the short circuit calculations of the design of metallic screen/sheath.
- ii) Ensuring mechanical protection of the cable.
- iii) Ensuring radial water tightness of the cable.

Test report ensuring the above compliance shall be furnished by the contractor.

i) Outer Sheath: The outer sheath shall be extruded black colour, High Density Polyethylene, type ST7 conforming to requirement of IEC. The High Density Polyethylene compound used shall be brand new from a reputed manufacturer and in no case shall recycled material be used.

The Corporation reserves the right to seek documentary proof of the source of material (insulation, outer sheath and other cable components) and to cross check with the supplier.

The outer sheath shall be designed for protecting against termite and rodent attack by adding suitable additives, which are harmless to operating personnel to High Density Polyethylene (HDPE) compound.

j) Coating: A hard baked one layer of graphite shall be applied over the outer sheath as outer electrode for testing sheath.

7.0 IDENTIFICATION:

The following information shall be embossed on the outer sheath of the cable continuously repeated through out the length of the cable.

- i) Brand Name of Manufacturer
- ii) Year of Manufacture
- iii) Voltage rating/conductor cross Section
- iv) Customer:
- v) XLPE
- vi) Running length of cables

The embossed letters and figures shall be raised and consist of upright block characters along one or more lines.

The maximum size of the characteristics shall be 20 mm and the minimum size not less than 15 percent of the nominal or specified external dia of cable or 3 mm whichever is greater

The gap between the end of one set of embossed characters and the beginning of the next shall not exceed 1 m. Any additional information embossed on the sheath shall not affect the spacing between repetitions of the legend.

Further as a safety if any additional ground wire is required for grounding all clamping equipment at ground potential shall also be supplied.

8.0 CABLE END TERMINATIONS:

- a) The cable end termination shall be outdoor type on both end suitable for cable size as specified in section-1 and shall conform to the relevant IEC.
- b) The outdoor termination should have a device for electrical stress control at the end of screen/shield. It should avoid partial discharges and surface Corona under the service conditions. It should seal any ingress of atmospheric elements. The total creepage distance shall not be less than 31 mm/kV.
- c) The terminations shall be suitable for insulation voltage, conductor size and current rating of the cable.
- d) Cable terminations (Sealing end pre-moulded type) – The sealing ends shall conform to the latest International Standards and shall be of thoroughly proven design. The internal electric stress by the pre-moulded cone epoxy resin unit arrangement preferably with epoxy bell mouth and all other accessories. The cable terminations shall be outdoor type. The outdoor type sealing end shall be suitable for installation in polluted atmosphere and shall be completely weather proof. Each outdoor type sealing end shall be supplied complete with mounting plate insulators to insulate the sealing end from the supporting structures and to control the sheath current. Each sealing end shall be provided with consumable materials such as viper and cleanant for cleaning. The power cable leading to sealing end shall be provided with proper sunshield cover.
- e) The material for the housing of the termination should be resistant to tracking, ultra violet radiation (U-V exposure) weathering and should have stable hydrophobic properties.
- f) The contractor shall provide necessary arrangement to limit flow of current in the structure supporting the sealing end.

- g) The sealing ends shall withstand the power frequency, impulse and cable testing voltage after installation as specified.
- h) The cable and accessories shall withstand all thermal and mechanical stresses under steady state and transient operating conditions.

9.0 SPARE CABLE:

- (a) One standby spares for 400 kV cable as per section -1 shall be supplied and installed complete with all accessories. The spare 400kV cable will be used to replace any one of the three cables of 400kV GT which may fail under normal service and shall be installed in such a manner as to permit rapid replacement and reconnection of the faulty circuit without exposing workmen to dangerous situations. The details of the installation and the method of moving and connecting to the existing terminal ends shall be furnished by the contractor
- (b) The spare cable shall be sufficient in length so that it can be used on the 400kV GT for replacement of a damaged cable.

10.0 SUPPORTS, HARDWARES AND ACCESSORIES:

- (a) The supporting structure (in BHEL scope) for the outdoor shall be fabricated from lattice steel structure along with detailed foundation design and drawing shall be furnished by the successful bidder. The Contractor shall furnish necessary information such as foundation load and mounting details to the Corporation.
- (b) Cable cleats, clamps, fire barriers, fixing bandage, miscellaneous accessories and hardware required for the assembly of the cable support system shall be supplied. The complete detailed fixing arrangement/ installation drawings of the cables shall be furnished.

11.0 PROTECTION AGAINST EARTH QUAKE:

Cable system shall be so designed as to be secured to the foundation clamps to withstand earthquake forces of the above.

12.0 CABLE DRUMS

Immediately after the inspection, both ends of each cable length shall be sealed by means of end caps in the presence of the inspector. Cable drums shall be of rugged construction, with a drum diameter of ample dimensions to accommodate the single- conductor cables. The drum cable length shall be chosen considering the lengths to be laid at site. No negative tolerance on the required lengths may be adopted.

Each drum shall be marked, by stenciling thereon, with an arrow the direction in which the drum should be rolled. The cable shall be wound on non-returnable strong steel drums. The

dimensional drawings of steel drums shall be furnished. The drum shall be provided with circumferential lagging of strong wooden planks. The ends of the cable shall be sealed with good quality heat shrink sealing caps. The required additional sealing caps of sufficient quantity shall be supplied for use for testing during laying at site and to seal spare lengths of cable.

The cable drums shall be supplied with definite cable length (to be informed before start of manufacturing) within +/- 2 m tolerance. Contractor shall not be reimbursed for excess lengths supplied. Cable drums with shorter lengths shall not be accepted.

13.0 INSTALLATION & COMMISSIONING

Cable drum shall be unloaded, handled and stored on hard and well drained surface so that they may not sink. In no case , the drum shall be stored flat i.e. with horizontal. Rolling of drums shall be avoided as far as possible. For un-reeling the cable, drum shall be mounted on suitable jacks or on cable wheels and shall be rolled slowly so that the cable comes out over the drum and not from below. All possible care shall be taken during unreeling and laying to avoid damage due to twist, kink or sharp bends. Cable ends shall always be kept sealed by heat shrinkable PVC caps to prevent damage and ingress of moisture.

While laying the cable, power rollers shall be used at required interval to avoid cable touching ground. The cables shall be pushed over the rollers by a gang of people positioned in between the rollers. Cables shall not be pulled from the end without having intermediate pushing arrangement. Pulling tension shall not exceed recommended values. Selection of cable drum for each run shall be planned so as to avoid using straight through joint. Cable splices will not be allowed unless approved by customer.

The cables shall be laid and terminations installed by skilled and experienced workers, fully qualified to carry out the work. The supplier shall also be responsible for providing clamps, required to support cables on racks for cable laying in trenches.

In surface trench, cable will be laid in trefoil arrangement on support angle and will be fixed with angle by clamps made of non-magnetic material. These surface trenches will be covered by suitable trench covers.

The sheath voltage under full load conditions shall be within safe limits. The value of sheath voltage shall be furnished for approval. Sheath shall be solidly grounded at both end. The connection to earth shall be as short as possible to prevent HV impulses and spikes. A sheath voltage limiter shall be provided as per section-1 to control the sheath voltage. These voltage limiters shall be without boxes.

14.0 TESTS

The cables and cable terminations shall be subjected to tests as per applicable standards in the presence of GSECL/BHEL and/ or their authorized representatives . After installation, the cables shall also be subjected to tests at sites. All tests shall be carried out generally as per the different standards listed in Cl. 3 above. Following test but not limited to this as mentioned below shall be conducted as per latest IEC.

14.1 TYPE TESTS (IEC 62067)

The Supplier shall conduct the type tests as per relevant IEC standards at no extra cost to customer. The supplier shall offer material for selection of samples for type testing, only after getting quality assurance plans approved. The sample shall be manufactured strictly in accordance

with the approved Quality Assurance Plan.

Following type tests shall be carried out(if valid type test report are not furnished).

- a) **Electrical type test on complete cable system (CI 12.4)**
 - i) Check for insulation thickness of cable for electrical type test (CI 12.4.1)
 - ii) Bending test (CI 12.4.4)
 - iii) Partial discharge test (CI 12.4.5)
 - iv) Tan δ measurement (CI 12.4.6)
 - v) Heating cycle voltage test (CI 12.4.7)
 - vi) Lightning impulse voltage test followed by a.c. voltage test (CI 12.4.9)
 - vii) Examination (CI 12.4.10)
 - viii) Resistivity of semi-conducting screens (CI 12.4.11)
 - ix) Switching impulse voltage test(CI 12.4.8)
- b) **Non electrical type test on cable components and on complete cable (CI 12.5)**
 - i) Check of cable construction (CI 12.5.1)
 - ii) Tests for determining the mechanical properties of insulation before and after ageing (CI 12.5.2)
 - iii) Tests for determining the mechanical properties of oversheaths before and after ageing (CI 12.5.3)
 - iv) Ageing tests on pieces of completed cable to check compatibility of materials (CI 12.5.4)
 - v) Loss of mass test on PVC sheaths of type ST2 (CI 12.5.5)
 - vi) Pressure test at high temperature on oversheaths (CI 12.5.6)
 - vii) Test on PVC oversheath ST2 at low temperature (CI 12.5.7)
 - viii) Heat shock test on PVC oversheath ST2 (CI 12.5.8)
 - ix) Hot set test for XLPE insulation (CI 12.5.10)
 - x) Test under fire conditions (CI 12.5.13)
 - xi) Water penetration test (CI 12.5.14)

14.2 Acceptance Tests (Sample Tests) on Cables (CI. 10 of IEC 62067)

Following tests shall be carried out on minimum 10% of the drums subject to minimum one sample in each lot:

- a) Tests on conductor (CI 10.4 & 10.5)
- b) Measurement of thickness of insulation and oversheaths (CI 10.6)
- c) Measurement of thickness of metallic sheath (CI 10.7)
- d) Measurement of diameters (CI 10.8)
- e) Hot set test for XLPE insulation (CI 10.9)
- f) Measurement of capacitance (CI 10.10)
- g) Lightning impulse voltage test followed by power frequency voltage test (CI 10.12)

14.3 SAMPLE TESTS ON ACCESSORIES

Tests and its procedure to be proposed by the supplier for GSECL/BHEL's approval.

14.4 ROUTINE TESTS

Following routine test shall be carried out as per Clause 9 of IEC 62067 on samples drawn from each drum and each accessory.

- a) Partial discharge test (Cl 9.2)
- b) Voltage test (Cl 9.3)
- c) Electrical test on non metallic sheath of the cable (Cl 9.4)
- d) Voltage test on outer sheath as per Clause 3.1 of IEC 60229

14.5 SITE TESTS

The suppliers shall furnish field quality assurance plans giving different checks and tests, including high voltage tests, to be carried out at site to ensure a maintenance-free installation. Atleast following site test shall be carried out as detailed in Clause 14 of IEC 62067.

- a) DC voltage test of the oversheath (Cl 14.1)
- b) AC voltage test of the insulation by applying a voltage U_0 to be applied for 24 hours (Cl 14.2) –

15.0 DESIGN REQUIREMENTS

Supplier of the cable system shall furnish the details calculations along with technical data sheet for verification/approval of design parameters elected. Detail design calculations/documents will be submitted for approval to GSECL/BHEL:

- a) Calculation of continuous current capacity for specified cable laying conditions
- b) Adequacy of XLPE insulation thickness.
- c) Calculation for short circuit currents for metal sheath or screen.
- d) Calculation for adequacy of metallic sheath/ screen for short circuit current carrying capability.
- e) Calculation of sheath induced voltage for cross bonding.
- f) Manufacturing Quality plan
- g) Field quality plan for site installation, commissioning and testing
- h) Instruction manual for jointing and cable laying.

16.0 PACKING AND MARKING

The packing should be able to withstand the rigors of transport.
The following information in bold letters in English shall be painted on the flanges.

- (i) Name and address of the Manufacturer, Trade name/Trade Mark/Brand.
- (ii) Size of cable (cross section) rated voltage, standard, insulation, cable code, drum number, year of manufacture.
- (iii) Length of cable (metres)
- (iv) Direction of Rolling
- (v) Net weight (in Kg)
- (vi) Gross weight (in Kg)
- (vii) Purchase order reference.

SECTION-3

3.0 GENERAL

This section stipulates the General Technical Requirements under the Contract and will form an integral part of the Technical Specification.

The provisions under this section are intended to supplement general requirements for the materials, equipments and services covered under other respective sections and are not exclusive. However in case of conflict between the requirements specified in this section and requirements specified under other sections, the requirements specified under respective sections shall hold good.

3.1 PROJECT INFORMATION AND SYSTEM PARAMETERS

a)	Customer/ Purchaser/ Owner	Gujrat State Electricity Corporation Ltd. Vadodara
b)	Consultant	TCE Consulting Engineers Ltd. Bangalore
c)	Project Title	1X500MW Unit-6 TPS-400/220kV Substation at Ukia
d)	Location	Ukai is situated in Surat district of Gujarat , 200 kM from Vadodara,100kM from NH , Nearest village- Songarh
e)	Elevation above MSL	86m
f)	Transport Facilities	Road/Rail, Nearest railway station is Songarh
g)	Postal Address	To follow
SITE CONDITIONS		
a)	Max. Ambient temp.	50°C
b)	Min. ambient temp.	8°C
c)	Design ambient temp.	50°C
d)	Latitude/Longitude	21° 21' North/74° 15' East
e)	Relative humidity (for design)	100 %
f)	Pollution Severity	Highly Polluted
g)	Seismic acceleration	0.3g
h)	Seismic zone	III
	Wind Pressure	150 kg/sq.m
j)	Average Annual rainfall during June to September	1500mm

13

SYSTEM PARAMETERS

Nominal system voltage	400 kV	2202 kV
Highest system voltage	400 kV	220 kV
Basic Impulse level	1425kVP	1050kVP
Power frequency withstand voltage	630kVrms	460kVrms
Switching Impulse withstand voltage	1050kVrms	-
Frequency	50 Hz	
Rated short time current	40 kA for 1 sec	
Creepage distance	31mm/kV	
System Earthing	Effectively Earthed	

AUXILIARY POWER SUPPLY

3 phase A.C power supply	415V, 50 Hz, 3-phase 3 wire, solidly earthed with variation in frequency of +/-5% and variation in voltage +/-10%.
1 phase A.C power supply	240V, 50 Hz, 1-phase AC supply with variation in frequency of +/-5% and variation in voltage +/-10%.
D.C. power supply	220V(variation from 190V to 240V) , 2-wire ungrounded 50V, 2 wire system (+) earthed

Combined variation of voltage and frequency shall be +/- 10%

3.2 GENERAL TECHNICAL REQUIREMENT

3.2.1 TYPE TESTS

The supplier shall offer type tested equipment as per applicable IEC standards or as specified in relevant sections of the specification.

3.2.3 CODES AND STANDARDS

All materials and equipment shall generally comply in all respect with the latest edition of relevant international electro-technical commission (IEC) or any other internationally accepted standard which ensure equal or better quality .

3.3 MATERIAL/WORKMANSHIP

3.3.1 General Requirement

Where the specification does not contain characteristics with reference to workmanship, equipment, materials and components of the covered Equipment it is understood that the same must be new, of highest grade of the best quality of their kind conforming to best engineering

practice and suitable for the purpose for which they are intended.

The design of the Works shall be such that installation, future expansions, replacements and general maintenance may be undertaken with a minimum of time and expenses. Each component shall be designed to be consistent with its duty and suitable factors of safety, subject to mutual agreements and shall be used throughout the design. All joints and fastenings shall be devised, constructed and documented so that the component parts shall be accurately positioned and restrained to fulfill their required function. In general screw threads shall be standard metric threads. The use of other thread forms will only be permitted when prior approval has been obtained from purchaser.

Whenever possible, all similar part of the Works shall be made to gauge and shall also be made interchangeable with similar parts. All spare parts shall be interchangeable with, and shall be made of the same materials and workmanship as the corresponding parts of the Equipment supplied under the Specification. Where feasible, common component units shall be employed in different pieces of equipment in order to minimize spare parts stocking requirements. All equipment of the same type and rating shall be physically and electrically interchangeable.

All materials and equipment shall be installed in strict accordance with the manufacturer's recommendation(s). Only first-class work in accordance with the best modern practices will be accepted. Installation shall be constructed as being the erection of equipment at its permanent location. This, unless otherwise specified, shall include unpacking, cleaning and lifting into position, grouting, leveling, aligning, coupling of or bolting down to previously installed equipment bases/foundations, performing the alignment check and final adjustment prior to initial operation, testing and commissioning in accordance with the manufacturer's tolerances and instructions and the Specification. All factory assembled rotating machinery shall be checked for alignment and adjustments made as necessary to re-establish the manufacture's limits suitable guards shall be provided for the protection of personal on all exposed rotating and / or moving machine parts and shall be designed for easy installation and removal for maintenance purpose. The spare equipment(s) shall be installed at designated locations and tested for healthiness. The Contractor shall apply oil and grease of the proper specification to suit the machinery, as is necessary for the installation of the equipment. Lubricants used for installation purposes shall be drained out and the system flushed through where necessary for applying the lubricant required for operation. The Contractor shall apply all operational lubricants to the equipment installed by him.

All oil, grease and other consumables used in the Works/ Equipment shall be purchased in India unless the Contractor has any special requirement for the specific application of a type of oil or grease not available in India. In such is the case he shall declare in the proposal, where such oil or grease is available. He shall help purchaser in establishing equivalent Indian make and Indian Contractor. The same shall be applicable to other consumables too.

3.3.2 Provisions For Exposure to Hot and Humid climate

Outdoor equipment supplied under the specification shall be suitable for service and storage

under tropical conditions of high temperature, high humidity, heavy rainfall and environment favorable to the growth of fungi and mildew. The indoor equipments located in non-air conditioned areas shall also be of same type.

3.4 COLOUR SCHEME AND CODES FOR PIPE SERVICE

The contractor shall propose a color scheme for those equipment/Items for which the colour scheme has not been specified in the specification for the approval of purchaser. The decision of purchaser shall be final. The scheme shall include:

Finishing colour of Indoor equipment

Finishing colour of Outdoor equipment.

Finish colour of all cubicles.

Finishing colour of various auxiliary system equipment including piping

Finishing colour of various building items.

All steel structures, plates etc shall be painted with non-corrosive plant on a suitable primer. It may be noted that normally all electrical equipment in switchyard are painted with shade 631 of IS-5. All The indoor cubicles shall be of same colour scheme and for other miscellaneous items, colour scheme will be approved by the purchaser.

3.5 PROTECTION

All coated surfaces shall be protected against abrasion, impact, discoloration and any other damages. All exposed threaded portions shall be suitably protected with either a metallic or a non-metallic protecting device. All ends of all valves, pipings and conduit equipment connections shall be properly sealed with suitable devices to protect them from damage.

All equipment accessories and wiring shall have fungus protection, involving special treatment of insulation and metal against fungus, insects and corrosion. The parts which are likely to get rusted, due to exposure to weather should also be properly treated and protected in a suitable manner. Screens of corrosion resistant material shall be furnished on all ventilating louvers to prevent entry of insects.

3.6 FUNGISTATIC VARNISH

Besides the space heaters, special moisture and fungus resistant varnish shall be applied on the parts, which may be subjected or predisposed to the formation of fungi due to the presence or deposit of nutrient substances. The varnish shall not be applied to any surface of part where the treatment will interface with the operation or performance of the equipment. Such surfaces or parts shall be protected against the application to the varnish.

3.7 SURFACE FINISH

All interiors and exteriors of tanks, control cubicles and other metal parts shall be thoroughly cleaned to remove all rust, scales, corrosion, greases or other adhering foreign matter. All steel surfaces in contact with insulating oil as far as accessible, shall be painted with not less than two coats of heat resistant, oil insoluble, insulating paints.

All metal surfaces exposed to atmosphere shall be given two primer coats of zinc chromate and two coats of epoxy paint with epoxy base thinner. All metal parts not accessible for painting shall be made of corrosion resisting material. All machine finished or bright surfaces shall be coated with a suitable preventive compound and suitably wrapped or otherwise protected. All paints shall be carefully selected to withstand tropical heat and extremes of weather within the limit specified. The paint shall not scale off or wrinkle or be removed by abrasion due to normal handling. All external painting shall be as per shade no. 631 of IS:5.

3.8 GALVANIZING

All ferrous parts including all sizes of nuts, bolts, Plain and spring washers, support channels, structures, shall be hot dip galvanised conforming to latest version of IS:2629 or any other equivalent authoritative standard. However, hardware less than M12 size shall be electro-galvanized. Minimum weight of zinc coating shall be 610 gm/sq.mm and minimum thickness of coating shall be 85 microns for all items thicker than 6mm. For items lower than 6 mm thickness, requirement of coating shall be as per relevant ASTM.

3.9 PACKING

The following details are to be clearly indicated in the material forwarding documents:

- a) Name and address of the consignee.
- b) Purchase order number.
- c) Name of supplier/s.
- d) Description of equipment / material.
- e) Net weight.
- f) Gross weight.

All the equipments shall be suitably protected, coated, covered or boxed and crated to prevent damage or deterioration during transit, handling and storage at Site till the time of erection. On request of the purchaser, the Contractor shall also submit packing details/associated drawing for any equipment material under his scope of supply, to facilitate the purchaser to repack any equipment/ material at a later date, in case the need arises. Any material found short inside the packing cases shall be supplied by the supplier without any extra cost. The cases containing easily damageable material shall be very carefully packed and marked with appropriate caution symbol i.e. fragile, handle with care, use no Hooks etc.



3.10 HANDLING, STORING AND INSTALLATION

Contractor may engage manufacturer's Engineers to supervise if required for unloading, transportation to site, storing, testing and commissioning of the various equipment being procured by them separately. In case of any doubt/misunderstanding as to the correct interpretation of manufacturer's drawings or instructions, necessary clarifications shall be obtained from the purchaser. Contractor shall be held responsible for any damage to the equipment consequent to not following manufacturer's drawings/instructions correctly.

Where assemblies are supplied in more than one section, contractor shall make all necessary mechanical and electrical connections between sections including the connection between buses. Contractor shall also do necessary adjustments/alignments necessary for proper operation of circuit breakers, isolators and their operating mechanisms. All components shall be protected against damage during unloading, transportation, storage, installation, testing and commissioning.

Contractor shall be responsible for examining all the shipment immediately of any damage, shortage, discrepancy etc. for the purpose of Purchaser's information only. Any demurrage, pilferage and other such charges claimed by the transporters, railways etc. shall be to the account of the Contractor. The Contractor shall be fully responsible, for the equipment/material until the same is handed over to the purchaser in an operating condition after commissioning.

The minimum phase to earth, phase to phase and section clearance along-with other technical parameters for the various switchyard voltage levels to be maintained shall be strictly as per the approved drawings.

The design and workmanship shall be in accordance with the best engineering practices to ensure satisfactory performance throughout the service life. If at any stage during the execution of the Contract, it is observed that the erected equipment(s) do not meet the above minimum clearances, the Contractor shall immediately proceed to correct the discrepancy at his risks and costs.

3.11 DEGREE OF PROTECTION

The enclosures of the Control Cabinets, Junction boxes and Marshalling boxes panels etc to be installed shall be provided with degree of protection as detailed here under:

- a) Installed out door: IP-55
- b) Installed indoor in air conditioned area: IP-31
- c) Installed in covered area IP:52
- d) Installed indoor-in non air-conditioned area where possibilities of entry of water is limited:IP-



e) For LT switchgear (AC & DC distribution Boards): IP-54

The degree of protection shall be in accordance with IS:13947, (Part-1)/IEC-947(Part-1). Type test report/or degree of protection test on each type of the box shall be submitted for approval.

3.12 QUALITY

BHEL quality plan to be followed subject to TBEM / customer's approval.

3.13 DOCUMENTATION

3.13.1 LIST OF DOCUMENTS

The bidder shall submit a detailed list of drawings / documents along with the bid proposal which he intends to submit to the Employer after award of the contract.

The supplier shall necessarily submit all the drawings / documents unless any thing is waived.

All engineering data submitted by the Contractor after final process including review and approval by the Employer shall form part of the Contract Document and the entire works performed under this specification shall be performed in strict conformity, unless otherwise expressly requested by the Employer in Writing.

3.13.2 DRAWINGS

All drawings submitted by the Contractor including those submitted at the time of bid shall be in sufficient detail to indicate the type, size, arrangement, material description, Bill of Materials, weight of each component, break-up for packing and shipment, the external connections, fixing arrangement required, the dimensions required for installation and interconnections with other equipments and materials, clearances and spaces required for installation and interconnection between various portions of equipments and any other information specifically requested in the specifications.

Each drawing submitted by the Contractor shall be clearly marked with the name of the Employer, name of consultant ,the unit designation, GSECL contract no. , and the name of the Project .If standard catalogue pages are submitted, the applicable items shall be indicated therein. All titles, noting, markings and writings on the drawing shall be in English. All the dimensions should be in metric units.

Further work by the Contractor shall be in strict accordance with these drawings and no deviation shall be permitted without the written approval of the Employer if so required.

All manufacturing and fabrication work in connection with the equipment prior to the approval of the drawing shall be at the Contractor's risk. The Contractor may make any changes in the design which are necessary to make the equipment conform to the provisions and intent of the Contract and such changes will again be subject to approval by the Employer. Approval of Contractor's drawing or work by the Employer shall not relieve the contractor of any of his responsibilities and liabilities under the Contract.

3.13.3 APPROVAL PROCEDURE

The scheduled dates for the submission of these as well as for, any data/information to be furnished by the Employer would be discussed and finalised at the time of award. The supplier shall also submit required no. of copies as mentioned in this specification of all drawings/design documents/test reports for approval by the Employer. The following schedule shall be followed generally for approval.

i.	Approval/comments/by employer on Initial submission	Within 2 weeks of receipt
ii.	Resubmission	Within 2 (two) weeks (whenever from date of comments required) Including both ways postal time.
iii.	Approval or comments	Within 2 weeks of receipt of resubmission
iv.	Furnishing of distribution copies	2 weeks from the date of last approval.

Note: The contractor may please note that all resubmissions must incorporate, all comments given in the submission by the Employer failing which the submission of documents is likely to be returned. Every revision shall be a revision number, date and subject, in a revision block provided in the drawing, clearly marking the changes incorporated.

The title block of drawings shall contain the following information incorporated in all contract drawings. Please refer enclosed **Annexure-1** for details of Title block.

3.13.4 DOCUMENTS TO BE SUBMITTED ALONGWITH OFFER

- 1) Drawings
- 2) Guaranteed Technical Particulars
- 3) Type Test Reports
- 4) Manufacturing Quality Plan

3.13.5 DOCUMENTATION SCHEDULE

S. No.	DESCRIPTION	TENDER STAGE	CONTRACT STAGE FOR APPROVAL	FINAL DOCUMENTATION	
				Prints	CDs
1	Drawings and Data Sheets	1	10	13	-
2	Drawings "As Built"	-	-	13	05
3	Type Test Reports	1	05	13	-
4	Erection Manuals	-	11	13	-
5	Operation and Maintenance	-	11	13	-

6

	Manuals				
6	Manufacturing Quality Plan	1	11	13	-
7	Field Quality Plan	1	11	13	-
8	Inspection Test Reports	-	-	13	-

Drawings will also be submitted in mini cartridges in AUTOCAD Release -14 package or any other CAD package along with conversion files for all major items.

Final Documentation shall be submitted in bound volumes with Customer & Project etc. written on top .

5

ANNEXURE -1


REV.	STATUS	TYPE	REASONS FOR REVISION	PREPARED BY	CHECKED BY	APPROVED BY	DATE

GSECL GUJARAT STATE ELECTRICITY CORPORATION LTD.

પરિચાલના કા શાખા 1X500MW, UNIT NO.6 UKAI THERMAL POWER STATION

NAME OF PROJECT

TCE TCE CONSULTING ENGINEERS LTD.
DRAWING TCE REF. NO. :

	આવરણ કંપની સંલગ્નિતકર્તા ઈજિનિયર	DWN	NAME	SIGN.	DATE
	સાંચાલકશ્રીના અધિકારીશ્રીના નિશાન	PREP.			
BHARAT HEAVY ELECTRICALS LTD.	TRANSMISSION BUSINESS GROUP	CHKD.			
		APPD.			

BHEL SUB VENDORS

DEPT.	TSEM
CODE	422
SCALE	NTS
CARD CODE	
W.O. No.	

DRAWING	DRAWG. NO. :	SHEET NO. 1	NEXT SHEET NO. :	REV NO. :
---------	--------------	-------------	------------------	-----------

Section-4

Guaranteed Technical Particulars for the 400kV XLPE Insulated Cable

Sl. No.	Item Description	Unit	Data
1	Manufacturer's Name & Address		
2	Cable Type		
3	Rating		
a)	Rated voltage	kV	
b)	Maximum rated voltage	kV	
4	Applicable Standard		
5	Number of cores		
6	CONDUCTOR		
a)	Cross sectional area	mm ²	
b)	Material		
c)	Design		
d)	Overall diameter	mm	
e)	Soldering Temperature	deg C	
6.1	CONDUCTOR SCREEN		
a)	Material		
b)	Nominal thickness	mm	
c)	Diameter over conductor screen	mm	
7	INSUALTION		
a)	Material		
b)	Type of curing		
c)	Nominal thickness	mm	
7.1	INSULATION SCREEN		
a)	Material		
b)	Nominal thickness	mm	
c)	Diameter over insulation screen	mm	
8	METAL Screen and SHEATH		
a)	Material		
b)	Nominal thickness	mm	
c)	Cross sectional area	sq mm	
8.1	WATER SEALING LAYER		
a)	Material		
b)	Thermal resistivity of material	km/W	
9	OUTER SHEATH		
a)	Material		
b)	Minimum average thickness	mm	
c)	Diameter over outer sheath	mm	
10	COMPLETED CABLE		
a)	Overall diameter	mm	
b)	Weight per meter	kg/m	
c)	Maximum drum length	m	
11	MAXIMUM DIELECTRIC STRESS		
a)	At the conductor (assumed smooth)	MV/m	
b)	At the conductor screen	MV/m	

12	MAXIMUM CONDUCTOR TEMPERATURE		
a)	Laid direct in ground	deg C	
b)	Drawn in ducts	deg C	
c)	Erected in air	deg C	
13	MINIMUM RADIUS OF BEND AROUND WHICH CABLES WILL BE LAID		
a)	Laid direct	m	
b)	In ducts	m	
c)	In air	m	
d)	Nominal internal diameter of pipes or ducts through which cable may be pulled		
14	MAXIMUM DC RESISTANCE PER METER OF CABLE AT 20 DEC C		
a)	Conductor	Micro-ohm	
b)	Metallic layer	Micro-ohm	
c)	Metallic sheath	Micro-ohm	
15	AC RESISTANCE PER METER OF CABLES AT MAXIMUM CONDUCTOR TEMPERATURE		
a)	Conductor	Micro-ohm	
b)	Metallic layer	Micro-ohm	
c)	Metallic sheath	Micro-ohm	
16	Insulation resistance		
a)	At 20 deg C	Mega-Ohm	
b)	At maximum rated temperature	Mega-Ohm	
17	Current carrying capacity of cable in RCC trench with removable cover		
a)	In air (Ambient temperature 50 deg C)		
	One circuit	A min	
	Two circuit	A min	
	Three circuit	A min	
18	Maximum dielectric loss angle of charging VA of cable at nominal voltage and frequency and conductor temperature of		
a)	50% rated voltage		
b)	200% rated voltage		
19	Creepage distance of sealing end porcelain	mm	
20	Metallic layer earth fault current carrying capacity for one second, cable fully loaded prior to earth fault and final screen temperature of 250 deg C	kA	



21	Dielectric loss of completed cable when laid direct in ground per 1000 meters and at maximum continuous operating temp	W	
22	Impulse withstand voltage		
a)	Positive 1.2/50 micro-second wave	kVp	
b)	Negative 1.2/50 micro-second wave	kVp	
23	Short circuit capacities with a conductor temperature of 90°C at the commencement		
a)	0.5 s duration		
b)	1.0 s duration		
c)	2.0 s duration		
d)	3.0 s duration		
24	Impedance per km of three-phase circuit, at 50 Hz and max. Conductor temperature		
a)	Positive and negative sequence	Ω	
b)	Zero sequence	Ω	
25	Maximum capacitance	MicroF/kM	
26	Max. Drum length of cable	m	
27	Screen earthing method	-	

CABLE TERMINATION KIT FOR 400kV XLPE INSULATED CABLE

S. No.	Item Description	Unit	Data
			Termination Kit
1.	Manufacturer's Name & Address		
2.	Country of Manufacture		
3.	Type of Cable Termination		
4.	Applicable Standards for manufacturing		
5.	Applicable Standards for testing		
6.	Rated Voltage	kV	
7.	Maximum service voltage	kV	
8.	Type & Material of bushing		
9.	Creepage Distance	mm	
10.	Whether full details of termination and BOQ furnished with offer		
11.	Whether cable sealing end is complete with all accessories		
12.	Whether descriptive pamphlet enclosed		
13.	Whether full details of tests to be carried out furnished with offer		
14.	Copies of type test reports enclosed		

Note – Please submit separate GTP for each size of HT cables

SCHEDULE OF TECHNICAL DEVIATIONS

Bidder shall list below all technical deviation clause wise w.r.t. tender specifications:

<u>S.No.</u>	<u>Page No.</u>	<u>Clause No.</u>	<u>Deviation</u>	<u>Reason / Justification</u>
--------------	-----------------	-------------------	------------------	-------------------------------

Any deviation not specifically brought out in this section shall not be admissible for any commercial implication at later stage. Except to the technical deviations listed in this schedule, bidder's offer shall be considered in full compliance to the tender specifications irrespective of any such deviation indicated / taken elsewhere in the submitted offer.

Date:

Tenderer's Stamp & Signature