



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN – 01

Ref: PSER:SCT:LRA-F2382:TCN-01

Date: 28-07-2025

Sub	Tender Change Notice (TCN) - 01.	
Job	Providing 2 Nos. 20MT or above capacity Tower Crane having Tip load of 3.5 MT below hook at 70M radius and critical load of 8.5 MT at 40M radius with clear height below hook of 51M (minimum) above ground level on monthly rental basis at BHEL-PSER 2X800 MW Lara super thermal power plant project, Stage II, Raigarh, Chhattisgarh. 1) Package A: 01 No for Unit#1 ESP. and 2) Package B: 01 No for Unit#2 ESP.	
Ref	1.0	Tender no. PSER:SCT:LRA-F2382:25
	2.0	BHEL's NIT, vide reference no. PSER:SCT:LRA-F2382:11057 Date: 17-07-2025
	3.0	All other pertinent issues till date.

With reference to above, following points/documents, relevant to tender, may please be noted and complied with while submitting the offer.

1. Due date of submission of offer is extended from 28-07-2025 to **31-07-2025 (13-00 hrs. IST)**.
2. Revised 'No deviation certificate' is attached. Bidder to submit 'No deviation certificate' as per attached format only.
3. All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD.

Manager / SCT

Encl.: As Above

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960

फोन/Phone : बोर्ड/EPABX : (033) 2339 8000

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Providing 2 Nos. 20MT or above capacity Tower Crane having Tip load of 3.5 MT below hook at 70M radius and critical load of 8.5 MT at 40M radius with clear height below hook of 51M (minimum) above ground level on monthly rental basis at BHEL-PSER 2X800 MW Lara super thermal power plant project, Stage II, Raigarh, Chhattisgarh. 1) Package A: 01 No for Unit#1 ESP. and 2) Package B: 01 No for Unit#2 ESP.	
Ref	1.0	Tender no. PSER:SCT:LRA-F2382:25
	2.0	BHEL's NIT, vide reference no. PSER:SCT:LRA-F2382:11057 Date: 17-07-2025
	3.0	BHEL's TCN-01, vide reference no. PSER:SCT:LRA-F2382:TCN-01 Date: 28-07-2025.
	4.0	All other pertinent issues till date.

Dear Sir/Madam,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website/ issued by you and in case of such observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT. We hereby confirm our unqualified acceptance to all terms & conditions, unqualified compliance to technical specification, integrity pact (if applicable) and acceptance to reverse auctioning process.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted/uploaded offer/documents in accordance with tender instructions with acceptance of the terms & conditions of the tender by us and as per aforesaid references.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ-9/1, SECTOR-II, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 033-2339 8000