



An ISO 9001  
Company

## Bharat Heavy Electricals Limited

(High Pressure Boiler Plant)

Tiruchirappalli – 620014, TAMIL NADU, INDIA

CAPITAL EQUIPMENT / MATERIALS MANAGEMENT

<b>ENQUIRY – Corrigendum 1</b>	Phone: +91 431 257 70 49 Fax : +91 431 252 07 19 Email : <a href="mailto:csguna@bheltry.co.in">csguna@bheltry.co.in</a> Web : <a href="http://www.bhel.com">www.bhel.com</a>
--------------------------------	---

NIT No. 4041	Enquiry Number:	Enquiry Date:	Due date for submission of quotation:
	2620800002	21.01.2008	20.02.2008

You are requested to quote the Enquiry number date and due date in all your correspondences. This is only a request for quotation and not an order

Details of Corrigendum	
<b><i>“ The circuit breaker in the 11KV RMU shall be Vacuum circuit breaker or SF6 circuit breaker in SF6 enclosure. This change is applicable in all the relevant clauses like 1.0, 1.1, 2.1.0, 3.2.5, 3.3, 3.5.1.”</i></b>	
<b>All other terms and conditions and specifications as published in the NIT 4041 remain unaltered.</b>	
Tenders should reach us before 14:00 hours on the due date Tenders will be opened at 14:30 hours on the due date Tenders would be opened in presence of the tenderers who have submitted their offers and who may like to be present	Yours faithfully, For BHARAT HEAVY ELECTRICALS LIMITED  Manager / Capital Equipment / MM