

भारत हेवी इलेक्टिकल्स लिमिटेड BHARAT HEAVY ELECTRICALS LIMITED

(भारत सरकार का उपकम)

Fax: 0091 - (0)510 - 2412110 Ph: 0091 - (0)510 - 2412697, e-mail: <u>akhatloiya@bhel.in</u> (A GOVT. OF INDIA UNDERTAKING) P.O. BHEL, JHANSI -284120 (INDIA)

Sub:	Erection protocol of equip	oment before charging.
1.	Customer	
2.	Site	
3.	Equipment	
4.	MVA Rating	
5.	KV-Class	
6.	Serial No	
7.	Work Order	
8.	Equipment has been unloaded & dragged to plinth. Erection of turrets, bushin cooler bank, equalizer pipelines, conservator, marshalling box, cabling, devices instruments etc have been completed. N2 dry-out of tank, oil filling under vacuand HOC (hot oil circulation) has been completed. All the pre-commissioning test equipment has been completed. The final oil parameter achieved after circulation is (BDVKV & Moisture ContentPPM). DATE OF CHARGING:	
9.	Balance work to be completed are as follows: Signed by (BHEL Representative) Signed by (CUSTOMER Representative)	
	Date:	Date: