



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

BHARAT HEAVY ELECTRICALS LIMITED

(भारत सरकार का उपक्रम)

(A GOVT. OF INDIA UNDERTAKING)

डाकघर भा. ह. इ. लि. झाँसी 284120 (भारत)

P.O. BHEL, JHANSI -284120 (INDIA)

Ph : 0091 – (0)510 – 2412767,

e-mail : milindk@bhel.in

Sub: Erection protocol of equipment before charging.

1.	Customer	
2.	Site	
3.	Equipment	
4.	MVA Rating	
5.	KV-Class	
6.	Serial No	
7.	Work Order	
8.	<p>Equipment has been unloaded & dragged to plinth. Erection of turrets, bushings, cooler bank, equalizer pipelines, conservator, marshalling box, cabling, devices and instruments etc. have been completed. N2 dry out of tank, oil filling under vacuum and HOC (hot oil circulation) has been completed. All the pre-commissioning test of equipment has been completed. The final oil parameter achieved after oil circulation is (BDV_____KV & Moisture Content _____ PPM).</p> <p>DATE OF CHARGING:</p>	
9.	<p>Balance work to be completed are as follows:</p>	
	<p>Signed by (BHEL Representative) Date:</p>	<p>Signed by (CUSTOMER Representative) Date:</p>