

FOR OFFICIAL USE ONLY

TENDERER'S COPY

NOT FOR PUBLICATION

ORIGINAL COPY

TENDER SPECIFICATIONS

TENDER NO. BHEL:NR(SCT): PARICHA (EXT II):BLR 5&6:470

FOR

ERECTION, TESTING, COMMISSIONING AND TRIAL OPERATION OF BOILERS OF 2 X 250 MW UNITS (UNITS 5 & 6) AT PARICHA (EXT II) THERMAL POWER STATION (PTPS) OF UPRVUNL, DIST JHANSI, UP.

PART I – TECHNICAL BID



Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)
Power Sector – Northren Region,
Plot No. 25 , Sector - 16A ,
Distt. Gautam Budh Nagar, NOIDA – 201 301 (INDIA)



ISO 9001-2000, ISO
14001 and OHSAS
18001 certified
company
SubContract and
Purchase Deptt.

Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)
Power Sector – Northren Region,
Plot No. 25 , Sector - 16A ,
Distt. Gautam Budh Nagar, NOIDA – 201 301.INDIA
Phone: 0091-0120-2515476 / 2515464 / 2515479
Fax 091-0120-2515464 / 2515467
Email: sku@bhelsnr.co.in / msd@bhelsnr.co.in

TENDER NO. BHEL:NR(SCT): PARICHA (EXT II):BLR 5&6:470

IMPORTANT NOTE

PURCHASER OF THIS TENDER DOCUMENT IS ADVISED TO CHECK AND ENSURE COMPLETION OF ALL PAGES OF TENDER DOCUMENT AND REPORT ANY DISCREPANCY TIMELY FOR CORRECTIVE ACTION, IF ANY, TO THE ISSUING AUTHORITY BEFORE THE BIDS ARE SUBMITTED. ORIGINAL COPY OF TENDER DOCUMENT COMPLETE IN ALL RESPECTS MUST BE SUBMITTED BACK AS PART OF THE BID WITHOUT WHICH THE SAME IS LIABLE TO BE REJECTED BY BHEL.

THIS TENDER SPECIFICATION ISSUED TO:

M/S-----

INDEX

Sl. No.	CONTENTS	PAGE
1.	Tender Notice	04-05
2.	Tender Notice- Newspaper	06
3.	Procedure for submission of tender	07
4.	Project Synopsis	08
5.	General Conditions of Contract (GCC)	Separate file
6	Special Conditions of Contract (SCC)- Section-III “A”	09-40
7	Special Conditions of Contract (SCC)- Section-III “B “	41-56
8	Annexure-IA Weight Schedule	57-58
9.	Annexure-IB- Weight Schedule (Piping System)	59-60
10.	Annexure-II-- List of T&Ps being provided by BHEL for use of contractor free of hire charges and ON SHARING BASIS.	61
11	Annexure-III—list of IMTES being provided by BHEL for use of contractor free of hire charges and on SHARING BASIS	62
12	Annexure-IV-- List of Major T&Ps to be arranged by Contracor at his own cost	63
13.	Annexure—V- List of IMTES to be arranged by Contracor at his own cost	64
14.	Annexure-VI-- CERTIFICATE OF DECLARATION FOR CONFIRMING THE KNOWLEDGE OF SITE CONDITIONS	65
15.	Annexure-VII-- NON-DISCLOSURE AGREEMENT	66
16.	Annexure-VIII-- FORMAT OF UNDERTAKING	67
16.	RATE SCHEDULE “A” & “B”	68 - 69



ISO 9001-2000, ISO 14001
and OHSAS 18001 certified
company
SubContract and Purchase
Deptt.

Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)
Power Sector – Northren Region,
Plot No. 25 , Sector - 16A ,
Distt. Gautam Budh Nagar, NOIDA – 201 301.INDIA
Phone: 0091-0120-2515476 / 2515464 / 2515479
Fax 091-0120-2515464 / 2515467
Email: sku@bhel.com / msd@bhel.com

TENDER NOTICE

Sealed tenders are invited from the contractors fulfilling qualifying requirements for the work of “erection, testing, commissioning and trial operation of Boilers of 2 X 250 MW units (units 5 & 6) at Paricha (Ext II) Thermal Power Station (PTPS) of UPRVUNL, Dist Jhansi, UP.

TENDER NO. BHEL:NR(SCT): PARICHA (EXT II):BLR 5&6:470

QUALIFYING REQUIREMENTS:

1.1 “Bidder should have completed works of similar nature, covered in this tender, for at least one Boiler of 300 TPH / 67 MW Unit and above during last Seven years.

OR

1.2 Should have completed works upto hydraulic test of boiler against direct BHEL’s order for a Boiler of 300 TPH / 67 MW Unit or above rating.

OR

1.3 “Should be executing works of similar nature, as covered in this tender, against direct BHEL’s order for a Boiler of 195 MW or above rating.”

2.0 Party should also have an average annual turnover of minimum of Rs. 1400 lacs during preceding three years or (2004-05, 2005-06 & 2006-07).

NOTES:

(i) The Tender Documents comprises of following;

- (a) Special Conditions of Contract (SCC), Tender Notice, Project Synopsis,
- (b) GCC
- (c) Rate Schedule

- (ii) Tender Documents with complete details are hosted on BHEL's web page www.bhel.com. Bidder(s) intending to participate may download the tender document from the web site. Bidder(s) downloading the tender documents from the web site, shall remit Rs.1000/- (Rupees One thousand only) in the form of crossed demand draft (non-refundable), in favour of BHEL, NOIDA along with their offer
- (iii) Bidder(s) can also purchase hard copy of tender documents from this office. Tender documents (non transferable) will be issued on all working days between 09.30 Hrs. to 12.30 Hrs within the sale period i.e **upto 22.01.2008** on payment of Rs.1,000/- (non-refundable) either in cash or by crossed demand draft in favour of BHEL, NOIDA. Request for issue of tender document should clearly indicate Tender no. and work.
- (iv) Tenders must be submitted to the undersigned (Room No. 104) at the address given above **latest by 22.01.2008** before opening of technical bids commences. Technical bids shall **be opened at 15.30 Hrs. on 22.01.2008**. Tenders received after the due date & time shall be liable to be summarily rejected.
- (v) Earnest Money Deposit (EMD): Refundable, Non-interest bearing **EMD of Rs 2,00,000/-** shall be deposited by Account Payee Pay Order 'OR' Demand Draft in favour of " Bharat Heavy Electricals Limited" payable at Delhi/NOIDA. Those bidders who have already deposited ' One Time 'EMD' of Rs. 2,00,000/- with BHEL, PSNR, NOIDA need not submit EMD with the present tender.
- (vi) Tenders not accompanied with Full Earnest Money Deposit, as indicated above, will not be considered.
- (vii) **All corrigenda, addenda, amendments and clarifications to this Tender will be hosted in this web page and not in the newspaper. Bidders shall keep themselves updated with all such amendments.**
- (viii) BHEL reserves the right to accept or reject any or all tenders without assigning any reason whatsoever.
- (ix) BHEL takes no responsibility for any delay/loss of documents or correspondences sent by courier/post.
- (x) Purchase Preference will be given to CPSU's as per Govt. Guidelines.

DGM/SCP



ISO 9001-2000, ISO
14001 and OHSAS
18001 certified company
SubContract and
Purchase Deptt.

Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)
Power Sector – Northren Region,
Plot No. 25 , Sector - 16A ,
Distt. Gautam Budh Nagar, NOIDA – 201 301 (INDIA)
Phone: 0091-0120-2515476 / 2515464 / 2515479
Fax 091-0120-2515464 / 2515467
Email: sku@bhelsnr.co.in / msd@bhelsnr.co.in

TENDER NOTICE - NEWSPAPER

LAST DATE OF SALE : 22.01.2008
DATE OF OPENING : 22.01.2008

NIT NO. / NAME OF WORK
<p style="text-align: center;">TENDER NO. BHEL:NR(SCT): PARICHA (EXT II):BLR 5&6:470</p> <p>Sealed tenders are invited from the contractors fulfilling qualifying requirements for the work of “erection, testing, commissioning and trial operation of Boilers of 2 X 250 MW units (units 5 & 6) at Paricha (Ext II) Thermal Power Station (PTPS) of UPRVUNL, Dist Jhansi, UP.</p>

NOTES:-

1. Purchase Preference will be given to CPSU as per Govt. Guidelines.
2. Please visit our website at www.bhel.com for complete details of the tender.

DGM/SCP

Bharat Heavy Electricals Limited
(A Govt. Of India Undertaking)
Power Sector – Northren Region,
Plot No. 25 , Sector - 16A ,
Distt. Gautam Budh Nagar, NOIDA – 201 301.INDIA

PROCEDURE FOR SUBMISSION OF SEALED TENDERS:

The tenderers must submit their tenders as required in **two parts** in separate sealed covers **prominently superscribed as Part-I Technical bid and Part-II ,Price bid** also indicating on each of the cover tender specification no., date and time as mentioned in tender notice.

TECHNICAL BID (COVER-I)

Except **Price bid Part-II**, complete set of tender document consisting of General conditions of Contract, “Technical specification & Special terms and condition” (Part-I) issued by BHEL shall be enclosed in **Part I Technical Bid only**. All schedules, data sheets and details called for in the specification shall also be submitted along with technical bid. All details / Data / Schedules including offer letter duly signed and stamped are to be **submitted in duplicate**.

PRICE BID (COVER-II)

Tenderers may please note that price bid is **to be submitted only in original copy** of Tender i.e. Price bid (Part-II) issued by BHEL and no duplicate copy of same is required.

These Two separate covers i.e. cover I & II shall together be enclosed in a **third envelope (Cover-III)** and this sealed cover shall be superscribed with tender specification No., due date, time and submitted to officer inviting tender as indicated in tender notice on or before due date as indicated.

PROJECT SYNOPSIS

1. Name of the Owner: Uttar Pradesh Rajya Vidyut Utpadan Nigam Ltd
2. Installed capacity: 2 x 110 MW + 2 x 210 MW
3. Proposed Extention : 2 x 250 MW
4. Nearest Railway station : Jhansi -- 22 km
Paricha -- 6 km
5. Nearest City : Jhansi .22 km by road on NH 25(Jhansi -
Kanpur Highway)
6. Nearest Airport : Kanpur - 200 km
Gwalior - 100 km
7. Maximum Tempreture : 48 Deg C
Minimum tempreture : Appx 2 Deg C

SECTION - III `A'

SPECIAL CONDITIONS OF CONTRACT

INDEX

CLAUSE No.	DESCRIPTION
34.	General
35.	Civil works, foundation and grouting
36.	Consumables
37.	Tools & Plants / IMTE's
38.	Supervisory staff & workmen
39.	Material handling and storage
40.	Preservation of components
41.	Erection
42.	Welding HT, RG and NDT
43.	Application of Insulation and refractory
44.	Testing, Pre-commissioning, commissioning and post-commissioning.
45.	Finish Painting
46.	Progress reporting
47.	Drawings and documents
48.	Taxes and Duties
49.	Extra work
50.	Price variation
51.	Rate schedule
52.	Instructions to tenderers

SECTION - III `A`

SPECIAL CONDITIONS OF CONTRACT

34.0 GENERAL

34.1 The intent of this specification is to provide services for execution of the project according to most modern and proven techniques and codes. The omission of specific reference to any method, equipment or material necessary for the proper and efficient services towards installation of the plant shall not relieve the contractor of the responsibility of providing such services / facilities to complete the work or portion of work awarded to him. The quoted / accepted rates / lumpsum price shall deem to be inclusive of all such contingencies.

34.2 The contractor shall carry out the work in accordance with standard practices / codes / instructions / drawings / documents / specification supplied by BHEL from time to time.

34.3 The work shall conform to dimensions and tolerances given in various drawings and documents that will be provided during erection. If any portion of work is found to be defective in workmanship, not conforming to drawings or other stipulations, the contractor shall dismantle and redo the work duly replacing the defective materials at his cost. Failing which the job will be carried out by BHEL by engaging other agencies/ departmentally and recoveries will be affected from contractor's bills towards expenditure incurred including BHEL's usual overhead charges.

34.4 **Following shall be the responsibility of contractor and have to be provided within finally accepted rates / prices:**

- a** Provision, as required, of all types of labour, supervisors, engineers, watch and ward, tools & tackles, calibrated inspection, measuring and testing equipment as specified and otherwise required for the work, consumables for erection, testing and commissioning including material handling.
- b** Proper out-turn as per BHEL plan and commitment.
- c** Completion of work as per BHEL Schedule.
- d** Good quality and accurate workmanship for proper performance of the equipment.
- e** Repair and rectification.
- f** Preservation / Re-conservation of all components during storage / erection / commissioning till handing over.

34.5 **BHEL-Power Sector(NR) is ISO 9001-2000, ISO 14001-1996, OHSAS 18001-1999, BS 7799 and SA-8000 certified company. Quality of work, to customer's satisfaction and system requirements is the essence of these certifications. The contractor in all respects will organize his work, systems, environment, process control documentation, tools, plant, inspection, measuring and testing equipments etc. as per instructions of BHEL engineer.**

The contractor shall also comply with applicable legislation and regulations with regards to Health, Safety and Environmental aspects for minimizing risk arising from occupational health & safety hazards, controlling pollution and wastage. The Contractor will be

responsible for Health, Safety & Environment management (HSE) at site for the construction activities to be carried out by them in accordance with requirements given under section I (a) of GCC and elsewhere in this tender document. The contractor, who is awarded the work, shall have to sign an MOU w.r.t implementation of HSE conditions with BHEL (Safe Work Practices).

35.0 CIVIL WORKS, FOUNDATIONS AND GROUTING.

35.1 BHEL shall provide foundations for all the equipment and columns including their grouting and necessary other civil work. The contractor for their scope shall check the dimensions of the foundations, locations of pockets, pitch of anchor bolts and other inserts as per drawings. Further, top elevation of foundations shall be checked with respect to benchmark etc. All minor adjustments of foundation level, dressing and chipping of foundation surfaces up to 50 mm, enlarging the pockets in foundations etc., as may be required for the erection of equipment / plants shall be carried out by the contractor.

35.2 While on the job, care is essential to avoid too much chipping and resultant lowering of level. In case of excess chipping, contractor has to arrange additional packing plates as per requirements provided BHEL Engineer allows it. When required by manufacturers, the embedded sub-sole plates shall be scraped and checked with prussian blue to get the required contact with frames.

35.3 The contractor shall ensure perfect matching of packer plates including machining, scraping and blue matching with foundation by dressing the foundation, as well as perfect matching between the packer plates and the base plate of equipment to the satisfaction of BHEL Engineer. If required the packer plates may have to be aligned and fixed on the foundations using approved quality special high strength, non-shrinking and quick-setting grouts. The minimum thickness below the packer plate should be 20 mm. The material required for this has to be arranged for by the contractor at his cost.

35.4 Entire grouting work of foundation bolt grouting, base plate grouting etc. including materials will be carried out by another agency carrying out Civil work . Contractor for subject work has to offer neat & clean foundations to the Civil Contractor to ensure perfect grouting. While grouting will be carried out by other agency, the contractor has to ensure that all the matching joints which are not to be grouted shall be kept free from the grouting mixture by applying tape or any other alternative method approved by Engineer. All assistance required has to be provided by the contractor.

35.5 The contractor shall check and verify the alignment of equipment, alignment of shafts of rotating machinery, the slopes of all bearing pedestals, centering of rotors with respect to their sealing bores, couplings etc. as applicable and the like items to ensure that no displacement had taken place during grouting. The values recorded prior to grouting shall be used during post grouting check up and verifications. Such pre and post grout records of alignment details shall be maintained by the contractor in a manner acceptable to the Engineer.

35.6 Any civil works required for safe and efficient operation of tools and tackles like grouting / excavation/ casting of foundation / anchor points for derricks, winches, guy ropes fastening, etc and any other temporary supports shall also be the contractor's responsibility. For these civil works, all materials including cement and required facilities shall have to be arranged by contractor at his own cost.

36.0 CONSUMABLES

- 36.1** The contractor shall provide within finally accepted price / rates, all consumables like all welding electrodes (including alloy steel and stainless steel), filler wires, TIG filler wires (over & above as supplied by the unit along with the plant materials, which will be given free of cost to bidder) all gases (inert, welding, cutting), soldering material, dye penetrants, radiography films. Other erection consumables such as tapes, jointing compound, grease, mobile oil, M-seal, Araldite, petrol, CTC / other cleaning agents, grinding and cutting wheels are to be provided by the contractor. Steel, H&S, packers, shims, wooden planks, scaffolding materials hardware items etc required for temporary works such as supports, scaffoldings are to be arranged by him. Sealing compounds, gaskets, gland packing, wooden sleepers, for temporary work, required for completion of work except those which are specifically supplied by manufacturing unit are also to be arranged by him.
- 36.2** All the shims, gaskets and packing, which go finally as part of equipment, shall be supplied by BHEL free of cost.
- 36.3** It shall be the responsibility of the contractor to plan the activities and store sufficient quantity of consumables. Non-availability of any consumable materials or equivalent suggested by BHEL cannot be considered as reason for not attaining the required progress or for additional claim.
- 36.4** Only TIG filler wire For Boiler and Filler wires and Electrodes for P91 Piping shall be supplied by BHEL free of cost. Required quantity as arrived at by calculation / standards will only be supplied. It would be the contractors' responsibility to account for the consumption of these filler wires. Additional consumption beyond standard / calculated quantity will be at cost recovery basis only unless and otherwise accounted for. Surplus quantity of TIG filler wire, if any, shall be properly stored and returned to BHEL stores.
- 36.5** It shall be the responsibility of the contractor to obtain prior approval of BHEL, regarding suppliers, type of electrodes etc before procurement of welding electrodes. On receipt of electrodes at site these shall be subjected to inspection and approval by BHEL. The contractor shall inform BHEL details regarding type of electrodes, batch number, date of expiry etc and produce test certificate for each lot / batch with correlation of batch / lot number with respective test certificate. No electrode without a valid test certificate will to be used.
- 36.6** BHEL reserves the right to reject the use of any consumable including electrodes, gases, lubricants / special consumables if it is not found to be of the required standard / make / purity or when shelf life has expired. Contractor shall ensure display of shelf life on consumable wherever required and records maintained.
- 36.7** Storage of all consumables including welding electrodes shall be done as per requirement / instruction of the Engineer by the contractor at his cost.
- 36.8** In case of improper arrangement for procurement of any consumable, BHEL reserves the right to procure the same from any source and recover the cost from the Contractor's first subsequent bill at market value plus the departmental charges of BHEL from time to time (30% at present). Postponement of such recovery is normally not permitted. The decision of Engineer in this regard shall be final and binding on the Contractor.
- 36.9** All lubricants and chemicals required for cleaning, pre-commissioning,

commissioning, testing, preservation and lubricants for trial runs of the equipment shall be supplied by BHEL / BHEL's client. All services including labour and T&P will be provided by the contractor for handling, filling, emptying, refilling etc. the consumption of lubricants / chemicals shall be properly accounted for. Surplus material if any shall be properly stacked and returned to BHEL/ CUSTOMER stores at no extra cost to BHEL. BHEL reserves the right to recover costs for wastage by the contractor.

36.10 Transportation of oil drums, from stores, filling of oil and filling of oil for flushing, first filling of oil and subsequent changeover or topping / making up till the unit is fully commissioned and handed over to customer is included in scope of this contract. The contractor shall have to return all the empty drums to BHEL / BHEL's client store at no extra cost. Any loss / damage to above drums shall be to contractor's account.

36.11 All charges on account of Octroi, terminal or sales tax and other duties on materials obtained for the works from any source shall be borne by the contractor.

37.0 TOOLS AND PLANTS / IMTE's

37.1 T&P / IMTE's being provided by BHEL , **as per Annexure-II & III**, to sub-contractor free of hire charges shall be shared by other subcontractors working for BHEL at site and the allotment done by BHEL Engineer shall be final and binding.

37.2 Besides the T&Ps and IMTEs being made available to contractor free of hire charges by BHEL, all other T&Ps and IMTEs which are required for successful and timely execution of the work covered within the scope of this tender, shall be arranged and provided by the contractor. Indicative lists of T&Ps and IMTEs to be arranged by the contractor are given **as per Annexure-IV & and Annexure-V**. He should ensure that these are in good working condition. In the event of the failure of contractor to bring necessary and sufficient T&Ps and IMTEs, BHEL will be at liberty to arrange the same and hire charges as applicable shall be deducted from contractor's bill. Decision of BHEL in this regard shall be final and binding on contractor.

37.3 All distribution boards, connecting cables, wire ropes, hoses, pipes etc, including temporary air / water / electrical connections etc shall have to be arranged by the contractor at his own cost.

37.4 In case of non-availability of the T&Ps to be provided by BHEL due to breakdown, major overhauls, distribution pattern or any other reason, the contractor shall plan / amend / alter his activities to meet erection / commissioning targets in consultation with BHEL.

37.5 The **operation** of all BHEL's cranes (**Except for 200/250 MT cranes**) being provided free of hire charges shall be in the scope of the contractor. The contractor shall arrange, at his own cost, trained operators and fuel and other minor consumables (i. e. cotton cloth / cotton waste) for their operation. (**Operator only for 200/250 MT cranes will be provided by BHEL**). **Further, Helpers and fuel for operation of all BHEL cranes, shall be provided by contractor within the final accepted rates).**

All Lubricants for the BHEL cranes such as mobil oil, gear oil, brake oil, hydraulic oil, torque converter oil and grease will be provided by BHEL free of cost. The contractor will give the requirement well in advance .

37.6 The contractor shall engage trained and experienced operators for the operation of BHEL's T&Ps. Their skill / performance will be checked by BHEL Engineer

before they are allowed to operate the same. However checking of skills by BHEL does not absolve the contractor of his responsibilities for proper and safe handling of equipment, consistent good performance of operators and regular performance evaluation of operators.

37.7 The day to day **operation and maintenance** of BHEL's T&Ps (**Other than cranes**) shall be carried out by contractor as per manufacturer's / BHEL's maintenance schedule at his cost. The contractor shall arrange, at his own cost, trained operators, fuel and other consumables for their operation. BHEL shall arrange all spares needed for upkeep of huck bolting machine, DG Set, Induction Machine and Hydraulic Test pumps supplied by BHEL. The contractor is to arrange for fixing of the spares and supervision will be provided in very specialized cases. For upkeep of all other T&Ps supplied by BHEL, spares shall be arranged by the Contractor. BHEL supplied T&Ps shall be maintained in good working condition during the entire period of use. T&Ps in defective / damaged condition shall be rectified promptly to the full satisfaction of BHEL engineer. Contractor shall maintain records for maintenance of major T&Ps. These shall be made available for Inspection whenever required. In case of any lapses on the part of the contractor, BHEL at its own discretion get the servicing / repair of equipment done at the risk and cost of the contractor with BHEL overheads. Further, if there are breakdowns / damages due to negligence of the contractor, the complete service / repair charges and cost of all the spares damaged with BHEL overheads shall be recovered from contractor's RA bills.

37.8 **Maintenance of all BHEL cranes shall be covered under AMC awarded by BHEL.** However, the helpers for planned maintenance and fuel for these cranes shall be in the scope of this contract. The contractor at his own cost shall arrange all supervision and labour required for routine / day-day maintenance of cranes. For attending breakdowns of these cranes, the contractor shall arrange for labour. However specialist's supervision, for attending breakdowns shall be arranged by BHEL as assessed by BHEL Engineer. Repair of self and dynamo shall be the responsibility of the contractor. The cranes shall be fitted with a set of new batteries at the time of initial issue from the stores. However, the charges of the replacement of the other damaged / worn out parts of BHEL cranes will be borne by BHEL, provided the damage is not due to the negligence of the contractor.

All the spares & lubricants (except for diesel) for the cranes (BHEL's Cranes) shall be supplied by BHEL. **For all BHEL cranes , if there are breakdowns / damages due to negligence of the contractor, the complete service / repair charges and cost of all the spares damaged with BHEL overheads shall be recovered from contractor's RA bills.**

37.09 Increasing / shortening of the crane boom to suit work requirements shall have to be arranged by the indenting contractor at his cost. All necessary manpower tools, support, consumables, illumination etc. will have to be arranged by contractor at his cost. If required, contractor has to return the crane with original boom.

37.10 The area and infrastructure development of the area to be carried out by the customer. However in construction projects of this magnitude it is possible that all the areas / approaches may not be ready. In such cases consolidation of ground and arrangement of sleepers / sand bag filling etc for safe operation / movement of equipment including cranes / trailers etc shall be the responsibility of the

contractor at his cost. No compensation on this account shall be payable.

- 37.11** In the event of contractor not using and maintaining BHEL T&Ps according to BHEL's instructions. BHEL will have the right to withdraw such item without any notice and no claim in this regard shall be entertained and contractor shall be responsible for delay in execution on this account.
- 37.12** The contractor shall furnish regular utilization report of the BHEL T&Ps, as per requirement of BHEL.
- 37.13** Any loss / damage to any part of BHEL T&Ps and IMTEs shall be to the contractor's account and any expenditure on these accounts by BHEL will be recovered from the contractor's bill in case the contractor fails to make good the loss.
- 37.14** It shall be responsibility of the contractor to take delivery of T&Ps from stores or place of use by other contractor at project site, transport the same to site and return the same to BHEL store / place as intimated by Engineer in project site in good working conditions after use.
- 37.15** The contractor shall return BHEL T&Ps and IMTEs issued to him in good working condition as and when desired by BHEL (on completion or reduction of workload). If contractor delays return of T&P and IMTE, hire charges as applicable shall be levied by BHEL from time, it was requisitioned till the time of actual return.
T&Ps and IMTEs returned in damaged / unserviceable condition shall be got repaired by BHEL at its own discretion and entire cost of repair with BHEL overheads shall be recovered from the contractor.
- 37.16** Replacement cost including BHEL overheads in respect of irreparable / completely damaged / non return of T&Ps and IMTEs shall be recovered from the contractor's running / final bills
- 37.17** Contractor shall ensure deployment of serviced and healthy T&Ps including cranes, lifting tackles, wire ropes, manila ropes, winches and slings etc. History card and maintenance records for major T&Ps will be maintained by the contractor and will be made available to BHEL Engineer for inspection as and when required. Fitness certificate / Test Certificates of T&P shall have to be submitted before it is put in use. Identification for such T&Ps will be done as per BHEL Engineer's advice.
The Contractor shall ensure that only new equipments are deployed for slings upto 20 mm and lifting tackles upto 3 MT capacity .
- 37.18** Contractor shall ensure deployment of reliable and calibrated IMTEs (Inspection measuring and testing equipment). The IMTEs shall have test / calibration certificates from authorized / Government approved / accredited agencies traceable to National / International standards. Each IMTE shall have a label indicating calibration status i.e. date of calibration, calibration agency and due date for calibration. A list of such instruments deployed by contractor at site with its calibration status is to be submitted to BHEL Engineer for control.
- 37.19** Re-testing / re-calibration shall also be arranged at regular intervals during the period of use as advised by BHEL Engineer within the contract price. The contractor will also have alternate arrangements for such IMTE so that work does not suffer when the particular instrument is sent for calibration. If any IMTEs not found fit for use, BHEL shall have the right to stop the use of such item. It will be necessary for the contractor to deploy proper item. Any readings taken by the defective instrument will be recalled and repeat the readings taken by that instrument with a proper one. In case he fails to do so, BHEL may deploy IMTEs

and retake the readings at contractor's cost.

37.20 BHEL shall have lien on all T&P, IMTEs and other equipment of the contractor brought to the site for the purpose of erection, testing and commissioning. BHEL shall continue to hold the lien on all such items throughout the period of contract / extended period. The contractor and / or his sub-contractors, without the prior written approval of the Engineer, shall remove no material brought to the site.

37.21 The month wise T&P deployment plan to be submitted as per format (**at Annexure-D to General Conditions of Contract**) is only to assess the capability as well as understanding of the contractor to execute the work. It shall be the contractor's responsibility to deploy the required T&P, for timely and successful completion of the job, to any extent over and above those indicated in the above deployment plan (including those which are not covered in the plan submitted) without any compensation on this account.

37.22 One CONSTRUCTION ELEVATOR / PASSENGER LIFT per boiler will be provided to the erection agency against the contract. The total erection including dismantling, commissioning, maintenance, statutory clearances shall be in the scope of erection agency against the contract, at no extra cost to BHEL. Necessary supervision of the supplier will be arranged for by BHEL.

All day to day and routine maintenance and checking of the lift is to be carried out by the contractor as per the recommendations of the supplier. He should periodically check the brakes and carry out the all works to ensure the safety for all those using the hoist.

The hoist should never be overloaded as this can lead to serious accidents. Ensuring all safety aspects in operation of lift shall be responsibility of contractor. All the landing platforms are to be erected by him. They are to be provided with proper barricades and hand railings. No separate payment for the temporary jobs will be made. The contractor will have to dismantle such temporary works and return the material to the stores.

The construction and dismantling of the foundations required for the passenger lifts is included in the scope of the contractor.

38.0 SUPERVISORY STAFF AND WORKMEN

38.1 The contractor shall deploy all the skilled workmen like millwright fitters, welders, crane operators, drivers, gas cutters, riggers, sarangs, masons, carpenters, electricians, helpers and instrument technicians to carry out the works as per specifications. In addition to skilled, semi-skilled and unskilled workmen required for all the works, suitable workmen required for handling and transporting of equipment from site storage to erection site, erection, testing and commissioning as contemplated under this specification shall be deployed. Only fully trained and competent men with previous experience on the job shall be employed. They shall hold valid certificates wherever necessary.

BHEL reserves the right to decide on the suitability of the workers and other personnel who will be deployed by the contractor. BHEL reserves the right to insist on removal of any employee / workman of the contractor at any time, if they find him unsuitable. The contractor shall remove him forthwith.

38.2 The supervisory staff including qualified Engineers deployed by the contractor shall ensure proper out-turn of work and discipline on the part of the labour put on the job by the contractor. They should in general see and ensure that the works are carried out in a safe and proper manner and in coordination with other labour and

staff deployed directly by BHEL or other contractors of BHEL or BHEL's client / other agency.

38.3 The work shall be executed under the usual conditions affecting major power plant construction and in conjunction with numerous other operations / activities at site. The contractor and his personnel shall cooperate with other personnel / contractors, coordinating his work with others and proceed in a manner that shall not delay or hinder the progress of work as a whole.

38.4 The contractor's supervisory staff shall execute the work in the most substantial and workman like manner in the stipulated time. Accuracy of work and aesthetic finish are essential part of this contract. The contractor shall be responsible to ensure that assembly and workmanship conforms to the dimensions and tolerances given in the drawings / documents / instructions given by BHEL Engineer from time to time.

38.5 The contractor shall deploy the necessary number of qualified and approved full time electricians at his cost to maintain his temporary electrical installation till the completion of work.

38.6 It is the responsibility of the contractor to engage his workmen in shifts or on overtime basis for achieving the targets set by BHEL and also during the period of commissioning and testing of unit. The contractor's finally accepted rates / prices shall include all these contingencies.

38.7 During the course of erection,

- If the progress is found unsatisfactory,
- If the target dates fixed from time to time for every mile stones are to be advanced / not being met,
- if it is found that the skilled workmen like fitters, operators, technicians etc deployed are not sufficient,

BHEL after giving reasonable opportunity to the contractor will induct on the work the required workmen in addition to contractor's workmen to improve the progress. The expenses so incurred will be recovered from the contractor's bills with overheads.

38.8 If the contractor or his workmen or employees shall break, deface, injure or destroy any part of a building, road kerb, fence, enclosure, water pipes, cables, drains, electric / telephone poles, wire, trees or any other property or to any part of erected components, the contractor shall make the same good at his own expense. In default, BHEL may cause the same to be made good by other workmen or by other means and deduct the expenses from any money due to the contractor. BHEL's decision will be final and binding.

38.9 Though every endeavor shall be made to ensure that all plant materials are supplied as per schedule. However in a job of this kind it is possible that some materials may be delayed. In order to achieve the ultimate targets, the contractor may have to augment his manpower and resources. No compensation on this account shall be admissible.

38.10 The month wise manpower deployment plan to be submitted as per format (**at Annexure-C to General Conditions of Contract**) is only to assess the capability as well as understanding of the contractor to execute the work. It shall be the contractor's responsibility to deploy the required manpower, for timely and successful completion of the job, to any extent over and above those indicated in the above deployment plan (including those which are not covered in the plan

submitted) without any compensation on this account. The contractor shall identify separate persons at site for quality control and safety. These are expected to be well versed and qualified in their respective functions

MATERIAL HANDLING AND STORAGE

39.0

39.1 All the equipments/materials furnished under this contract shall be received from the project stores, sheds / storage yards and transported to pre assembly area / erection site and stored in the storage spaces in a manner so that they are easily retrievable till the contractor erects them. **While drawing lifting material from BHEL / customer stores, the contractor shall ensure that the balance / other materials are stacked back immediately. No claim is admissible on this account**

39.2 While BHEL will endeavor to store / stack / identify materials properly in their open / close / semi closed / tarpaulins covered storage yard / shed, it shall be contractor's responsibility to assist BHEL in identifying materials well in time for erection. They should take the delivery of the same, following the procedure indicated by BHEL, and transport the material safely to pre-assembly yard / erection site in time, according to program.

39.3 The contractor shall take delivery of components, equipment / consumables from storage area after getting the approval of BHEL Engineer on standard indent forms.

39.4 The contractor shall identify and deploy necessary Engineers / supervisors / workmen for the above work in sufficient number as may be needed by BHEL, for areas covering their scope.

39.5 All the equipment shall be handled very carefully to prevent any damage or loss. No untested wire ropes / slings etc. shall be used for unloading / handling. The equipment shall be properly protected to prevent damage either to the equipment or to the floor where they are stored. The equipment from the stores shall be moved to the actual location at the appropriate time so as to avoid damage of such equipment at site.

39.6 Contractor shall ensure that while lifting slings shall be put over the points indicated on the equipment or as indicated in the manufacturer's drawings. Slings / shackles of proper size shall be used for all lifting and rigging purposes. All care shall be taken to safe guard the equipment against any damage. Dragging of piping / valves should be avoided. In case of any damage the cost shall be covered from the contractor.

39.7 Approach road conditions from the stores / yards to the erection site may not be equipped and ideal for smooth transportation of the equipment. Contractor may have to be adequately prepared to transport the materials under the above circumstances without any extra cost. . The contractor may familiar himself with soil conditions at site.

39.8 Contractor shall be responsible for examining all the plant and materials issued to him and notify the Engineer immediately of any damage, shortage, discrepancy etc before they are moved out of the stores / storage area. The contractor shall be solely responsible for any shortages or damages in transit, handling, storage and erection of the equipment once received by him. As the erection work will be spread in different areas / locations of the project, contractor has to arrange sufficient number of watch / ward personal to avoid any pilferage of material. As

per General Conditions of contract under provisions of clause No 29 BHEL will reserve the right to recover the cost of repair / replacement, if any, to bring back the equipment in original order, in case the equipment / material is lost / damaged while in the custody of the contractor. BHEL's decision in this regard shall be final and binding on the contractor.

39.9 The contractor shall maintain an accurate and exhaustive record-detailing out the list of all equipment received by him for the purpose of erection and keep such record open for the inspection of the engineer at any time.

39.10 All the material in the custody of contractor and stored in the open or dusty locations must be covered with suitable weather proof / fire retardant covering material wherever applicable and shall be blocked up on raised level above ground. All covering materials including blocks and sleeper shall be arranged by the contractor at his cost.

39.11 If the material belonging to the contractor are stored in area other than those earmarked for his operation the engineer will have the right to get it moved to the area earmarked for the contractor at the contractors risk and cost.

39.12 The contractor shall be responsible for making suitable indoor storage facilities to store all equipment (drawn by the contractor from BHEL / customer stores), which require indoor storage till the time of their installation. The Engineer will direct the contractor in this regard, which item in his opinion will require indoor storage, and the contractor shall comply with Engineer's decision.

39.13 The contractor shall ensure that all surplus / damaged / scrap / unused material, packing wood / containers/ special transporting frames etc are returned to BHEL at a place in project area identified by the Engineer. The contractor will maintain an account for all items received and returned to BHEL. Any shortage in returning such items shall be chargeable to the contractor except for a 5% allowable against wastage for packing wood only.

39.14 The contractor shall hand over all parts / materials remaining extra over the normal requirement with proper identification tags to the stores as directed by the concerned BHEL engineer.

39.15 The contractor shall ensure that all the packing materials and protective devices installed on equipment during transit and storage are removed before installation.

39.16 It shall be the responsibility of the contractor to keep the work / storage areas in neat, tidy and working conditions. All surplus/unusable packing and other materials shall be removed and deposited at location(s) specified by BHEL within the project premises. If required weighing of the same within the project premises will have to be carried out.

40.0 PRESERVATION OF COMPONENTS

40.1 After taking delivery from BHEL / customer's stores, plant materials storage shall be subjected to the following protection besides other provisions indicated in these specifications elsewhere.

a) Items stored outdoors shall be blocked up at least six inches (6") off the ground . He should have sufficient numbers of wooden / concrete / steel sleepers for the job.

b) Motors, valves, electrical equipment, control equipment and instruments etc shall be stored indoors in a warehouse provided by contractor. Motor windings shall be kept dry by use of external heat or space heaters.

- c) Bearings and other wearing surfaces of plant materials shall be protected against corrosion and kept clean.
- d) Insulation materials shall be stored indoors or otherwise protected against getting wet/ damaged.
- 40.2** It shall be the responsibility of the contractor to apply preservatives / touch up paints (primer) on equipment handled and erected by him till such time of final painting. It shall be contractor's responsibility to arrange for required paints (primer), thinners, labour, scaffolding materials, cleaning materials like wire brush, emery sheets, etc, cleaning of surface and provide one coat of preservatives / paints (primer) from time to time as decided by BHEL engineer. The accepted rate shall include this work also. It is to be noted that such painting may have to be done as and when required till such time the final painting is carried out.
- 40.3** The contractor shall effectively protect the finished work from action of weather and from damage or defacement and shall cover the finished parts then and there for their protection.
- 40.4** Any failure on the part of contractor to carry out works according to above clauses will entail BHEL to carry out the job from any other party and recover the cost from contractor.
- 41.0 ERECTION**
- 41.1** All normal erection and assembly techniques necessary for completion of works under this specification and magnitude have to be carried out. It is not possible to specifically list out all of them. Absence of any specific reference will not absolve the contractor of his responsibility for the particular operation. These would include,
- Scaffolding and rigging operations,
 - Machine / flame / electric cutting, grinding, welding, radiography and stress relieving
 - Fitting, fettling, filing, straightening, chamfering chipping, scrapping, reaming, as cleaning, checking, leveling, blue matching, aligning and assembly.
 - Machining, surface grinding, drilling, doweling, shaping
 - Temporary erections for alignment, dismantling of certain equipment for checking, cleaning, servicing and site fabrication.
- 41.2** Any fixtures, scaffolding materials, approach ladder, concrete block supports, steel structures required for temporary supporting, pre-assembly or checking, welding, lifting and handling during pre-assembly and erection shall be arranged by contractor at his cost.
- 41.3** No members of any ladder / structure / platform should be cut without specific approval of BHEL. In case it is necessary to cut, the contractor shall rectify / repair in a manner acceptable to BHEL / customer without any additional cost.
- 41.4** The contractor shall erect scaffolding / temporary platforms for erection. These should be of adequate capacity and shall never be over loaded. These should be replaced when not found suitable during erection work and dismantled on work completion and removed from work site.
- 41.5** It shall be the responsibility of the contractor to provide ladders on columns for initial work till such time stairways are completed. For this, the ladder should not be welded on the column and should be pre-fabricated clamping type ladders.

No temporary welding on any structural member is permitted except under special circumstances with the approval of BHEL. In case it is absolutely necessary then the contractor shall cut the temporary structure and rectify the column as directed by the engineer.

- 41.6** The contractor is strictly prohibited in using the Boiler / ESP / Auxiliary Components for any temporary supporting or scaffolding works etc. In case of such misuse a sum of determined by Engineer will be recovered from contractor's bills.
- 41.7** Boiler auxiliary columns are plate formed box section and the erection joint is welded type where as the columns are butt type with HSFG bolted flange and partition plates, boiler main column are having flange with splice plates and bolted connections. However, the contractor has to carry out work at site as per drawing.
- 41.8** The material for platform section weight approx. 250-300 MT under PG-36 shall be supplied in running meters. These shall be cut to size / shape / fabricated to required size / shape and to be welded by contractor.
- 41.9** Certain adjustment in length may be necessary while erecting pipelines / ducts / casings etc. The contractor should remove the extra lengths / add extra lengths to suit the final layout after preparing edges afresh by adopting specified heat treatment procedures.
- 41.10** Economizer, super-heaters, re-heater coils, burner panels may have to be hydraulically tested individually, if required, before erection as instructed by BHEL Engineer within finally accepted rates.
- 41.11** Suspensions for ducting will be supplied in running lengths, which shall be cut to size and adjusted as required. Ducts / expansion bellows are dispatched to site in loose walls plates / pieces and these are to be assembled and welded at site along with stiffeners etc., before erection within the finally accepted rates. All joints connecting duct expansion piece and dampers shall be seal welded on inside as well as on outside.
- 41.12** Assistance in mechanical work associated with the power cylinders, valves, valve actuators etc., coming under various groups shall be provided by contractor within the finally accepted rates.
- 41.13** Hanger rods are shown in the pressure parts arrangement drawings for boiler. Any cutting / welding of these hangers rods will be done by the contractor. The hangers for pressure parts will be tested for even distribution of load with the help of a torque wrench.
- 41.14** The headers are provided with hand holes. The contractor, shall as per requirement, carry out removal and re-fixing of hand hole plates within finally accepted rates.
- 41.15** Burner tilt mechanism will be checked for freeness, serviced and adjusted, if necessary to obtain optimum tilt before installation.
- 41.16** Skin casing sheet for covering the boiler roof panels, rear arch tube and other areas will be supplied by BHEL. Any cutting, addition and re-fabrication to suit the site conditions shall be carried out within the finally accepted rates.
- 41.17** ESP collecting electrodes may require straightening and repair due to minor transport damages before erection and spot heating in position to get correct alignment and same will be carried out by the contractor at no extra cost.
- 41.18** The contractor shall carry out trial run of all motors including checking the

direction of rotation in the uncoupled condition. Checking of alignment and re-coupling of the motor to the driven equipment as per instructions of BHEL engineer and to their satisfaction.

- 41.19** The contractor shall fabricate pipe, special bends etc., threading and welding as required for installing lube oil system and carry out the acid cleaning of the fabricated piping. The contractor shall also service the lube oil system, carrying out the hydraulic test of oil coolers etc.
- 41.20** Contractor shall carry out kerosene testing of all bearing housings of various rotating equipment like pumps, fans etc., as per BHEL engineer's instructions. Performance of hydro test of oil coolers of rotating machines and hydro test of SCAPH and other equipment as per BHEL engineer's instructions is included in the scope of work.
- 41.21** Forced lube oil system of motors or rotating equipment form parts of the work under this specification.
- 41.22** Certain rotating machinery after initial runs and commissioning of the equipment have to be hot aligned as per the instructions of BHEL engineer. Cleaning air pre-heater, fans, boiler ducting etc., free of extraneous steel, scaffolding materials electrodes, all foreign materials etc., before trial run of rotating machinery, and at various stages of pre-commissioning activities as per BHEL engineer's instruction, is within the scope of work.
- 41.23** Some of the rotating equipment and electrical motors are provided with protective greases only. Contractor shall arrange for cleaning of the same with kerosene or some other reagent. If necessary, dismantling some of the parts of the equipment would be necessary. He shall arrange for re-greasing / lubricating them with recommended lubricants and for assembling back the dismantled parts, at quoted rate. Lubricants will, however, be supplied free of cost by BHEL.
- 41.24** After initial trial of rotating equipment, control and power cabling for motors and other equipment / instrumentation shall have to be disconnected for checking alignment and re-setting / re-alignment / hot alignment. Contractor shall have to arrange for disconnecting control and power cabling as per BHEL engineer's instructions and clearance and reconnect the control and power cabling after realignment. Quoted tonnage rate shall be inclusive of the above.
- 41.25** Packer plates supplied may have to be machined to the correct dimensions. It may also be necessary to blue match the same with each other/ with equipment / with foundations as per BHEL instructions.
- 41.26** Contractor shall arrange changing of preservative oil in the gearboxes, journal and other bearing assemblies of rotating equipment when in storage areas or after erection of equipment as the case may be as per the instructions of BHEL engineer. Necessary lubricants / oil will be supplied by BHEL and the same will be drawn by contractor from BHEL / customer's stores and transporting to site. **No additional payment will be made for such works** even though supply of lube oil might have been made under regular dispatch-able unit (DU) number against product group main assembly (PGMA) and appearing in the shipping list. Prior to the commissioning of the equipment, oil should be drained and collected in drums provided by BHEL and returned to BHEL / customer's stores.
- 41.27** The air-preheater rotor may be disturbed during the initial operation. This may change the original clearances. It requires rechecking and correction of seal clearances. Contractor shall carry out such checks and resetting of clearances as per the instructions of BHEL engineer. The resetting may have to be repeated till

satisfactory results are obtained.

- 41.28** Checking of air gaps and adjustment of stator / rotor for magnetic center of HT motors shall be carried out as part of erection.
- 41.29** The fans, mills and other rotating machines shall be checked for clearances and other vital tolerances. The IGV unit shall be serviced. Necessary assistance for balancing of equipment during trial run, if required, shall be provided by the contractor free of cost.
- 41.30** Complete penetration of water wall (Panel to Panel) welding shall be achieved either by one side or both sides welding.
- 41.31** Whenever required the contractor shall arrange for pre-qualification of process task performers.
- 41.32** All attachments welding including those for insulation works coming on pressure parts / non-pressure parts which the contractor has erected shall be done by IBR / BHEL tested welders only.
- 41.33** All electrical cabling including proper glanding, termination, dressing etc., control and instrumentation works required for completion of Electrostatic Precipitator including its commissioning shall be part of this work. This will include erection of all electrical equipment such as rectifier, transformers, and power supply and control panel, laying of trays and cables and other associated equipment.
- 41.34** All rotating machines and equipment shall be cleaned, lubricated, checked for their smooth rotation, if necessary by dismantling and refitting before erection. If, in the opinion of Engineer, the equipment is to be checked for clearance, tolerance at any stage of work or during commissioning period, all such works are to be carried out by contractor at his cost.
- 41.35** All the shafts of rotating equipment shall be properly aligned to those of the matching equipment within design tolerances All bearings, shafts and other rotating parts shall be thoroughly cleaned and suitably lubricated before starting.
- 41.36** All the motors and equipment shall be suitably doweled after alignment of shafts with taper / parallel machined dowels as per the direction of the Engineer. Dowel pins required are to be machined by the contractor at his own cost. However the materials for dowel pins shall be issued by BHEL free of cost.
- 41.37** The HT motor bearings shall be blue matched at site and checked for bearing clearances. The contractor if required shall carry out scraping of bearing housing. No extra claim for blue matching up to 1mm initial gap will be entertained.
- 41.38** The contractor at no extra cost to BHEL shall carry out servicing and realignment of skid mounted equipment.
- 41.39** Certain instruments like pressure gauges, pressure transmitters, temperature gauges, flow switches and indicators, etc., are received in assembled condition as integral part of equipment. Contractor shall be responsible for safe receipt, installation and custody of these instruments supplied mounted on skids / equipment. The calibration of skid / equipment mounted instruments shall be arranged by BHEL through other agency engaged for C&I. Contractor will be informed by BHEL engineer about the details of C&I agency. The contractor shall coordinate with the C&I agency for removal, calibration and re-installation of the instruments. Though C&I agency will remove and reinstall the instruments after calibration, the contractor for this package will maintain the list of all the instruments removed & reinstalled. Instruments prior to removal and after reinstallation shall be considered in custody of the contractor for this package. All

instruments such as pressure gauges / temperature gauges, switches etc. forming part of product group (PG) are under the erection scope of this contract and shall be installed and commissioned by the contractor of this package at no extra cost to BHEL. However the calibration of these instruments shall be done by C&I agency as above

- 41.40** All electrical panels, control gears, motors and such other devices shall be properly dried by heating to improve IR valve, before they are energized. Bearings, slip rings commutators and other exposed parts shall be protected against moisture ingress and corrosion during storage and periodically inspected.
- 41.41** The contractor shall completely erect and test all the piping systems, covered in the specification including sampling lines up to and including sample coolers, hangers & supports, valves and accessories in accordance with the drawings furnished. This includes all necessary bolting, welding, pre-heating, stress relieving, testing, cleaning and painting. System shall be demonstrated in condition to operate continuously in a manner acceptable to the Engineer. Welding shall be used throughout for joining pipes except where flanged, screwed or other type joints are specified or shown on the drawings. All piping shall be erected true to the lines and elevation as indicated in the drawings.
- 41.42** Pipes sent in standard length shall be cut to suit the site conditions and the layouts. Tubes or pipes wherever deemed to be convenient will be sent in running lengths with sufficient bends. Bends upto 65-mm nominal bore will have to be fabricated at site. Only cold cutting methods are to be employed for cutting of pipes and tubes irrespective of the size and material . Gas Cutting , if any , will be allowed only in CS LP piping
- 41.43** The contractor shall ensure lowering of pipes in position with adequate precautions as to avoid any damage to either material or men. Only the anchoring points earmarked for the purpose of lowering the pipes are to be used.
- 41.44** It is possible that a few flanges may not be matching. The contractor shall be required to cut and re-weld the same as and when required without any additional cost.
- 41.45** Wherever piping erected by the contractor is connected to equipment / piping erected by the other agencies the joint at the connecting point shall be the responsibility of the contractor who is erecting the piping under this specifications.
- 41.46** Normally the high-pressure valves will have prepared edges for welding. But, if it becomes necessary, the contractor will prepare new edges or recondition the edges by grinding or chamfering to match the corresponding tubes and pipes within the scope of the work.
- 41.47** All fittings like `T'-pieces, weld neck flanges, reducers etc., shall be suitably matched with pipes for welding. The valves will have to be checked, cleaned or overhauled in full or in part before erection after chemical cleaning and during commissioning.
- 41.48** The contractor shall be responsible for correct orientation of all valves so that seats, stems and hand wheels will be in desired location. It is the responsibility of the contractor to obtain the information regarding orientation of valves not fully located on drawings before the same are installed.
- 41.49** Suspension for piping, etc., will be supplied in running lengths, which shall be cut to suitable sizes and adjusted as required.
- 41.50** The adjustment of all hangers & supports erected in both cold & hot conditions for

maintaining the proper slopes towards the drain pots and application of cold pull in the piping wherever required is also included in the scope of the contractor.

- 41.51** No temporary supports should be welded on the pressure parts and piping. In case of absolute necessity prior approval should be taken from BHEL Engineer. In such cases the contractor if required, shall carry out heat treatment.
- 41.52** Spring suspensions / constant load hangers have to be pre-assembled for required load and erection carried out as per instructions of BHEL. Any adjustments, removal of temporary arrests / locks etc., have to be carried out as and when required.
- 41.53** Contractor shall install piping in such a way that no excessive or destructive expansion forces exists in either the cold condition or under conditions of maximum temperature and pressure. All bends, expansion joints and any other special fittings necessary to take care of proper expansion shall be incorporated as per the advice of Engineer. During installation of expansion joints, anchors, care must be taken to see that full design movement is available at all times from maximum and minimum temperature.
- 41.54** The hanger assemblies shall not be used for attachment of rigging to hoist the pipes into position. Other means shall be used to securely hold the pipe in position till pipe supports are completely assembled and attached to the pipe and building structure.
- 41.55** Layout of small-bore piping in boiler, oil systems etc. as required shall be done as per site requirement. Necessary sketch for routing these lines should be got approved from BHEL by the contractor. There is a possibility of slight change in routing the above pipelines even after completion of erection or from aesthetic point of view. Contractor at no extra cost should carry this out. As built drawing is to be submitted by the contractor after erection completion.
- 41.56** All the valves, including motorized valves, flap valves, dampers, actuators, etc. shall be serviced and lubricated to the satisfaction of Engineer before erecting the same and during pre-commissioning also. Welding or jointing of extension spindle for valves to suit the site conditions and operational facility shall be part of erection work within the quoted rates.
- 41.57** Erection and welding of necessary instrumentation tapping points, thermocouple pads, thermo-wells, valves, battery of first root valves, condensing vessels, flow nozzles and control valves to be provided on, auxiliaries and pipe lines are covered within the scope of this specification. This will be the responsibility of the contractor and will be done as per the instructions of BHEL Engineer. The welding of all the above items will be contractor's responsibility even if the:
- a** Product groups, under which these items are released, are not covered in the scope of this tender.
 - b** Items are supplied by any agency other than BHEL.
- 41.58** The contractor shall carry out the tightening of the field bolts on the equipment and piping covered under this specification by using either the calibrated torque wrench method or the turn of part method. The methods used the tools and the equipment deployed shall be subject to the approval of Engineer. The competent technicians shall carry out the bolting work.
- 41.59** The contractor shall assist BHEL in preparation of as built piping drawing.
- 41.60** Erection of power cylinders, motorised valves, valve actuators etc. coming under various groups is covered under the scope of this specification. However C&I

calibration / commissioning for pneumatic valves & power cylinders shall be arranged by BHEL through C&I agency at no cost to the contractor for this package. The contractor will however be responsible for drawing the materials from the stores and handing over to the agency that is to commission these. Any damage / loss in their custody will be the contractors account. The alignment and any mechanical adjustments including link adjustment, opening & reconnection of links, replacement of valve / actuator or any mechanical part, air filter & regulator cleaning etc. required during calibration and operation, the same shall be carried by the contractor for this package. However, if re-calibration is required till handing over of the equipments the same shall be organised by the contractor for this package as detailed above with in the final accepted rates. The contractor will however be responsible for drawing the materials from the stores and handing over to the agency that is to commission these. Any damage / loss in their custody will be the contractors account.

41.61 The erection of all pneumatic power cylinders for the burner-tilt mechanism and SADC is covered within the scope of this specification. **BHEL will get these power cylinders for the burner-tilt mechanism and SADC calibrated & commissioned.** The contractor for this scope of work shall assist and co-ordinate for the same with the agency engaged by BHEL to calibrate such pneumatic actuators.

41.62 The Erection, testing and commissioning of all electrically operated valves, actuators and dampers is covered within the scope of this specification.

41.63 Boiler Drum Erection is to be carried out by the contractor as mentioned in clause no. 54.1 of this tender . The contractor has to carry out all works as mentioned therein and as required to complete this work .

41.64 Welding of P91 and T91 materials in Piping and Boiler is to be carried out as mentioned in clause nos. 54.2 and 54.3 respectively of this tender.

41.65 Scope of Work for Chemical Cleaning for the Boiler system has been covered under clause no. 54.4 of this tender.

42.0 WELDING HEAT TREATMENT, RADIOGRAPHY AND NON-DESTRUCTIVE TESTING

42.1 The pressure parts, equipment and piping shall be erected in conformity with the provisions of Indian Boiler Regulation and as may be directed by BHEL as per any standard / specification in practice in BHEL. The method of welding (arc, gas, TIG or other method) may be indicated in the detailed drawings / schedules. BHEL Engineer will have the option of changing the method of welding as per site requirements. **Semi automatic welding (GMAW) process shall be used for non-pressure parts / ducting / structures etc to the maximum possible, considering its cost efficiency, better quality and time saving features.**

42.2 Welding of pressure parts, equipment, piping, high tensile structural steel shall be done by certified high pressure welders who posses valid certificate of CIB of the State in which the equipment is erected as per provision of IBR. The H.P. welder who possesses necessary certificate shall ensure re-validation as per relevant provisions of IBR and keep the certificate valid till the completion of work. The services of such welders, the validity of whose certificates have expired shall not be utilized for high-pressure works.

42.3 All welders including tack welders, structural and high pressure welder shall be tested as per ASME section IX / IBR and approved by BHEL Engineer before they are actually engaged on work even though they may possess a valid IBR

certificate. BHEL reserves the right to reject any welder if the welder's performance is not found to be satisfactory. The contractor shall maintain the records of qualification AND performance of welders. BHEL Engineer will issue all the welders qualified for the work, an identity card. The welder will keep the same with him at work place at all times. He may be stopped from work if he is not found in possession of the same.

- 42.4** Engineer may stop any welder from the work if his performance is unsatisfactory for any technical reason or if there is a high percentage of rejection in the joints welded by him. The welder's having passed qualification tests does not absolve the contractor of contractual obligation to continuously check the welder's performance.
- 42.5** Faulty welds caused by the poor workmanship shall be cut and re-welded at the contractor's expense. The Engineer prior to any repair being made shall approve the procedure for the repair of defective welds. After the repair has been carried out, the compliance shall be submitted to the quality engineer.
- 42.6** The contractor shall carry out the root run welding of all HP / LP piping, valves by TIG welding method only. The contractor shall have to carry out full TIG welding of butt weld joints of tubes / pipes of lesser thickness if required. During the root runs of stainless steel joints, the contractor shall before and during welding have to purge the pipes with inert gas. All welded joints for temporary piping required for chemical cleaning and steam blowing should be got done by HP welders only. The root run should be done by TIG welding. All arrangements required for the above shall be the responsibility of the contractor at no additional cost. Argon Purging is to be done for TIG Run of SS Pipes
- 42.7** All expenses for testing of contractor's welders including destructive and nondestructive tests conducted by BHEL at site or at laboratory shall have to be borne by the contractor only. While the contractor will arrange for the test pieces, limited quantity of tube and pipe material required for making test pieces will be supplied by BHEL free of cost.
- 42.8** The regulators used on welding machines shall be calibrated before putting these into use for work. The Contractor at his cost shall also arrange periodic calibration for the same.
- 42.9** **Only BHEL approved electrodes and filler wire will be arranged and used by the contractor, within the finally quoted price. BHEL reserves the right to test any approved electrode being used by the contractor. Testing charges for the same shall be borne by the contractor.** All electrodes shall be baked and dried in the electric electrode-drying oven to the required temperature for the period specified by the Engineer before these are used in erection work. All welders shall have electrodes drying portable oven at the work spot. The electrodes brought to the site will have valid manufacturing test certificate. The test certificate should have a co-relation with the lot number / batch number given on electrode packets. No electrodes will be used in the absence of above requirement. The thermostat and thermometer of electrode drying oven will be also calibrated and test certificate from Govt. approved / accredited test house traceable to National / International standards will be submitted to BHEL before putting the oven in use. The contractor shall also arrange periodical calibration for the same.
- 42.10** All butt / fillet welds shall be subject to dye penetration test as per the instructions of the engineer at no additional cost.

- 42.11** The contractor shall maintain a record in the form as prescribed by BHEL of all operations carried out on each weld. He has to maintain a record indicating the number of welds, the names of welders who welded the same, date and time of start and completion, preheat temperature, radiographic results, rejection if any, percentage of rejection etc. and submit copies of the same to the BHEL Engineer as required. Interpretation of the BHEL Engineer regarding acceptability or other wise of the welds shall be final.
- 42.12** The contractor shall carry out the edge preparation of weld joints at site in accordance with the details acceptable to BHEL Engineer. Wherever possible machining or automatic flame cutting should be done. Gas cutting will be allowed only wherever edge preparation otherwise is impractical. All slag / burrs shall be removed from the edge and all the hand cuts shall be ground smooth to the satisfaction of engineer.
- 42.13** All welds shall be painted with anticorrosive red oxide paint once radiography and stress relieving works are over. Necessary consumables and scaffolding etc including paints shall be provided by contractor at his own cost.
- 42.14** Pre-heating, radiography and other NDT tests, post heating and stress relieving after welding of tubes, pipes, including attachment welding wherever necessary, are part of erection work and shall be carried out by the contractor in accordance with the instructions of the Engineer. Contractor at his cost shall arrange all equipment and consumables essential for carrying out the above process.
- 42.15** Contractor shall arrange all necessary stress relieving equipment with automatic recording devices. The contractor shall arrange for labour, heating elements, thermocouples, thermo-chalks, temperature recorders, thermocouple attachment units, graphs, sheets insulating materials like asbestos cloth, ceramic beads, asbestos ropes etc. required for heat treatment/ stress relieving operations. The contractor should take a note of the following,
- Temperature shall be measured by thermocouple and recorded on a continuous printing type recorder. All the recorded graphs for heat treatment works shall be the property of BHEL.
 - All stress relieving equipment will be used after due calibration and submission of test certificate to BHEL. Periodic calibration from Govt. Approved / accredited Test Houses traceable to National / International standards will also be arranged by the contractor for such equipment at his cost.
 - The contractor shall obtain the signature of Engineer or his representative on the strip chart of the recorder prior to the starting of SR operations.
- 42.16** The contractor shall also be equipped for carrying out other NDT like LPI / MPI / Hardness test etc. as required as per welding schedules / drawings within the finally accepted price / rates. Ultrasonic testing, wherever required, will be arranged by BHEL. Necessary help in conducting the UT shall however be rendered by contractor.
- 42.17** The technical particulars, specification and other general details for radiography work shall be in accordance with ASME, IBR or ISO as specified by BHEL.
- 42.18** The contractor for radiography work shall use iridium-192. The geometric unsharpness shall not exceed 1.5 mm. The contractor should take adequate safety precautions while carrying out radiography. Contractor at his cost shall arrange

necessary safe guards required for radiography (including personnel from BARC).

- 42.19** Low speed high contrasts, fine grain films (D-7 or equivalent) in 10 cm width only be used for weld joint radiography. Film density shall be between 1.5 to 2.0.
- 42.20** All radiographs shall be free from mechanical, chemical or process marks, to the extent they should not confuse the radiographic image and defect finding. Pentrameter as per ASME or ISO must be used for each exposure.
- 42.21** Lead numbers and letters are to be used (generally 6mm size) for identification of radiographs. Contract number, joint identification, source used, welder's identification and SFD are to be noted down on paper cover of radiograph.
- 42.22** Lead intensifying screens for front and back of the film should be used as per the above-referred ASME specification.
- 42.23** The joint is to be marked with permanent mark A, B, C to identify the segments. For this a low stress stamp shall be used to stamp the pipe on the down streamside of the weld.
- 42.24** For multiple exposures on pipes, an overlap of about 25-mm of film should be provided.
- 42.25** Radiography personnel with sufficient experience and certified by M/s BARC for conducting radiographic tests in accordance with safety rules laid down by Division of Radiological protection only have to be deployed. These personnel should also be registered with DRP / BARC for film badge service.
- 42.26** All arrangements for carrying out radiography work including dark room and air conditioner and other accessories shall be provided by contractor within the space allotted for office at his cost. As an alternative the contractor may deploy an agency having all above facilities and who are duly approved / accredited by BARC and / or other Regulatory authorities. Detailed particulars of such agencies will be submitted and got approved by BHEL Engineer before the actual deployment of agency for radiography work.
- 42.27** The contractor shall have a dark room fully equipped with radiography equipment, film (un-exposed), chemicals and any other dark room accessories.
- 42.28** **Contractor shall note that 100% radiography will be done at the initial stages on all the piping welding joints.** Subsequently radiographic inspection will be done on the basis of quality of welding. However minimum percentage of joints to be radiographed shall not be less than the requirement of BHEL welding schedule / IBR / Customer's requirements. The percentage may be increased depending upon the quality of joints and at the discretion of BHEL. Radiography on LP piping joints is not envisaged. However other NDT test as called for in the FQP including LPI, MPI and HT will have to be carried out.
- 42.29** All the Radiographs shall be properly preserved and shall become the property of BHEL. They are to be reconciled with the work done, joints radiographed and submitted to BHEL / customer.
- 42.30** Since radioisotopes are being used, all precautions and safety rules as prescribed by BHEL/BARC/ Customer shall be strictly followed. BARC / DRP certificate to be provided before taking up the work.
- 42.31** Radiography of joints shall be so planned after welding, that the same is done either on the same day or next day of the welding to assess the performance of HP welders. If the performance of welder is unsatisfactory, he is to be replaced immediately.

- 42.32** Wherever radiographs are not accepted, on account of bad shot, joints shall be re-radiographed and re- submitted for evaluation.
- 42.33** However, if the defect persists after first repair, further repair work followed with radiography shall be repeated till the joint is made acceptable. In case the joint is not repairable, the same shall be cut, re-welded and re-radiographed at contractor's cost.
- 42.34** If the contractor does not carry out radiography work due to non-availability of source / film / chemical / operator etc., BHEL will get the work done departmentally or through some other agency at the risk and cost of the contractor.
- 42.35** Heat treatment and radiography may be required to be carried out at any time (day and night) to ensure the continuity of the progress. The contractor shall make all necessary arrangements including labour, supervisors/ Engineer required for the work as per directions of BHEL.
- 42.36** The contractor shall assist BHEL Engineer in preparing complete field welding schedule for all the field welding activities to be carried out in respect of piping and equipment erected by him involving high pressure welding at least 30 days prior to the scheduled start of erection work at site. The contractor shall strictly adhere to such schedules.
- 42.37** For P91 materials, clauses no. 54.2 of this tender will be applicable besides above mentioned clauses from 42.1 to 42.36.
- 42.38** For T91 materials, clauses no. 54.3 of this tender will be applicable besides above mentioned clauses from 42.1 to 42.36.
- 43.0** **APPLICATION of INSULATION and REFRACTORY**
- 43.1** All attachment welding, including welding of hooks / supports as per pitch both on equipment and piping shall be done as directed by Engineer. Attachment welding shall have to be done by certified welders. If necessary contractor may have to cut the hooks to correct length without any extra cost to BHEL.
- 43.2** Contractor has to supply and apply heat resistant primer on welded portions before application of insulation.
- 43.3** The mineral wool mattresses (bonded / un-bonded) / LRB mattresses are received at site in standard sizes. These are to be dressed / cut to suit site requirements by the contractor.
- 43.4** The number of layers / thickness of mineral wool / LRB mattresses for auxiliaries, pipe lines, valves and other vessels shall be as per various drawings and as directed by Engineer. For applying the mineral wool mattress, the required holding materials, if necessary by fabrication of rings/ hooks shall be fixed as directed and as per drawings and spec.
- 43.5** The contractor should ensure, proper finishing of surface of the insulation, sheeting and cementing
- 43.6** The contractor should ensure that the finished surface of the insulation works conforms to the dimensions and tolerances given in the drawings. Aesthetic finish and accuracy of work are most important.
- 43.7** It is the responsibility of the contractor to ensure that the insulation materials and sheet metal covering issued to him for application are well protected against loss or damage from weather conditions. Closed / semi closed sheds or any other arrangements required for this will be made by him at his cost. If any damage

occur to the material due to improper storage or due to any causes attributable to the contractor except for normal breakage or damages allowed in such cases, the cost of such damaged material shall be to the account of the contractor.

- 43.8** Aluminum sheet cladding will be fabricated to the sizes and shapes specified in drawings. Beading, swaging, beveling of sheets, crowning the sheets if necessary will be carried out by him. Two coats of anti-corrosive black bituminous paint are to be applied on inner surfaces of the cladding. Bitumen sealing compound on the joints if necessary is included in the scope of this work. **Contractor may note that they will also supply anti-corrosive black bituminous paint and bituminous sealing compound required for above works at his cost. However , if any material is received from the unit , the same shall be issued free of cost to the contractor**
- 43.9** Aluminum sheet metal cladding over insulation will consists of plain / ribbed / corrugated sheets. The sheets will be supplied in standard sizes. Cutting them to required size, grooving, fabricating bends, boxes etc., for proper covering is contractor's responsibility. Any cutting / bending / welding of fabricated skin casing sheets if required will also be covered within the scope of this contract.
- 43.10** A logbook shall be maintained by the contractor to obtain clearance for application of insulation. If the contractor does the work on his own accord without prior permission the area may have to be redone at his cost.
- 43.11** Contractor is liable for the exact accounting of the material issued to him and he shall make any unaccountable losses good. Wastage allowance for the material issued are as below:
1. Wool / LRB mattresses and cladding sheets..... 2%
 2. Insulation bricks and mortar2%
 3. Castable refractory 1%
- 43.12** The entire surplus, unused materials etc., supplied by BHEL shall be returned to BHEL after the work is over. Materials like gunny bags and packing materials, empty containers may be returned at periodical intervals.
- 43.13** The contractor shall leave certain gaps and opening while doing the work as per instructions of BHEL engineer to facilitate inspection during commissioning and to fix gauges, fittings and instruments. The gaps will have to be finished as per drawings at a later date by the contractor at his cost.
- 43.14** If during erection and commissioning any of the parts are to be temporarily fixed and then replaced by permanent ones at a later date or if any of the parts are to be removed for modification, rectification, adjustment and then refitted or if some parts are to be opened for inspection and checking and for measurement of metal surface temperature the same may necessitate removal and re-application of insulation and sheet metal cladding, which shall be done by the contractor and the erection rate quoted shall be inclusive of such contingencies.
- 43.15** Removable type of insulation shall be provided for valves, fittings, expansion joints etc as per the drawings or as directed by BHEL Engineer.
- 43.16** All temporary pipelines required during testing, pre-commissioning and commissioning should be insulated as directed by BHEL at no extra cost to BHEL. However required insulation material shall be issued by BHEL free of cost.
- 43.17** Insulation of expansion joints, dampers, etc shall be carried out after NDT / gas tightness test is completed.

- 43.18** Special type of Insulation wool used in pent house shall not be cut indiscriminately.
- 43.19** Contractor shall mix and apply the refractory / insulation as per the instructions of BHEL Engineer. Castable refractory / insulation after application shall be cured as per the instructions of BHEL Engineer. The contractor shall provide the required quantity of wire nails, planks for formwork and other materials for centering and grouting work.
- 43.20** Application of castable and pourable refractory between tubes, around burners, on ceiling and as directed by Engineer and as per detailed drawings and specifications.
- 43.21** Dressing of insulation brick to suit site conditions, curing refractory concrete applied/sheet cladding over insulation forms a part of this work.
- 43.22** Contractor shall observe all precautions for laying / curing of castable refractory. Any defective works found shall be re-laid by contractor at his cost.
- 43.23** Making structural supporting work for pourable insulation, laying pourable insulation, adhering to all specifications and instructions during application forms a part of this work.
- 43.24** Day to day cleaning of insulation debris and scraps to be ensured by the contractor. Excessive wastage will attract cost recovery.
- 44.0 TESTING, PRE-COMMISSIONING, COMMISSIONING AND POST-COMMISSIONING.**
- 44.1** The contractor shall carry out all the required tests and pre-commissioning and commissioning activities required for their successful and reliable operation. These would include hydraulic test of boiler, land flow test, clean air flow test, chemical cleaning of piping and boiler, water washing, oil flushing of oil system etc. as instructed by BHEL using contractors own consumables, labour and scaffoldings etc. Air leak test on pressure parts preliminary to hydraulic test by compressed air shall also be carried out to check and rectify the various leakage and defects etc.
- All the chemicals required for carrying out these activities will be supplied by BHEL free of cost.
- All required tests (Mechanical and electrical) indicated by BHEL and their clients for successful commissioning are included in the scope of these specifications. These tests / activities may not have been listed in these specifications.
- Specialized test equipment, if any, shall be provided by BHEL / its client free of hire charges. However contractor has to take proper care of the equipment issued to him.
- 44.2** Commissioning of ESP shall involve required tests such as air leak test, gas distribution test, motor no load test, rapping mechanism trial runs, interlock tests, charging of transformer fields, commissioning of all electrical equipment / panels, heaters and their proper tuning etc. The contractor shall provide all consumables, labour, scaffoldings and items required for satisfactory testing.
- 44.3** After completion of erection of furnace, ducts and air heaters, a test shall be performed on the steam generator by the contractor to establish the tightness of the erected equipment from the outlet of FD fan through the steam generator up to stack.
- 44.4** All the tests may have to be repeated till all the equipment satisfy the requirement

/ obligation of BHEL at various stages. The contractor shall do all the repairs for site-welded joints arising out of the failure during testing.

44.5 The scope of pre-commissioning activities cover installation of all necessary equipment including temporary piping, supports, valves, blanking, pumps, tanks, with access platforms valves, along with accessories required for hydro test, chemical cleaning, steam blowing or for any other tests. The scope also covers the off site disposal of effluents.

44.6 All items / material required for conducting hydraulic test, chemical cleaning, steam blowing etc., will be supplied by BHEL/ its customer and the contractor shall take delivery of material as mentioned under clause no. 39 of this tender. However, servicing, erection, dismantling and returning of the same to stores shall be the responsibility of the respective contractor who shall be erecting the equipment / piping. The contractor may note that **no separate payment shall be released for any temporary works** that are to be carried out for conducting pre-commissioning and commissioning tests. Bidders are advised to include expenses on temporary works along with the rates being quoted by them. Broadly the work on temporary systems will be divided as under:

Boiler -: Erection etc. of all temporary piping along with insulation and supports for steam blowing, interfacing for chemical cleaning and affluent disposal are to be carried out as part of Boiler part-A work. However **Installation and operation** of all equipment including tanks and electrical switchgear along with their accessories shall be carried out by **another agency**. Contractor for Part-A work will be responsible for assisting their operation till completion of the commissioning activities. He will also service the equipment and handover the equipment to the other agency for further erection/commissioning activities.

ESP AND DUCTING : Erection etc. of blowers and blanks and putty required for conducting air tightness test and GD Test are to be carried out by the contractor. (Putty to be procured by the contractor).

The above is only a broad breakup of the temporary works. The engineer at site will make final break up. His decision will be final and binding by all the parties.

Dismantling of the temporary equipment and piping will be done by the respective agency that has erected the equipment. He will also return the equipment to the stores.

44.7 Drum will be dispatched without fixing internals and internals will be sent separately. The internals have to be fixed as and when required. Dismantling and re-assembly to be done to suit various commissioning requirements.

44.8 Commissioning of the boiler will involve trial run of all the equipment erected. The boiler has to be lighted up for refractory drying, alkali boil out, acid cleaning, passivation, preservation, steam blowing and floating of safety valves. Flushing of all the lines by air, oil or steam as the case may be, trial run of the boiler, servicing of valves and any other works incidental to commissioning are to be carried out. During this period though the BHEL's customer's staff will also be associated in the work, the contractor's responsibility will be to arrange for the complete requirement of supervision, men, consumables, T&P and IMTEs till such time the commissioned units are taken over by the BHEL's customer.

44.9 It shall be the responsibility of the contractor to preserve the boiler as per BHEL's requirement.

- 44.10** It shall be the responsibility of the contractor to provide various category of workers in sufficient numbers along with Supervisors during Pre-commissioning, commissioning and post commissioning of equipment and attending any problem in the equipment erected by the contractor till handing over. The contractor will provide necessary consumables, T&Ps, IMTEs etc., and any other assistance required during this period. Association of BHEL's / Client's staff during above period will not absolve contractor from above responsibilities.
- 44.11** It shall be specifically noted that the above employees of the contractor may have to work round the clock along with BHEL Engineers and hence overtime payment by the contractor to his employees may be involved. The contractors finally accepted rates should be inclusive of all these factors also.
- 44.12** In case, any rework is required because of contractor's faulty erection, which is noticed during pre-commissioning and commissioning, the same has to be rectified by the contractor at his cost. If any equipment / part is required to be inspected during pre-commissioning and commissioning, the contractor will dismantle / open up the equipment / part and reassemble / redo the work without any extra claim.
- 44.13** During commissioning, opening / closing of valves, changing of gaskets, realignment of rotating and other equipment, attending to leakage and adjustments of erected equipment may arise. The finally accepted price / rates shall also include all such work.
- 44.14** The contractor shall make all necessary arrangements including making of temporary closures on piping / equipment for carrying out the hydro-static testing on all piping, equipment covered in the specification at no extra cost.
- 44.15** The valves will have to be checked, cleaned or overhauled in full or in part before erection, after acid cleaning, steam blowing and during commissioning as may be necessary.
- 44.16** In case any defect is noticed during tests, trial runs and commissioning such as loose components, undue noise or vibration, strain on connected equipment etc., the contractor shall immediately attend to these defects and take necessary corrective measures. If any readjustment and realignment are necessary, the contractor at his cost shall do the same as per Engineer's instructions including repair, rectification and replacement work. The parts to be replaced shall be provided by BHEL.
- 44.17** All temporary supports shall be removed in such ways that pipe supports are not subjected to any sudden load. During hydraulic testing of pipes, all piping having variable spring type supports shall be held securely in place by temporary means while constant spring type support hangers shall be pinned or blocked solid during the test.
- 44.18** The contractor shall carry out cleaning and servicing of valves and valve actuators prior to pre-commissioning tests and / or trial operations of the plant. A system for recording of such servicing operations shall be developed and maintained in a manner acceptable to BHEL Engineer to ensure that no valves and valve actuators are left un-serviced. Wherever necessary as required by BHEL Engineer, the contractor shall arrange to lap / grind valve seats.
- 44.19** Cleaning and servicing of all the filters / strainers, toppings of oils coming in the system shall be done by the contractor within the accepted price.
- 44.20** At the time of each inspection, the contractor shall take note of the decisions / changes proposed by the Engineer and incorporate the same at no additional cost.

The contractor shall carry out any other test as desired by BHEL Engineer/ Manufacturer on erected equipment covered under scope of this contract during testing and commissioning to demonstrate the physical completion of any part or parts of the work performed by the contractor

45.0 FINISH PAINTING

45.1 All exposed metal parts of the equipment, structure, auxiliaries, piping, and other items (covered within the scope of this contract) after installations are to be painted. The surfaces are to be thoroughly cleaned of all dirt, rust, scales, grease, oils and other foreign materials by wire brushing, scrapping, any other method as per requirement of BHEL. The same will be inspected and approved by the engineer before painting.

45.2 Mostly the equipment / items/ components will be supplied with one coat of primer paint and one coat of finish paint. However during storage and handling, the same may get peeled off / deteriorate. All such surfaces are to be thoroughly cleaned and to be touch up painted with suitable approved primer and finish paint matching with shop paint / approved final colour. Besides above two coats of approved primer paint is to be applied on all the bare / unpainted surfaces. The gas cut stubs would require being ground and rounded.

45.3 After applying the primer paints, wherever required, all structure / equipment / items, shall be finish painted with paints as specified by BHEL engineer. The number of coats / paint thickness shall be as indicted in the drawing / documents. However at least two coats of finish painting is to be applied. In case proper finish is not obtained in two coats, the contractor shall apply additional coat (s) till proper finish / paint thickness is achieved. Certain equipment / Items are required to be painted with approved quality heat resistant paint / primer . After completion of painting all bright spots shall be cleaned to the satisfaction of Engineer. Minimum paint thickness is to be ensured at all places as per specifications.

45.4 Certain equipment like control panels, valves etc. shall require spray painting. The contractor shall make arrangements of the required equipment for spray painting. Spray painting at the job site shall be permitted only at times and locations approved by Engineer.

45.5 **Contractor at no extra cost to BHEL shall supply all paints, primers, tools and other consumables including scaffolding materials required for finish painting.** Paint is to be of BHEL approved make only and painting should be as per colour scheme and quality approved / specified by Engineer. Valid Test Certificate for the paint so supplied shall be made available before use of the same on work.

45.6 The contractor may be required to fill up dents / marks by applying putty before final painting of equipment. All materials and arrangements have to be made within quoted lumpsum price/rates.

45.7 The contractor shall provide legends with direction of flow on equipment and piping in size specified by Engineer. Letter writing shall be done in Hindi / English or in both languages.

45.8 The painters have to under go test and only qualified painters will be allowed to work.

46.0 PROGRESS REPORTING

46.1 Contractor is required to draw mutually agreed monthly erection programs in consultation with BHEL well in advance. Contractor shall ensure achievement of

agreed program and shall also timely arrange additional resources considered necessary at no extra cost to BHEL.

- 46.2** Weekly progress review meetings will be held at site during which actual progress during the week vis-a-vis scheduled program shall be discussed for actions to be taken for achieving targets. Contractor shall also present the program for subsequent week. The contractor shall constantly update / revise his work program to meet the overall requirement. All quality problems shall also be discussed during above review meetings. Necessary preventive and corrective action shall be discussed and decided upon in such review meetings and shall be implemented by the contractor in time bound manner so as to eliminate the cause of non-conformities.
- 46.3** The contractor shall submit daily, weekly and monthly progress reports, manpower reports, materials reports, consumables (gases / electrodes) report and other reports as per Performa considered necessary by the Engineer.
- 46.4** The progress report shall indicate the progress achieved against planned, with reasons indicating delays, if any. This should give the remedial actions which the contractor intends to take to make good the slippage or lost time, so that further works again proceed as per the original program and the slippage do not accumulate and effect the overall program.
- 46.5** The daily manpower reports shall clearly indicate the manpower deployed, category wise specifying also the activities in which they are engaged.

47.0 DRAWINGS AND DOCUMENTS

- 47.1** The detailed drawings, specifications available with BHEL engineers will form part of this tender specification. These documents will be made available to the contractor during execution of work at site. The contractor will also ensure availability of all drawings / documents at work place.
- 47.2** Necessary drawings to carry out the erection work will be furnished to the contractor by BHEL on loan, which shall be returned to BHEL Engineer at site after completion of work. Contractor shall ensure safe storage and quick retrieval of these documents.
- 47.3** The contractor shall maintain a record of all drawings and documents available with him in a register as per format given by BHEL Engineer. Contractor shall ensure use of pertinent drawings / data / documents and removal of obsolete ones from work place and returning to BHEL.
- 47.4** The data furnished in various annexure enclosed with this tender specification are only approximate and for guidance. However, the change in the design and in the quantity may occur as is usual in any such large scale of work.
- 47.5** Should any error or ambiguity be discovered in the specification or information the contractor shall forthwith bring the same to the notice of BHEL before commencement of work. BHEL's interpretation in such cases shall be final and binding on the contractor.
- 47.6** Deviation from design dimensions should not exceed permissible limit. The contractor shall not correct or alter any dimension / details, without specific approval of BHEL.

48.0 TAXES AND DUTIES

- 48.1** **TDS under Income Tax, Sales Tax, VAT etc, if any, shall be deducted at prevailing rates on gross invoice value from the running bills unless Exemption Certificate from appropriate Authority / Authorities is furnished.**

48.2 **Price quoted shall be inclusive of all taxes except service tax.** The service tax, as legally leviable & payable by the contractor under the provisions of applicable law/act, shall be paid by BHEL as per contractor's bill. However, contractor shall have to submit proof of service tax deposited by them immediately after the deposit but not later than the next bill submitted after the due date of deposit. The contractor shall furnish proof of Service Tax registration with Central Excise Division covering the services covered under this contract. Registration should also bear endorsement for the premises from where the billing shall be done by contractor on BHEL for this project. The contractor shall obtain prior approval of BHEL before billing the service tax amount.

With introduction of Cenvat credit rules 2004 which came into force w.e.f. 10.09.2004, excise duty paid on input goods including capital goods used for providing the output service and service tax paid on input service can be taken credit of against the service tax payable on output service. **As such, while offering the rates, the contractors may take into account the benefit of above provisions as the cost of input to contractors will be the cost net of excise duty and service tax and adjust their offer price accordingly to make it more competitive.**

48.3 In VAT applicable States, "Tax Invoice" if required under the relevant State VAT law shall be submitted alongwith other compliances as per concerned VAT Act.

48.4 Contractor shall get his organization registered with concerned sales tax/VAT authorities within 15 days of award of this contract, if applicable. The delay on this account and delay in bringing the material shall be to contractor's account and no extension of time shall be allowed on this account. The sales tax/VAT registration for this contractor shall be forwarded to BHEL within 30 days from the date of LOI. In case the contractor is already registered for sales tax/VAT with Govt. Authorities he must quote his registration no, while submitting their tender.

48.5 Contractor has to make his own arrangement at his cost for completing the formalities, if required, with Sales Tax/VAT Authorities, for bringing their materials, plants, and equipment at site for the execution of the work under this contract.

49.0 EXTRA WORK:

49.1 BHEL may consider for payment of extra works on man hour basis @ Rs.30/- (Rupees thirty only) per man hour only for such of those works which:

- A** Require major revamping or rework and which are totally unusual to normal erection work.
- B** Require rectification / modification for improvement in the design during commissioning,

C Requiring fresh fabrication of components in place of rejected / replaced components.

49.2 The rates indicated as above, shall include over time, if any, consumables, supervision, use of tools and tackles and other site expenses and incidentals.

49.3 The extra works, if any, shall be carried out by a separate gang, which will be identified for certification of man-hours. This gang will not be utilized for any other work during the period that they are engaged in the extra-work. Logbook should be maintained and should be signed jointly by the contractor's representative and BHEL Engineer on day-to-day basis. However, signing of the logbook does not necessarily mean acceptance of the extra works, which would be identified by Engineer, whether work is covered in one of the above categories. Only those works and man-hours that are certified by the BHEL Engineer-in-charge will be considered for payment. The decision of BHEL in this regard shall be final and binding on the contractor.

50.0 PRICE VARIATION

50.1 The finally accepted rates for scope of work as defined in this tender are subjected to price variation provisions as per following formula:

$$P1 = \frac{0.75 \times P0 (F1 - F0)}{F0}$$

P1=Increase/decrease in billing amount (variation) for the particular month of billing.

P0 = Gross billed amount for the month as per contract provisions.

F1 = All India CPI published by Labour bureau, Simla, Govt. of India, for Industrial workers (Base 1982 =100) applicable for the month under consideration i.e. for which bill has been raised.

F0 = All India CPI published by Labour bureau, Simla, Govt. of India, for Industrial workers (Base 1982 =100) applicable for the month of opening of technical bid.

50.2 Price variation as per above formula will be calculated and paid on the total contract value (excluding payments towards extra works and over run, if any) on month-to-month basis from the date of award. BHEL however reserves the right to freeze variation for that much of duration of delays, from time to time, which are entirely attributable to the contractor. **Price variation on last 5% of CV will be based on average index.**

50.3 With the provision of price variation as per above clauses NO CLAIM / COMPENSATION on account of any increase whatsoever, (irrespective of whether escalation are steep/unanticipated or not compensated by the above escalation provisions in full towards minimum wages, consumables, coarse / fine aggregates, steel , wood, electrodes, gases or any other item / reason) will be payable during the entire period of execution including extended period, if any.

51.0 RATE SCHEDULE

51.1 Contractor shall fully understand equipment description and scope of work before quoting. The scope of work and responsibility of the contractor as mentioned under these specifications shall be covered within the quoted rates.

51.2 The tenderer shall quote the rates as per the rate schedule only, in part II price bid (Original). Conditional price bids or price bids with any deviation / clarification etc. are liable to be rejected. No cutting / erasing / over writing shall be done.

51.3 **"THE TENDERER MAY QUOTE FOR UNIT-5 AND UNIT-6 . TENDERERS ARE REQUIRED TO SUBMIT BID IN ONE SEALED ENVELOPE AS PER RATE SCHEDULE.**

52.0 INSTRUCTIONS TO TENDERER

52.1 Offers received without data / information, required under tender clauses-11.1 to 11.11, is liable to be rejected. All these data / information should be duly supported by documentary evidences (Refer note below clause-11)

52.2 No deviations to the tender conditions will normally be accepted.

52.3 The tenderers are advised to actually visit the site and fully acquaint themselves with site conditions, location of stores, transportation routes, quantum of work etc. before quoting their rates for this work. BHEL shall not be responsible in any way for non-familiarization of the site conditions. Once the tenderer has quoted for the work, it is implied that he has ascertained various site conditions and NO CLAIM whatsoever will be entertained by BHEL on any such account.

52.4 The contractor in the event of this work being awarded to him shall establish a site office at site and keep posted an authorized responsible officer who should hold a valid power of attorney for the purpose of the contract. Any order or instruction of the Engineer or his duly authorized representative communicated to the contractor's representative at site office, will be deemed to have been communicated to the contractor at his legal address.

52.5 LIQUIDATED DAMAGES (LD)

For delay in completion of work attributable to the contractor, the LD shall be applicable at the rate of ½% of the contract value per week of delay or part thereof limited to a ceiling of 10% of the contract value as mentioned under clause no.25.5 of the GCC of the tender.

52.6 SECURITY DEPOSIT

The contractor shall submit Security Deposit within 15 days from the date of issue of LOI as per clause no. 16.2 of the General Conditions of Contract (GCC). In case the contractor opts to furnish Bank Guarantee as a part of Security Deposit, the BG shall be issued as per the Performa enclosed as per Annexure-H of the GCC and also that the BG should be issued preferably through any of the Member Banks listed on Page No. 34(a) of the GCC;

For BG through any other Nationalized Bank (Not covered in the list of Member Banks of GCC), the discretion of its acceptance shall lie solely with BHEL.

52.7 OTHERS

52.7.1 In case of any contradiction between General Conditions of Contract (GCC) and Special Conditions of Contract (SCC), the latter shall prevail.

52.7.2 The Price Bids of only those bidders will be opened who will be qualified for the subject job on the basis of pre-qualification evaluation / Techno-commercial bids and acceptance of customer. BHEL reserves the right to reject the bidders with unsatisfactory past performance in the execution of a contract. BHEL's decision in this regard shall be final & binding.

52.7.3 Unsolicited rebate/discount shall not be accepted after bid opening.

SECTION - III B

SPECIAL CONDITIONS OF CONTRACT

CLAUSE NUMBER	DESCRIPTION
53	SCOPE OF WORK
54	SPECIAL PROCESSES
55	FACILITIES TO BE PROVIDED BY BHEL / CONTRACTOR
56	TIME SCHEDULE
57	OVER RUN
58	TERMS OF PAYMENT

SECTION - III B**SPECIAL CONDITIONS OF CONTRACT****53.0 SCOPE OF WORK**

53.1 BHEL has been awarded the work of Design, Manufacture, supply, installation, erection, testing & commissioning of 2*250 MW units (STAGE-III, UNIT 5 & 6) at PARICHA (EXT II) Thermal Power Station (PTPS) of UPRVUNL at Paricha , Dist Jhansi, UP, on lumpsum basis. The main equipment in steam generation package consists of boiler, Electro-static precipitator, fans, milling systems, steam turbines, generators, boilers feed pumps, piping along with the associated auxiliaries supports and controls.

The scope of work under this tender consists of taking delivery of the boiler materials from the project storage yard / stores / sheds to erection site (approximately 1 to 2 Km),

- Their preservation, safe keeping, watch and ward.
- Checking, dressing, chipping and leveling of foundations.
- Pre-assembly, erection, alignment of various equipment, machining and grouting.
- Welding, heat treatment, radiography, UT and other non-destructive tests wherever required
- Hydraulic testing, air leak test, land flow test , clean air flow test and other pre commissioning tests,
- Carrying out of Special processes as per clause 54.0
- Insulation and finish painting including supply of paints etc.,
- Chemical cleaning, and passivation as per the scope given in the tender
- Steam blowing and safety valve floating including erection and dismantling of all temporary piping, valves, pumps, tanks etc. required for above operations and other commissioning activities including post commissioning operations and stabilisation of the unit,
- Unit trial operation, resolving any deficiencies observed and handing over of 2*250 MW Boiler at PTPS, PARICHA (EXT II), JHANSI.

53.2 The work of the 2 Boilers has been combined into 1 Package. However, the Supervisory Manpower and Smaller T& P mobilization is envisaged to be exclusive of each Boiler as per the major divisions of Part –A (Main Boiler) and Part-B (ESP and Rotating Equipments).

The PG wise break up of boiler – and piping is tentatively as indicated under Annexure-I (A) & I(B). Certain PGs have been indicated under more than one billing head . In case of dispute regarding the billing head , the decision of the BHEL Engineer with respect to scope , and keeping the work suitability will be final and binding on the contractor-

Approx. weight to be erected shall be 29733 MT (consisting of 28312 MT of boiler components & 1421 MT of piping systems) as indicated in Annexure-I(A) & I(B). The contractor is required to erect actual tonnage (irrespective of any variation plus or minus) which may be necessary to complete their work and commission above boiler and complete the work in all respects as detailed in tender specifications, for which payments shall be released on finally accepted tonnage rates. The contractor undertakes to erect / commission actual quantities as per advice of BHEL Engineer and accordingly the final contract price shall be worked out on the basis of quantities actually erected at site and payments will also be regulated for the same. **However, in case of over all variation in final executed value (w.r.t the awarded value indicated in the LOI) beyond (minus) 30% i.e in case of reduction in executed value w.r.t awarded value, the contractor will be eligible for compensation as per the following provision;**

“The final executed value shall be raised by 10 % of the executed value subject to the condition that the total value of work executed plus increase as above shall be limited to 70 % of the awarded contract value”

Contractors shall take above into account while quoting the unit rates quoted as per Rate Schedule so as to take care of such variation during execution stage

53.3 The contractor under this contract shall also provide free of cost services of skilled persons for a total period of 115 Man-months exclusively for use by BHEL. This manpower will be required for following services;

Qualified computer operators for office work. (23 man months)

Skilled workers for working in store, office and colony. (46 manmonths)

Unskilled workers for working in store, office and colony. (46 manmonths)

Persons so deployed shall have to work in extended hours whenever required. Workmen provided as per the above provisions shall be fully trained and experienced in the nature of work for which they are deployed.

In case these services are not utilized for any reason whatsoever, fully or partly, recovery at the rate of the prevailing minimum wages at PARICHA for the categories given plus 10% will be made from the final bill of the contractor.

53.4 Deleted.

53.5 The customer M/s. UPRVUNL and / or their Consultant (M/s NTPC) may depute their representative for checking and supervision of important stages of work. The contractor shall be required to provide all facilities for inspection of works, without any cost implications to the BHEL. Any defect in quality of work or deviations from drawings / specifications pointed out during such inspection shall be made good by the contractor in the same way as if pointed out by the BHEL Engineer, without any cost implication to BHEL

53.6 Health, Safety & Environment management (HSE)

53.6.1 Besides provision with regard to SAFETY under Clause 27 of GCC, the contractor will be responsible for Health, Safety & Environment management at site for the construction activities to be carried out by them in accordance with requirements **given under section I(a) of GCC of this document**. The contractor shall continuously take special care to ensure the safety and prevention of human and equipment accidents and maintain good sanitary conditions in and around the site. All the construction work and plant operation must be carried out in the safest possible manner. The Engineer reserves the right to stop any process which, in the Engineer's opinion, is being performed dangerously. In this case the contractor must immediately adhere the requisite safety precautions and any delays attributed to the work stoppage on this account shall not affect the agreed contractual finishing dates.

The contractor shall appoint dedicated full-time Qualified Safety Officers who shall have full authority to ensure that all necessary safety precautions are observed by the Contractor's employees and sub-contractors. These appointees shall have full responsibility for the safety of all personnel within the contractor's area of the works.

Some of the common safety rules to be followed during working are as follows :-

- No body is allowed to enter at construction site without Safety Shoe.
- Never enter work area without Safety helmet & chin strap in place.
- No climbing/working allowed without proper safety belt above 2 m. height.
- Do not exceed the speed limit 25 Kmph within premises.
- No debris obstacles allowed on the roads & passages.
- Do not walk on pipelines or false ceiling.
- Maintain good Housekeeping at work site.
- No photography/ Videography allowed without permission
- All Site supervisors & engineers (including subcontractor's) must be imparted structured training on construction safety before start of the job & record to be maintained.
- Availability of qualified & trained Site Engineer at site during all working hours.
- Site Safety training to be imparted to all workers & plan to be made to cover every worker.
- Tools box talk (5-15 minutes) by supervisor prior to commencement of any job.
- All accident / incidents(Near Miss) to be reported & investigated.(formats & procedure should be finalized)
- Daily Safety Checking by Each Site Engineer along with Safety engineer.

- Weekly co-ordination meeting of all Safety engineers with BHEL safety officer.
- Monthly safety meeting with Site In-charges.
- All Safety equipment must be ISI marked & checked by Safety officer before use.
- Tag system for erection & use of scaffoldings.
- Bamboo/wooden Scaffolding material not allowed.
- LPG cylinders not allowed for gas cutting.
- Good House keeping. Separate waste bins to be used for flammable & non flammable material.
- Safety awareness programs for workers by display of boards, posters, competitions, talks etc.
- Deployment of Safety Supervisors for every 250 workers and part there of at work site.
- Display of List of First Aid trained persons.
- Testing certificates for lifting tools & tackle.
- Provision & maintenance of fire extinguishers at construction site & material stores.
- Display of emergency telephone numbers at various locations.
- For work in confined space use 24 V lamp fitting & use tools with air motors or electric tools with max. 24 V.
- For confined space entry Gas test must be done before & at regular intervals.
- Checking & tag of equipment like grinding machine, welding machine, gas cutting set etc. by supervisors before use.

Further, the contractor is required to provide proper Safety Net System wherever the hazard of fall from height is present as per instructions of BHEL Engineer at site. The safety net shall be fire resistant, duly tested and shall be of ISI mark and the nets shall be located as per site requirement to arrest or to reduce the consequences of a possible fall of persons working at different heights.

53.6.2

Contractor shall make necessary arrangements to ensure that the atmosphere in working area (under the scope of work in this tender) and on roads is free from particulate matter like dust, sand etc. by keeping the top surface wet for ease in breathing. Provision of required tanker with spraying arrangement has to be ensured by contractor within the quoted rates, at no extra cost to BHEL

Contractor shall ensure following:

1. Contractor has to maintain contact with local hospital having ambulance facility , scanning & other ultra modern medical facilities required during emergency.
2. Contractor has to ensure pre employment medical check for all staff & workers.
3. Contractor has to ensure that adequate First Aid facilities with trained nurse are available at work site for emergency purpose. This emergency set-up should include, but not limited to, following

- Male nurse (in shifts)
- Oxygen set up
- Breathing apparatus
- Eye wash facility
- Stretcher
- Trauma blanket
- Medicines.

In addition to above, BHEL has arranged ambulance at work site for emergency purpose, which can be utilized by contractor in case of emergency. Monthly maintenance charges, as decided by BHEL, for this service will have to be paid by the contractor. In case, under unavoidable circumstances, if the ambulance is not available, the contractor will have to arrange for the same as under clause 53.6.2.1.

53.6.3 The contractor shall comply with following towards Social Accountability;

- (a) The contractor shall not employ any employee less than 15 years of age in pursuant to ILO convention. If any child labour were found to have been engaged, the Contractor shall be levied with expenses of bearing his education expenditure which will include stipend to substantiate appropriate education or employ any other member of family enabling to bear the child education expenditure.
- (b) The contractor shall not engage Forced/Bonded Labour and shall abide by abolition of Bonded Labour System (Abolition) Act, 1976.
- (c) The contractor shall maintain Health & safety requirement as stipulated in the Contract and Contract Labour (Regulation & Abolition) Act, 1970.
- (d) The Contractor shall abide by UN convention w.r.t Human Rights and shall be liable for Discrimination/Corporal punishment for failure in meeting with relevant requirements.
- (e) The Contractor shall abide the requirement of Contract Labour (Regulation & Abolition) Act, 1970 for working hours.
- (f) The Contractor shall abide by the Statutory requirement of Minimum Wages Act 1948, payment of Wages Act 1936.
- (g) The Contractor shall arrange potable drinking water to its employees & workers.

53.6.4 Contractor shall make necessary arrangements to ensure following:

- **Contractor for Part 'A' work shall ensure deployment of Qualified level-2 Engineer for NDT services at site.**
- Contractor shall ensure **deployment of Qualified & Experienced Safety Engineer / Officer** at site.
- Contractor shall ensure that all the **T & Ps deployed** by them, including cranes, (Indicative lists of T&Ps and IMTEs to be arranged by the contractor are given as per Annexure-IV & Annexure-V.) **are regularly certified by approved testing agency** & the relevant certificates to this effect are to be given to BHEL for records.

It may be noted that non-compliance to the above three conditions

will result in penal action as may be decided by BHEL.

The Contractor shall be fully responsible for accidents caused due to him or his agents or workmen's negligence or carelessness in regard to the observance of the safety requirements and shall be liable to pay compensation for injuries. **It may be noted that non-compliance to HSE requirements will result in penal action. In case of violations of safety requirements, the Contractor shall be liable for a penalty of Rs. 200/- for the first violation and Rs. 500/- for the subsequent violations. For serious lapses, as decided by BHEL Engineer, fines upto Rs. 5000/- at a time can be imposed.**

The amount towards penalties as above will be deducted from running bills of the Contractor. The amount so collected above will be utilized for supporting the safety activities at site. The decision of BHEL on above will be final and binding on the Contractor.

53.6.5 In order to meet the environmental concerns it is expected that the contractor shall plant, protect and maintain at least 200 trees in the vicinity of the project as per the available space and as per the advise of Engineers. In case no area is earmarked for tree plantation, the contractor may take up any other equivalent environment related project after due approval of the BHEL Engineer.

54.0 SPECIAL PROCESSES**54.1 DRUM LIFTING**

54.1.1 Boiler drum shall be transported and placed near the boiler structure by another agency. Shifting / dragging (Approx. 300 m) and positioning of the drum below the structure and its alignment is to be carried out by the contractor under this contract.

54.1.2 The contractor at site will fabricate drum-lifting structures. The contractor at his cost shall arrange necessary steel and other consumable for the same. The contractor, at his own cost, shall carry out fabrication, erection and complete installation of drum lifting structure. After completion of drum erection and alignment, the contractor shall dismantle the drum lifting arrangements. T&P given to contractor for drum lifting shall be returned to BHEL stores in good condition and to the satisfaction of the Engineer.

54.1.3 BOILER DRUM LIFTING will be carried out by STRAND JACK METHOD. For this the STRAND JACK EQUIPMENT will be provided and operated by BHEL. Under this operation, the following is envisaged in the scope of the Contractor:

1. Fabrication and Installation of Cathead Structure as per drawing supplied.
2. Fabrication and Installation of Fixing Arrangements for Strand Jack and associated equipments
3. Installation of Strand Jacks and associated equipments in position in the Boiler as per instruction. All these equipments will be provided near the Boiler.
4. Providing the services of Unskilled workers for handling/ installation of the Strands and associated equipments .

5. Shifting of all the materials for Drum Lifting (Boiler Drum , U Bolts etc) to the required position from Stores.
6. Making arrangement for lifting of U-bolt by winch method.
7. Coordinating the Lifting of Drum and U-Bolts.
8. Alignment of Drum and fixing of U-Bolt.
9. Dismantling, lowering and handing over of Lifting Equipments near Boiler .

54.1.4 Lashing of wire ropes on the drum with suitable wire ropes has to be done before fixing the lifting arrangement. Contractor has to provide suitable size and quality of wire ropes and clamps for lashing and other purposes. Certificate for the wire ropes and clamps are to be submitted to BHEL Engineer at site for approval.

54.1.5 Drum lifting shall be allowed after completion of main structural work and all the bracing including the bracing for all the columns and horizontal boiler level platforms. Contractor shall carry out the drum lifting as per the instructions of BHEL Engineer.

54.1.6 For drum lifting, certain temporary bracings (to be supplied by BHEL) have to be erected to obtain proper rigidity of structure in place of permanent bracing. The same has to be removed and replaced with permanent bracing. **No payment shall be made for erection and dismantling of temporary bracing.**

54.1.7 HSFG Bolts are to be tightened by calibrated torque wrench as per the instructions of the Engineer. These should be check tightened / re-tightened by torque wrenches before drum lifting as instructed by the Engineer.

54.2 Welding HT, RG and NDT for P91 Piping materials

54.2.1 For Piping Systems , P91 materials is envisaged for PGMA 80-300 , 80-301 and 80-304 . Special care is essential for carrying out the installation of this system and strict quality norms and welding procedure will have to be followed at site . The Contractor is advised to get familiarized with the work procedure . In addition to the general clauses for Welding , RG and NDT given under clause 42 of this tender, the following clauses will be applicable. This welding is to carried out strictly under the supervision of BHEL Engineer and all repairs etc will be carried out as per the laid out procedure .

54.2.2 For carrying out the installation , the following items are being provided by BHEL free of cost:

- a) Induction Heating Machine with Outgoing Cables
- b) Suitable Power BackUp (DG Set)
- c) Spot welding Machine for Fixing of Thermocouples
- d) Calibrated Thermocouples
- e) Calibrated temperature Recorder

- f) Contact Type calibrated temperature Gauge.
- g) UT Testing and Hardness testing
- h) Electrodes and fillers for the P91 welding

The contractor shall be issued the above in line with the General Conditions of Contract Clause 37 .

54.2.3 The following will have to be provided by the Contractor:

- a) Qualified operator for Induction Machine and DG Set
- b) All cables for connecting Induction Machine and DG Set to Main Supply along with Changeover System.
- c) Welder Qualified as per ASME IX and IBR for P91 Materials . Site Welder Qualification tests will be conducted also .
- d) Exclusive Trained Welding Engineer for Supervising P91 Welding and Heat Treatment
- e) Qualified NDE Engineer (Level -II) and welding Supervisor (Level-I)
- f) Required GTAW and SMAW machines
- g) Welding Machine for Demagnetizing along with cable and Residual Field Indicator
- h) Providing Enclosure for Welding area suitable for guarding against cold draught, water and dust at all welding locations .
- i) Providing of Argon purging for the welding operation (including supply of consumables eg Water Soluble Paper / Aluminium Dam arrangement.)
- j) Providing of Heating by Gas Burner as Standby Arrangement.
- k) Providing of Baking ovens and portable ovens
- l) Providing Band Saw/ hacksaw/ Grinder for Cutting with tools.
- m) Providing machining for Edge preparation
- n) Providing of LPI and MPI Facility as specified in the Welding process, including supply of all consumables.
- o) Providing and applying insulation band as specified in the welding procedure.

The above comprise of the major requirements for the process . The Contractor has to provide all services and consumables for completion of the work.

54.3 Welding, HT, RG and NDT for T91 materials

Welding in T91 materials is envisaged in the Reheater of the Boiler. The Contractor has to carry out the work for the same including supply of all consumables for completing the process .The HT , RG and NDT will have to be carried out by the contractor as per welding specifications

54.4 Chemical Cleaning

54.4.1 Chemical Cleaning will carried by a separate agency appointed by BHEL. While the work of installation of tanks , Pumps , Piping and operation of the

system is in the scope of that agency, the Contractor has to extend all assistance (including providing of welding power point) and complete interface requirements for the completion of the work.

55.0 FACILITIES TO BE PROVIDED BY BHEL/ CONTRACTOR

55.1 BHEL shall provide free of charge limited open space, for office & storage shed, as and where made available by M/s UPRVNL. It is the responsibility of the contractor to construct sheds, provide all utilities and dismantle and clear the site after completion of work or as and when required, as a part of his scope of work.

55.2 BHEL shall provide limited open space for labour colony near the plant free of rental charge. The Contractor shall be responsible for providing all necessary facilities like residential accommodation, transport, electricity, water, medical facilities etc. at his own cost as required under various labour laws and statutory rules and regulations framed there under to the personnel employed by him.

Electricity will be provided at one point on chargeable basis. Water will be provided at one point on free of cost basis. Meter for electricity will have to be provided by the Contractor at his own cost.

55.3 Construction power, for construction purposes will be provided free of cost at one point each Boiler near erection site (at a distance upto 500 meters) . The contractor shall submit to the Engineer his electrical power requirements. Further distribution of power shall be done by contractor at his cost. All wiring must comply with local regulations and will be subject to Engineer's inspection and approval before connecting supply

NOTES:

- The contractor will be provided construction power free of charge.
- They will however ensure that there is no wastage. Periodical audits will be held to ensure that these resources are being optimally used. For this the contractor has to provide an energy meter at his end .
- In case any wastage is observed bhel reserves the right to recover any charges / penalty as deemed fit.
- Contractor will have to provide proper insulated cables for power distribution and joints, if any, will be done with proper jointing kits .

55.4 Water for construction purposes shall be provided free of charge at a one point each for Boiler within erection site. Contractor shall arrange further distribution of water for construction purposes.

55.5 Permanent lighting inside the powerhouse will be provided at a later stage. Till such time such arrangements are made, the contractor at his cost should arrange for temporary lighting in and around his work area. **Adequate lighting facilities such as flood lamps, hand lamps and area lighting shall be arranged by the contractor at the site of construction, contractor's material storage area etc. within finally accepted rates.**

55.6 BHEL will not be responsible for any loss or damage to the contractor's equipment as a result of variation in voltage or frequency or interruptions in power supply.

55.7 Provision of distribution lines of both electrical power and water from the

central points to the required place with proper distribution boards observing the safety rules laid down by the electrical authorities of the state shall be done by the contractor, supplying all the materials like cables, distribution board, switch boards, TPN, CBS, ELCBS/ MCCBS/ Copper / Brass clamps, copper conductor, change over switches pipes etc. If any failure is caused in supply of the power and water, it is the responsibility of the contractor to make alternate arrangements at his own cost. The contractor shall adjust his working shifts / hours accordingly and deploy additional manpower if necessary so as to achieve the targets.

55.8 The contractor while drawing construction power supply from Distribution Board should strictly adhere to following points.

- a) All electrical installations should be as per Indian Electricity rules.
- b) All distribution Boards installed by the contractor should be constructed with fireproof materials viz. Steel frames, Bakelite sheets etc.
- c) Connection for single phase should be taken from phase and neutral. Nowhere the connection should be taken with earth as neutral.
- d) Contractors have to make their own arrangement for their equipment/ DB earthing
- e) All electrical connections should be made through connectors, nuts and bolts, switches, plug and sockets. Loose connections or hooking up of wires shall not be permitted.
- f) All electrical equipment / tools and plants should be properly earthed. DBs to be earthed diagonally opposite at two points.
- g) Contractor should use "MCCB" and "ELCB" either on incoming or outgoing connections to the DBs.
- h) Contractor should ensure that all the CBs / TPNs/ Fuses/ MCCB / ELCB cables etc. should be of adequate rating/ capacity.

For permission of supply connections contractor has to submit a test report of their installations with a single line diagram of connected/ proposed loads.

55.9 ELCB will be tested once in a week or as directed by BHEL by actually simulating the earth leakage for all installations and the same shall be recorded in the logbook to be maintained by the contractor.

55.10 In case of power cuts / load shedding no compensation for idle labour or extension of time for completion of work will be given to contractor.

55.11 Adequate lighting facilities such as floodlights, hand lamps and area lighting shall be arranged by the contractor at the site of construction, contractor's material storage area etc as well in labour colony .

55.12 On completion of work or as and when required by BHEL, all the temporary buildings, structures, pipe lines, cables etc shall be dismantled and levelled and debris shall be removed, as per instructions of BHEL, by the contractor at his cost. In the event of his failure to do so, the Engineer will get it done and expanses incurred shall be recovered from the contractor along with prevailing overheads. The decision of BHEL Engineer in this regard shall be final.

55.13 **The construction and dismantling of the foundations required for the passenger lifts is included in the scope of the contractor. Erection of CONSTRUCTION ELEVATOR / PASSENGER LIFT, including the**

construction and dismantling of the foundations required for the passenger lifts, is in the scope of the contractor. However BHEL will assist in commissioning of the same. The periodic upkeep and maintenance of the elevator is to be carried out by the contractor. Required spare parts other than rubber items and consumables shall be given by BHEL free of cost.

55.14 Contractor should install a PC ALONG WITH MODEM to connect with our server (LAN) AT SITE

56.0 TIME SCHEDULE

56.1 The contractor is required **to commence the work within 15 days from the date of issue of letter of intent** unless BHEL decides to fix any other later date.

56.2 Entire work as detailed in tender specification **shall be completed within 23 months** from the scheduled date of start of work as per the programs / milestones indicated by BHEL from time to time. Contractor has to mobilise adequate resources to meet BHEL's commitments to their customer as indicated from time to time. **In case due to reasons not attributable to the contractor, the work gets delayed and additional manpower / resources have to be mobilized so as to expedite the work to meet various milestones, same shall be done within the quoted rates as per Rate Schedule, at no extra cost to BHEL. In the event the contractor fails to respond to these requirements, BHEL shall take appropriate actions to meet customer's commitments in line with the provisions of General Conditions of Contract.**

56.3 The various mile stone dates to be achieved, for BOILER # 5, as per the current status of contract are as below

MILE STONES	MONTH
Start of Erection	15 days from issue of LOI
Drum lifting	4 th Month
Hydro Test	11 th Month
Light up	15 th Month
Chemical Cleaning & restoration	16 th Month
Steam Blowing completion & SVF	18 th Month
Synchronisation & Coal Firing	18 th Month
Trial operation and Handing Over	19 nd Month

The milestones of Boiler # 6 shall follow with a time lag of three months. be same and will be applicable from the Date of Start as informed by BHEL

56.4 The work under the scope of this contract is deemed to be completed in all

respects, only when the contractor has discharged all the responsibilities laid down in the contract. The decision of BHEL on completion date shall be final and binding on the contractor.

57.0 OVER RUN

57.1 In case due to reasons not attributable to the contractor, the work gets delayed and the scheduled completion gets extended, the contractor shall not be entitled for any over run compensation for a period of first 3 (THREE) months after the contractual completion date. In case the scheduled completion time gets extended beyond 3 (THREE) months as stated above, the contractor shall be considered for payment of fixed over run charges,

@ Rs.1,00,000/- per month (Rupees Hundred thousand only)

on receipt of advance notice intending to claim over run and on fulfillment of following conditions:-

(a) The reasons for delay in completion of work are not attributable to contractor but however subject to the provisions of clause – 31.

(b) Contractor achieves the targets fixed during the over run period.

57.2 Once the claim of over run charges is admitted no other compensation whatsoever (like for delays in receipt of materials, availability of fronts etc.) will be entertained.

57.3 The contractor shall maintain sufficient workforce (both skilled and unskilled) and other resources required for completion of the job expeditiously for the entire contractual period including total extended period.

58.0 TERMS OF PAYMENT

58.1 Advance Payment

58.1.1 Interest bearing advance limited to a maximum of 5 (five) % of the contract price shall be payable at site in stages in the following manner. Rate of interest shall be two (2) % above the PLR of State Bank of India applicable at the time of drawing the.

58.1.2 Two and a half (2.5) % maximum to be released on submission of following.

- i. Unqualified acceptance to LOI.
- ii. Requisite security deposit as per tender document.
- iii. Bank guarantee (BG) equivalent to 1.2 times the advance amount valid for an initial period of one year.
- iv. Detailed bar chart and its approval by BHEL.
- v. Opening of site office & on certification of the same by BHEL site.

58.1.3 Two and a half (2.5) % maximum to be released on submission of following.

- i. Bank guarantee (BG) equivalent to 1.2 times the advance amount valid for an initial period of one year.
- ii. Deployment of tools & plants as agreed to be deployed.

58.1.4 Recovery of advance shall be made at the rate of 10 % from each bill starting from the 1st applicable RA bill (gross), till the entire amount is adjusted.

58.1.5 Each bank guarantee shall be kept valid till the entire advance amount paid against it is recovered

58.1.6 Each BG against advance shall be returned after full adjustment of the entire advance paid against it.

58.2 Progressive Payment.

58.2.1 The 'Engineer' will certify regarding the actual work executed in the measurement books and bills, which shall be accepted by the contractor in measurement book.

58.2.2 Contractor shall submit bills for the work completed under the specification, once in a month detailing work done during the month. The format for billing shall be approved by BHEL before raising invoices.

58.2.3 Subject to any deduction that BHEL may be authorised to make under the contract, the contractor on the certificate of the Engineer at site be entitled for payment as explained hereunder.

I.AA **0.25 %** of awarded value on start of pre assembly work by deploying one number of 75 T crane, one 18/20 T OR one number 8/10 T Hydra in working condition at site and one no trailer **of Each Boiler** .

I.AB **An amount limited to 1.0 % shall be payable in one or more installments**, solely at the discretion of Construction Manager/ BHEL at different stages of the contract execution to facilitate resource augmentation or to meet any exigency of work. In case of its non utilization 'OR' its part utilization, the entire/balance payment against this category shall be released along with commissioning of respective boiler (Coal Firing Operation)

**I.BA PROGRESSIVE PAYMENT on pro-rata basis
(80% of unit rates)**

(Applicable for all items except Insulation and Sl. No. 3 of rate schedule work)

1 15% of the contract rate on pro-rata basis on completion of pre assembly wherever required and 15% of the contract rate on pro-rata basis on placement in position and rough alignment.

OR

30% of the contract rate on pro-rata basis on placement in position and rough alignment for the items where pre-assembly is not involved.

2 50% of the contract rate on pro-rata basis on completion of final alignment / fastening / welding / grouting along with proper supports including radiography / NDT / stress relieving wherever involved.

**I.BB PROGRESSIVE PAYMENT on pro-rata basis
(80% of unit rates)**

(For INSULATION AND REFRACTORY work)

1 65% of the contract unit rate on fabrication/fixing of retainers, lagging & stitching of mattresses and welding of retainers, fixing of casing supports, fabrication, beading, sealing, bitumen painting, installation and screw fixing of cladding & completion of all jobs as per specifications. The above work includes transportation of required material on location and its proper protection

2 15% of the contract unit rate payable on system completion and area cleaning.

I.C PROGRESSIVE PAYMENT on pro-rata basis

(Sl. No. 3 of the Rate Schedule)

80 % of the item rate will be paid on acceptance of the joint after RG and NDT

NOTE: BHEL site incharge, at his discretion can split / re-group above payment schedule, to facilitate site operations.

II MILESTONE PAYMENTS (10 % of awarded CV)

- 1** 0.25 % on start of erection work of Each Main Boiler column after checking their trueness and on certification by BHEL Engineer
- 2** 0.25 % of CV on successful completion of hydro test of each boiler.
- 3** 0.25 % of CV on successful completion of air and gas tightness test of furnace / APH and ducts required for Boiler Light Up of Each Boiler
- 4** 0.5 % of CV on successful completion of boiler light up and EDTA Cleaning of Each Boiler
- 5** 0.5% of CV value on successful completion of steam blowing and SVF of Each Boiler
- 6** 0.5 % of CV on successful achieving full load of Each Boiler
- 7** 0.25 % on start of erection work of ESP column, after checking their trueness and on certification by BHEL Engineer of Each Boiler
- 8** 2 X 0.25 % of CV on successful completion of mechanical work of each pass of ESP of Each Boiler
- 9** 2 X 0.125 % of CV on successful completion of electrical work of each pass of ESP of Each Boiler
- 10** 0.25 % of CV on successful completion of air tightness test of all Ducts of Each Boiler
- 11** 6 X 0.05 % of CV on successful completion of trial run of ID, FD & PA fans of Each Boiler
- 12** 6 X 0.05 % of CV on successful completion of all the milling system and its clean air flow test of Each Boiler
- 13** 0.25 % of contract value on coal firing.
- 14** 0.15 % of CV on completion and commissioning of hoists and handling equipment for FD/ID/PA/MILLS of Each Boiler
- 15** 0.5 % of CV on successful completion of-Trial Operation of Each Boiler

NOTE: If the commissioning activities could not be carried out due to no fault of contractor, BHEL Site incharge, at his discretion, after recording reasons for exercising such option, can split and release payment upto 50% of milestone payment on completion of work, to the extent possible, required for carrying out that particular milestone / commissioning activity. Milestone Payments can be further split and released after ensuring commensurate completion and recording reasons.

III Providing and applying PAINTING-Payment on Prorata basis –3.5%

1.25 % of awarded CV for Each Boiler work including piping system

0.50 % of awarded CV for Each ESP and Rotating Equipments System

IV 2x1.25% of contract value will be payable on handing over of the boiler to BHEL's Customer or 3 months after contractor has discharged his responsibilities as stipulated in this contract, whichever is earlier, if delay in handing over is not attributable to contractor. The boiler shall be considered as handed over on completion of trial operation.

V **The balance 2.5% CV shall be payable on completion of all pending work, rework wherever required, area cleaning, reconciliation of materials, fulfillment of contractual obligations, and on submission and passing of Final Bill.**

NOTE: Payments at IV & V shall be released after adjustment of the CV based on actual work carried out.

Annexure – 1 (A)**WEIGHT SCHEDULE
(BOILER PART A & PART B)****AA: SUMMARY OF WEIGHTS**

Approximate weight to be erected for each boiler:

- a) Boiler Part – A Package: 7644 MT
 b) Boiler Part – B Package: 6512 MT

BB: Product Group (PG) Wise Weight Schedule For BOILER

Sl.No.	PG	DESCRIPTION	TOTAL (MT)	PART – A (MT)	PART –B (MT)
1	4	Boiler drum	151	151	
2	5	Water wall headers and lower drums	64	64	
3	6	Water wall panels	292	292	
4	7	Circulation system components	280	280	
5	8	Buckstays & framing	247	247	
6	9	Seal Boxes	8	8	
7	10	Super heater headers	88	88	
8	11	Super heater coils and walls	588	588	
9	12	Super heater components	164	164	
10	15	Reheater Header	22	22	
11	16	Reheater and coils and walls	137	137	
12	17	Reheater components	28	28	
13	18	Roof skin casing	13	13	
14	19	Economiser headers, coils & supports	316	316	
15	20	Soot blowers	38	38	
16	21	Soot blowers & soot blowing system	13	13	
17	22	HP & LP bypass system	4	4	
18	24	Boiler integral trim piping	168	168	
19	28	Manholes & furnace openings	6	6	
20	30	Fixing components for main boiler lining & Insul.	84	84	
21	31	Boiler skin casing	10	10	
22	32	Fixing components for boiler aux. insulation	192	64	128
23	33	Lining and insulation material	565	415	150
24	35	Boiler supporting structure	1821	1821	
25	36	Boiler galleries & stairways	770	770	

Sl.No.	PG	DESCRIPTION	TOTAL (MT)	PART – A (MT)	PART –B (MT)
26	37	Boiler outer casing	37	37	
27	38	Inter connecting walk ways	130	45	85
28	39	External structure	654		654
29	41	Oil system components	3	3	
30	42	Oil piping, pump & filter (excluding C&I items)	44	44	
31	43	Scanner fan and ppg	40	18	22
32	45	Wind box	66	66	
33	47	Pulverised fuel piping	272	272	
34	48	Ducts Dampers & expansion joints	1175	585	590
35	50	SCAPH	5	5	
36	52	Air preheater	594	594	
37	55	Axial fans	100		100
38	56	Radial fans	132		132
39	57	Gates	212		212
40	62	Bowl tube mills	550		550
41	65	Coal feeders	39		39
42	67	Coal valves	49		49
43	78	Electrostatic precipitator	3758		3758
44	80	Piping	133	133	
45	81	Tanks and vessels	33	33	
46	89	Galleries & stairs for ESP	43		43
47	99	Lifting tackles & other handling equipment	18	18	
	TOTAL		14156	7644	6512

NOTE: Above details are only to give a general idea to the contractor to quote the rates as per rate schedule. Besides PGs indicated above, there is likelihood of addition of new PGs for release of some items integral to Boiler. Contractor is required to carryout such PGs also within their applicable tonnage rate. The decision of BHEL regarding inclusion of new / additional PG in Part-A or Part-B will be final & binding on the contractor. Certain items like insulation material, cladding, valves etc. may / may not be supplied by other suppliers / BHEL units like PEM etc. as per PGMA applicable for Boiler system. Such items are also to be erected as per tonnage rates & as directed by BHEL. No extra claim shall be entertained on this account.

Annexure – 1 (B)**WEIGHT SCHEDULE
(PIPING SYSTEMS)****AA: SUMMARY OF WEIGHTS**

Approximate tonnage for Each boiler : 604 MT

Approximate tonnage common to both boilers (Unit-5 Scope) : 33 MT

**BB: Product Group (PG) Wise Weight Schedule For piping common to both boilers
Unit-5 Scope**

SL NO	PGMA	DESCRIPTION	WT/kgs	IBR
1	80-341	AUX STEAM HEADER INTERCONN BETWEEN UNITS	33,000	IBR
		TOTAL	33,000	

**CC: Product Group (PG) Wise Weight Schedule For each
Boiler**

SL NO	PG MA	Description	BLR SCOPE	TYPE
1	80-301	MS FROM BOILER STOP VALVE TO ESV	81,000	P91+IBR
2	80-303	MS HEADER TO AUX PRDS	8,700	IBR
3	80-304	MS HEADER TO HPBP VALVE	6,300	P91+IBR
4	80-307	HP AND LP BYPASS WARM UP	1,100	IBR
5	80-310	HRH FROM REHEATER TO INTERCEPTOR VALVE	125,500	IBR
6	80-311	HRH FROM INTERCEPTOR VALVE TO TURBINE	11,700	IBR
8	80-320	CRH FROM TURBINE TO REHEATER	60,200	IBR
9	80-321	HPBP VALVE TO CRH PIPING	5,200	IBR
11	80-324	CRH HEADER TO AUX.PRDS	1,000	IBR
18	80-340	AUX STEAM HEADER	1,200	IBR
19	80-345	AUX STEAM TO DEAERATING HEATER	1,400	IBR
20	80-346	AUX STEAM TO SJAE - SG SCOPE	1,000	IBR
21	80-348	AUX STEAM TO GLAND SEALS - SG SCOPE	500	IBR
22	80-369	HP DRAIN FLASH TANK VENT TO SYSTEM	1,600	IBR
23	80-373	AUX STEAM HEADER SV EXHAUST	1,200	IBR
39	80-421	BOILER FEED PUMP RECIRCULATION	7,600	IBR
40	80-423	BOILER FEED PUMP TO HPH INCLUDING BYPASS	43,100	IBR
41	80-424	BFD BETWEEN HTRS AND GROUP PROTECTION	17,500	IBR
42	80-425	BFD FROM FINAL HPH TO SG TP	63,500	IBR
43	80-430	SPRAY WATER TO HPBP	1,300	IBR
44	80-431	SPRAY WATER TO AUX PRDS	2,300	IBR
45	80-432	SPRAY WATER TO BOILER DESH UPTO SG TP	3,100	IBR
53	80-452	HP PIPING DRAINS - SG SCOPE	3,000	IBR

SL NO	PG MA	Description	BLR SCOPE	TYPE
54	80-453	LP PIPING DRAINS - SG SCOPE	2,000	
57	80-600	HIGH PRESSURE DOSING PIPING	600	IBR
61	80-921	H AND S FOR LIGHT UP STEAM LINE	24,000	
62	80-922	H AND S FOR LIGHT UP - NON STEAM LINES	13,500	
63	80-923	H AND S FOR STEAM BLOWING	105,000	
64	80-924	H AND S FOR SYNCHRONISATION-STEAM LINES	3750	
65	80-925	H AND S FOR SYNCHRONISATION-NON STEAM LI	6000	
67	80-992	IMPORTED ELECTRODES	187.5	
68	81-415	TEST THERMOWELLS	300	
69	81-416	PERFORMANCE GUARANTEE TEST MATERIALS	450	
			604,788	

PGMAs NOT PAYABLE

65	80992	IMPORTED ELECTRODES	187.5
TOTAL			187.5

NOTES:

- a) All the above systems of piping include the erection of pipes, bends, valves, fittings, impulse piping and including root valves, sampling lines, drains, hangers and supports & other accessories so as to make the systems complete in all respect.
- b) Above system of piping can be regrouped / renamed or any addition / deletion in the system can be made in order to make system complete as per requirement. No extra cost shall be entertained on this account.
- c) The piping systems mentioned above are only indicative and does not cover all the piping systems to be erected / commissioned. Contractors are however required to erect commission all piping systems shown in drawings & other documents which may be necessary for erection, completion & overall commissioning of Cogeneration plant at the accepted unit rates.
- d) The tonnages indicated are tentative only and may vary during execution of work. The contractor is required to erect / commission all piping systems shown in drawings and documents which may be necessary for overall commissioning of BOILER. Payment shall be released on the basis of actual work executed as per final accepted rates.
- e) Bidders may note above while quoting / accepting tonnage rates for subject work.

Annexure-II**LIST OF T&Ps BEING PROVIDED BY BHEL FOR USE OF CONTRACTOR FREE OF HIRE CHARGES ON SHARING BASIS**

SI.No.	EQUIPMENT	CAPACITY	Quantity	
			UNIT-5	UNIT-6
1	Crawler crane	200 / 250 MT	1 nos to be shared	
2	Crawler crane	75 / 100 MT	1 nos to be shared	
3	EOT crane in TG Hall	120 / 20 MT	Sharing Basis	
4	Motorized Hydraulic test pump	450 kg / sq.cm	1 nos to be shared	
5	Construction Elevator		1 nos	1 nos
6	Huck Bolting machine		2 nos	2 nos
7	Drum Lifting Arrangement .***	By BHEL agency	1 set	
8	Chemical Cleaning Arrangement ###	By BHEL agency	1 set	
9	Equipments for P91 piping system Installation \$\$\$	By BHEL	1 set	

NOTE :

- Any other special T&P if supplied by the manufacturer will also be provided to the contractor free of hire charges as and when made available. Special tools and tackles are to be used only for the purpose for which these are meant and to be returned in good condition.
- The operation and maintenance of 200T/250 crane shall be carried out by BHEL, however required maintenance crew and fuel for operation of crane shall be provided by the contractor at his cost. the lubricant will be issued free by BHEL . **200T crane is for erection of Upper tier of boiler columns , ceiling girders and Silencers.** However, BHEL entirely at its discretion can allow use of this crane in other areas / works also on the same terms and conditions.
- The 75 / 100 MT crane will be provided in case of non-availability of the 200/250 MT crane , or as decided by the Engineer .**
- Other terms and conditions regarding above items shall be as per Clause No.37 (T&P/IMTEs).
- *** Please refer to Clause No 54.1
- ### Please refer to Clause No 54.4

7 . \$\$\$ Please refer to Clause No 54.2

Annexure-III**LIST OF IMTEs BEING PROVIDED BY BHEL FOR USE OF CONTRACTOR FREE OF HIRE CHARGES ON SHARING BASIS**

SL NO	EQUIPMENT	QUANTITY	
		UNIT-5	UNIT-6
1	ANEOMETER 0-15 M / SEC	1 NO	1 NO
2	PITOT TUBE	1 NO	1 NO
3	mV / mA source (0-200 mV, mA)	1 NO	1 NO
4	5 kv Motorised megger	1 NO	1 NO

NOTE :

Any other special IMTEs if supplied by the manufacturer will also be provided to the contractor free of hire charges as and when made available. Special IMTEs are to be used only for the purpose for which these are meant and to be returned in good condition.

Other terms and conditions regarding above items shall be as per Clause No.37 (T&P/IMTEs).

ANNEXURE-IV

**INDICATIVE LIST OF MAJOR T&P TO BE PROVIDED BY CONTRACTOR FOR
EXECUTION OF TENDERED WORKS FOR MOST DURATION OF THE
CONTRACT**

SL NO	EQUIPMENT	QUANTITY	
		UNIT-5	UNIT-6
1	CRAWLER CRANE 75 T +++	1 NO	1 NO
2	MOBILE CRANE 18 / 20 T	1 NO	1 NO
3	HYDRA CRANE 8 / 10 T	2 NO	2 NO
4	TRAILER WITH PULLING UNIT (20/25 T)	1 NO	1 NO
5	TRAILER WITH PULLING UNIT (10/15 T)	2 NO	2 NO
6	LOW BED TRAILER (50 MT) @@@	APR	
7	AIR COMPRESSOR 250 CFM	1 NO	1 NO
8	ELECTRIC WINCH 2/3/5 T	15 NO	15 NO
9	WELDING SETS WITH ACCESSORIES	50 NO	50 NO
10	POWER DRILL MACHINE FOR PLATFORM GRILL & ROOF	3 NO	3 NO

NOTE:

1. The above list specifies only major T&P (may not be complete) to be deployed by the contractor and is based on minimum requirement. All additional / other tools and plants including suitable capacity D shackles, slings, rails sleepers hydraulic / mechanical jacks etc which are required for satisfactory & timely completion of work shall also be deployed by the contractor within finally accepted rate / price.
2. Other terms and conditions regarding above items shall be as per clause no 37 (Tools & Plants/IMTE) .
3. @@@ AS PER REQUIREMENT
4. +++ **ONE 75 MT CRANE CAN BE RELEASED AFTER HT OF UNIT-6 BASED ON SITE PROGRESS**
5. Mobilisation will be considered on availability of at least 1 no the items at sl no 1 , 2 OR 3 , 4 OR 5 at site
6. Only qualified and experienced crane operators will be deployed by the contractor . The acceptance and approval of the Engineer will be final in this matter

ANNEXURE-V

**INDICATIVE LIST OF MAJOR IMTEs TO BE PROVIDED BY CONTRACTOR FOR
EXECUTION OF TENDERED WORKS FOR MOST DURATION OF THE
CONTRACT**

SL NO	EQUIPMENT	QUANTITY	
1	HAND OPERATED MEGGER 500 / 1000 V	As per requirement	
2	TONG TESTER 10,20 OR 50 Amp + / - 3 % ACCURACY	As per requirement	
3	DIGITAL MULTIMETER	As per requirement	
4	ANALOGUE MULTIMETER	As per requirement	
5	6 / 12 Point temperature recorder (0 to 1000 degree C) for stress relieving including thermocouples, cables etc	As per requirement	
6	U TUBE MANOMETER 0-2000 MM WATER COLOUM	As per requirement	
7	INCLINED MANOMETER 0-50 MM WATER COLOUM	As per requirement	
8	BOLT TENSION CALIBRATOR	As per requirement	

NOTE:

1. The above list specifies only major IMTEs (may not be complete) to be deployed by the contractor and is based on minimum requirement. All additional / other IMTEs which are required for satisfactory & timely completion of work shall also be deployed by the contractor within finally accepted rate / price.
2. Other terms and conditions regarding above items shall be as per clause no 37 (Tools & Plants/IMTE)

ANNEXURE-VI

CERTIFICATE OF DECLARATION FOR CONFIRMING THE KNOWLEDGE OF SITE CONDITIONS

We,.....
..... Hereby declare and confirm that we have visited the project site under the subject namely,and acquired full knowledge and information about the **site conditions, wage structure, Industrial climate and total work involved**. We further confirm that the above information is true and correct and we will not raise any claim of any nature due to lack of knowledge of site condition.

Tenderers Name and Address

Place: (Signature of the Tenderer with stamp)

Date:

ANNEXURE-VII

**NON DISCLOSURE AGREEMENT
Memorandum of Understanding**

BHEL PSNR is committed to Information Security Management System as per Information Security Policy.

M/s....., providing.....service to BHEL PSNR, Noida hereby undertake to comply with the following in line with Information Security Policy of BHEL PSNR;

- To maintain confidentiality of documents & information which shall be used during the execution of the Contract.
- The documents & information shall not be revealed to or shared with third party which shall not be in the business interest of BHEL PSNR.

()
M/s. BHEL, PSNR

()
M/s.....

**FORMAT OF UNDERTAKING
(To be submitted in the bidder's letter head)**

REF:

Dt.

**Bharat Heavy Electricals Limited
Power Sector – Northren Region,
Plot No. 25 , Sector - 16A ,
Distt. Gautam Budh Nagar,
NOIDA – 201 301.INDIA**

**Sub.: Erection, testing, commissioning and trial operation of Boilers of 2 X 250
MW units (units 5 & 6) at Paricha (Ext II) Thermal Power Station (PTPS) of
UPRVUNL, Dist Jhansi, UP.**

TENDER NO. BHEL:NR(SCT): PARICHA (EXT II):BLR 5&6:470

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited [Paricha site](#) before submission of our offer and noted the job content & site conditions etc.

We also confirm that we have not changed / modified the tender documents as appeared in the website and in case of observance at any stage, it shall be treated as null and void. We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT and we hereby convey our unqualified acceptance to all terms and conditions as stipulated in the tender and NIT. In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer strictly in accordance with tender instructions.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized representative of the bidder)

ANNEXURE-VIII(A)

RATE SCHEDULE

SI. No	DESCRIPTION OF WORK	Unit Rate in Rupees (In figures and words)	TOTAL VALUE in Rupees (In figures and words)
I	BOILER PART-A		
1	Rate in Rupees per MT for handling, erection, testing, commissioning, trial operation and handing over of 2 x 250 MW BOILER (for BOILER PART 'A' WORKS) including auxiliaries etc as per tender specifications (Approx. tonnage involved is 15288 MT as per Annexure- I A)		
2	Rate in Rupees per MT for handling, erection, testing, commissioning, trial operation and handing over of Piping systems for 2 x 250 MW BOILER as per tender specifications		
a	All Piping systems Except P91 (Approx. tonnage involved is 1041 MT as per Annexure- I B)		
b	P91 Piping (Approx. tonnage involved is 200 MT as per Annexure- I B)		
c	Insulation for Piping (Approx. tonnage involved is 360 MT)		
3.	Differential Rate in Rupees per Joint for Welding , HT ,RG and NDT for T91 Joints in Boiler (extra rate over and above the rate covered at sl no 1 of Rate Schedule) (Approx Joints for BOTH BOILER is 1000 nos)		
	TOTAL VALUE BOILER PART-'A'		
II	BOILER PART-'B'		
4	Rate in Rupees per MT for handling, erection, testing, commissioning, trial operation and handing over of 2 x 250 MW BOILER (for BOILER PART 'B' WORKS) including auxiliaries etc as per tender specifications (Approx. tonnage involved is 13024 MT as per Annexure- I A)		
	TOTAL VALUE BOILER PART-'B'		
	TOTAL CONTRACT VALUE (FOR BOILER PART-'A' & BOILER PART'B')		

_ (Seal and Signature of Tenderer)

NOTES:

1. Only 'Unit Rate' shall be considered for evaluation and award. Evaluation of the bids shall be done based on total value for Part-A and Part-B.
2. The rate shall be entered in figures as well as in words. In case of difference in rates between words and figures, the lesser of the two will be treated as valid rate.
3. In case of omission in quoting any rate, the evaluation will be done considering the highest quoted rate obtained against that item. But the work, if awarded, will be on the lowest quoted rate obtained against that item.
4. The quantities indicated against each item above are tentative and these are liable to vary depending upon the site requirement. The contractor has to handle / erect / commission all items indicated by BHEL Engineer for achieving unit wise milestone and completion of work.
5. The contractor while quoting the price / rates as above, categorically confirms having understood the fullest implications of the price Variation provisions contained in clause 50.0 of this tender. Accordingly, taking into considerations all aspects thereof, quoted the above rates. Further the contractor confirms that he will not come up with any other claim / compensation on account of any increase whatsoever during entire period of execution including extended period, if any.

(Seal and Signature of Tenderer)