



CORRIGENDUM- 01

<b>PROJECTs</b>	<b>:</b>	<b>5X800 MW YADADRI TPS</b>
<b>PACKAGE</b>	<b>:</b>	<b>WEIGH BRIDGE</b>
<b>GeM Bid NO</b>	<b>:</b>	<b>GEM/2023/B/3392769 Dated 27.04.2023</b>
<b>SUBJECT</b>	<b>:</b>	<b>PRE-BID CLARIFICATION + DUE DATE EXTENSION</b>

Type of Corrigendum			
Technical Corrigendum -	<input checked="" type="checkbox"/>	Commercial Corrigendum -	<input checked="" type="checkbox"/>

1. Refer below BHEL replies to pre-bid query:

<b>Bidders Query</b>	<b>BHEL Reply</b>
As per technical specification platform size is - 20-meter X 04 meter. Details as per drawing no.(PE-DG-417-885-C003) - column width C/c-2200 mm	Specification requirement is clear. Further please note that this is load cell centre line. Supplier to place beam at outer edge of platform for straighten the structure.

2. Due date & time of bid submission has been extended upto 15.05.2023 @11:00 AM.

All the other terms and conditions of the tender enquiry remain unchanged. All the bidders are requested to quote accordingly.

Yours faithfully,

For and on behalf of BHEL

SUMEET  
SAHAY

Digitally signed by SUMEET SAHAY  
DN: cn=, o=BHARAT HEAVY ELECTRICALS  
LIMITED, ou=POWER SECTOR/PROJECT  
ENGINEERING MANAGEMENT (PS-PEM),  
2.5.4.20=1535c8ba364d0a3d0ed3c773682  
5f62d2d2710630c6b42af28b19d58c19,  
postalCode=201301, st=UTTAR PRADESH,  
serialNumber=7CB2F832DF17391F51  
438EE10F6CD2BDE3713B47406CD3727A  
BD274E, cn=SUMEET SAHAY  
Date: 2023.08.08 16:41:05 +05'30'

**Sumeet Sahay**  
**Manager/BOP**