

Bid Document

Bid Details	
Bid End Date/Time	24-11-2021 15:00:00
Bid Opening Date/Time	24-11-2021 15:30:00
Bid Life Cycle (From Publish Date)	90 (Days)
Bid Offer Validity (From End Date)	60 (Days)
Ministry/State Name	Ministry Of Heavy Industries And Public Enterprises
Department Name	Department Of Heavy Industry
Organisation Name	Bharat Heavy Electricals Limited (bhel)
Office Name	10170006-ivp Goindwal
Total Quantity	7
Item Category	High Pressure Fire Fighting Hose with Delivery Couplings as per IS 14933 (Q2) ()
MSE Exemption for Years of Experience and Turnover	No
Startup Exemption for Years of Experience and Turnover	No
Document required from seller	Certificate (Requested in ATC), OEM Authorization Certificate *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled	No
Time allowed for Technical Clarifications during technical evaluation	2 Days
Estimated Bid Value	52430
Evaluation Method	Total value wise evaluation

EMD Detail

Required	No
----------	----

ePBG Detail

Required	No
----------	----

Splitting

Bid splitting not applied.

MSE Purchase Preference

MSE Purchase Preference	No
-------------------------	----

Details of the Competent Authority for MSE

Name of Competent Authority	Rakesh Kumar
Designation of Competent Authority	Sr. DGM
Office / Department / Division of Competent Authority	Material management
CA Approval Number	NA
Competent Authority Approval Date	2021-11-11 00:00:00
Brief Description of the Approval Granted by Competent Authority	Fire fighting hose pipe is not reserved for MSE. Counter-offer clause is not proposed (including MSE preference).

Competent Authority Approval for not opting Micro and Small Enterprises Preference : [View Document](#)

MII Purchase Preference

MII Purchase Preference	No
-------------------------	----

1. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

High Pressure Fire Fighting Hose With Delivery Couplings As Per IS 14933 (7 pieces)

Brand Type	Registered Brand
------------	------------------

Technical Specifications

[* As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
GENERIC	Type of Hose	Type A (Normal fire hoses, rubber lined or rubberized fabric lined, woven jacketed with or without elastomeric coating/covering for application under normal fire conditions.)
CONSTRUCTIONAL	Nominal Diameter (As per clause 3-2 and 3-3 of IS 14933:2001 Latest Amendment)	63.0
	Hose Length (As per clause 4 of IS 14933:2001 Latest Amendment)	30.0

Specification	Specification Name	Bid Requirement (Allowed Values)
	Mass/Metres (max) (in grams) (As per clause 5 of IS 14933:2001 Latest Amendment)	550 gram for 63 mm Diameter
	Test Requirements	Hydrostatic Proof Pressure Test as per Clause 10 of IS 14933:2001 Latest Amendment, Hydrostatic Burst Pressure Test as per Clause 11 of IS 14933:2001 Latest Amendment, Kink Test as per Clause 12 of IS 14933:2001 Latest Amendment, Adhesion Test as per Clause 13 of IS 14933:2001 Latest Amendment, Abrasion Resistance as per Clause 14 of IS 14933:2001 Latest Amendment, Accelerated Ageing Test as per Clause 15 of IS 14933:2001 Latest Amendment, Change in length of Hose As per clause 16.1 and 16.2 of IS 14933-2001 Latest Amendment
	Additional Test Requirements for Type-B Hose (Hint: Select NA for Type-A Hose)	NA
FIRE HOSE DELIVERY COUPLINGS, BRANCH PIPE, NOZZLES AND NOZZLE SPANNER	Size of Delivery Coupling (as per clause 5-3 of IS 903:1993 Latest Amendment)	63.0
	Material of Delivery Coupling	Stainless steel as per Clause 5.2.6 of IS 903:1993 Latest Amendment
	Binding with Delivery Coupling (Hint: Select NA if not applicable)	Binding of Delivery Coupling with hose after riveting and providing good quality canvas paddings (10 cm width) with 16 SWG copper wire.
	Additional Accessories included in the scope of supply with Delivery Coupling (Hint: Select NA if not applicable)	NA
	Material of Branch Pipe (as per clause 6-1 of IS 903:1993 Latest Amendment) (Hint: Select NA if Branch Pipe is not part of supply)	NA
	Shape and Dimension of the Branch Pipe (Hint: Select NA if Branch Pipe is not part of supply)	NA
	Hydraulic Test Requirement of Branch Pipe (Hint: Select NA if Branch Pipe is not part of supply)	NA
	Material of Nozzles (as per clause 7-1 of IS 903:1993 Latest Amendment) (Hint: Select NA if Nozzle is not part of supply)	NA

Specification	Specification Name	Bid Requirement (Allowed Values)
	Size of nozzles (as per clause 7-2 of IS 903:1993 Latest Amendment) (Hint: Select NA if Nozzle is not part of supply)	NA
	Hydraulic Test Requirements of Nozzles (Hint: Select NA if Nozzle is not part of supply)	NA
	Material of Nozzle Spanner (Hint: Select NA if Nozzle Spanner is not part of supply)	NA
	Shape and dimension of Nozzle spanner (Hint: Select NA if Nozzle Spanner is not part of supply)	NA
	Anti-corrosive treatment of Nozzle spanner (Hint: Select NA if Nozzle Spanner is not part of supply)	NA
	Deflection Test Requirement for Nozzle spanner (Hint: Select NA if Nozzle Spanner is not part of supply)	NA

Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Samir Shandilya	143422,BHEL, Industrial Valves Plant, Plot No. 433, Industrial Complex Phase-I, Goindwal Sahib	7	45

Buyer Added Bid Specific Terms and Conditions

1. Generic

Upload Manufacturer authorization: Wherever Authorised Distributors are submitting the bid, Manufacturers Authorisation Form (MAF)/Certificate with OEM details such as name, designation, address, e-mail Id and Phone No. required to be furnished along with the bid.

2. Certificates

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

3. **Scope of Supply**

Scope of supply (Bid price to include all cost components) : Only supply of Goods

4. **Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

The special requirements of bid are given below

CERTIFICATION :-

- 1) BIS CM/L Number :
- 2) Availability of Test Report from Central Govt/NABL/ILAC accredited lab to prove conformity to specification- Availability of Test Report from NABL accredited Laboratory.
- 3) Name and Address of the Laboratory :
- 4) Agreed to submit the test report to buyer/consignee on demand.

Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization. Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specification and / or terms and conditions governing the bid. Any clause incorporated by the Buyer such as demanding Tender Sample, incorporating any clause against the MSME policy and Preference to make in India Policy, mandating any Brand names or Foreign Certification, changing the default time period for Acceptance of material or payment timeline governed by OM of Department of Expenditure shall be null and void and would not be considered part of bid. Further any reference of conditions published on any external site or reference to external documents / clauses shall also be null and void. If any seller has any objection / grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---Thank You---