



Bid Number/बोली क्रमांक (बिड संख्या)[:] GEM/2024/B/4659545 Dated/दिनांक : 19-02-2024

Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण				
Bid End Date/Time/बिड बंद होने की तारीख/समय	29-02-2024 17:00:00			
Bid Opening Date/Time/बिंड खुलने की तारीख/समय	29-02-2024 17:30:00			
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	90 (Days)			
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Heavy Industries And Public Enterprises			
Department Name/विभाग का नाम	Department Of Heavy Industry			
Organisation Name/संगठन का नाम	Bharat Heavy Electricals Limited (bhel)			
Office Name/कार्यालय का नाम	10090001-edn Bangalore			
Total Quantity/कुल मात्रा	20			
ltem Category/मद केटेगरी	TEMPERATURE SURVEILLANCE UNIT (BHEL Material Code: SA0653941021) (Q3)			
MSE Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से एमएसई छूट	No			
Startup Exemption for Years of Experience and Turnover/ अनुभव के वर्षों से स्टार्टअप छूट	No			
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Additional Doc 1 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer			
Bid to RA enabled/बिंड से रिवर्स नीलामी सक्रिय किया	No			
ITC available to buyer/क्रेता के लिए उपलब्ध आईटीसी	Yes			
Type of Bid/बिंड का प्रकार	Two Packet Bid			
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	2 Days			
Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No			

Bid Details/बिड विवरण				
Payment Timelines	Payments shall be made to the Seller within 90 days of issue of consignee receipt-cum-acceptance certificate (CRAC) and on-line submission of bills (This is in supersession of 10 days time as provided in clause 12 of GeM GTC)			
Evaluation Method/मूल्यांकन पद्धति Total value wise evaluation				
EMD Detail/ईएमडी विवरण				
Required/आवश्यकता	No			
Required/आवश्यकता	No			
·	No			
Splitting/विभाजन				
Splitting/विभाजन Bid splitting not applied/बोली विभाजन लाग	्र नहीं किया गया.			
·	् नहीं किया गया. रीद वरीयता			
Splitting/विभाजन Bid splitting not applied/बोली विभाजन लाग MII Purchase Preference/एमआईआई ख	् नहीं किया गया. रीद वरीयता इ वरीयता			

1. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer)of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 25%(selected by Buyer) percentage of total QUANTITY. The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023 OM No.1 4 2021 PPD dated 18.05.2023 for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

TEMPERATURE SURVEILLANCE UNIT (BHEL Material Code: SA0653941021) (20 pieces)

Technical Specifications/तकनीकी विशिष्टियाँ

Buyer Specification Document/क्रेता विशिष्टि दस्तावेज़	Download
---	----------

Input Tax Credit(ITC)/इनपुट कर क्रेडिट(आईटीसी) and/ तथा Reverse Charge(RCM)/रिवर्स प्रभार (आरसीएम) Details

ITC on GST/जीएसटी पर इनपुट कर क्रेडिट	ITC on GST Cess/जीएसटी उपकर कर क्रेडिट		
100%	NA		

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Bhagat	560026,MANAGER STORES,- GI Bharat Heavy Electricals Limited Electronics Division, Mysore Road, Bangalore - 560026 Karnataka India	20	30

Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

1. Scope of Supply

Scope of supply (Bid price to include all cost components): Only supply of Goods

2. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

3. Generic

Data Sheet of the product(s) offered in the bid, are to be uploaded along with the bid documents. Buyers can match and verify the Data Sheet with the product specifications offered. In case of any unexplained mismatch of technical parameters, the bid is liable for rejection.

4. Generic

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

5. Generic

Supplier shall ensure that the Invoice is raised in the name of Consignee with GSTIN of Consignee only.

6. Generic

While generating invoice in GeM portal, the seller must upload scanned copy of GST invoice and the screenshot of GST portal confirming payment of GST.

7. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

A. PRE-QUALIFICATION REQUIREMENT (PQR)

Bidder should submit documentary evidence for PQC, for evaluating the eligibility of Bidder as per **Buyer s pecification document** in this bid.

B. Payment Timelines:

Type of Bidder Payment Terms (Number of days

Micro & Small Enterprises (MSEs) 45 days from CRAC date
Medium Enterprises 60 days from CRAC date
Non MSME 90 days from CRAC date

C. Risk Purchase - In case of failure of supplier, BHEL at its discretion may make purchase of the material s/ services not supplied/ rendered in time at the RISK & COST of the supplier. Under such situation, the supplier who fails to supply the goods in time shall be wholly liable to make good to BHEL any loss due to risk purchase. In case of invocation of risk purchase, BHEL shall get Balance work/ supply done at supplier risk and cost, which shall be recovered from supplier out of dues of this contract, any other contract with BHEL and balance amount, if any shall be required to be deposited by supplier.

D. Contact Details:

Engineering Dept. Tender Dept.

Mr. Rajkumar R/ Manager Mr. Dinesh Kumar Bhagat/ Manager

e-mail: rajkumarrangu@bhel.in e-mail: dkbhagat@bhel.in Tel: 080 26998107 Tel: 080 26998108

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. Any clause(s) incorporated by the Buyer regarding following shall be treated as null and void and would not be considered as part of bid:-

- 1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
- 2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.

- 3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
- 4. Creating BoQ bid for single item.
- 5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
- 6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
- 7. Floating / creation of work contracts as Custom Bids in Services.
- 8. Seeking sample with bid or approval of samples during bid evaluation process.
- 9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
- 10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
- 11. Creating bid for items from irrelevant categories.
- 12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
- 13. Reference of conditions published on any external site or reference to external documents/clauses.
- 14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो।बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।

---Thank You/धन्यवाद---



PRE-QUALIFICATION CRITERIA FOR TEMPERATURE SURVEILLANCE UNIT

PQC:408-0016

REV. NO. 00

	A	4 - 10		UNIT	Page	1 of 1
MUST NOT		SI. No.	CF	RITERIA	DOCUMENT REQUIRED	
LS LIMITED. IT OF THE COMPA		1.	The bidder shou manufacturer/su Surveillance Uni	upplier of "Temperature		ication for M Certification s.
D CONFIDENTIAL y of bharat heavy electrica detrimental to the interest	9	2.	standard mentice specification PS, 11 of 2 on the confer against the have supplied	all have valid test plying with relevant oned in the technical /408/2083 clause no. date of submission of the tender OR should the item to BHEL or purchase order.		ficates for em may be d.
COPY RIGHT AND CONFIDENTIAL THE INFORMATION ON THIS DOCUMENT IS THE PROPERTY OF BHARAT HEAVY ELECTRICALS LIMITED. IT MUST NOT BE USED DIRECTLY OR INDIRECTLY IN ANY WAY DETRIMENTAL TO THE INTEREST OF THE COMPANY.		3.	documents "Temperature S should have su	shall submit the indicated for Gurveillance Unit" or upplied the item to an earlier purchase	a) At least one end user performance certificate from a power plant. b) Reference list of customers. c) Purchase order copies along with invoice and delivery challan.	
THE INFORMATION ON' BE USED DIRECT		4.	is observed that rework / rectifi arrange for the	urchaser's works, if it at the item requires cation, supplier shall same at EDN works, n 6 working days.	Conforma	ance for
	REV	/ 00		APPROVED		
				PREPARED	ISSUED	DATE
				SRIDEEP RAJENDREN	408	05/04/2021

BHEL MATERIAL CODE: SA0653941021

TEMPERATURE SURVEILLANCE UNIT FOR RECTIFIER

TRANSFORMER WITHOUT THERMISTORS PART NOS. APR-103 OR TPR-404

SUPPLY VOLTAGE:220V,1PH,50HZ,AC

TEMPERATURE SENSORS: PTC

WARNING OR ALARM TEMPERATURE: 160 DEG C TRIPPING TEMPERATURE: 180 DEG CELCIUS FAN 'ON' TEMPERATURE: 130 DEG CELCIUS FAN 'OFF'TEMPERATURE: 110 DEG CELCIUS

PROJECTION MOUNTING DOCS TO BE SUBMITTED

WITH OFFER WITH COMPLETE CATALOGUE &

ELEC.CIRCUIT DRG. As per PS4082083

(100) (180) A (10) (1	बिपचर्ड पत्त मिह्नेहर A4-10	Purchas	se Specificatio	<u>n</u>	PS / 408 / 2083 REV: 00 Page: 01 of 04
Copy Right And Confidential The Information On This Document Is The Property Of Bharat Heavy Electricals Limited. It Must Not Be Used Directly Or Indirectly In Any Way Detrimental To The Interest Of The Company.			ASE SPECIFICA FOR JRE SURVEILL		The state of the s
	Revision: 00	100.00	Reviewed by:	R. Rukmani	ocal
			Prepared by Srideep Rajendren	Issued by CE-Engg. (GCE) - 4	Date 08 05/04/2021

A4-11 The Information On This Document Is The Property Of Bharat Heavy Electricals Limited. It Must Not Be Used Directly Or Indirectly In Any Way Detrimental To

The Interest Of The Company.

Copy Right and Confidential

Purchase Specification

PS / 408 / 2083

REV: 00

Page: 02 of 04

1.0 APPLICATION:

Temperature Surveillance Unit monitors temperature of the three phases of Resin cast dry type rectifier transformer used in excitation system.


2.0 SPECIFICATION:

In each phase of transformer thermistors are provided one each for Alarm, Trip, Fan ON & FAN OFF. The Temperature surveillance unit shall have four input channels for connection to these 4 thermistor sets. Each thermistor system is normally 3 thermistors in series. The response temperature depends upon the thermistors.

Three numbers of relays, one each for Alarm, Trip and Fan ON & OFF shall be part of the unit. Each relay shall operate corresponding to the response temperature of respective thermistors.

An additional relay shall be provided which operates after a delay when the device is switched ON.

Sl. No.	DESCRIPTION	Compliance
	Technical data	
1.	Temperature Sensors input to each channel: PTC Thermistor	
	(not part of supply of Temperature Surveillance unit)	
2.	No. of input channels: 4	
	PTC for alarm, trip, Fan ON and Fan OFF will be connected to each	
	of the 4 input channels.	
3.	Temperature ranges	
	(1) Warning or Alarm: 160 DEG CELCIUS	
	(2) Tripping: 180 DEG CELCIUS	
	(3) Fan ON: 110 DEG CELCIUS*	
	(4) Fan OFF: 90 DEG CELCIUS*	
1		•





Purchase Specification

PS / 408 / 2083

REV: 00

Page: 03 of 04

Sl. No.	DESCRIPTION	Compliance
4.	Relay Output – Potential Free Contact,	
	(1) Alarm: 1no	
	(2) Trip: 1no	
	(3) Fan ON & OFF *: 1no	
	(4) Contact for power supply availability	
5.	Mounting: Projection / DIN Rail 35mm	
6.	Power Supply (Voltage levels): 220VAC +10%, -15%, 1PH, 50Hz	
7.	Insulation level: 2.5KV, 50Hz FOR 1 MIN.	
	Applied between	
	(a)Auxiliary contact & (sensors + power terminals shorted together)	
	(b)Power terminals & (sensors + relay terminals, shorted together)	
	(c)Sensor terminals & (power + relay terminals, shorted together)	
8.	Auxiliary Contact: 1Changeover Contact each for : Alarm, Trip, Fan	
	ON & OFF, Power supply is available	
	Resistive load: 0.6A @125VDC	
	Inductive load: 0.3A @ 125VDC	
9.	Protection: IP20	
10.	Ambient temperature: Shall include 0 deg C +60 deg C	
11.		
	(1) Interference Immunity as per IEC 61000-6-2	
ļ	(2) Electrostatic discharge as per IEC 61000-4-2	
	(3) Electrical fast transient/burst as per IEC 61000-4-4	
	(4) Surge as per IEC 61000-4-5	
12.	Resistance value of thermistor at which Alarm/Trip/Fan ON & OFF	1200Ω to 1600 Ω
	is detected	
13.	Resistance value of thermistor at which Alarm/Trip/Fan ON & OFF	400Ω to 650Ω
	is reset	

Note:

*When temperature is more than 110 deg C, Fan ON & OFF relay is switched ON and when temperature is below 90 deg C, Fan ON & OFF relay is switched OFF.

3.0 SUPPLIER DOCUMENT REQUIREMENT SCHEDULE 3.1 BIDDING STAGE

Supplier shall provide the following information along with the offer. <u>Bids without detailed</u> <u>and point wise compliance statement / documents required, will not be considered for further processing.</u>

- i) Compliance to this specification and material description in the Request For Quotation / Purchase Order. List of deviations, if any, clause number-wise with reasons thereof, wherever applicable shall be clearly brought out.
- ii) Technical datasheets, dimensional drawing, Mounting arrangement, wiring diagram.
- iii) Type test & Routine test reports of similar item as mentioned in the clause no. 11 of 2 (specification) and also as per 5.1. Type test and Routine test reports are not required, if the item has already been supplied to BHEL against an earlier purchase order.)





A4-11

Purchase Specification

PS / 408 / 2083

REV: 00

Page: 04 of 04

5.0 TESTS TO BE CONDUCTED:

5.1 Routine tests (conducted on every batch / item & reports to be submitted before dispatch for dispatch clearance)

Routine tests shall be conducted as per IS/IEC/Equivalent standard/ Manufacturer's Standard.

- 1. Insulation/Dielectric Withstand Test
- 2. Functional test Actuation of relay
 - a. Based on variation in input resistance
 - b. On Switching ON.
- 3. Operation on Auxiliary Supply variation. (voltages indicated in Sl.No.6 of Table under Clause no.2)

6.0 PACKING

The item shall be properly packed to ensure that there are no damages / dislocation of parts during transit.

7.0 ACCEPTANCE CRITERIA

- 1. Verification of routine test reports submitted.
- 2. On receipt of item at BHEL-EDN acceptance will be by quality services of purchaser, verifying the conformance of item to this purchase specification and Inspection of item as per specification / drawings / documents at purchaser's works.