

## बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	23-09-2025 15:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	23-09-2025 15:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	90 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Ministry Of Heavy Industries And Public Enterprises
विभाग का नाम/Department Name	Department Of Heavy Industry
संगठन का नाम/Organisation Name	Bharat Heavy Electricals Limited (bhel)
कार्यालय का नाम/Office Name	10060010-r&d
कुल मात्रा/Total Quantity	32
वस्तु श्रेणी /Item Category	Stationary Valve Regulated Lead Acid Batteries (V2) as per IS 15549 (Q3)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Exemption for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Exemption for Years of Experience and Turnover	No
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	2
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	7
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	1
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	No
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	Stationary Valve Regulated Lead Acid Batteries (V2) as per IS 15549

बिड विवरण/Bid Details	
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	2 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

#### ईएमडी विवरण/EMD Detail

आवश्यकता/Required	No
-------------------	----

#### ईपीबीजी विवरण /ePBG Detail

आवश्यकता/Required	No
-------------------	----

#### विभाजन/Splitting

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

#### एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	No
--	----

#### एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
---	-----

1. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase

preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

2. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

## Stationary Valve Regulated Lead Acid Batteries (V2) As Per IS 15549 ( 16 pieces )

### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Battery voltage (in volt)	12
	Battery capacity (in Ah)	42
Construction	Material of container	Polypropylene co-polymer (PPCP), Acrylonitrile butadiene styrene (ABS), Styrene-acrylonitrile (SAN)
	Number of cells per battery	1 Cell for 2 Volt Battery, 3 Cells for 6 Volt Battery, 6 Cells for 12 Volt Battery
	Method of connections between cells	Bolted, Burnt
Warranty and Marking	Warranty (in years)	3 Or higher

### Additional Specification Parameters - Stationary Valve Regulated Lead Acid Batteries (V2) As Per IS 15549 ( 16 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
1. Battery Specification	a) Conformity of the specification : As per clause 4 of IS 15549 b) Discharge rating : C 10. c) Material of construction: As per clause 4 of IS 15549 d) Marking : As per clause 8 of IS 15549
2. Battery Specification	e) Availability of type test report from Central Government Lab/ NABL accredited Lab / ILAC accredited lab to prove conformity of the specification: Yes, as per clause 10 of IS 15549. f) Material of separators : Glass Mat as per clause 4.5 of IS 15549 g) Total Number of new Batteries needed and old batteries to be exchanged : New :16 No's and Old -16 No's for exchange

Specification Parameter Name	Bid Requirement (Allowed Values)
3. Buy back of old batteries	a) Vendor should buyback the 16 Numbers of existing batteries (Rays industrial Batteries,, Rating: 12V-42Ah). Serial number of old batteries is enclosed as Annexure 1. b) The supplier may visit BHEL Energy system facility, Nacharam, Hyderabad-500076 campus to check the existing batteries before bid submission.
4. Scope	a) The old batteries are to be dismantled by the vendor. The vendor shall take back the old batteries from BHEL R&D, Hyderabad at their own cost. b) Supply, Installation, interconnection and integration of the new batteries with the existing UPS at BHEL Energy systems facility, Nacharam is under scope of the vendor. c) The vendor shall demonstrate the UPS functionality after battery installation
5. Delivery Period & Deliverables	a) Delivery period : Delivery period is within 45 days from the date of PO for the complete scope (i.e supply, installation, interconnection and integration) b) Deliverables: 16 Nos of new batteries as per specifications & Warranty Certificates for Batteries.

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Ambati Sandeep	500042,BHEL, Corp.R&D, Vikasnagar, Near BBR Hospital, Hyderabad	16	45

**Buyback Detail**

Item Name	Rays industrial Batteries
Item Description	Rays industrial Batteries, Rating: 12V-42Ah
Serial No.	As per Annexure-1
Model	SP12-42
Brand	Rays industrial Batteries
Year of Manufacturing	2021
Purchase On	2021-04-09
Age	
Size	
Rating	
Quantity	16
Unit	Numbers
Remark	1) Refer Annexure-1 for Serial numbers of 16nos. old batteries

Uploaded Image

[View Uploaded Image](#)

#### अस्वीकरण/Disclaimer

The vendor will be responsible for the un-installation of Buyback items.

### Stationary Valve Regulated Lead Acid Batteries (V2) As Per IS 15549 ( 14 pieces )

#### तकनीकी विशिष्टियाँ /Technical Specifications

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	Battery voltage (in volt)	12
	Battery capacity (in Ah)	75
Construction	Material of container	Polypropylene co-polymer (PPCP), Acrylonitrile butadiene styrene (ABS), Styrene-acrylonitrile (SAN)
	Number of cells per battery	1 Cell for 2 Volt Battery, 3 Cells for 6 Volt Battery, 6 Cells for 12 Volt Battery
	Method of connections between cells	Bolted, Burnt
Warranty and Marking	Warranty (in years)	3 Or higher

#### Additional Specification Parameters - Stationary Valve Regulated Lead Acid Batteries (V2) As Per IS 15549 ( 14 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
1. Battery Specification	a) Conformity of the specification : As per clause 4 of IS 15549 b) Discharge rating : C 10 c) Material of construction: As per clause 4 of IS 15549 d) Marking : As per clause 8 of IS 15549
2. Battery Specification	e) Availability of type test report from Central Government Lab/ NABL accredited Lab / ILAC accredited lab to prove conformity of the specification: Yes, as per clause 10 of IS 15549. f) Material of separators : Glass Mat as per clause 4.5 of IS 15549 g) Total Number of new Batteries needed and old batteries to be exchanged : New :14 No's and Old -14 No's for exchange
3. Buy back of old batteries	a) Vendor should buyback the 14 Numbers of existing batteries (Exide power safe plus, Rating: 12V-75Ah). Serial number of old batteries is enclosed as Annexure 2. b) The supplier may visit BHEL Energy system facility, Nacharam, Hyderabad-500076 campus to check the existing batteries before bid submission.

Specification Parameter Name	Bid Requirement (Allowed Values)
4. Scope	a) The old batteries are to be dismantled by the vendor. The vendor shall take back the old batteries from BHEL R&D, Hyderabad at their own cost. b) Supply, Installation, interconnection and integration of the new batteries with the existing UPS at BHEL Energy systems facility, Nacharam is under scope of the vendor. c) The vendor shall demonstrate the UPS functionality after battery installation
5. Delivery Period & Deliverables	a) Delivery period : Delivery period is within 45 days from the date of PO for the complete scope (i.e supply, installation, interconnection and integration) b) Deliverables: 14 Nos of new batteries as per specifications & Warranty Certificates for Batteries.

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity**

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Ambati Sandeep	500042,BHEL, Corp.R&D, Vikasnagar, Near BBR Hospital, Hyderabad	14	45

**Buyback Detail**

Item Name	Exide power safe plus
Item Description	Exide power safe plus, Rating: 12V-75Ah
Serial No.	As per Annexure-2
Model	EP 75-12
Brand	Exide power safe plus
Year of Manufacturing	2018
Purchase On	2018-05-18
Age	
Size	
Rating	
Quantity	14
Unit	Numbers
Remark	1) Refer Annexure-2 for Serial numbers of 14nos. old batteries
Uploaded Image	<a href="#">View Uploaded Image</a>

**अस्वीकरण/Disclaimer**

The vendor will be responsible for the un-installation of Buyback items.

**Stationary Valve Regulated Lead Acid Batteries (V2) As Per IS 15549 ( 2 pieces )****तकनीकी विशिष्टियाँ /Technical Specifications**

[\\* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
Generic	<b>Battery voltage (in volt)</b>	12
	<b>Battery capacity (in Ah)</b>	75
Construction	Material of container	Polypropylene co-polymer (PPCP), Acrylonitrile butadiene styrene (ABS), Styrene-acrylonitrile (SAN)
	<b>Number of cells per battery</b>	1 Cell for 2 Volt Battery, 3 Cells for 6 Volt Battery, 6 Cells for 12 Volt Battery
	Method of connections between cells	Bolted, Burnt
Warranty and Marking	<b>Warranty (in years)</b>	3 Or higher

**Additional Specification Parameters - Stationary Valve Regulated Lead Acid Batteries (V2) As Per IS 15549 ( 2 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
1. Battery Specification	a) Conformity of the specification : As per clause 4 of IS 15549 b) Discharge rating : C 10 c) Material of construction: As per clause 4 of IS 15549 d) Marking : As per clause 8 of IS 15549
2. Battery Specification	e) Availability of type test report from Central Government Lab/ NABL accredited Lab / ILAC accredited lab to prove conformity of the specification: Yes, as per clause 10 of IS 15549. f) Material of separators : Glass Mat as per clause 4.5 of IS 15549 g) Total Number of new Batteries needed and old batteries to be exchanged : New :2 No's
3. Scope	a) Supply, Installation, interconnection and integration of the new batteries with the existing UPS at BHEL Energy systems facility, Nacharam is under scope of the vendor. b) The vendor shall demonstrate the UPS functionality after battery installation
4. Delivery Period & Deliverables	a) Delivery period : Delivery period is within 45 days from the date of PO. b) Deliverables: 2 Nos of new batteries as per specifications & Warranty Certificates for Batteries.

\* Bidders offering must also comply with the additional specification parameters mentioned above.

परिचालन/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परिचालन/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Ambati Sandeep	500042,BHEL, Corp.R&D, Vikasnagar, Near BBR Hospital, Hyderabad	2	45

**Special terms and conditions-Version:1 effective from 19-08-2024 for category Stationary Valve Regulated Lead Acid Batteries (V2) as per IS 15549**

- Battery serial number list to be furnished by the seller along with the supply of the battery to the buyer.

**क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions**

**1. Buyer Added Bid Specific ATC**

Buyer uploaded ATC document [Click here to view the file.](#)

**2. Buyer Added Bid Specific ATC**

Buyer Added text based ATC clauses

**Description: Batteries for UPS with Buyback.**

**1) Pre-Qualification Criteria (PQC):**

**1a) Prior Experience:**

Vendor should submit at least one PO copy for batteries which were supplied in the last 5 years from the date of Enquiry.

**1b) Relaxation of Norms for Startups:** The condition of Prior Turnover and prior experience is relaxed for all startups whether Micro & Small Enterprises (MSEs) or otherwise subject to meeting of quality and technical specifications in accordance with the relevant provision of GFR,2005 and other DOE-PPD notifications for relaxation norms for startups issued from time to time.

**2) Payment term:** 100% basic payment shall be made within stipulated days as mentioned below from the date of completion of entire scope (i.e. Supply, Installation, interconnection, integration and acceptance) at BHEL Energy system facility, Nacharam, Hyderabad-500076.

Type of bidder:

- For Micro & Small enterprises(MSEs) payment will be made within 45 days
- For Medium Enterprises will be made within 60 days
- Non MSMEs will be made within 90 days

However, GST Portion of Invoice shall be released only upon:

- Vendor declaring the Invoice in their GSTR-1.
- Receipt of Goods and Tax Invoice by BHEL.
- Confirmation of Payment of GST thereon by vendor on GSTN.

**3) Compliance on restrictions under Rule 144 (XI) of the GFR :** Submit the Annexure - A which is attached in buyer added bid specific ATC document.

**4) Conflict of Interest Clause:** Submit the Annexure - B which is attached in buyer added bid specific ATC document.

**5) Invoice registration and documents upload in SUVIDHA portal by suppliers:**

Irrespective of the value of the invoice amount, the bidder / vendor should necessarily upload the despatch & invoice details on BHEL SUVIDHA portal at <https://suvidha.bhel.in/suvidha/> , prior to despatch.

All documents as per PO checklist , along with additional documents (if any), must be uploaded on the portal. It is mandatory that tax invoices with a net amount (including taxes) exceeding Rs five (5) lakhs uploaded on the portal are digitally signed using a Class 3 Digital Signature Certificate (DSC) issued by a licensed Certifying Authority. Submission of invoice document in hard copy is allowed for invoices with a net amount (including taxes) equal to and upto Rs five (5) lakhs , in case they were not digitally signed and uploaded on the portal.

The material will not be accepted inside BHEL in absence of the above. "

**6) Terms of Delivery :** Shall be Free On Road (FOR) BHEL Energy systems facility, C/o IICT pilot plant chemical complex, Road no 7, Nacharam Industrial Area, Nacharam, Hyderabad 500076.

**7)** Vendor has to submit this GeM bid document duly signed and stamped on all pages. By submitting signed GeM bid document it affirms that vendor has accepted to all the terms and conditions mentioned in this bid such as Payment terms, delivery period etc.

**8)** Insurance, loading/unloading from vendor site to BHEL Energy systems facility, C/o IICT pilot plant chemical complex, Road no 7, Nacharam Industrial Area, Nacharam will be in vendor scope only. Vendor has to quote price(s) inclusive of GST, Transportation/Insurance, Loading/Unloading charges.

**9) Breach of contract, Remedies and Termination:** In case of breach of contract, wherever the value of security instruments like performance bank guarantee available with BHEL against the said contract is at least 10% of the contract value, the same be encashed. In case the value of the security instruments available is less than 10% of the contract value, the balance amount be recovered from other financial remedies (i.e. available bills of the contract or, retention amount, etc. with BHEL) or legal remedies be pursued. Further, levy of liquidated damages, debarment, termination, de-scoping, short-closure, etc., shall be applied as per provisions of the contract.

**10) Bank Details :** For reference please find below Bank details for BHEL R & D:

Bharat Heavy Electricals Ltd., State Bank of India,  
A/c No : 10202162640, IFSC code: SBIN0010622.

**11) Un-Price Bid:** Should be submitted along with Technical Bid. Format is enclosed as Annexure-I in buyer added bid specific ATC document. **Please do not mention prices in this format.**

**12) Safety and statutory requirement:** contractor / vendor shall ensure all safety and statutory requirement related to its staff.

**13) Following documents to be submitted by bidders along with offer:**

- a. PAN Number
- b. GSTIN Registration Status
- c. Bank details

**14) Suspension of Business Dealings with Suppliers / Contractors:**

The offers of the bidders who are under suspension as also the offers of the bidders, who engage the services of the banned firms / principal / agents, shall be rejected. The list of banned firms is available on BHEL web site <https://www.bhel.com/supplier-registration>

**15)** List of serial numbers of old batteries is as per Annexure-1 & 2, which is attached in buyer added bid specific ATC document.

## अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.

3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.
16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

**All GeM Sellers / Service Providers are mandated to ensure compliance with all the applicable laws / acts / rules including but not limited to all Labour Laws such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972 etc. Any non-compliance will be treated as breach of contract and Buyer may take suitable actions as per GeM Contract.**

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

**---धन्यवाद/Thank You---**