



Bid Number/बोली क्रमांक (बिड संख्या):
GEM/2023/B/3165779
Dated/दिनांक : 21-02-2023

Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	04-03-2023 13:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	04-03-2023 13:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	90 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Heavy Industries And Public Enterprises
Department Name/विभाग का नाम	Department Of Heavy Industry
Organisation Name/संगठन का नाम	Bharat Heavy Electricals Limited (bhel)
Office Name/कार्यालय का नाम	10140027-hbbp Trichy
Total Quantity/कुल मात्रा	615
Item Category/मद केटेगरी	LED Luminaire for High Bay Lighting (Q3) , Led Luminaire (For Road And Street Lights)-IS:10322, IS: 16107, IS:16108,IS: 16103,IS:10322 (Q3) , Led Flood Light (Q3)
MSE Exemption for Years of Experience/अनुभव के वर्षों से एमएसई छूट/ and Turnover	No
Startup Exemption for Years of Experience/अनुभव के वर्षों से स्टार्टअप छूट/ and Turnover	No
Document required from seller/विक्रेता से मांगे गए दस्तावेज़	Certificate (Requested in ATC),OEM Authorization Certificate,Additional Doc 1 (Requested in ATC),Additional Doc 2 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया	Yes
RA Qualification Rule	50% Lowest Priced Technically Qualified Bidders
Type of Bid/बिड का प्रकार	Two Packet Bid
Primary product category	Led Flood Light
Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय	2 Days

Bid Details/बिड विवरण

Payment Timelines	Payments shall be made to the Seller within 90 days of issue of consignee receipt-cum-acceptance certificate (CRAC) and on-line submission of bills (This is in supersession of 10 days time as provided in clause 12 of GeM GTC)
Evaluation Method/मूल्यांकन पद्धति	Item wise evaluation/

EMD Detail/ईएमडी विवरण

Required	No
----------	----

ePBG Detail/ईपीबीजी विवरण

Required	No
----------	----

Splitting/विभाजन

Bid splitting not applied.

MII Purchase Preference/एमआईआई खरीद वरीयता

MII Purchase Preference/एमआईआई खरीद वरीयता	Yes
--	-----

MSE Purchase Preference/एमएसई खरीद वरीयता

MSE Purchase Preference/एमएसई खरीद वरीयता	Yes
---	-----

1. Preference to Make In India products (For bids < 200 Crore): Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate. In case Buyer has selected Purchase preference to Micro and Small Enterprises clause in the bid, the same will get precedence over this clause.

2. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for

Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 25%(selected by Buyer) percentage of total QUANTITY.

3. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

4. Reverse Auction would be conducted amongst first 50% of the technically qualified bidders arranged in the order of prices from lowest to highest. Number of sellers eligible for participating in RA would be rounded off to next higher integer value if number of technically qualified bidders is odd (e.g. if 7 bids are technically qualified, then RA will be conducted amongst L-1 to L-4). In case number of technically qualified bidders are 2 or 3, RA will be between all without any elimination. If Buyer has chosen to split the bid amongst N sellers, then minimum N sellers would be taken to RA round. In case Primary products of only one OEM are left in contention for participation in RA based on lowest 50% bidders qualifying for RA, the number of sellers qualifying for RA would be increased to get at least products of one more OEM (directly participated or through its reseller) if available. Further, if bid(s) of any seller(s) eligible for MSE preference is / are coming within price band of 15% of Non MSE L-1 or if bid of any seller(s) eligible for Make in India preference is / are coming within price band of 20% of non MII L-1, then such MSE / Make in India seller shall also be allowed to participate in the RA process.

Evaluation Method (Item Wise Evaluation Method)

Contract will be awarded schedulewise and the determination of L1 will be done separately for each schedule. The details of item-consignee combination covered under each schedule are as under:

Evaluation Schedules	Item/Category	Quantity
Schedule 1	Led Luminaire For High Bay Lighting	115
Schedule 2	Led Luminaire (for Road And Street Lights)-is:10322, Is: 16107, Is:16108,is:16103,is:10322	80
Schedule 3	Led Luminaire (for Road And Street Lights)-is:10322, Is: 16107, Is:16108,is:16103,is:10322	160
Schedule 4	Led Luminaire (for Road And Street Lights)-is:10322, Is: 16107, Is:16108,is:16103,is:10322	125
Schedule 5	Led Flood Light	115
Schedule 6	Led Luminaire (for Road And Street Lights)-is:10322, Is: 16107, Is:16108,is:16103,is:10322	20

LED Luminaire For High Bay Lighting (115 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Brand Type/ब्रांड का प्रकार	Registered Brand
-----------------------------	------------------

Technical Specifications/तकनीकी विशिष्टियाँ

[* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	Installation and commissioning	No
	Scope of installation and commissioning	Not applicable
RATINGS	Operating input voltage range (in Volts)	100 to 280
	Luminaire System Wattge (in Watts)	200
	Luminaire System Efficacy - Lumen output - (Lumen/watt)	≥ 120
	Color Temperature (CCT) +/- 500 K (in Kelvin)	6000 K
	Colour Rendering Index (CRI) (in % age)	≥ 70
	Power Factor (PF)	≥ 0.95 at full load
	Ingress Protection (IP) Rating of Luminaire (agreed to furnish test certificates to buyer / consignee on demand)	IP 66
	Impact resistance (If claimed "Yes" - agreed to furnish test certificates to buyer / consignee on demand)	Yes. IK07 (as per IEC 62262:2002), Yes. IK08 (as per IEC 62262:2002)
	Minimum operating temperature range (in deg. C)	-10 to 0
	Maximum operating temperature range (in deg. C)	55.0 - 60.0 Or higher
SAFETY	The luminaire shall be protected against surges and transients (Internal)	≥ 5 KV
	The luminaire shall be protected against surges and transients (External)	≥ 10 KV
	Flame/Fire proof compliance (If claimed - agreed to furnish test certificates to buyer / consignee on demand)	Fire retardant Class - FV-0 (as per IS:11731 Part-II), Flame proof, IIA, T6 temp. Class (as per IS/IEC 60079-0 & 1 : 2007 latest), No
	Other compliacne (If claimed - agreed to furnish test certificates to buyer / consignee on demand)	EMC (as per IEC:61000-3-2:2014 latest)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
CONSTRUCTION	Shape of Luminaire	Round
	Type of mounting	Metallic adjustable Brackets with Eye Bolt
	Installation height range from floor level (in m) - Must declare	22
	Colour of Luminaire	Grey, Black
	Optic Lens	Yes. Polycarbonate-UV stabilised
	Type of Control Gear	Constant Current
	Number of electronic control gear on each luminaire (power supplies) - (in Nos.)	1
	Luminaire fitted with connecting cables for input power	ISI Marked 3 Core cable for input power (Length:500 mm)
	Accessories for each luminaire	Set of Bolt,Nut, Washers (SS)
MARKING	Marking/Identification details on inside of each luminaire and outside of each packing box	Manufacturer's Name, Model Number, Serial Number, Month and year of manufacturing, Voltage, System Wattage
	Marking/Identification details on each control gear	Manufacturer's Name, Model Number
CERTIFICATIONS	Warranty period (in Months)	36, 48, 60 Or higher
	Availability of test reports from Central Govt. Lab/NABL/ILAC accredited laboratory to prove conformity of the specification	Yes
	Agreed to furnish LM 79 , LM 80 reports from Central Government lab/NABL/ILAC accredited lab	Yes as per IS:16106:2012 latest and as per IS:16105:2012 latest
	Agreed to furnish TM 21 report from Central Government lab/NABL/ILAC accredited lab	Yes

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्र

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्र	Delivery Days/डिलीवरी के दिन
1	Subramanian Samiappan	620014,HIGH PRESSURE BOILER PLANT, BHARAT HEAVY ELECTRICALS LIMITED, TIRUCHIRAPPALLI - 620014. TAMILNADU. INDIA.	115	60

Led Luminaire (For Road And Street Lights)-IS:10322, IS: 16107, IS:16108,IS: 16103,IS:10322 (80 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Brand Type/ब्रांड का प्रकार	Registered Brand
-----------------------------	------------------

Technical Specifications/तकनीकी विशिष्टियाँ

[* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	LED Rating (in Watts)/System Wattage/Rated Power	25W
	Luminaire System Efficacy (Lumen/watt)	>/= 100 Lm/Watt
	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP66
	Warranty for free replacement (in years)	3, 4, 5
ELECTRICAL EFFICIENCY	Input operating Voltage range and frequency	90 to 300 Volts AC at 50 Hz+/-2
OPTICAL	LED chip Efficacy	≥130 Lm/Watt
	Colour temperature	6000+/-500K
THERMAL MANAGEMENT	Heat sink should be die-cast aluminium along with sufficient heat sink fins to dissipate heat effectively	Yes
	Operating temperature range	-20 deg. C to +50 deg. C, -10 deg C to +50 deg C
PROTECTION	Short circuit Protection	Yes
	Over load protecton	Yes
	Over Voltage protection	Yes

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Reverse polarity	Yes
	The luminaire shall be protected against surges and transients (Internal)	>/=5KV
	The luminaire shall be protected against surges and transients of >/=10KV (External)	Yes
CONSTRUCTIONAL	Protection of the entire housing (both LED section and driver section) as per IS:10322 (Part 1):1982 latest	IP66
	Number of electronic control gear (power supplies)	1 No.
	Light Source	SMD LED Chip as per LM 80/IS16106
	Length of ISI marked three core wire (shall be provided along with supply of material)	50 cm
MARKING	"Manufactures Name and and brand on the aluminium die cast body "	Engraved/Embossed
Reports And Certifications	LED Make	OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND
	LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer / consignee on demand (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,	Yes
	LM 80 & TM 21 (Ref. IS:16105:2012) Report and Photo biological report for LED report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer / consignee on demand (LM-80 report shall have the Pohoto Biological re	Yes

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Availability of test Report from Central Government Lab /NABL/ILAC accredited lab to Indian Standard IS:10322/part 5/sec-3/2012 and IS 16107 (Part 2/Sec 1) : 2012	Yes
	Seller shall furnish the Type test reports to the buyer / consignee on demand	Yes

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Subramanian Samiappan	620014,HIGH PRESSURE BOILER PLANT, BHARAT HEAVY ELECTRICALS LIMITED, TIRUCHIRAPPALLI - 620014. TAMILNADU. INDIA.	80	60

Led Luminaire (For Road And Street Lights)-IS:10322, IS: 16107, IS:16108,IS: 16103,IS:10322 (160 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Brand Type/ब्रांड का प्रकार	Registered Brand
-----------------------------	------------------

Technical Specifications/तकनीकी विशिष्टियाँ

[* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	LED Rating (in Watts)/System Wattage/Rated Power	60W
	Luminaire System Efficacy (Lumen/watt)	>/= 100 Lm/Watt

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP66
	Warranty for free replacement (in years)	3, 4, 5
ELECTRICAL EFFICIENCY	Input operating Voltage range and frequency	90 to 300 Volts AC at 50 Hz+/-2
OPTICAL	LED chip Efficacy	≥130 Lm/Watt
	Colour temperature	6000+/-500K
THERMAL MANAGEMENT	Heat sink should be die-cast aluminium along with sufficient heat sink fins to dissipate heat effectively	Yes
	Operating temperature range	-20 deg. C to +50 deg. C, -10 deg C to +50 deg C
PROTECTION	Short circuit Protection	Yes
	Over load protecton	Yes
	Over Voltage protection	Yes
	Reverse polarity	Yes
	The luminaire shall be protected against surges and transients (Internal)	>/=5KV
	The luminaire shall be protected against surges and transients of >/=10KV (External)	Yes
CONSTRUCTIONAL	Protection of the entire housing (both LED section and driver section) as per IS:10322 (Part 1):1982 latest	IP66
	Number of electronic control gear (power supplies)	2 Nos.
	Light Source	SMD LED Chip as per LM 80/IS16106
	Length of ISI marked three core wire (shall be provided along with supply of material)	50 cm
MARKING	"Manufactures Name and and brand on the aluminium die cast body "	Engraved/Embossed
Reports And Certifications	LED Make	OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer / consignee on demand (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,	Yes
	LM 80 & TM 21 (Ref. IS:16105:2012) Report and Photo biological report for LED report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer / consignee on demand (LM-80 report shall have the Pohoto Biological re	Yes
	Availability of test Report from Central Government Lab /NABL/ILAC accredited lab to Indian Standrad IS:10322/part 5/sec-3/2012 and IS 16107 (Part 2/Sec 1) : 2012	Yes
	Seller shall furnish the Type test reports to the buyer / consignee on demand	Yes

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्र

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्र	Delivery Days/डिलीवरी के दिन
1	Subramanian Samiappan	620014,HIGH PRESSURE BOILER PLANT, BHARAT HEAVY ELECTRICALS LIMITED, TIRUCHIRAPPALLI - 620014. TAMILNADU. INDIA.	160	60

Led Luminaire (For Road And Street Lights)-IS:10322, IS: 16107, IS:16108,IS:

16103,IS:10322 (125 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Brand Type/ब्रांड का प्रकार	Registered Brand
-----------------------------	------------------

Technical Specifications/तकनीकी विशिष्टियाँ

[* As per GeM Category Specification/जेम कैटेगरी विशिष्टि के अनुसार](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	LED Rating (in Watts)/System Wattage/Rated Power	90W
	Luminaire System Efficacy (Lumen/watt)	>/= 100 Lm/Watt, 130 Lm/Watt
	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP66
	Warranty for free replacement (in years)	2, 3, 4, 5
ELECTRICAL EFFICIENCY	Input operating Voltage range and frequency	90 to 300 Volts AC at 50 Hz +/-2
OPTICAL	LED chip Efficacy	≥130 Lm/Watt
	Colour temperature	6000+/-500K
THERMAL MANAGEMENT	Heat sink should be die-cast aluminium along with sufficient heat sink fins to dissipate heat effectively	Yes
	Operating temperature range	-20 deg. C to +50 deg. C, -10 deg C to +50 deg C
PROTECTION	Short circuit Protection	Yes
	Over load protecton	Yes
	Over Voltage protection	Yes
	Reverse polarity	Yes
	The luminaire shall be protected against surges and transients (Internal)	>/=5KV
	The luminaire shall be protected against surges and transients of >/=10KV (External)	Yes
CONSTRUCTIONAL	Protection of the entire housing (both LED section and driver section) as per IS:10322 (Part 1):1982 latest	IP66

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Number of electronic control gear (power supplies)	2 Nos.
	Light Source	SMD LED Chip as per LM 80/IS16106
	Length of ISI marked three core wire (shall be provided along with supply of material)	50 cm
MARKING	"Manufactures Name and brand on the aluminium die cast body "	Engraved/Embossed
Reports And Certifications	LED Make	OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND
	LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer / consignee on demand (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,	Yes
	LM 80 & TM 21 (Ref. IS:16105:2012) Report and Photo biological report for LED report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer / consignee on demand (LM-80 report shall have the Pphoto Biological re	Yes
	Availability of test Report from Central Government Lab /NABL/ILAC accredited lab to Indian Standrad IS:10322/part 5/sec-3/2012 and IS 16107 (Part 2/Sec 1) : 2012	Yes
	Seller shall furnish the Type test reports to the buyer / consignee on demand	Yes

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Subramanian Samiappan	620014,HIGH PRESSURE BOILER PLANT, BHARAT HEAVY ELECTRICALS LIMITED, TIRUCHIRAPPALLI - 620014. TAMILNADU. INDIA.	125	60

Led Flood Light (115 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Brand Type/ब्रांड का प्रकार	Registered Brand
-----------------------------	------------------

Technical Specifications/तकनीकी विशिष्टियाँ

[* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार](#)

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Electrical Efficiency	AC Power Factor at full load	≥ 0.95
	Input operating Voltage range and frequency	140 to 270 V olts AC at 50 Hz ± 2 with auto cutt off at below 120V
	Total Harmonics Distortion (as per IS: 16102)	≤ 10
	Automatic Higher Cut off voltage above 300 volt	Yes
	Driver Efficiency (in %age)	Above 100W: $\geq 90\%$
Constructional	LED Rating (in Watts)/System Wattage/Rated Power	120, 150, 160, 180, 200, 240 Or higher
	Mounting Plate size	(430mm x 340mm) ± 10 mm
	Length of ISI marked three core wire (shall be provided along with supply of material)	50, 100, 40 Or higher
	Adjustable Mounting Bracket	Yes
Optical	LED Beam Angle (degree)	$\geq 120, 120$
	Colour temperature	5700 K
	LED chip Efficacy	≥ 130 Lm/Watt
	Colour Rendering Index(CRI)	≥ 70

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
Protection	Over Voltage Protection	Yes
	The luminaire shall be protected against surges and transients of $\geq 10KV$ (External)	Yes
	Short Circuit Protection	Yes
	Over Load Protection	Yes
	The luminaire shall be protected against surges and transients (Internal)	$\geq 4KV$
	Reverse Polarity	Yes
Thermal Management	Operating Temperature Range	-10 deg C to +50 deg C
Marking	Manufacturer's Name, Model Number, Serial Number on the aluminium die cast body Engraved/Embossed	Yes
Standards	Warranty for free replacement (in years)	5
	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP66
Reports And Certifications	Photo biological Safety report as per IEC- 62471 issued by NABL/ vs EPA accredited lab to be submitted	Yes
	Test Report for Protection from High Voltage to be submitted	Yes
	Test Report for Over Volatage Cut off with self restart feature to be submitted	Yes
	LED Make	OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGE
	Wind Speed report as per IEC 62262 from NABL accredited Lab to be submitted	Yes
	Orinial Test Report from independent NABL Lab for Compliance with CRS Scheme as per IS-15885 & IS-16104 to be submitted	Yes

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	Test certificate as per IEC62305 & IEC61643 from NABL/EPA certified third party Lab to be submitted	Yes

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Subramanian Samiappan	620014,HIGH PRESSURE BOILER PLANT, BHARAT HEAVY ELECTRICALS LIMITED, TIRUCHIRAPPALLI - 620014. TAMILNADU. INDIA.	115	60

Led Luminaire (For Road And Street Lights)-IS:10322, IS: 16107, IS:16108,IS: 16103,IS:10322 (20 pieces)

(Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively/क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक)

Brand Type/ब्रांड का प्रकार	Registered Brand
-----------------------------	------------------

Technical Specifications/तकनीकी विशिष्टियाँ

* As per GeM Category Specification/जेम केटेगरी विशिष्टि के अनुसार

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
STANDARDS	LED Rating (in Watts)/System Wattage/Rated Power	48W
	Luminaire System Efficacy (Lumen/watt)	>/= 100 Lm/Watt
	Ingress Protection (IP Rating) as per IS:10322 (Part 1):1982 latest	IP66
	Warranty for free replacement (in years)	2

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
ELECTRICAL EFFICIENCY	Input operating Voltage range and frequency	90 to 300 Volts AC at 50 Hz+/-2
OPTICAL	LED chip Efficacy	≥130 Lm/Watt
	Colour temperature	6000+/-500K
THERMAL MANAGEMENT	Heat sink should be die-cast aluminium along with sufficient heat sink fins to dissipate heat effectively	Yes
	Operating temperature range	-10 deg C to +50 deg C
PROTECTION	Short circuit Protection	Yes
	Over load protecton	Yes
	Over Voltage protection	Yes
	Reverse polarity	Yes
	The luminaire shall be protected against surges and transients (Internal)	>/=5KV
	The luminaire shall be protected against surges and transients of >/=10KV (External)	Yes
CONSTRUCTIONAL	Protection of the entire housing (both LED section and driver section) as per IS:10322 (Part 1):1982 latest	IP66
	Number of electronic control gear (power supplies)	1 No.
	Light Source	SMD LED Chip as per LM 80/IS16106
	Length of ISI marked three core wire (shall be provided along with supply of material)	50 cm
MARKING	"Manufactures Name and brand on the aluminium die cast body "	Engraved/Embossed
Reports And Certifications	LED Make	OSRAM / NICHIA / CREE / SAMSUNG / SEOUL / LUMILEDS / PHILIPS / SYSKA / LUMENMAX / EVERLIGHT / EDISON / BRIDGELUX / NATIONSTAR / REFOND

Specification	Specification Name/विशिष्टि का नाम	Bid Requirement/बिड के लिए आवश्यक (Allowed Values)/अनुमत मूल्य
	LM 79 (Photometry) (Ref.IS:16106:2012) report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer / consignee on demand (LM-79 report shall have total lumen output, power, PF, Current in Amps, CRI & CCT etc.,	Yes
	LM 80 & TM 21 (Ref. IS:16105:2012) Report and Photo biological report for LED report from Central Government Lab /NABL/ILAC accredited lab. Reports shall be furnish to the buyer / consignee on demand (LM-80 report shall have the Pohoto Biological re	Yes
	Availability of test Report from Central Government Lab /NABL/ILAC accredited lab to Indian Standrad IS:10322/part 5/sec-3/2012 and IS 16107 (Part 2/Sec 1) : 2012	Yes
	Seller shall furnish the Type test reports to the buyer / consignee on demand	Yes

Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Saji P J	622507,POWER PLANT PIPING UNIT, BHARAT HEAVY ELECTRICALS LIMITED, THIRUMAYAM.	20	30

Buyer added Bid Specific Additional Scope of Work

S.No.क्र.सं	Document Title	Description	Applicable/रिवर्स प्रभार के अनुसार जोएसटी i.r.o. Items
1	PQC View	PQC-VENDOR TO CONFIRM	LED Luminaire For High Bay Lighting(115),Led Luminaire (For Road And Street Lights)-IS:10322, IS: 16107, IS:16108,IS: 16103,IS:10322 (80),Led Luminaire (For Road And Street Lights)-IS:10322, IS: 16107, IS:16108,IS: 16103,IS:10322 (160),Led Luminaire (For Road And Street Lights)-IS:10322, IS: 16107, IS:16108,IS: 16103,IS:10322 (125),Led Flood Light(115),Led Luminaire (For Road And Street Lights)-IS:10322, IS: 16107, IS:16108,IS: 16103,IS:10322 (20)
2	DELIVERY LOCATIONS View	DELIVERY LOCATIONS	LED Luminaire For High Bay Lighting(115),Led Luminaire (For Road And Street Lights)-IS:10322, IS: 16107, IS:16108,IS: 16103,IS:10322 (80),Led Luminaire (For Road And Street Lights)-IS:10322, IS: 16107, IS:16108,IS: 16103,IS:10322 (160),Led Luminaire (For Road And Street Lights)-IS:10322, IS: 16107, IS:16108,IS: 16103,IS:10322 (125),Led Flood Light(115),Led Luminaire (For Road And Street Lights)-IS:10322, IS: 16107, IS:16108,IS: 16103,IS:10322 (20)
3	ANNEXURE-A View	Additional Terms and Conditions for GeM Enquiry	LED Luminaire For High Bay Lighting(115),Led Luminaire (For Road And Street Lights)-IS:10322, IS: 16107, IS:16108,IS: 16103,IS:10322 (80),Led Luminaire (For Road And Street Lights)-IS:10322, IS: 16107, IS:16108,IS: 16103,IS:10322 (160),Led Luminaire (For Road And Street Lights)-IS:10322, IS: 16107, IS:16108,IS: 16103,IS:10322 (125),Led Flood Light(115),Led Luminaire (For Road And Street Lights)-IS:10322, IS: 16107, IS:16108,IS: 16103,IS:10322 (20)

The uploaded document only contains Buyer specific Additional Scope of Work and / or Drawings for the bid items added with due approval of Buyer's competent authority. Buyer has certified that these additional scope and drawings are generalized and would not lead to any restrictive bidding.

Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

Disclaimer/अस्वीकरण

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. Any clause(s) incorporated by the Buyer regarding following shall be treated as null and void and would not be considered as part of bid:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process.
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो।बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।

---Thank You/धन्यवाद---