



Bid Number/बोली क्रमांक (बिड संख्या):  
GEM/2023/B/3286503  
Dated/दिनांक : 20-03-2023

### Bid Document/ बिड दस्तावेज़

Bid Details/बिड विवरण	
Bid End Date/Time/बिड बंद होने की तारीख/समय	30-03-2023 14:00:00
Bid Opening Date/Time/बिड खुलने की तारीख/समय	30-03-2023 14:30:00
Bid Offer Validity (From End Date)/बिड पेशकश वैधता (बंद होने की तारीख से)	80 (Days)
Ministry/State Name/मंत्रालय/राज्य का नाम	Ministry Of Heavy Industries And Public Enterprises
Department Name/विभाग का नाम	Department Of Heavy Industry
Organisation Name/संगठन का नाम	Bharat Heavy Electricals Limited (bhel)
Office Name/कार्यालय का नाम	10250020-pem, Noida
Total Quantity/कुल मात्रा	234500
	1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MAIN SUPPLY- 2C - 16- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MAIN SUPPLY- 2C - 25- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MAIN SUPPLY- 3C - 16- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MAIN SUPPLY- 3C - 50- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MAIN SUPPLY- 3C - 95- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MAIN SUPPLY- 3C - 185- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MAIN SUPPLY- 3.5C - 185- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MAIN SUPPLY- 4C - 16- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round Wire Armoured for multi-core cables-MAIN SUPPLY- 1C - 400- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round Wire Armoured for multi-core cables-MAIN SUPPLY- 1C - 630- AL ARMOURED , 1.1KV, Cu conductor, XLPE insulated, Galvanised Steel Round Wire Armoured for multi-core cables-MAIN SUPPLY-1C - 16- CU ARMOURED , 1.1KV, Cu conductor, XLPE insulated, Galvanised Steel Round Wire Armoured for multi-core cables-MAIN SUPPLY-2C - 2.5- CU ARMOURED , 1.1KV, Cu conductor, XLPE insulated, Galvanised Steel Round Wire Armoured for multi-core cables-MAIN SUPPLY-3C - 2.5- CU ARMOURED , 1.1KV, Al

	<p><b>Bid Details/बिड विवरण:</b></p> <p>conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MANDATORY SPARES- 2C - 16- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MANDATORY SPARES- 2C - 25- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MANDATORY SPARES-2C - 95- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MANDATORY SPARES- 3C - 16- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MANDATORY SPARES- 3C - 50- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MANDATORY SPARES- 3C - 95- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MANDATORY SPARES- 3C - 185- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MANDATORY SPARES- 3C - 300- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MANDATORY SPARES- 3.5C - 50- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MANDATORY SPARES- 3.5C - 185- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round-Formed Wire Armoured for multi-core cables-MANDATORY SPARES- 4C - 16- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round Wire Armoured for multi-core cables, MANDATORY SPARES- 1C - 400- AL ARMOURED , 1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round Wire Armoured for multi-core cables, MANDATORY SPARES- 1C - 630- AL ARMOURED , 1.1KV, Cu conductor, XLPE insulated, Galvanised Steel Round Wire Armoured for multi-core cables, MANDATORY SPARES- 1C - 16- CU ARMOURED , 1.1KV, Cu conductor, XLPE insulated, Galvanised Steel Round Wire Armoured for multi-core cables, MANDATORY SPARES- 2C - 2.5- CU ARMOURED , 1.1KV, Cu conductor, XLPE insulated, Galvanised Steel Round Wire Armoured for multi-core cables, MANDATORY SPARES- 3C - 2.5- CU ARMOURED</p>
<p><b>Item Category/मद केटेगरी</b></p>	
<p><b>BOQ Title/बीओक्यू शीर्षक</b></p>	<p>LT XLPE POWER CABLES FOR PANKI PROJECT</p>
<p><b>Years of Past Experience Required for same/similar service/उन्हीं/समान सेवाओं के लिए अपेक्षित विगत अनुभव के वर्ष</b></p>	<p>1 Year (s)</p>
<p><b>MSE Exemption for Years of Experience/अनुभव के वर्षों से एमएसई छूट/ and Turnover</b></p>	<p>No</p>
<p><b>Startup Exemption for Years of Experience/अनुभव के वर्षों से स्टार्टअप छूट/ and Turnover</b></p>	<p>No</p>

<b>Bid Details/बिड विवरण</b>	
<b>Document required from seller/विक्रेता से मांगे गए दस्तावेज़</b>	Experience Criteria,Past Performance,Certificate (Requested in ATC),Additional Doc 1 (Requested in ATC),Compliance of BoQ specification and supporting document *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
<b>Past Performance/विगत प्रदर्शन</b>	10 %
<b>Bid to RA enabled/बिड से रिवर्स नीलामी सक्रिय किया</b>	Yes
<b>RA Qualification Rule</b>	H1-Highest Priced Bid Elimination
<b>Type of Bid/बिड का प्रकार</b>	Two Packet Bid
<b>Primary product category</b>	1.1KV, Cu conductor, XLPE insulated, Galvanised Steel Round Wire Armoured for multi-core cables, MANDATORY SPARES- 3C - 2.5- CU ARMoured
<b>Time allowed for Technical Clarifications during technical evaluation/तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय</b>	7 Days
<b>Payment Timelines</b>	Payments shall be made to the Seller within <b>90</b> days of issue of consignee receipt-cum-acceptance certificate (CRAC) and on-line submission of bills (This is in supersession of 10 days time as provided in clause 12 of GeM GTC)
<b>Evaluation Method/मूल्यांकन पद्धति</b>	Total value wise evaluation

**EMD Detail/ईएमडी विवरण**

Required	No
----------	----

**ePBG Detail/ईपीबीजी विवरण**

Advisory Bank	State Bank of India
ePBG Percentage(%) / ईपीबीजी प्रतिशत (%)	5.00
Duration of ePBG required (Months) / ईपीबीजी की अपेक्षित अवधि (महीने).	26

(a). EMD & Performance security should be in favour of Beneficiary, wherever it is applicable./ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए।

**Beneficiary/लाभार्थी :**

Branch CAG II New Delhi  
10250020-PEM, Noida, Department of Heavy Industry, Bharat Heavy Electricals Limited (BHEL), Ministry of Heavy Industries and Public Enterprises  
(A/c No. 39922687394 Ifsc Sbin0017313)

## Splitting/विभाजन

Bid splitting not applied.

## Reserved for Make In India products

Reserved for Make In India products	Yes
-------------------------------------	-----

## MSE Purchase Preference/एमएसई खरीद वरीयता

MSE Purchase Preference/एमएसई खरीद वरीयता	Yes
---	-----

1. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU / Public Listed Company for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

2. Bid reserved for Make In India products: : Procurement under this bid is reserved for purchase from Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. However, eligible micro and small enterprises will be allowed to participate. The minimum local content to qualify as a class 1 local supplier is denoted in the bid document. All bidders must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which the bid is liable to be rejected. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020 . In case Buyer has selected Purchase preference to Micro and Small Enterprises clause in the bid, the same will get precedence over this clause.

3. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 25%(selected by Buyer) percentage of total QUANTITY.

4. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

5. Past Performance: The Bidder or its OEM {themselves or through re-seller(s)} should have supplied same or similar Category Products for 10% of bid quantity, in at least one of the last three Financial years before the bid opening date to any Central / State Govt Organization / PSU / Public Listed Company. Copies of relevant contracts (proving supply of cumulative order quantity in any one financial year) to be submitted along with bid in support of quantity supplied in the relevant Financial year. In case of bunch bids, the category related to primary product having highest bid value should meet this criterion.

6. Reverse Auction would be conducted amongst all the technically qualified bidders except the Highest quoting bidder. The technically qualified Highest Quoting bidder will not be allowed to participate in RA. However, H-1 will also be allowed to participate in RA in following cases:

- i. If number of technically qualified bidders are only 2 or 3.

- ii. If Buyer has chosen to split the bid amongst N sellers, and H1 bid is coming within N.
- iii. In case Primary product of only one OEM is left in contention for participation in RA on elimination of H-1.
- iv. If L-1 is non-MSE and H-1 is eligible MSE and H-1 price is coming within price band of 15% of Non-MSE L-1
- v. If L-1 is non-MII and H-1 is eligible MII and H-1 price is coming within price band of 20% of Non-MII L-1

**1.1KV, Al Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured For Multi-core Cables-MAIN SUPPLY- 2C - 16- AL ARMoured**

**(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	8500	999

**1.1KV, Al Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured For Multi-core Cables-MAIN SUPPLY- 2C - 25- AL ARMoured**

**(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
-------------------------------	---------------------------

**BOQ Detail Document**[View File](#)

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	4000	999

**1.1KV, AI Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured For Multi-core Cables-MAIN SUPPLY- 3C - 16- AL ARMOURED**

**(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	9000	999

**1.1KV, Al Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured For Multi-core Cables-MAIN SUPPLY- 3C - 50- AL ARMoured**

(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	1500	999

**1.1KV, Al Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured For Multi-core Cables-MAIN SUPPLY- 3C - 95- AL ARMoured**

(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	4000	999

**1.1KV, Al Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured For Multi-core Cables-MAIN SUPPLY- 3C - 185- AL ARMOURED**

**(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	2000	999

**1.1KV, AI Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured For Multi-core Cables-MAIN SUPPLY- 3.5C - 185- AL ARMoured****(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	4000	999

**1.1KV, AI Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured**

**For Multi-core Cables-MAIN SUPPLY- 4C - 16- AL ARMOURED****(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	17500	999

**1.1KV, Al Conductor, XLPE Insulated, Galvanised Steel Round Wire Armoured For Multi-core Cables-MAIN SUPPLY- 1C - 400- AL ARMOURED****(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	1500	999

**1.1KV, Al Conductor, XLPE Insulated, Galvanised Steel Round Wire Armoured For Multi-core Cables-MAIN SUPPLY- 1C - 630- AL ARMOURED****(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
----------------	---	-------------	-----------------	------------------------------

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	14000	999

**1.1KV, Cu Conductor, XLPE Insulated, Galvanised Steel Round Wire Armoured For Multi-core Cables-MAIN SUPPLY-1C - 16- CU ARMoured**

(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	9000	999

**1.1KV, Cu Conductor, XLPE Insulated, Galvanised Steel Round Wire Armoured For Multi-core Cables-MAIN SUPPLY-2C - 2.5- CU ARMoured**

(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	32500	999

**1.1KV, Cu Conductor, XLPE Insulated, Galvanised Steel Round Wire Armoured For Multi-core Cables-MAIN SUPPLY-3C - 2.5- CU ARMoured**

**(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	69000	999

**1.1KV, Al Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured For Multi-core Cables-MANDATORY SPARES- 2C - 16- AL ARMoured****(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	2000	999

**1.1KV, Al Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured**

**For Multi-core Cables-MANDATORY SPARES- 2C - 25- AL ARMoured****(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	1000	999

**1.1KV, Al Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured For Multi-core Cables-MANDATORY SPARES-2C - 95- AL ARMoured****(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	500	999

**1.1KV, Al Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured For Multi-core Cables-MANDATORY SPARES- 3C - 16- AL ARMoured****(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
----------------	---	-------------	-----------------	------------------------------

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	3500	999

**1.1KV, Al Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured For Multi-core Cables-MANDATORY SPARES- 3C - 50- AL ARMoured**

(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	1500	999

**1.1KV, Al Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured For Multi-core Cables-MANDATORY SPARES- 3C - 95- AL ARMoured**

(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	1500	999

**1.1KV, Al Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured For Multi-core Cables-MANDATORY SPARES- 3C - 185- AL ARMoured**

**(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	1000	999

**1.1KV, AI Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured For Multi-core Cables-MANDATORY SPARES- 3C - 300- AL ARMOURED****(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	1000	999

**1.1KV, AI Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured**

**For Multi-core Cables-MANDATORY SPARES- 3.5C - 50- AL ARMoured****(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	2500	999

**1.1KV, Al Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured For Multi-core Cables-MANDATORY SPARES- 3.5C - 185- AL ARMoured****(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	1500	999

**1.1KV, Al Conductor, XLPE Insulated, Galvanised Steel Round-Formed Wire Armoured For Multi-core Cables-MANDATORY SPARES- 4C - 16- AL ARMoured****(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
----------------	---	-------------	-----------------	------------------------------

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	3000	999

**1.1KV, Al Conductor, XLPE Insulated, Galvanised Steel Round Wire Armoured For Multi-core Cables, MANDATORY SPARES- 1C - 400- AL ARMOURED**

(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	1500	999

**1.1KV, Al Conductor, XLPE Insulated, Galvanised Steel Round Wire Armoured For Multi-core Cables, MANDATORY SPARES- 1C - 630- AL ARMOURED**

(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	4500	999

**1.1KV, Cu Conductor, XLPE Insulated, Galvanised Steel Round Wire Armoured For Multi-core Cables, MANDATORY SPARES- 1C - 16- CU ARMoured**

**(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	2000	999

**1.1KV, Cu Conductor, XLPE Insulated, Galvanised Steel Round Wire Armoured For Multi-core Cables, MANDATORY SPARES- 2C - 2.5- CU ARMoured****(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)**

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

**Technical Specifications/तकनीकी विशिष्टियाँ**

<b>Specification Document</b>	<a href="#">View File</a>
<b>BOQ Detail Document</b>	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

**Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा**

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	13500	999

**1.1KV, Cu Conductor, XLPE Insulated, Galvanised Steel Round Wire Armoured For**

## Multi-core Cables, MANDATORY SPARES- 3C - 2.5- CU ARMoured

(Minimum 60% Local Content required for qualifying as Class 1 Local Supplier)

Brand Type/ब्रांड का प्रकार	Unbranded
-----------------------------	-----------

### Technical Specifications/तकनीकी विशिष्टियाँ

Specification Document	<a href="#">View File</a>
BOQ Detail Document	<a href="#">View File</a>

Advisory-Please refer attached BOQ document for detailed consignee list and delivery period.

### Consignees/Reporting Officer/परेषिती/रिपोर्टिंग अधिकारी and/ तथा Quantity/मात्रा

S.No./क्र. सं.	Consignee Reporting/Officer/ परेषिती/रिपोर्टिंग अधिकारी	Address/पता	Quantity/मात्रा	Delivery Days/डिलीवरी के दिन
1	Dinesh Kumar Vaishy	208020,Construction Manager, Bharat Heavy Electricals Limited c/o Chief Engineer (Projects), UPRVUNL PANKI TPS EXTENSION Panki , Dist. Kanpur (U.P) Pin-208020 (Uttar Prades)h	17500	999

### Buyer Added Bid Specific Terms and Conditions/क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें

#### 1. Generic

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity by up to 25% of the contracted quantity during the currency of the contract at the contracted rates. Bidders are bound to accept the orders accordingly.

#### 2. Inspection

**Nominated Inspection Agency:** On behalf of the Buyer organization, any one of the following Inspection Agency would be conducting inspection of stores before acceptance:  
Pre-dispatch Inspection at Seller Premises (applicable only if pre-dispatch inspection clause has been selected in ATC):

At Vendors Works

Post Receipt Inspection at consignee site before acceptance of stores:  
NA

### 3. **Certificates**

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

### 4. **Certificates**

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

### 5. **Generic**

Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.

### 6. **Generic**

Buyer Organization specific Integrity Pact shall have to be complied by all bidders. Bidders shall have to upload scanned copy of signed integrity pact as per Buyer organizations policy along with bid. [Click here to view the file](#)

### 7. **Generic**

Data Sheet of the product(s) offered in the bid, are to be uploaded along with the bid documents. Buyers can match and verify the Data Sheet with the product specifications offered. In case of any unexplained mismatch of technical parameters, the bid is liable for rejection.

### 8. **Generic**

While generating invoice in GeM portal, the seller must upload scanned copy of GST invoice and the screenshot of GST portal confirming payment of GST.

### 9. **Buyer Added Bid Specific ATC**

Buyer uploaded ATC document [Click here to view the file.](#)

## **Disclaimer/अस्वीकरण**

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. Any clause(s) incorporated by the Buyer regarding following shall be treated as null and void and would not be considered as part of bid:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.

7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process.
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

This Bid is also governed by the General Terms and Conditions/ यह बिड सामान्य शर्तों के अंतर्गत भी शासित है

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws./जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।

**---Thank You/धन्यवाद---**

## Index of Annexures

### GeM Tender Enquiry for LT XLPE POWER CABLES for 1x 660 MW Panki Project

Sl. No.	Description	Annexures
1.	Additional terms and conditions (ATC)	Annexure I
2.	BOQ (For Main Supply and Mandatory Spares)	Annexure II
3.	Delivery Schedule	Annexure III
4.	Land border certificate	Annexure IV
5.	Certificate for local Content	Annexure V
6.	Technical PQR	-
7.	Technical Specification	-
8.	Price Variation Clause (PVC)	-
9.	Integrity Pact (IP)	-
10.	NTPC Sub vendor Questionnaire	-

## ANNEXURE –I (LT XLPE POWER CABLES)

### Additional Terms and Conditions (ATC)

#### **Additional Terms and Conditions for subject Tender Enquiry to be complied by Bidders for Consideration in this tender:**

##### **1. Dispatch Markings: -**

Each box shall be marked with Capital Letters in “Red” indicating the PEM supply (Main Supply/ Commissioning spare/ Mandatory Spare) for 1x 660 MW Panki Thermal Power Station Project. Each package delivered under the Contract shall be marked by Supplier and such marking must be distinct and in English Language (all previous irrelevant markings being carefully obliterated). Such marking shall show the description and quantity of contents, the name and address of consignee, the Gross weight and Net weight of the package, the name of the Supplier, PEM P.O. reference number, with a distinctive number of mark sufficient for purposes of identification. Besides above necessary, packing shall bear a special marking `TOP`, `BOTTOM`, `DO NOT TURN OVER`, “KEEP DRY”, “HANDLE WITH CARE”, etc.

##### **IMPORTANT**

- Two copies of respective standard manufacturer’s erection instruction/operation instruction manual shall be kept in each package / container for immediate reference by BHEL site and same shall be reflected in packing slip also
- The Packing list details for the consignment must be put inside the Box/Boxes.

**Mandatory Spares:** - The commissioning spares shall be properly packed separately in separate box and each spare shall be properly tagged giving details i.e. dispatch (to match the description given in the packing slip) to facilitate their proper identification. One Copy of Packing list must be put inside the Box.

**Note:-** Main Supply items and items for Mandatory spares must be packed separately.

##### **2. Liquidated Damages: -**

- a) **Main Supply:-** Purchaser reserves the right to recover from the Seller/ Contractor, as agreed liquidated damages and not by way of penalty, a sum equivalent to half ( $\frac{1}{2}$ ) percent and applicable GST thereon, of the total main supply & commissioning spares contract price excluding GST per week or part thereof, subject to a maximum of ten(10) percent of the total main supply & commissioning Spares contract price excluding GST, if the Seller/ Contractor fails to deliver any part of the ordered goods/stores within the period stipulated in the Order/ Contract.
- b) **LD on mandatory spares portion:** - LD shall be applicable @  $\frac{1}{2}$  percent and applicable GST thereon, of the total mandatory spares portion contract value excluding GST per week or part thereof, limiting to 10% of total contract value of mandatory spares excluding GST

##### **NOTE:**

i. LR/RR date for indigenous supplies (Bill of Lading/AWB for Foreign supplies) shall be treated as the date of dispatch for levying LD. However, if receipted LR date for indigenous supply is beyond 30 days for FTL/ 45 days for PTL from the date of LR (PTL to be clearly mentioned in LR), such excess period shall be considered for LD purpose irrespective of dispatch date. Import General Manifest (IGM)/Bill of entry date (whichever is earlier), for foreign supplies, is beyond 90 days from the date of Bill of Lading/AWB, such excess period shall be considered for LD purpose irrespective of dispatch date.

## **ANNEXURE –I (LT XLPE POWER CABLES)**

### **Additional Terms and Conditions (ATC)**

ii. In case of any amendment/ revision, LD shall be linked to the amended/ revised contract value and delivery date(s).

iii. If Order/ Contract involves two or more Units/ Sets/ Lots/ Stages, then Liquidated Damages shall be levied on order/ contract value excluding GST of the delayed Unit/ Set/ Lot/ Stage, provided delivery stipulated in the Order/ Contract is Unit/ Set/ Lot/Stage wise, however total LD amount shall be limited to 10% of total order/ amended order value excluding GST of delayed Unit/ Set/ Lot/Stage. Any subsequent lot released (not envisaged in original contract) due to increase in quantity within permissible quantity variation shall be treated as separate lot for the purpose of LD.

iv. The sum specified above is not a penalty but a genuine pre-estimate of the loss/ damage which will be suffered by purchaser on account of delay on the part of the Contractor/Seller and the said amount will be deductible without proof of actual loss or damage caused by such delay.

### **3. Risk & Cost Purchase**

BHEL reserves the right to terminate the contract or withdraw portion of work and get it done through other agency, at the risk and cost of the contractor after due notice of a period of 14 days' by BHEL in any of the following cases:

i) If the Seller/Contractor fails to deliver the goods or materials or any instalment thereof within the period(s) fixed for such delivery or the Seller's poor progress of the supply/ services vis-à-vis delivery/execution timeline as stipulated in the Contract, backlog attributable to seller including unexecuted portion of supply does not appear to be executable within balance available period;

ii) Delivers goods or materials not of the contracted quality and failing to adhere to the contract specifications;

iii) Withdrawal from or repudiation/ abandonment of the supply/ services by Seller before completion as per contract or if the Seller refuses or is unable to supply goods or materials covered by the Order/Contract either in whole or in part or otherwise fails to perform the Order/Contract;

iv) Non-supply by the Seller within scheduled completion/delivery period as per Contract or as extended from time to time, for the reasons attributable to the Seller;

v) Termination of Contract on account of any other reason (s) attributable to Seller.

vi) Assignment, transfer, subletting of Contract without BHEL's written permission resulting in termination of Contract or part thereof by BHEL.

vii) If the Seller be an individual or a sole proprietorship Firm, in the event of the death or insanity of the Seller;

viii) If the Seller/Contractor being an individual or if a firm on a partnership thereof, shall at any time, be adjudged insolvent or shall have a receiving order for administration of his estate made against him or shall take any proceeding for composition under any Insolvency Act for the time being in force or make any assignment of the Order/Contract or enter into any arrangement or composition with his creditors or suspend payment or if the firm dissolved under the Partnership Act;

## **ANNEXURE –I (LT XLPE POWER CABLES)**

### **Additional Terms and Conditions (ATC)**

ix) If the Seller/Contractor being a company is wound up voluntarily or by order of a Court or a Receiver, Liquidator or Manager on behalf of the debenture holders and creditors is appointed or circumstances shall have arisen which entitles the Court of debenture holder and creditors to appoint a receiver, liquidator or manager;

x) Non-compliance to any contractual condition or any other default attributable to Seller.

Such defaulting vendor/Seller shall not be eligible to participate in re-tendering conducted on account of risk purchase made due to fault of such vendor/Seller.

#### **3.1 Risk & Cost Amount against Balance Work:**

Risk & Cost amount against balance work shall be calculated as follows:

$$\text{Risk \& Cost Amount} = [(A-B) + (A \times H/100)]$$

Where,

A= Value of Balance scope of Work (\*) as per rates of new contract

B= Value of Balance scope of Work (\*) as per rates of old contract being paid to the contractor at the time of termination of contract i.e. inclusive of PVC & ORC, if any.

H = Overhead Factor to be taken as 5

In case (A-B) is less than 0 (zero), value of (A-B) shall be taken as 0 (zero).

#### **3.2 \* Balance scope of work (in case of termination of contract):**

Difference of Contract Quantities and Executed Quantities as on the date of issue of Letter for 'Termination of Contract', shall be taken as balance scope of Work for calculating risk & cost amount.

Contract quantities are the quantities as per original contract. If, Contract has been amended, quantities as per amended Contract shall be considered as Contract Quantities.

Items for which total quantities to be executed have exceeded the Contract Quantities based on drawings issued to contractor from time to time till issue of Termination letter, then for these items total Quantities as per issued drawings would be deemed to be contract quantities.

Substitute/ extra items whose rates have already been approved would form part of contract quantities for this purpose.

Substitute/ extra items which have been executed but rates have not been approved, would also form part of contract quantities for this purpose and rates of such items shall be determined in line with contractual provisions.

However, increase in quantities on account of additional scope in new tender shall not be considered for this purpose.

NOTE: In case portion of work is being withdrawn at risk & cost of contractor instead of termination of contract, contract

## **ANNEXURE –I (LT XLPE POWER CABLES)**

### **Additional Terms and Conditions (ATC)**

quantities pertaining to portion of work withdrawn shall be considered as 'Balance scope of work' for calculating Risk & Cost amount.

#### **3.3 LD against delay in executed work in case of Termination of Contract:**

LD against delay in executed work shall be calculated in line with above LD clause, for the delay attributable to contractor. For limiting the maximum value of LD, contract value shall be taken as Executed Value of work till termination of contract.

Method for calculation of LD against delay in executed work in case of termination of contract" is given below.

i. Let the time period from scheduled date of start of work till termination of contract excluding the period of

Hold (if any) not attributable to contractor = T1

ii. Let the value of executed work till the time of termination of contract = X

iii. Let the Total Executable Value of work for which inputs/fronts were made available to contractor and were

planned for execution till termination of contract = Y

iv. Delay in executed work attributable to contractor i.e. T2 =  $[1-(X/Y)] \times T1$

v. LD shall be calculated in line with LD clause (clause 16) of the Contract for the delay attributable to contractor taking "X" as Contract Value and "T2" as period of delay attributable to contractor.

#### **3.4 Recoveries arising out of Risk & Cost and LD or any other recoveries due from Contractor**

Without prejudice to the other means of recovery of such dues from the Seller recoveries from the Seller on whom risk & cost has been invoked shall be made from the following:

a) Dues available in the form of Bills payable to seller, SD, BGs against the same contract.

b) Dues payable to seller against other contracts in the same Region/Unit/ Division of BHEL.

c) Dues payable to seller against other contracts in the different Region/Unit/ division of BHEL.

In-case recoveries are not possible with any of the above available options, Legal action shall be initiated for recovery against contractor.

4. For recognition of dispatch, vendor to submit following documents to BHEL by e-mail/ fax immediately on dispatch: - GST compliant invoice, LR (indicating Invoice No., no. of boxes, PTL (if applicable) etc.), Packing List (Must be indicating No. of boxes, Packing size, Gross weight and net weight of each package, Contents of the package with cross reference to BoM item code no. or item serial no. and Quantity of each item separately), Insurance Intimation to underwriter through email/fax, Dispatch Clearance.

#### **B. Following ATC available in GEM shall also be made part of NIT: -**

## **ANNEXURE –I (LT XLPE POWER CABLES)**

### **Additional Terms and Conditions (ATC)**

- i.** Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.
- ii.** Bidders are advised to check applicable GST on their own before quoting. Buyer will not take any responsibility in this regards. GST reimbursement will be as per actuals or as per applicable rates (whichever is lower), subject to the maximum of quoted GST %.
- iii.** Data Sheet of the product(s) offered in the bid, are to be uploaded along with the bid documents. Buyers can match and verify the Data Sheet with the product specifications offered. In case of any unexplained mismatch of technical parameters, the bid is liable for rejection.
- iv.** The bidder is required to upload, along with the bid, all relevant certificates such as BIS license, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.
- v.** While generating invoice in GeM portal, the seller must upload scanned copy of GST invoice and the screenshot of GST portal confirming payment of GST.

## ANNEXURE –I (LT XLPE POWER CABLES)

### Additional Terms and Conditions (ATC)

#### **Additional Terms and Conditions for subject Tender Enquiry to be complied by bidders for consideration in this tender:**

- A.** Bidders to ensure that Third party/Customer issued certificates being submitted as proof of PQR qualification should have verifiable details of document/certificate issuing authority such as name & designation of Issuing Authority and its organization contact number and E-mail Id. In case the same is found not available, BHEL has the right to reject such document from evaluation.
- B.** "This item /package/system falls under the list of items defined in para 3 of ministry of finance guideline date 20.09.16 (procurement of items related to public safety, health, critical security operations and Equipment's etc.) & hence criteria of prior experience /turnover shall be same for all bidders including start up /MSME".
- C. Guarantee & Warrantee** shall be as per Cl. No. 10 of GTC on GeM for the bid. However, Guarantee & Warrantee time period shall be 18 months from the date of last supply in the contract.
- D.** Evaluation shall be on the basis of total all inclusive, landed price at consignee destination (Refer Cl. No. 6 of GTC on GEM).
- E. Terms of Delivery:** FOR Dispatch Station Basis. However, Transit insurance shall be in the scope of seller and unloading of items (at delivery point) shall be in buyer scope. Further, w.r.t. Transit Insurance supplier has to inform the details of dispatches (such as Policy No., Consignee Name, Consignment Packing details, Project Name, Purchase Order No., LR No. & date, Invoice No. & date, Dispatch Origin & destination details etc.) to policy underwriter under intimation to BHEL.
- F.** PQR criteria uploaded with Buyer uploaded Bid Specific document shall prevail value of Experience criteria and Past performance parameter mentioned in GeM bid.
- G.** "Due to COVID-19 pandemic condition prevailing in the country BHEL/PEM may go for Remote Inspection of Offered items if required. Vendors are requested to be equipped with the facilities/gadgets as indicated in the guidelines available at : <https://pem.bhel.com/Documents/VendorSection/Vendor/Guidelines.pdf> to take up the inspection remotely.
- H. Inspection call to be raised by bidder on BHEL CQIR portal** (details shall be shared at the of execution of order) and Inspection agency shall attend at the inspection within seven (07) days of the date on which the material is notified as being ready. In case of delay in witnessing of inspection beyond stipulated time (i.e. 7 days from the date on which the material is notified as being ready), by BHEL arising due to reasons not attributable to vendor, BHEL will extend the delivery period for such delay in carrying out inspection. If BHEL is not able to witness inspection up to 15 days then in addition to delay beyond stipulated period, extension in delivery time of 07 days for arranging fresh inspection will be given.

When the tests have been satisfactorily completed at Seller/ Contractor's works, the Inspection Agency shall issue an inspection report that effect within seven (07) days after completion of the tests, but if the tests were not witnessed by the Inspection Agency or his representative, the material acceptance report would be issued within seven (07) days after receipt of the test certificates by the Purchaser.

Purchaser will issue MDCC to the Seller/ Contractor within 7 days based on inspection report/ test certificates/Certificate of Conformance as applicable. In case of delay in issuance of MDCC beyond 7 days stipulated time (i.e. from the date of successful inspection report), by BHEL arising due to reasons not attributable to vendor, BHEL will extend the delivery period for such delay in issuing

## ANNEXURE –I (LT XLPE POWER CABLES)

### Additional Terms and Conditions (ATC)

MDCC. If BHEL is not able to issue MDCC up to 15 days then in addition to delay beyond stipulated period, 7 days' additional time shall be given to vendor to facilitate the vendor for arranging logistics arrangements.

- I. All Bidders shall be required to submit applicable Freight % & GST % included in their prices during clarification stage of Tender.
- J. Performance Bank Guarantee: shall be as per Cl. No. 7 of GTC of GeM. Performance Security amount shall be @5% of the value of contract value.
- K. **Payment Terms:** As per clause no. 12 (i) of GTC on GeM. Payments shall be made to the Seller within 90 days (45 days for seller qualified and registered as Micro or small and 60 days for Medium enterprises as per MSMED Act.) of issue of consignee receipt-cum-acceptance certificate (CRAC) and on-line submission of bills (This is in supersession of 10 days' time as provided in clause 12 of GeM GTC).

Supplier has to provide Original Tax Invoice + 1 copy of Tax invoice, Packing List, LR/RR or AWB, CRAC, Insurance intimation, Guarantee Certificate, E-way bill (as applicable) for payment.

Further bidder to submit the final documents (Final drgs & Inspection document) in 12 no.s of hard copies and 04 no.s of CD along with Invoice.

Provision of offline payment in GeM shall be utilized.

- L. **Bid reserved for Make in India products:** - Procurement under this bid is reserved for purchase from Class 1 local suppliers as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a class 1 local supplier is denoted in the bid document as 60%. All bidders must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which the bid is liable to be rejected.

Regarding verification of local content, the local supplier at the time of tender, bidding or solicitation shall be required to provide certification (as per enclosed **Annexure-V**) as per para 9 of PP-MII order revision dated 16.09.2020.

- M. **This is conditional tender enquiry. Financial bid opening (Part-II) of a bidder shall be subjected to following:** -

- (i) Approval of bidder by Customer (NTPC/UPRVUNL)
- (ii) Techno-Commercial evaluation/recommendation by BHEL.
- (iii) Qualification of Technical PQR
- (iv) Offered item should mandatorily conform to PP-MII order provisions.

- N. **Consignee Details** (for PRC - Provisional Receipt Certificate & CRAC - Consignee's Receipt cum Acceptance Certificate, as applicable) shall be as per Project Site official details.

- O. The Bidder has to declares that they will not enter into any illegal or undisclosed agreement or understanding, whether formal or informal with other Bidder(s). This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to introduce cartelization in the bidding process. In case, the bidder is found having indulged in above activities, suitable action shall be taken by BHEL as per extant policies/guidelines.

## ANNEXURE –I (LT XLPE POWER CABLES)

### Additional Terms and Conditions (ATC)

**P. Bidders to ensure the following: -**

- Ensure compliance to Ministry of Power (MoP) Order No. 11/05/2018-Coord. dt. 28/07/2020, if applicable.
- Ensure compliance of Ministry of Finance (MoF) Order (Public Procurement No. 1 & 2) F. No. 6/18/2019/PPD dt. 23/07/2020.
- to submit “Model Certificate for Tenders” as per **Annexure-IV** of Ministry of Finance (MoF) Order (Public Procurement No. 1 & 2) F. No. 6/18/2019/PPD dt. 23/07/2020, 08/02/21, 06/09/22 & 23.02.23. Bidder to submit the following undertaking on their letter head duly signed from the highest competent authority at your end (i.e Owner, partner, CMD, Director etc.)

**Q. Delivery Period:** As per attached Annexure-III. Delivery period for sake of GeM bid shall be chosen as 999 days from PO date. However, this period shall not be considered for delivery and delay analysis purpose.

**R.** For registration in BHEL PEM- Online registration portal is operational, Non-registered Vendors who wish to apply for registration in BHEL-PEM can apply through Online Registration Portal available at [www.pem.bhel.com](http://www.pem.bhel.com) - vendor section - Online Supplier Registration. All credentials and/or documents duly signed and stamped related to registration can be uploaded on the website and submit the application for registration. However, registration of suppliers is not mandatory in case of open tender.

**S.** Quantity Variation clause of +/- 25% of GeM ATC shall be utilized using option clause.

**T.** CIF is not applicable for subject tender.

**U.** PVC shall be applicable for subject package as per enclosed PVC annexure. Base date is February 2023 (One month prior to date of tendering). Price variation shall be limited to +20% and -ve price variation shall be unlimited. PVC shall be payable only for contractual delivery period (including delivery extensions if any) i.e no PVC shall be payable for delay in delivery attributed to vendor & in delayed delivery cases, PVC for contractual delivery date & actual delivery date shall be compared and whichever is found lower side shall be payable to vendor.

**V.** Integrity pact applicable as per below details: -

**Integrity Pact (IP)**

- (a) IP is a tool to ensure that activities and transactions between the Company and its Bidders/ Contractors are handled in a fair, transparent and corruption free manner. Following Independent External Monitors (IEMs) on the present panel have been appointed by BHEL with the approval of CVC to oversee implementation of IP in BHEL.

Sl	IEM	Email
1.	Shri Otem Dai, IAS (Retd.)	<a href="mailto:iem1@bhel.in">iem1@bhel.in</a>
2.	Shri Bishwamitra Pandey, IRAS (Retd.)	<a href="mailto:iem2@bhel.in">iem2@bhel.in</a>
3.	Shri Mukesh Mittal, IRS (Retd.)	<a href="mailto:iem3@bhel.in">iem3@bhel.in</a>

- (b) The IP as enclosed with the tender is to be submitted (duly signed by authorized signatory) along with techno-commercial bid (Part-I, in case of two/ three part bid). Only those bidders who have entered into such an IP with BHEL would be competent to participate in the bidding. In other words, entering into this Pact would be a preliminary qualification.

## ANNEXURE –I (LT XLPE POWER CABLES)

### Additional Terms and Conditions (ATC)

- (c) Please refer Section-8 of IP for Role and Responsibilities of IEMs. In case of any complaint arising out of the tendering process, the matter may be referred to any of the above IEM(s). All correspondence with the IEMs shall be done through email only.

Note:

*No routine correspondence shall be addressed to the IEM (phone/ post/ email) regarding the clarifications, time extensions or any other administrative queries, etc on the tender issued. All such clarification/ issues shall be addressed directly to the tender issuing (procurement) department's officials whose contact details are provided below:-*

Details of contact person(s):

(1)

Name: Shri Prakash Yadav/MGR

Deptt: PG III

Address: PS-PEM, BHEL

Sector16 A, Noida 201301

Phone: 0120-4213635/8800377855

Email: spyadav@bhel.in

(2)

Name: Sanjay Kumar Dubey/SDGM

Deptt: PG III

Address: PS-PEM, BHEL

Sector16 A, Noida 201301

Phone: 0120-4213621/9911775641

Email: skdubey@bhel.in

- W.** MSE Preference: - Being subject package is divisible and MSE preference (maximum 25%) shall be given. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L 1 + 15% of margin of purchase preference /price band defined in relevant policy, such Seller(s) shall be given opportunity to match L-1 price and contract will be awarded for 25% percentage of total quantity.

a) If L1 bidder is MSE bidder, entire quantity will be given to such MSE bidder only.

b) In case of more than one such MSE, within the price band of L1 +15%, the supply shall be shared proportionately, provided the available quantum can be split.

- X.** Bidder to note the following: -

A bidder shall not have conflict of interest with other bidders. Such conflict of interest can lead to anti-competitive practices to the detriment of Procuring Entity's interests. The bidder found to have a conflict of interest shall be disqualified. A bidder may be considered to have a conflict of interest with one or more parties in this bidding process, if:

- they have controlling partner (s) in common; or
- they receive or have received any direct or indirect subsidy/ financial stake from any of them; or
- they have the same legal representative/agent for purposes of this bid; or
- they have relationship with each other, directly or through common third parties, that puts them in a position to have access to information about or influence on the bid of another Bidder; or

## **ANNEXURE –I (LT XLPE POWER CABLES)**

### **Additional Terms and Conditions (ATC)**

- Bidder participates in more than one bid in this bidding process. Participation by a Bidder in more than one Bid will result in the disqualification of all bids in which the parties are involved. However, this does not limit the inclusion of the components/ sub-assembly/ Assemblies from one bidding manufacturer in more than one bid, or
  - In cases of agents quoting in offshore procurements, on behalf of their principal manufacturers, one agent cannot represent two manufacturers or quote on their behalf in a particular tender enquiry. One manufacturer can also authorize only one agent/dealer. There can be only one bid from the following:
    1. The principal manufacturer directly or through one Indian agent on his behalf; and
    2. Indian/foreign agent on behalf of only one principal,'or
  - A Bidder or any of its affiliates participated as a consultant in the preparation of the design or technical specifications of the contract that is the subject of the Bid, or
  - In case of a holding company having more than one independently manufacturing units, or more than one unit having common business ownership/management, only one unit should quote. Similar restrictions would apply to closely related sister companies. Bidders must proactively declare such sister/ common business/ management units in same/ similar line of business. "
- Y.** All other terms & conditions shall be as per GeM bid, selected Additional Terms & Conditions from GeM library and GTC on GeM 4.0 (version 1.18) available on GeM Portal on enquiry floating date shall be applicable.

**PACKAGE- LT XLPE POWER CABLE (MAIN SUPPLY)- ANNEXURE II**

**PROJECT-1 X 660 MW PANKI TPP**

<b>S. No.</b>	<b>Item Description</b>	<b>Drum Lengh ( METERS)</b>	<b>Quantity (METERS)</b>
<b>(A)</b>	<b>1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round/Formed Wire Armoured for multi-core cables, INNER SHEATH: Extruded HRPVC compound conforming to type ST2 of IS: 5831 for multicore cable, OVERALL SHEATH: Extruded FRLS HRPVC compound conforming to type ST2 of IS: 5831 &amp; black in colour.</b>		
<b>1</b>	2C - 16- AL ARMOURED	500	8500
<b>2</b>	2C - 25- AL ARMOURED	500	4000
<b>3</b>	3C - 16- AL ARMOURED	500	9000
<b>4</b>	3C - 50- AL ARMOURED	500	1500
<b>5</b>	3C - 95- AL ARMOURED	500	4000
<b>6</b>	3C - 185- AL ARMOURED	500	2000
<b>7</b>	3.5C - 185- AL ARMOURED	500	4000
<b>8</b>	4C - 16- AL ARMOURED	500	17500
<b>(B)</b>	<b>1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round Wire Armoured for multi-core cables, (Non Magnetic Hard drawn Aluminium Round Wire Armoured conforming to H4 grade for single core cables)INNER SHEATH: Extruded HRPVC compound conforming to type ST2 of IS: 5831 for multicore cable &amp; no inner sheath for single core cables, OVERALL SHEATH: Extruded FRLS HRPVC compound conforming to type ST2 of IS: 5831 &amp; black in colour.</b>		
<b>1</b>	1C - 400- AL ARMOURED	500	1500
<b>2</b>	1C - 630- AL ARMOURED	500	14000

**PACKAGE- LT XLPE POWER CABLE (MAIN SUPPLY)- ANNEXURE II**

**PROJECT-1 X 660 MW PANKI TPP**

<b>S. No.</b>	<b>Item Description</b>	<b>Drum Length ( METERS)</b>	<b>Quantity (METERS)</b>
<b>(C)</b>	<b>1.1KV, Cu conductor, XLPE insulated, Galvanised Steel Round Wire Armoured for multi-core cables (Non Magnetic Hard drawn Aluminium Round Wire Armoured conforming to H4 grade for single core cables), INNER SHEATH: Extruded HRPVC compound conforming to type ST2 of IS: 5831 for multicore cable &amp; no inner sheath for single core cables, OVERALL SHEATH: Extruded FRLS HRPVC compound conforming to type ST2 of IS: 5831 &amp; black in colour.</b>		
<b>1</b>	1C - 16- CU ARMOURED	500	9000
<b>2</b>	2C - 2.5- CU ARMOURED	1000	32500
<b>3</b>	3C - 2.5- CU ARMOURED	1000	69000

**NOTES :**

- 1) The standard drum length shall be 500/1000 meters as indicated above. Tolerance on individual drum length shall be  $\pm 5\%$ .
- 2) Overall tolerance on total dispatched quantity of each size shall be (-) 2% and (+) 0% except where the total ordered quantity is one single drum length of 500/1000m, in which case it shall be -5% to 0%. Cables consumed for testing and inspection shall be to bidder's account.
- 3) For each individual cable size, one short length of not less than 200m may be accepted only in the final drum length to complete the supply (except where the total ordered quantity is one single drum length of 500/1000m). The overall tolerance limits stipulated above shall continue to apply (in case short lengths are accepted).
- 4) In case of the quantities cleared by BHEL for manufacturing are manufactured and offered for inspection by successful bidder in more than one batch, BHEL reserves the right to witness type testing on all batches without any price implications.
- 5) Unit price of cables quoted by bidder shall be inclusive of type test charges. No separate charges shall be payable for type tests.

**PACKAGE- LT XLPE POWER CABLE (MANDATORY SPARES) -ANNEXURE II****PROJECT-1 X 660 MW PANKI TPP**

<b>S. No.</b>	<b>Item Description</b>	<b>Drum Lengh</b>	<b>Quantity</b>
<b>(A)</b>	<b>1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round/Formatted Wire Armoured for multi-core cables, INNER SHEATH: Extruded HRPVC compound conforming to type ST2 of IS: 5831 for multicore cable, OVERALL SHEATH: Extruded FRLS HRPVC compound conforming to type ST2 of IS: 5831 &amp; black in colour.</b>		
<b>1</b>	2C - 16- AL ARMoured	500	2000
<b>2</b>	2C - 25- AL ARMoured	500	1000
<b>3</b>	2C - 95- AL ARMoured	500	500
<b>4</b>	3C - 16- AL ARMoured	500	3500
<b>5</b>	3C - 50- AL ARMoured	500	1500
<b>6</b>	3C - 95- AL ARMoured	500	1500
<b>7</b>	3C - 185- AL ARMoured	500	1000
<b>8</b>	3C - 300- AL ARMoured	500	1000
<b>9</b>	3.5C - 50- AL ARMoured	500	2500
<b>10</b>	3.5C - 185- AL ARMoured	500	1500
<b>11</b>	4C - 16- AL ARMoured	500	3000
<b>(B)</b>	<b>1.1KV, Al conductor, XLPE insulated, Galvanised Steel Round Wire Armoured for multi-core cables, (Non Magnetic Hard drawn Aluminium Round Wire Armoured conforming to H4 grade for single core cables)INNER SHEATH: Extruded HRPVC compound conforming to type ST2 of IS: 5831 for multicore cable &amp; no inner sheath for single core cables, OVERALL SHEATH: Extruded FRLS HRPVC compound conforming to type ST2 of IS: 5831 &amp; black in colour.</b>		
<b>1</b>	1C - 400- AL ARMoured	500	1500
<b>2</b>	1C - 630- AL ARMoured	500	4500
<b>(C)</b>	<b>1.1KV, Cu conductor, XLPE insulated, Galvanised Steel Round Wire Armoured for multi-core cables (Non Magnetic Hard drawn Aluminium Round Wire Armoured conforming to H4 grade for single core cables), INNER SHEATH: Extruded HRPVC compound conforming to type ST2 of IS: 5831 for multicore cable &amp; no inner sheath for single core cables, OVERALL SHEATH: Extruded FRLS HRPVC compound conforming to type ST2 of IS: 5831 &amp; black in colour.</b>		

<b>1</b>	1C - 16- CU ARMoured	500	2000
<b>2</b>	2C - 2.5- CU ARMoured	1000	13500
<b>3</b>	3C - 2.5- CU ARMoured	1000	17500

**NOTES :**

- 1) The standard drum length shall be 500/1000 meters as indicated above. Tolerance on individual drum length shall be  $\pm 5\%$ .
- 2) Overall tolerance on total dispatched quantity of each size shall be (-) 2% and (+) 0% except where the total ordered quantity is one single drum length of 500/1000m, in which case it shall be -5% to 0%. Cables consumed for testing and inspection shall be to bidder's account.
- 3) For each individual cable size, one short length of not less than 200m may be accepted only in the final drum length to complete the supply (except where the total ordered quantity is one single drum length of 500/1000m). The overall tolerance limits stipulated above shall continue to apply (in case short lengths are accepted).
- 4) In case of the quantities cleared by BHEL for manufacturing are manufactured and offered for inspection by successful bidder in more than one batch, BHEL reserves the right to witness type testing on all batches without any price implications.
- 5) Unit price of cables quoted by bidder shall be inclusive of type test charges. No separate charges shall be payable for type tests.

## Annexure III to Delivery Schedule

Sl. No.	Package Code	Package name	DEPTT	BHEL Drawing No	Drawing Title	Primary/Secondary	Drg Sch for Vendors	Standard Delivery Terms for Supply Portion and Mandatory Spares
1	507-28000-A	LT XLPE POWER CABLES	ELECT	PE-V0-426-507-E113	CROSS SECTION DRGS.	Primary	R-0 within 14 days from PO & subsequent revisions within 10 days of comments received from BHEL.	Delivery completion for PO Quantity shall be "180" days from PO date. Supplier to complete the package engineering in time and get the applicable engineering Drgs. /docs approved from BHEL/End Customer before start of manufacturing and supply. BHEL shall furnish comments / approval on each submission / re-submission of drawing/documents within 18 days from receipt of same.
2	507-28000-A	LT XLPE POWER CABLES	ELECT	PE-V0-426-507-E913	QUALITY PLAN	Primary		
3	507-28000-A	LT XLPE POWER CABLES	ELECT	PE-V0-426-507-E111	TECHNICAL DATA SHEET	Primary		
4	507-28000-A	LT XLPE POWER CABLES	ELECT	PE-V0-426-507-E114	TYPE TEST CERTIFICATES	Secondary	Within 1 week after conduction of type test	Subsequent Lots, if any (released within validity of contract under Qty. variation. clause): Supply within "90" days from the date of Quantity clearance by BHEL.  Mandatory Spares:- Within 04 months from clearance by BHEL (clearance shall be given within validity of contract).

**Notes :-**

- The end period specified is for completion of the deliveries. Deliveries to start progressively so as to meet the completion schedule.
- The delivery conditions specified are for contractual LD purposes, however BHEL may ask for early deliveries without any compensation thereof.
- Drawings /documents submission/re-submission schedule shall be as indicated above shall be used for progress monitoring purpose and required course correction, if any. Wherever schedule of drawings/documents submission / re-submission is stipulated in the Technical Specifications, same shall be superseded by delivery specified above/NIT.

**4. Delivery Extension:Extension of contractual delivery time**

Delivery time mentioned in the NIT includes Engineering completion time (time for drawing/document submission/resubmission by the vendor and review/approval of the same by the BHEL\End customer), manufacturing, inspection, Packing and dispatch time. Due diligence is to be exhibited by the vendor to ensure timely completion of engineering and supply.

During the execution of the contract, time loss occurred owing to the reason attributable to BHEL besides force majeure shall be considered for delivery time extension to the vendor as given below:-

- Delay in providing comments/ approval on Primary drawing/documents beyond 18 days or as specified in drawing/ documents submission/re-submission schedule enclosed with NIT for each iteration.
- Time Loss in approval of the drawing/document as a result of increase in the iteration not attributable to the vendor as certified by BHEL. Time extension equivalent to the resubmission time specified in the NIT and consequential increase in the approval time shall be applicable.
- Delay in providing engineering input/material by BHEL.
- Delay in deputing inspector for inspection and delay in release of MDCC in line with GCC/ GEM ATC terms.
- Any HOLD put by BHEL for whatever reasons.

Note: No delay analysis will be applicable if supply is completed within delivery schedule as specified in Purchase order.

**5. Validity of contract:**

5.a) Validity of the contract for main supply including subsequent lots:

Contract shall be valid for 730 days from the PO date. However, delay at vendor's end (if any) shall be added to the validity period and contract validity shall get extended by the delay period at vendor's end.

For example: Delivery period: A (in days)

Delay at vendor's end: B (in days)

Contract validity: 730+B (in days)

Note: B is the Vendor delay days beyond contractual delivery period "A" / extended delivery period owing to time taken by BHEL at point no. 3 above.

5.b)Subsequent lots including quantity variation released within contractual validity period, to be supplied by vendor/supplier at PO rates, terms and condition.

5.c)Execution of the contract beyond contract validity period or PO delivery date whichever is later shall be decided on mutual consent basis.

## **Annexure IV**

**An undertaking regarding Model Clauses on company letter head only**

**(To be provided along with bid)**

Reference: NIT No.-

Package: - LT XLPE Power Cables

Project: 1x 660 MW Panki TPS

### **TO WHOM SO IT MAY CONCERN**

This is with reference to Ministry of Finance circular dated 23.07.20, 08.02.21,06.09.22 & 23.02.23 reg. restriction under rule 144 (xi) of GFR.

"I have read the clause regarding restrictions on procurement from a bidder of a country which shares a land border with India. I hereby certify that M/s ..... (bidder name) is not from such a country and is eligible to be considered/participate in tender enquiry for against aforesaid tender enquiry.

Sign & Signature (Not below Director/owner of the company)

Date:

Place:

**ANNEXURE V**  
**1x 660 MW Panki TPS**  
**LT XLPE POWER CABLES**  
**Letter head of Company**

Ref.....

Date.....

To,  
Bharat Heavy Electricals Limited  
PEM, PPEI Building, Plot No 25,  
Sector -16A, Noida (U.P) -201301

**Subject: - Certification regarding local content**

Reference: Tender Enquiry No.....

Name of Package: LT XLPE POWER CABLES

Dear Sir,

We hereby certify that items offered by us of LT XLPE POWER CABLES for 1x 660 MW Panki TPS .....(minimum % of local content) meets the requirement of minimum local content in line with applicable clause of Make In India and the Public Procurement (Preference to Make in India), Order 2017 dated-15.06.2017, 28.05.2018 & 29.05.2019, 04.06.20, 16.09.20 and subsequent order dated 16.11.21.

We further confirm that details of location at which the local value addition is made will be our registered works at .....(address of the works)


Yours very truly

..... (authorized signatory of company)

..... (firm name)

authorized signatory  
of company





1356268/2023/PS-PEM-EL

	<b>PRE-QUALIFICATION REQUIREMENTS OF LT XLPE POWER CABLE FOR 1X660MW PANKI TPS</b>	PE-PQ-426-507-E012
		REVISION NO. 0 DATE 02.03.2023
		SHEET NO. 1 OF 1

<b>ITEMS</b> : LT XLPE POWER CABLE	
<b>SCOPE</b> : Supply : YES; Erection & Commissioning : NO;	
1.0	Vendor should be a manufacturer of LT Power cables.
2.0	Availability of test reports of tests on LT XLPE FRLS Power cables to establish in-house capability to carry out all routine, type & acceptance tests as per relevant IS / International Standards (except UV radiation & hydrolytic stability test which can be conducted at Govt. Lab / Govt. approved Independent lab).
3.0	Capacity of manufacturing 100 km of LT Power cables per month.
4.0	Manufactured and supplied at least LT Power cable of minimum 240sq.mm for 3/3.5 cable.
5.0	Manufactured and supplied at least one (1) km of FRLS cables as on 02.11.15.
6.0	Manufactured and supplied 1.1kV or higher-grade power cable of minimum 630sq.mm conductor size as on 02.11.15.
7.0	Manufactured and supplied at least 100 km of aluminium conductor, XLPE insulated, PVC sheathed power cables of 1.1kV or higher grade in one single contract as on 02.11.15
8.0	Manufactured and supplied at least 100 km of aluminium conductor, PVC insulated, PVC sheathed power cables of 1.1kV or higher grade in one single contract as on 02.11.15
9.0	Minimum two (2) nos. purchase orders for LT XLPE Power cable shall be submitted which should not be more than five (5) years old from the date of techno- commercial bid opening for establishing continuity in business.

**NOTES:**

1. Consideration of bidder's offer is subject to NTPC approval.
2. Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.
3. Notwithstanding anything stated above, BHEL reserves the light to assess the capabilities and capacity of the bidder/collaborators to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL.
4. After satisfactory fulfillment of all the above criteria! requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.
5. PQR 5, 6, 7 and 8 are in line with end customer proveness criteria.

PREPARED BY  NAME: PRIYANKA GUPTA DESIGNATION: MANAGER	CHECKED BY  NAME: HEMA KUSHWAHA DESIGNATION: SR. MANAGER	REVIEWED BY  NAME: PRAVEEN DUTTA DESIGNATION: AGM	APPROVED BY  NAME: DEBASIS BARATH DESIGNATION: DH-ELECT (AGM)
---	---	--	--

**VOLUME-II**

1 X 660 MW PANKI TPS

**TECHNICAL SPECIFICATION**

**FOR**

**LT XLPE POWER CABLE**

**SPECIFICATION NO: PE-TS-426-507-E002**

**REVISION: 00**



**BHARAT HEAVY ELECTRICALS LIMITED**

**POWER SECTOR**

**PROJECT ENGINEERING MANAGEMENT**

**NOIDA, UP (INDIA) – 201301**

1356258/2023/PS-PEM-EL



**TECHNICAL SPECIFICATION FOR  
LT XLPE POWER CABLES**

SPECIFICATION NO. PE-TS-426-507-E002

VOLUME II

SECTION

REVISION:00

DATE: 02.03.2023

SHEET 1 OF 1

**CONTENTS**

<b><u>S. NO.</u></b>	<b><u>DESCRIPTION</u></b>	<b><u>NO. OF SHEETS</u></b>
1.	CONTENTS	01
2.	SECTION – I	
	COMPLIANCE CERTIFICATE	01
	SPECIFIC TECHNICAL REQUIREMENTS	01
	DATA SHEET-A	03
	DATA SHEET-C	03
3.	SECTION – II	
	STANDARD TECHNICAL SPECIFICATION	02
	QUALITY PLAN (ALONGWITH ANNEXURE A TO QP)	15
	<b>TOTAL NO. OF SHEETS=</b>	<b>29</b>
	<b>(INCLUDING COVER/ SEPARATOR SHEETS)</b>	

1356258/2023/PS-PEM-EL



TECHNICAL SPECIFICATION FOR  
LT XLPE POWER CABLES

SPECIFICATION NO. PE-TS-426-507-E002

VOLUME II

SECTION I


REVISION00

DATE: 02.03.2023

**SECTION – I**

**SPECIFIC TECHNICAL REQUIREMENTS**

1356258/2023/PS-PEM-EL

	<b>TECHNICAL SPECIFICATION FOR LT XLPE POWER CABLES</b>	SPECIFICATION NO.PE-TS-426-507-E002	
		VOLUME II	
		SECTION I	
		REVISION :00	DATE:02.03.2023
		SHEET 1 of 1	

### COMPLIANCE CERTIFICATE

The bidder shall confirm compliance to the following by signing/ stamping this compliance certificate and furnishing same with the offer.

1. The scope of supply, technical details, construction features, design parameters etc. shall be as per technical specification & there are no exclusion/ deviation with regard to same.
2. There is no deviation with respect to specification other than those furnished in the 'schedule of deviations'.
3. Only those technical submittals which are specifically asked for in NIT to be submitted at tender stage shall be considered as part of offer. Any other submission, even if made, shall not be considered as part of offer.
4. Any comments/ clarifications on technical/ inspection requirements furnished as part of bidder's covering letter shall not be considered by BHEL, and bidder's offer shall be construed to be in conformance with the specification.
5. Any changes made by the bidder in the price schedule with respect to the description/ quantities from those given in 'BOQ-Cum-Price schedule' of the specification shall not be considered (i.e., technical description & quantities as per specification shall prevail).

-----  
BIDDER'S STAMP & SIGNATURE

1356258/2023/PS-PEM-EL



**TECHNICAL SPECIFICATION FOR  
LT XLPE POWER CABLES**

SPECIFICATION NO. PE-TS-426-507-E002

VOLUME II

SECTION I

REVISION 00

DATE: 02.03.2023

SHEET 1 OF 1


## 2.0 SCOPE OF ENQUIRY

- 2.1 Design, Manufacture, Inspection and Testing at Manufacturer's works, proper packing and delivery to site of LT XLPE Power Cable conforming to this specification.
- 2.2 It is not the intent to specify herein all the details of design & manufacture of material. However, the material shall conform in all respects to high standard of design, engineering & workmanship and shall be capable of performing in continuous commercial operation at site condition.
- 2.3 Technical requirements of LT XLPE Power Cable are indicated in Data Sheet-A & Section-II.
- 2.4 The stipulation of Data Sheet-A shall prevail in case of any conflict between the stipulations of Data Sheet-A & Section-II.

## 3.0 BILL OF QUANTITIES

The bidder to quote for items as per price schedule attached with NIT.

1356258/2023/PS-PEM-EL

	DOCUMENT TITLE		SPECIFICATION NO. PE-TS-426-507-E002	
	<b>TECHNICAL SPECIFICATION FOR LT XLPE POWER CABLES</b>		VOLUME II	
			SECTION I	
	REVISION 00	DATE: 02.03.2023		
			SHEET 1 OF 3	

**DATA SHEET-A**

1.0	Type of Cable	Flame Retardant Low Smoke halogen (FR-LSH)	
2.0	Standard applicable in general (Latest amendment to be referred if any)	IS:7098 (Part-1), IS:8130, IS:5831, IS:10810, IS:3975, ASTM D:2843, ASTM D:2863, IEC-754-1, IEC:60332 (Part-1), IEC:60332-3-23, IEEE:60383	
3.0	Voltage Grade	1.1kV	
4.0	Number of cores, cross sectional area of conductors and quantities	As per BOQ-Cum-Price Schedule	
5.0	<b>FAULT CHARACTERISTICS</b>		
	Fault Level	50kA RMS	
	Fault Clearing Time	1.0 sec – for 630 Sq mm cross section cables 0.5 sec – for 400 Sq mm cross section cables 0.25 sec – for 300 Sq mm cross section cables 0.2 sec – for 240 Sq mm cross section cables	
6.0	<b>CONDUCTOR</b>		
(a)	Material	Aluminium	Copper
	Grade and Class	Stranded, Compacted, H2, Class 2	Stranded, plain annealed high conductivity, Class 2
(b)	Standard Applicable	IS: 8130	
(c)	Shape	Aluminium	Copper
		Circular/ Shaped – as per IS	Circular – for all sizes
(d)	Min. number and diameter of strands for main and neutral conductor [Neutral conductor cross section w.r.t main conductor shall be as per Table-2 of IS: 7098 (Part-1)]	As per Table-2 of IS: 8130	
7.0	<b>INSULATION</b>		
(a)	Material	Cross-Linked Polyethylene (XLPE)	
(b)	Standard Applicable	IS: 7098 (Part-1)	
(c)	Continuous withstand temperature	90°C	
(d)	Short-circuit withstand temperature	250°C	
(e)	Method of application	By extrusion; sleeve extrusion not permitted.	
(f)	Nominal Thickness of insulation	As per IS: 7098 (Part-1)	
8.0	<b>CORE IDENTIFICATION</b>	Colour coding as per IS-7098 (Part-I)	
9.0	<b>INNER SHEATH</b>		
(a)	Material	Extruded HRPVC Type ST-2	
(b)	Standard Applicable	IS: 7098 (Part-1) & IS: 5831	
(c)	Colour	Black	
(d)	Whether FR-LSH	Yes	
(e)	Inner sheath applicable for single core cable	No	

1356258/2023/PS-PEM-EL



DOCUMENT TITLE

**TECHNICAL SPECIFICATION FOR LT  
XLPE POWER CABLES**

SPECIFICATION NO. PE-TS-426-507-E002

VOLUME II

SECTION I

REVISION 00

DATE: 02.03.2023

SHEET 2 OF 3

(f)	Fillers	Acceptable
(g)	Material of fillers (if permitted)	Same as inner sheath (Material of filler to be compatible with that of inner sheath)
(h)	Method of application	
(1)	Multi-core cables:	
(i)	With fillers	Pressure/ Vacuum extruded
(ii)	Without fillers	Pressure extruded
(2)	Single-core cables:	<b>NOT APPLICABLE</b>
10.0	<b>ARMOUR</b>	
(a)	Applicable	YES
(b)	Material:	
(i)	Single core cables	Non Magnetic Hard drawn Aluminium Round Wire H4 grade to IS: 8130
(ii)	Multi-core cables	Galvanised Steel Round/ Formed Wire Armoured for multi-core cables
(iii)	Standard Applicable	Dimension as per IS: 7098 (Part-1) Table-6 and tolerance on dimension as per IS:3975
(c)	Minimum Coverage	90%
(d)	Gap between armour wires	Shall not exceed one armour wire space (No cross-over/ over-riding)
(e)	Breaking load of joint	95 % of normal armour
(f)	Paint on joint	Zinc rich paint shall be applied on armour joint surface of G.S. wire / formed wire
11.0	<b>OUTERSHEATH</b>	
(a)	Material	HRPVC Type ST2 as per IS: 5831
(b)	Colour	Black
(c)	Whether FR-LSH	Yes
(d)	Method of application	Extruded
(e)	Thickness of outer sheath	As per Table-8 of IS: 7098 (Part-1)
(f)	Marking	<p>Cable size (cross section area and no. of cores), voltage grade and Reference IS @ 1m (by embossing)</p> <p>Word "XLPE", "FR-LSH" @ 1m (by embossing)</p> <p>Manufacturer's name and/ or trade name, and year of manufacture @ 1m (by embossing)</p> <p>'BHEL-PEM' and 'CUSTOMER' Name @1m (by embossing)</p> <p>Progressive sequential marking of length of the cable in metres @ 1m (by embossing/ printing)</p> <p><i>Further customer specific marking requirement (if any) shall be informed later.</i></p> <p>The embossing shall be progressive, automatic, in line and marking shall be legible and indelible.</p>
12.0	<b>FR-LS CHARACTERISTICS</b>	
(a)	Oxygen index	Min 29 (As per IS 7098-I /ASTMD 2863/)

1356258/2023/PS-PEM-EL



DOCUMENT TITLE

**TECHNICAL SPECIFICATION FOR LT  
XLPE POWER CABLES**

SPECIFICATION NO.,PE-TS-426-507-E002

VOLUME II

SECTION I


REVISION 00

DATE: 02.03.2023

SHEET 3 OF 3

(b)	Temperature index	Min. 250°C(As per IS 7098-I /ASTMD 2863)
(c)	Acid gas generation	Max. 20% by weight (As per IS 7098-I /IEC-60754-1)
(d)	Smoke density rating	Max. 60% (As per IS 7098-I /ASTM D 2843)
(e)	<b>Flammability Test</b>	
(i)	Flammability test for single cable	YES As per IEC-60332 Part-1
(ii)	Flammability test for bunched cables	YES As per IEC-60332 Part-3-23, CAT-B
(iii)	Flammability test as per IEEE: 60383	YES
(iv)	As per Swedish Chimney test SEN-SS-424-1475-F3	YES
(f)	<b>Special Tests</b>	
I.	Hydrolytic Stability Test	No/ Refer Cl. 3.4 of Sec-II
II.	Ultraviolet Radiation Test	No/ Refer Cl. 3.4 of Sec-II
13.0	<b>Anti-rodent and Termite repulsion Test</b>	YES
14.0	<b>Anti-Fungal Test</b>	No
15.0	<b>TOLERANCE ON OUTER DIAMETER</b>	+ 2mm
16.0	<b>MINIMUM BENDING RADIUS</b>	
(a)	Single core cables	15 x O.D.
(b)	Multi core cables	12 x O.D.
17.0	<b>SAFE PULLING FORCE</b>	
(a)	Aluminium conductor cable	30 N/ sq. mm.
(b)	Copper conductor cable	50 N/ sq. mm.
18.0	<b>CABLE DRUMS</b>	
(a)	Type of Drum	Wooden as per IS 10418
(b)	Standard drum length	500m (±) 5% / 1000m (±) 5%. (as specified in BOQ-Cum-Priced Schedule)
(c)	Painting	Entire surface to be painted
(d)	Construction details	<i>Clause no 4.2 of Section-II of this technical specification</i>
(e)	Particular details on Drum	<i>Clause no 4.3 of Section-II of this technical specification. Further customer specific marking requirement (if any) shall be informed later.</i>
19.0	Sea Worthy packing	No

1356258/2023/PS-PEM-EL


	DOCUMENT TITLE	SPECIFICATION NO. PE-TS-426-507-E002
	<b>TECHNICAL SPECIFICATION FOR LT XLPE POWER CABLES</b>	VOLUME II
		SECTION I
		REV NO.00 DATE:02.03.2023
	SHEET 1 OF 3	

**DATASHEET C****GUARANTEED TECHNICAL PARTICULARS  
(TO BE SUBMITTED BY SUCCESSFUL BIDDER)**

S.No.		Unit	Description
<b>A</b>	<b>GENERAL</b>	-	
1	Name of manufacturer	-	
2	Place of Manufacture	-	
3	Current rating of cables conforms to	-	
4	Short circuit rating conforms to	-	
5	Formula for calculating short circuit current for different duration	-	
6	Permissible conductor temperature		
	(a) Maximum continuous rating	deg. C	
	(b) Short circuit rating	deg. C	
7	(a) Installation Conditions at site		
	i) Ambient air temperature	deg. C	
	ii) Ground temperature	deg. C	
	iii) Depth of laying of cables buried in ground	cm	
8	CHARACTERISTICS OF FRLS SHEATH		
	(a) Oxygen index	%	AS PER DATA SHEET-A
	(b) Temperature index	deg. C	
	(c) Acid gas generation	%	
	(d) Smoke density rating	%	
9	CABLE DRUMS		
	(a) Type & construction	-	
	(b) Standard drum length	Mtr	
	(c) Tolerance on drum length	%	
<b>B</b>	<b>INFORMATION TO BE FILLED IN FOR EACH SIZE CABLE IN THE FORM OF TABLE</b>		
1	No. of cores x size	No. x sq.mm	
2	Voltage grade (Uo/U)	kV	
3	Base current ratings (*) based on SI. (A) 7.0		
	(a) In air	Amp	
	(b) In ground	Amp	
	(c) ducts	Amp	


NAME OF VENDOR			SEAL	REV.	
NAME	SIGNATURE	DATE			

1356258/2023/PS-PEM-EL

	DOCUMENT TITLE	SPECIFICATION NO. PE-TS-426-507-E002
	<b>TECHNICAL SPECIFICATION FOR LT XLPE POWER CABLES</b>	VOLUME II
		SECTION I
		REV NO. 00 DATE 02.03.2023
	SHEET 2 OF 3	

4	Short circuit rating for 1 sec duration	kA	
5	(a) D.C. resistance of conductor at 20 deg C (main / neutral)	ohm/km	
	(b) A.C. resistance of conductor at 90 deg. C (main / neutral)	ohm/km	
	(c) Reactance of cable at Normal frequency	ohm/km	
	(d) Electrostatic capacitance of cable at normal frequency	μF/km	
6	CONDUCTOR		
	(a) Material type	-	AS PER DATA SHEET-A
	(b) Grade	-	
	(c) No & dia of wires in each core before stranding	no x mm	
	(d) Shape	-	
7	INSULATION		
	(a) Material	-	Cross-Linked Polyethylene(XLPE)
	(b) Nominal thickness (main / neutral)	mm	
	(c) Minimum thickness (main / neutral)	mm	
	(d) Minimum volume resistivity at 27 deg. C	Ohm-cm	
	(e) Minimum volume resistivity at 90 deg. C	Ohm-cm	
8	INNERSHEATH		
	(a) Material	-	Extruded HRPVC Type ST-2
	(b) Whether FRLS	-	YES
	(c) Thickness (min.)	mm	
	(d) Method of application for multi-core cables	-	
	(e) Type and shape of fillers (if used)	-	
	(f) Colour	-	BLACK
9	ARMOUR		
	(a) Material	-	YES
	(b) Type of armour	-	
	(c) Size/ dimensions (Nominal dia of wire)	mm	
	(d) Minimum no. of round / formed wires	No.	
	(e) Minimum coverage	%	
	(f) Gap between armour wire/strip	-	
	(g) Breaking load of joint	-	
	(h) Maximum resistivity of GS formed / Round wire	Ohm-cm	
	(i) Maximum resistivity of Aluminium round wire	Ohm-cm	
10	OUTERSHEATH		
	(a) Material	-	Extruded HRPVC Type ST-2
	(b) Whether FRLS	-	YES
	(c) Minimum thickness	mm	
NAME OF VENDOR		SEAL	REV.
NAME	SIGNATURE		DATE

1356258/2023/PS-PEM-EL

	DOCUMENT TITLE  <b>TECHNICAL SPECIFICATION FOR LT XLPE POWER CABLES</b>	SPECIFICATION NO. PE-TS-426-507-E002	
		VOLUME II	
		SECTION I	
		REV NO.00	DATE 02.03.2023
SHEET 3		OF	3

	(d) Colour	-	
	(e) Method of application	-	
11	DIAMETERS		
	(a) Diameter of insulated conductor	mm	
	(b) Cable diameter under armour	mm	
	(c) Cable diameter over armour	mm	
	(d) Overall diameter of cable	mm	
	(e) Tolerance on overall diameter	(±) mm	
12	Ovality	mm	
13	Minimum bending radius	x O.D	
14	Safe Pulling Force	N/mm <sup>2</sup>	
15	Weight of cable	kg./km	
16	Dimension of drum	mm	
17	Shipping weight (approx.)	kg	
18	Cable marking on outer sheath	-	
19	Marking on drum	-	

(\*) For single core cables, the continuous current rating shall be furnished separately for armour earthed at one end and at both ends.

NAME OF VENDOR			SEAL	REV.	
NAME	SIGNATURE	DATE			

1356258/2023/PS-PEM-EL

**TECHNICAL SPECIFICATION FOR  
LT XLPE POWER CABLES**

SPECIFICATION NO. PE-TS-426-507-E002

VOLUME II

SECTION II

REVISION .00

02.03.2023

**SECTION-II****STANDARD TECHNICAL REQUIREMENTS**

1356258/2023/PS-PEM-EL



## TECHNICAL SPECIFICATION FOR LT XLPE Power Cable

SPECIFICATION NO.:PE-TS-426-507-E002

VOLUME II

SECTION II

REVISION 00

DATE:02.03.2023

Sheet 1 of 2

### 1.0 CODES AND STANDARDS

- 1.1 The material shall comply with all currently applicable safety codes and statutory regulations of India as well as of the locality where the material is to be installed.
- 1.2 The design, material, construction, manufacture, inspection and testing of LT XLPE POWER Cable shall conform to the latest revision of relevant standards as per Data Sheet-A.
- 1.3 In case of conflict between the applicable reference standard and this specification, this specification shall govern.

### 2.0 TECHNICAL REQUIREMENTS

- 2.1 LT XLPE POWER Cable shall be supplied as per technical particulars specified in Data Sheet – A.

### 3.0 QUALITY ASSURANCE, TESTING & INSPECTION

- 3.1 Bidder shall confirm compliance with the BHEL Standard Quality Plan (PE-QP-999-507-E002, Rev-01) as attached with the specification without any deviations. At contract stage (project specific), the successful bidder shall submit the same QP for BHEL/ ultimate customer's approval. In case bidder has reference QP agreed with ultimate customer, same can be submitted for specific project after award of contract for BHEL/ultimate customer's approval. There shall be no commercial implication to BHEL on account of minor changes in QP during contract stage.
- 3.2 All materials shall be procured, manufactured, inspected and tested by vendor/ sub-vendor as per approved quality plan.
- 3.3 Type testing, routine / acceptance testing and special testing requirements shall be as per Annexure –A to QAP. Charges for all these tests for all the equipments & components shall be deemed to be included in the bid price (except UV Radiation & Hydraulic Stability test).
- 3.4 The charges of UV Radiation test & Hydrolytic Stability test (if applicable) shall be reimbursed extra at actual against original money receipt of Govt. Lab. (CPRI/ ERDA etc).
- 3.5 Cost of cables consumed for testing shall be to bidder's account.

### 4.0 PACKING

- 4.1 Cables shall be supplied in non-returnable drums. Material of cable drums shall be wooden.
- 4.2 For wooden drums, all wooden parts shall be manufactured from seasoned wood treated with copper naphthenates / zinc naphthenates (refer IS: 401) and anti-termite. The surface of the drum and the outer most cable layer shall be covered with water proof cover. Both the ends of the cables shall be properly sealed with heat shrinkable PVC/ rubber caps secured by 'U' nails so as to eliminate ingress of water during transportation, storage and erection. Dimensions of wooden drums shall be as per IS 10418. All ferrous parts shall be treated with suitable rust protective

1356258/2023/PS-PEM-EL



**TECHNICAL SPECIFICATION FOR  
LT XLPE Power Cable**

SPECIFICATION NO:PE-TS-426-507-E002

VOLUME II

SECTION II

REVISION00

DATE:02.03.2023

Sheet 2 of 2

finish or coating to avoid rusting during transit and storage. BIS certification mark shall be stamped on each cable drum.

- 4.3 Each drum shall carry manufacturer's name, purchaser's name, address and contract no., item no. & type, size & length of cable and net gross weight stencilled on both sides of drum. A tag containing same information shall be attached to the leading end of the cable. An arrow & suitable accompanying wording shall be marked on one end of the reel indicating the direction in which it should be rolled.

**MANUFACTURER/ BIDDER/ SUPPLIER NAME & ADDRESS**  
**CUSTOMER :**  
**PROJECT :**  
**ITEM: LT XLPE POWER CABLE**

**STANDARD QUALITY PLAN**  
**SPEC. NO. :**  
**QP NO.:** PE-QP-999-507-E002, REV 02.  
**PO NO.:**

**DATE:**  
**SECTION: II**

**SHEET 1 OF 12**

SI. No.	COMPONENTS & OPERATIONS	CHARACTERISTICS	CLAS S	TYPE OF CHECK	QUANTUM OF CHECK	REFERENCE DOCUMENT	ACCEPTANC E NORMS	FORMAT OF RECORD	AGENCY	REMARKS	
1	2	3	4	5	6	7	8	9	**		
					M	C/N		D	M	C	N

**1.0 RAW MATERIALS**

**1.1 Aluminium /Copper Rods**

**GENERAL :**

1. Physical properties	MA	Physical Tests	Sample/ Batch	Sample / Batch	IS:8130 (Al), IS:613 (Cu)	IS:8130 (Al), IS:613 (Cu)	Test Cert.	P/ V	-
2. Elec. Properties <td>MA</td> <td>Electrical Tests <td>Sample/ Batch <td>Sample / Batch <td>-do-</td> <td>-do-</td> <td>-do-</td> <td>P/ V</td> <td>-</td> </td></td></td>	MA	Electrical Tests <td>Sample/ Batch <td>Sample / Batch <td>-do-</td> <td>-do-</td> <td>-do-</td> <td>P/ V</td> <td>-</td> </td></td>	Sample/ Batch <td>Sample / Batch <td>-do-</td> <td>-do-</td> <td>-do-</td> <td>P/ V</td> <td>-</td> </td>	Sample / Batch <td>-do-</td> <td>-do-</td> <td>-do-</td> <td>P/ V</td> <td>-</td>	-do-	-do-	-do-	P/ V	-

**SPECIFIC CHECKS:**

a) Make	MA	Verify	100%	100%	Manufacturer approved source	Manufacturer approved source	Test Cert.	P	V	-
b) Grade <td>MA</td> <td>-do-</td> <td>-do-</td> <td>-do-</td> <td>IS:8130 (Al), IS:613 (Cu)</td> <td>IS:8130 (Al), IS:613 (Cu)</td> <td>-do-</td> <td>P</td> <td>V</td> <td>-</td>	MA	-do-	-do-	-do-	IS:8130 (Al), IS:613 (Cu)	IS:8130 (Al), IS:613 (Cu)	-do-	P	V	-
c) Resistivity <td>MA</td> <td>Electrical Tests <td>Manufacturer std.</td> <td>Manufacturer std.</td> <td>IS:613 (Cu), IS:5082 (Al)</td> <td>IS:613 (Cu), IS:5082 (Al)</td> <td>-do-</td> <td>P</td> <td>V</td> <td>-</td> </td>	MA	Electrical Tests <td>Manufacturer std.</td> <td>Manufacturer std.</td> <td>IS:613 (Cu), IS:5082 (Al)</td> <td>IS:613 (Cu), IS:5082 (Al)</td> <td>-do-</td> <td>P</td> <td>V</td> <td>-</td>	Manufacturer std.	Manufacturer std.	IS:613 (Cu), IS:5082 (Al)	IS:613 (Cu), IS:5082 (Al)	-do-	P	V	-

**1.2 XLPE Compound for insulation**


**GENERAL :**

1. Physical properties	MA	Physical Tests	Sample/ Batch	Sample / Batch	IS 7098-I	IS 7098-I	Test Cert.	P	V	-
------------------------	----	----------------	---------------	----------------	-----------	-----------	------------	---	---	---

ENGINEERING				QUALITY			
Prepared by:	Sign & Date	Name	Checked by:	Sign & Date	Name	Reviewed by:	Seal
<i>Manish Shukla</i>	<i>18/09/20</i>	VIKAS KUMAR SINGH	<i>Kunal Gandhi</i>	<i>18/09/20</i>	KUNAL GANDHI	<i>Ritesh Kumar</i>	
Reviewed by:		MANISH SHUKLA	Reviewed by:		RITESH KUMAR JAISWAL		

FOR CUSTOMER REVIEW & APPROVAL			
Doc No:	Sign & Date	Name	Seal
Reviewed by:			
Approved by:			

	<b>MANUFACTURER/ BIDDER/ SUPPLIER NAME &amp; ADDRESS</b>		<b>STANDARD QUALITY PLAN</b>		<b>SPEC. NO. : 16</b>	<b>DATE: 16</b>
	<b>CUSTOMER :</b>		<b>QP NO.: PE-QP-999-507-E002, REV 02.</b>			
	<b>PROJECT:</b>		<b>PO NO.:</b>			
<b>ITEM: LT XLPE POWER CABLE</b>			<b>SYSTEM: CABLE</b>			<b>SECTION: II</b>
<b>SHEET 2 OF 12</b>						

SI. No.	COMPONENTS & OPERATIONS	CHARACTERISTICS	CLASS	TYPE OF CHECK	QUANTUM OF CHECK		REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY			REMARKS
					M	C/N				M	C	N	
1	2	3	4	5	6	7	8	9	*	D	**		

	2. Elec. Properties	MA	Electrical Tests	Sample/ Batch	Sample / Batch	-do-	-do-	✓	P	V	-	
<b><u>SPECIFIC CHECKS:</u></b>												
	a) Make	MA	Verify	100%	100%	Manufacturer approved source	Manufacturer approved source	✓	P/V	V	-	
	b) Type/ Grade	MA	-do-	-do-	-do-	-do-	-do-	✓	P/V	V	-	
	c) Shelf life/ Storage condition	MA	-do-	-do-	-do-	-do-	-do-	✓	P/V	V	-	

<b>1.3</b>	<b>PVC Compound (for sheath)</b>											
<b><u>GENERAL:</u></b>												
	1. Physical properties	MA	Physical Tests	Sample/ Batch	Sample / Batch	IS 5831	IS 5831	✓	P/V	V	-	
	2. Elec. Properties	MA	Electrical Tests	Sample/ Batch	Sample / Batch	-do-	-do-	✓	P/V	V	-	
	3. FRLS Properties (as applicable)	CR	Chemical/ Environ.	Sample/ Batch	Sample / Batch	Approved datasheet	Approved datasheet	✓	P/V	V	-	
<b><u>SPECIFIC CHECKS:</u></b>												

ENGINEERING				QUALITY			
Prepared by:	Sign & Date	Name	Checked by:	Sign & Date	Name	Reviewed by:	Name
	<i>[Signature]</i>	VIKAS KUMAR SINGH	<i>[Signature]</i>	<i>[Signature]</i>	KUNAL GANDHI		
Reviewed by:	Sign & Date	Name	Reviewed by:	Sign & Date	Name	Approved by:	Name
	<i>[Signature]</i>	MANISH SHUKLA	<i>[Signature]</i>	<i>[Signature]</i>	RITESH KUMAR JAISWAL		

FOR CUSTOMER REVIEW & APPROVAL			
Doc No:	Sign & Date	Name	Seal

STANDARD QUALITY PLAN  
 CUSTOMER :  
 PROJECT:

SPEC. NO :  
 QP NO.: PE-QP-999-507-E002, REV 02.  
 PO NO.:

DATE: 17

SYSTEM: CABLE  
 SECTION: II

ITEM: LT XLPE POWER CABLE

SHEET 3 OF 12

SI. No.	COMPONENTS & OPERATIONS	CHARACTERISTICS	CLASS	TYPE OF CHECK	QUANTUM OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY	REMARKS
1	2	3	4	5	6	7	8	9	**	
					M			D	M	
					C/N				C	
									N	

SI. No.	COMPONENTS & OPERATIONS	CHARACTERISTICS	CLASS	TYPE OF CHECK	QUANTUM OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY	REMARKS
1.4	Fillers (as applicable)	a) Make b) Type/ Grade c) Shelf life/ Storage condition	MA	Verify	100%	Manufacturer approved source	Manufacturer approved source	Test Cert.	✓	Fillers material chosen shall be compatible with the temperature rating of the cable and shall have no deleterious effect on any other
			MA	-do-	-do-	Approved datasheet	Approved datasheet	-do-	✓	
			MA	-do-	-do-	Compound Manufacturer	Compound Manufacturer	-do-	✓	
			MA	Verify	100%	Manufacturer approved source	Manufacturer approved source	Test Cert.	✓	
			MA	-do-	-do-	Approved datasheet	Approved datasheet	-do-	✓	
			MA	-do-	-do-	Compound Manufacturer	Compound Manufacturer	-do-	✓	

**BHEL**

ENGINEERING		QUALITY	
Sign & Date	Name	Sign & Date	Name
<i>Manish Shukla</i>	MANISH SHUKLA	<i>Ritesh Kumar</i>	RITESH KUMAR
Prepared by:	Checked by:	Reviewed by:	Checked by:
<i>Manish Shukla</i>	VIKAS KUMAR SINGH	<i>Ritesh Kumar</i>	KUNAL GANDHI
Reviewed by:	Reviewed by:	Reviewed by:	Reviewed by:
<i>Manish Shukla</i>	MANISH SHUKLA	<i>Ritesh Kumar</i>	RITESH KUMAR
			JAI SWAL

**BIDDER/ SUPPLIER**

Sign & Date	Seal

**FOR CUSTOMER REVIEW & APPROVAL**

Doc No:	Sign & Date	Name	Seal
Reviewed by:			
Approved by:			





**MANUFACTURER/ BIDDER/ SUPPLIER NAME & ADDRESS**  
**CUSTOMER :**  
**PROJECT :**  
**ITEM: LT XLPE POWER CABLE**

**SPEC. NO :**  
**QP NO.:** PE-QP-999-507-E002, REV 02.  
**PO NO.:**

**DATE:** 20  
**SHEET 6 OF 12**

**SYSTEM: CABLE SECTION: II**

SI. No.	COMPONENTS & OPERATIONS	CHARACTERISTICS	CLAS S	TYPE OF CHECK	QUANTUM OF CHECK		REFERENCE DOCUMENT	ACCEPTANC E NORMS	FORMAT OF RECORD	AGENCY				REMARKS
					M	C/N				**	D	M	C	
1	2	3	4	5	6	C/N	7	8	9	*	D			

SI. No.	COMPONENTS & OPERATIONS	CHARACTERISTICS	CLAS S	TYPE OF CHECK	QUANTUM OF CHECK	REFERENCE DOCUMENT	ACCEPTANC E NORMS	FORMAT OF RECORD	AGENCY	REMARKS
2.2	Stranding of wires	3. % of Elongation	MA	Mechanical	-do-	IS 8130	IS 8130	-do-	✓	P V -
		1. No. of wires	MA	Counting	Plant Mfg. Std.	Appd. Datasheet	Appd. Datasheet	Inspection Report / Test report	✓	P V -
		2. Resistance	CR	Electrical	-do-	-do-	-do-	-do-	-do-	P - -
		3. Sequence, lay length & Direction	MA	Visual, Meas.	One Sample of each size/ lot	Mfrs Std.	Mfrs Std.	-do-		P - -
		4. Surface Finish	MA	Visual	100%	Surface shall be smooth	Surface shall be smooth	-do-		P - -
		5. Dimension	MA	Measurement	One Sample of each size/ lot	Appd. Datasheet	Appd. Datasheet	-do-		P - -
2.3	Core Insulation (XLPE) (No repair permitted)									

**BHEL**

ENGINEERING			QUALITY		
Sign & Date	Name	Checked by:	Sign & Date	Name	
<i>[Signature]</i>	VIKAS KUMAR SINGH	<i>[Signature]</i>		KUNAL GANDHI	
<i>[Signature]</i>	MANISH SHUKLA	Reviewed by:	<i>[Signature]</i>	RITESH KUMAR JAISWAL	

18/10/20

**BIDDER/ SUPPLIER**

Sign & Date  
Seal

**FOR CUSTOMER REVIEW & APPROVAL**

Doc No:  
Sign & Date  
Name  
Seal

Reviewed by:  
Approved by:



**MANUFACTURER/ BIDDER/ SUPPLIER NAME & ADDRESS**  
**CUSTOMER :**  
**PROJECT :**  
**ITEM: LT XLPE POWER CABLE**

**SPEC. NO. :**  
**QP NO.:** PE-QP-999-507-E002, REV 02.  
**PO NO.:**

**DATE:**  
**SECTION: II**

**SYSTEM: CABLE**

**SHEET 8 OF 12**

**STANDARD QUALITY PLAN**

**ACCEPTANCE CRITERIA**

**REFERENCE DOCUMENT**

**QUANTUM OF CHECK**

**TYPE OF CHECK**

**CLASSIFICATION**

**CHARACTERISTICS**

Sl. No.	COMPONENTS & OPERATIONS	CHARACTERISTICS	CLASSIFICATION	TYPE OF CHECK	QUANTUM OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE CRITERIA	FORMAT OF RECORD	AGENCY	REMARKS
1	2	3	4	5	6	7	8	9	M C N	

2.5	Inner Sheath Extrusion (as applicable)	2. Sequence of lay & direction 1. Surface finish	MA	Visual & Meas. Visual	-do- 100%	IS 7098-I & Mfr. Std. Surface shall be smooth	IS 7098-I & Mfr. Std. Surface shall be smooth	-do- Inspection Report / Test report	P - -	
2.6	Armour (as applicable)	1. No. of wires/Strips 2. Lay length / Direction 3. Dia over inner sheath armouring	MA	Counting Visual & Meas. Measurement	At the start of the process -do- -do-	Mnfr's Std Mfr. Std. Appd. Datasheet	Mnfr's Std Mfr. Std. Appd. Datasheet	Inspection Report / Test report -do- -do-	P - -	

**BHEL**

ENGINEERING		QUALITY	
Sign & Date	Name	Sign & Date	Name
<i>[Signature]</i>	VIKAS KUMAR SINGH	<i>[Signature]</i>	KUNAL GANDHI
<i>[Signature]</i>	MANISH SHUKLA	<i>[Signature]</i>	RITESH KUMAR JAISWAL

Prepared by: *[Signature]*  
 Reviewed by: *[Signature]*

18/03/20

FOR CUSTOMER REVIEW & APPROVAL		
Doc No:	Sign & Date	Seal
Reviewed by:		
Approved by:		

**MANUFACTURER/ BIDDER/ SUPPLIER NAME & ADDRESS**  
**BHEL**

**STANDARD QUALITY PLAN**

**SPEC. NO.:**  
**QP NO.:** PE-QP-999-507-E002, REV 02.  
**PO NO.:**

**CUSTOMER:**  
**PROJECT:**

**DATE:**

**ITEM:** LT XLPE POWER CABLE  
**SYSTEM:** CABLE  
**SECTION:** II

**SHEET 9 OF 12**

Sl. No.	COMPONENTS & OPERATIONS	CHARACTERISTICS	CLASS	TYPE OF CHECK	QUANTUM OF CHECK		REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD		AGENCY	REMARKS
					M	C/N			*	D		
1	2	3	4	5	6	C/N	7	8	9			

		4. Coverage	MA	Measurement	-do-		-do-	-do-			P	-
2.7	Outer Sheath Extrusion (No repair permitted)	1. Surface finish	MA	Visual	100%		Surface shall be smooth	Surface shall be smooth	Inspection Report / Test report		P	-
		2. Sheath Thickness	CR	Measurement	One Sample of each size/ lot		Appd. Datasheet	Appd. Datasheet	-do-		P	-
		3. Dia over outer sheath	MA	-do-	-do-		-do-	-do-	-do-		P	-
		4. Embossing/ Sequential Marking	MA	Visual	100%		Approved data sheet	Approved data sheet	-do-		P	-
3.0	Final Inspection (INTERNAL)	1. Routine Test (Refer Note-H)	CR	Electrical Tests & Measurement	100%		#	#	-do-	✓	P	V
												#: Refer Annexure-A to QP


**BHEL**

ENGINEERING		QUALITY	
Sign & Date	Name	Sign & Date	Name
<i>[Signature]</i> 18/03/20	VIKAS KUMAR SINGH	<i>[Signature]</i>	KUNAL GANDHI
<i>[Signature]</i> 18/03/20	MANISH SHUKLA	<i>[Signature]</i>	RITESH KUMAR JAISWAL

**FOR CUSTOMER REVIEW & APPROVAL**

Doc No:	Sign & Date	Name	Seal



	<b>MANUFACTURER/ BIDDER/ SUPPLIER NAME &amp; ADDRESS</b>	<b>STANDARD QUALITY PLAN</b>	<b>SPEC. NO.:</b>	<b>DATE:</b>
		<b>CUSTOMER:</b>	QP NO.: PE-QP-999-507-E002, REV 02.	
		<b>PROJECT:</b>	PO NO.:	
		<b>ITEM: LT XLPE POWER CABLE</b>	<b>SYSTEM: CABLE</b>	<b>SECTION: II</b>
<b>SHEET 11 OF 12</b>				

SI. No.	COMPONENTS & OPERATIONS	CHARACTERISTICS	CLAS S	TYPE OF CHECK	QUANTUM OF CHECK		REFERENCE DOCUMENT	ACCEPTANC E NORMS	FORMAT OF RECORD	AGENCY			REMARKS
					M	C/N				M	C	N	
1	2	3	4	5	6	C/N	7	8	9	D	**		

	<b>5.0 Packing</b>	End sealing / Polythene wrapping	MA	Visual	100%	100%	Appd. Datasheet	-do-	Appd. Datasheet	✓	P	W	
--	--------------------	----------------------------------	----	--------	------	------	-----------------	------	-----------------	---	---	---	--

**NOTES:**

- A. Joints in conductors & armour shall be as permitted by IS:8130 & IS:7098-I respectively.
- B. No repair of core insulation permitted.
- C. Cable ends shall be sealed.
- D. Record of raw material, process & all stages shall be certified by Vendors QC and are liable to audit check by purchaser.
- E. Fillers/dummy cores etc. Shall be as per BHEL specification.
- F. Wherever extent of check for stage is mentioned as 'sample' & not defined in QP, the same shall be as per vendors sampling plan agreed by purchaser.
- G. Vendor shall furnish compliance certificate to the inspection agency confirming the packing as per IS/ BHEL specification.
- H. For lists of routine tests, acceptance tests & type tests refer annexure to QAP.
- I. Cable manufacturer to maintain records to show co-relation of raw materials to finished cables i.e. raw material batch/ lot no. should be traceable to the final cable drum number or batch no.
- J. Cable manufacturer to maintain all quality records identified as per all QP stages enumerated below whether it is identified for BHEL verification or witness or not.
- K. BHEL reserves the right to perform repeat test, if required.
- L. Photographs of cable to be despatched shall be sent to BHEL purchase group for review prior to issue of mdcc.
- M. Project specific QP to be prepared in line with this standard QP.
- N. In case of export jobs, sea worthy packing as per BHEL technical specification shall be carried out.

**LEGENDS:**

BHEL			
ENGINEERING	QUALITY		
Sign & Date	Name	Sign & Date	Name
<i>Manish</i> 18/03/20	VIKAS KUMAR SINGH	<i>Manish</i> 18/03/20	KUNAL GANDHI
Prepared by:	Checked by:	Reviewed by:	Reviewed by:
Manish	Manish Shukla	Manish	Ritesh Kumar Jaiswal
18/03/20			

FOR CUSTOMER REVIEW & APPROVAL			
Doc No:	Sign & Date	Name	Seal
Reviewed by:			
Approved by:			

**MANUFACTURER/ BIDDER/ SUPPLIER NAME & ADDRESS**  
**CUSTOMER :**  
**PROJECT :**

**STANDARD QUALITY PLAN**  
**SPEC. NO. :**  
**QP NO.:** PE-QP-999-507-E002, REV 02.  
**PO NO.:**

**DATE:**

**ITEM: LT XLPE POWER CABLE**  
**SYSTEM: CABLE**  
**SECTION: II**

**SHEET 12 OF 12**

**MANUFACTURER/ BIDDER/ SUPPLIER NAME & ADDRESS**

**CUSTOMER :**

**PROJECT :**

**STANDARD QUALITY PLAN**

**SPEC. NO. :**

**QP NO.:** PE-QP-999-507-E002, REV 02.

**PO NO.:**

**DATE:**

**ITEM: LT XLPE POWER CABLE**

**SYSTEM: CABLE**

**SECTION: II**

**SHEET 12 OF 12**

**MANUFACTURER/ BIDDER/ SUPPLIER NAME & ADDRESS**

**CUSTOMER :**

**PROJECT :**

**STANDARD QUALITY PLAN**

**SPEC. NO. :**

**QP NO.:** PE-QP-999-507-E002, REV 02.

**PO NO.:**

**DATE:**


SI. No.	COMPONENTS & OPERATIONS	CHARACTERISTICS	CLAS S	TYPE OF CHECK	QUANTUM OF CHECK	REFERENCE DOCUMENT	ACCEPTANC E NORMS	FORMAT OF RECORD	AGENCY	REMARKS
1	2	3	4	5	6	7	8	9	M C N	

\*RECORDS, IDENTIFIED WITH "TICK"(✓) SHALL BE ESSENTIALLY INCLUDED BY SUPPLIER IN QA DOCUMENTATION,  
 \*\* M: SUPPLIER/ MANUFACTURER/ SUB-SUPPLIER, B: MAIN SUPPLIER/ BHEL/ THIRD PARTY INSPECTION AGENCY, C: CUSTOMER,  
 P: PERFORM, W: WITNESS, V: VERIFICATION, AS APPROPRIATE  
 MA: MAJOR, MI: MINOR, CR: CRITICAL  
 D: DOCUMENTATION

ENGINEERING		QUALITY	
Sign & Date	Name	Sign & Date	Name
<i>Manish</i> 18.10.2020	VIKAS KUMAR SINGH	<i>Manish</i> 18.10.2020	KUNAL GANDHI
<i>Manish</i> 18.10.2020	MANISH SHUKLA	<i>Manish</i> 18.10.2020	RITESH KUMAR JAISWAL

FOR CUSTOMER REVIEW & APPROVAL			
Doc No:	Sign & Date	Name	Seal
Reviewed by:			
Approved by:			

	ANNEXURE-A TO QP	CUSTOMER:	PROJECT TITLE	SPECIFICATION NUMBER:
		BIDDER/VENDOR:	QUALITY PLAN NUMBER : PE-QP-899-507-E002, R02	SPECIFICATION TITLE:
	SHEET 1 OF 3	SYSTEM: CABLE	ITEM: LT XLPE POWER CABLE	DOC. NO.

**TYPE/ ACCEPTANCE/ ROUTINE TEST REQUIREMENTS**

**A. Type Test Conduction:**

1. Tests for which "T" is indicated in the 'Test Conduction Required As' column below shall be conducted as Type Test.
2. Sampling:
  - a) Type test to be conducted on one size of cable for every lot and type of cable (CU/AL conductor)
  - b) FRLS & Flammability Test to be conducted only on one sample/ lot.

**B. Acceptance Test Conduction:**

1. Tests for which "A" is indicated in the 'Test Conduction Required As' column below shall be conducted as Acceptance tests.
2. Sampling:  
Sampling for acceptance tests shall be as per Appendix-B (Clause 15.2.2) of IS: 7098 Part-I.
3. Flammability Test to be conducted only on one sample/ lot.

**C. Routine Test Conduction:**

1. Tests for which "R" is indicated in the 'Test Conduction Required As' column below shall be conducted as Routine tests.

**D. Tests listed in S.No-7.0 & 8.0 shall be conducted only on one sample / lot.**


Note: LOT shall be considered as per IS: 7098 Part-I, appendix-B.

S. No.	TEST	APPLICABLE FOR	TEST CONDUCTION REQUIRED AS	REFERENCE STANDARD	REMARKS
1.0	Tests for Conductor				
I.	Annealing test	For copper conductor only	T, A	IS 10810 Pt 1	<i>Internal in process Test Report to be furnished for acceptance test</i>
II.	Tensile test	For aluminium conductor only (Not applicable for compacted circular or shaped conductor)	T, A	IS 10810 Pt 2	
III.	Wrapping test	For aluminium conductor only (Not applicable for compacted circular or shaped conductor)	T, A	IS 10810 Pt 3	
IV.	Resistance test	For Al/Cu	T, A, R	IS 10810 Pt 5	

BHEL					
ENGINEERING			QUALITY		
	Sign & Date	Name		Sign & Date	Name
Prepared by:	<i>[Signature]</i> 18-03-2023	VIKAS KUMAR SINGH	Checked by:	<i>[Signature]</i> 12/3/23	KUNAL GANDHI
Reviewed by:	<i>[Signature]</i>	MANISH SHUKLA	Reviewed by:	<i>[Signature]</i>	RITESH KUMAR

BIDDER/ SUPPLIER	
Sign & Date	Seal

FOR CUSTOMER REVIEW & APPROVAL			
Doc No:	Sign & Date	Name	Seal
Reviewed by:			
Approved by:			

	ANNEXURE-A TO QP	CUSTOMER:	PROJECT TITLE	SPECIFICATION NUMBER:
		BIDDER/VENDOR:	QUALITY PLAN NUMBER : PE-QP-999-507-E002, R02	SPECIFICATION TITLE:
	SHEET 2 OF 3	SYSTEM: CABLE	ITEM: LT XLPE POWER CABLE	DOC. NO.

S. No.	TEST	APPLICABLE FOR	TEST CONDUCTION REQUIRED AS	REFERENCE STANDARD	REMARKS
<b>2.0</b>	<b>Tests for Armour Wires/Strips</b>				
I.	Measurement of dimensions	Applicable for Aluminium wire & GS wire/Strip	T,A	IS 10810 Pt 36	
II.	Tensile test	Applicable for Aluminium wire & GS wire/Strip	T, A	IS 10810 Pt 37	
III.	Elongation at break test	Applicable for GS wire/Strip only	T, A	IS 10810 Pt 37	
IV.	Torsion test	For GS round wire only	T, A	IS 10810 Pt 38	
V.	Winding / Adhesion Test	For GS strip only	T, A	IS 10810 Pt 39	
VI.	Resistivity test	Applicable for Aluminium wire & GS wire	T, A	IS 10810 Pt 42	
VII.	Uniformity of Zinc coating test	For G. S. wires/Strip only	T, A	IS 10810 Pt 40	
VIII.	Mass of Zinc coating test	For G. S. wires/Strip only	T, A	IS 10810 Pt 41	
IX.	Wrapping Test	Applicable for Aluminium wire & GS wire	A	IS 10810 Pt 3	
<b>3.0</b>	<b>Physical Tests for XLPE Insulation &amp; PVC sheath</b>				
I.	Test for thickness	Applicable for XLPE insulation, PVC inner sheath & PVC outer sheath	T, A	IS 10810 Pt 6	
II.	Tensile strength and elongation test at break	Applicable for XLPE insulation & PVC outer sheath			
(a)	Before ageing		T, A	IS 10810 Pt 7	
(b)	After ageing		T, A	IS 10810 Pt 7	
III.	Ageing in air oven	Applicable for XLPE insulation & PVC outer sheath	T	IS 10810 Pt 11	
IV.	Loss of mass in air oven test	For PVC outer sheath only	T	IS 10810 Pt 10	
V.	Hot deformation test	For PVC outer sheath only	T	IS 10810 Pt 15	
VI.	Heat shock test	For PVC outer sheath only	T	IS 10810 Pt 14	
VII.	Shrinkage test	For XLPE insulation & PVC outer sheath only	T	IS 10810 Pt 12	
VIII.	Thermal stability test	For PVC outer sheath only	T	IS 10810 Pt 60	
IX.	Hot set test	For XLPE insulation only	T, A	IS 10810 Pt 30	
X.	Water absorption (gravimetric) test	For XLPE insulation only	T	IS 10810 Pt 33	
<b>4.0</b>	<b>Improved Fire performance (FR-LSH) Tests</b>				

BHEL				
ENGINEERING			QUALITY	
	Sign & Date	Name	Sign & Date	Name
Prepared by:	<i>Vikas</i> 19-02-2024	VIKAS KUMAR SINGH	Checked by:	<i>Kunal</i> 19/2/24 KUNAL GANDHI
Reviewed by:	<i>Manish</i>	MANISH SHUKLA	Reviewed by:	<i>Ritesh</i> RITESH KUMAR

BIDDER/ SUPPLIER	
Sign & Date	
Seal	

FOR CUSTOMER REVIEW & APPROVAL			
Doc No:	Sign & Date	Name	Seal
Reviewed by:			
Approved by:			



**Price Variation Formulae for cables -Annexure-I**

1. Prices shall be variable as per price variation formulae given below (basis IEEMA).  
The price variation shall be limited to + 20% of total ex-works price actually supplied (cable size wise) and -ve price variation shall be unlimited. Rates for working out price variation shall be as per rates published by IEEMA for the factors given in Annexure-II

**2. Base date for prices:**

**Initial Price (As per IEEMA) for-Alo, Cuo, CCo, PVCCo & Feo:**

Base Date shall be- 1<sup>st</sup> working day of the previous month to the date of issue of tender enquiry.

**Final Price (as per IEEMA) for- AI, Cu, Cc, PVCC & Fe:**

1<sup>st</sup> working day of month, one month prior to the date on which cable is notified as being ready for inspection i.e TPIA inspection call raise date on web portal.

3. Variation factor value for ALF, CuF, CCFAL, CCFCu, XLFAL, XLFCu, FeF & FeW as applicable shall be as per Technical Specification.

4. PVC shall be payable within contractual delivery period (including any extension thereto).

Vikas  
15.01.19

VIKAS KUMAR SINGH  
E3 - ELECTRICAL

Alekheta  
15/01/19.

Manish Shukla  
15/01/19

**IEEMA table for Price variation cause for various type of cable**

**1. Aluminium conductor cable**

S.No	Cable Type	AIF (Single core unarmoured & Multi core armoured)	AIF (Single core armoured)	CCFAI	XLFAL (Single core)	XLFAL (Multi core)	FeF	FeW	IEEMA Formula
1.	HT XLPE Power cable	ALP	H1	H2	XL3	XL4	H3	H5	$P = P_o + AIF(AL-Alo) + XLFAL(CC-CCo) + CCFAI(PVCC-PVCCo) + FeF(Fe-Feo)$
2.	LT XLPE Power Cable	ALP	P1	L2	XL1	XL1	P3	P3 (Additional)	$P = P_o + AIF(AL-Alo) + XLFAL(CC-CCo) + CCFAI(PVCC-PVCCo) + FeF(Fe-Feo)$
3.	LT PVC Power Cable	ALP	P1	P2	-	-	P3	P3 (Additional)	$P = P_o + AIF(AL-Alo) + CCFAI(PVCC-PVCCo) + FeF(Fe-Feo)$
4.	LT HRPVC Power Cable	ALP	P1	P2	-	-	P3	P3 (Additional)	$P = P_o + AIF(AL-Alo) + CCFAI(PVCC-PVCCo) + FeF(Fe-Feo)$

**2. Copper conductor cable**

S no.	Cable type	CuF	AIF (single core armoured)	CCFCu	XLFCU (Single core)	XLFCU (Multi core)	FeF	FeW	IEEMA Formula
1	HT XLPE Power cable	CUP	H4	H2	XL3	XL4	H3	H5	$P = P_o + CuF(Cu-Cuo) + XLFCU(CC-CCo) + CCFCu(PVCC-PVCCo) + FeF(Fe-Feo) + AIF(AL-Alo)$
2	LT XLPE Power Cable	CUP	P4	L2	XL1	XL1	P3	P3 (Additional)	$P = P_o + CuF(Cu-Cuo) + XLFCU(CC-CCo) + CCFCu(PVCC-PVCCo) + FeF(Fe-Feo) + AIF(AL-Alo)$

S no.	Cable type	CuF	AIF (single core armoured)	CCFCu	XLFCU (Single core)	XLFCU (Multi core)	FeF	FeW	IEEMA Formula
3	LT PVC Power Cable	CUP	P4	P2	--	--	P3	P3 (Additional)	$P=Po+CuF(Cu-Cuo) + CCFCu (PVCC-PVCCo) + FeF(Fe-Feo) + AIF(AL-Alo)$
4	LT HRPVC Power Cable	CUP	P4	P2	--	--	P3	P3 (Additional)	$P=Po+CuF(Cu-Cuo) + CCFCu (PVCC-PVCCo) + FeF(Fe-Feo) + AIF(AL-Alo)$
5	LT XLPE Control Cable	CUC	--	P5	--	XL2	P6	P6 (Additional)	$P=Po+CuF(Cu-Cuo) + XLFCU(CC-CCo) + CCFCu (PVCC-PVCCo) + FeF(Fe-Feo)$
6	LT PVC Control Cable	CUC	--	P5	--	--	P6	P6 (Additional)	$P=Po+CuF(Cu-Cuo) + CCFCu (PVCC-PVCCo) + FeF(Fe-Feo)$
7	LT HRPVC Control Cable	CUC	--	P5	--	--	P6	P6 (Additional)	$P=Po+CuF(Cu-Cuo) + CCFCu(PVCC-PVCCo) + FeF(Fe-Feo)$
8	LT XLPE Fire Survival Power Cable	CUP	P4	L2	XL1	XL1	P3	P3 (Additional)	$P=Po+CuF(Cu-Cuo) + XLFCU(CC-CCo) + CCFCu (PVCC-PVCCo) + FeF(Fe-Feo) + AIF(AL-Alo)$
9	LT XLPE Fire Survival Control	CUC	--	P5	--	XL2	P6	P6 (Additional)	$P=Po+CuF(Cu-Cuo) + XLFCU(CC-CCo) + CCFCu (PVCC-PVCCo) + FeF(Fe-Feo)$
10	LT EPR Fire Survival Power Cable	CUP	P4	L2	--	--	P3	P3 (Additional)	$P=Po+CuF(Cu-Cuo) + CCFCu (PVCC-PVCCo) + FeF(Fe-Feo) + AIF(AL-Alo)$
11	LT EPR Fire Survival Control cable	CUC	--	P5	--	--	P6	P6 (Additional)	$P=Po+CuF(Cu-Cuo) + CCFCu (PVCC-PVCCo) + FeF(Fe-Feo)$
12	Screened control Cable (Overall screen)	Cu POS	--	--	--	--	Fe POS	Fe POS	$P=Po+CuF(Cu-Cuo) + FeF(Fe-Feo)$
13	Screened control Cable (Individual)	Cu PIS	--	--	--	--	Fe PIS	Fe PIS	$P=Po+CuF(Cu-Cuo) + FeF(Fe-Feo)$

**IEEMA Table for Price Variation Clause for various types of Cables****Notes:-**

(i) Cu POS, Cu PIS, Fe POS & Fe PIS tables shall be as per IEEMA circular No. IEEMA (PVC) /Instrumentation Cable/2014 effective from dtd 01.07.2014.

(ii) All other tables shall be as per IEEMA circular No. 35//DIV/CAB/05/ dated 24.04.2018.

**Terms used in PVC formulae:**

P = Price payable as adjusted in accordance with above appropriate formula (In Rs./Km).

Po= Price quoted/confined (in Rs./km).

**1. ALUMINIUM**

ALF Variation factor for aluminium.

Al =Price of aluminium.

Alo = Price of aluminium.

**2 COPPER**

CuF =Variation factor for copper.

Cu = Price of CC copper rods.

Cuo = Price of CC copper rods.

**3.PVCC COMPOUND/POLYMER**

PVCC = Price of PVC compound.

PVCCo= Price of PVC compound.

CCFAL= Variation factor for PVC compound/Polymer for aluminium conductor cable.

CCFCu =Variation factor for PVC compound/Polymer for copper conductor cable.

**4. XLPE COMPOUND**

Cc = Price of XLPE compound.

Cco= Price of XLPE compound.

XLFAL= Variation factor for XLPE compound for aluminium conductor cable.

XLFCu =Variation factor for XLPE compound for copper conductor cable.

**5.STEEL**

Fe= Price of steel strips/steel wire.

Feo= Price of steel strips/steel wire.

FeF =Variation factor for steel.

FeW=Variation factor for round wire steel armouring.



501, Kakad Chambers  
132, Dr. Annie Besant Road, Worli  
Mumbai 400018  
India

P: +91 22 2493 0532  
F: +91 22 2493 2705  
E: [mumbai@ieema.org](mailto:mumbai@ieema.org)  
[www.ieema.org](http://www.ieema.org)

IEEMA (PVC)/Instrumentation Cable/2014

Effective from: 1<sup>st</sup> July 2014

#### Material Price Variation Clause For Instrumentation Cables

The Price quoted/confirmed is based on the input cost of raw materials/components as on the date of quotation, and the same is deemed to be related to the prices of raw materials as specified in the price variation clause given below. In case of any variation in these prices, the price payable shall be subject to adjustment up or down in accordance with the formulae provided in this document.

Terms used in price variation formulae:

P Price payable as adjusted in accordance with above appropriate formula (in Rs/Km)

P<sub>0</sub> Price quoted/confirmed (in Rs/Km)

#### COPPER

CuF Variation factor for copper

Cu Price of CC copper rods. This price is as applicable on first working day of the month, one month prior to the date of delivery.

Cu<sub>0</sub> Price of CC copper rods. This price is as applicable on first working day of the month, one month prior to the date of tendering.

#### STEEL

FeF Variation factor for steel

Fe Price of Steel Strips/steel wire. This price is as applicable on the first working day of the month, one month prior to the date of delivery.

Fe<sub>0</sub> Price of steel strips/steel wire. This price is as applicable on first working day of the month, one month prior to the date of tendering.

The above prices and indices are as published by IEEMA vide Circular reference IEEMA(PVC)/CABLE/--/-- prevailing as on 1<sup>st</sup> working day of the month i.e. one month prior to the date of tendering.

The date of delivery is the date on which the cable is notified as being ready for inspection/dispatch (in the absence of such notification, the date of manufacturer's dispatch note is to be considered as the date of delivery) or the contracted delivery date (including any agreed extension thereto), whichever is earlier.

Page 1 of 2

<b>New Delhi</b> Rishyamook Building, First Floor 85 A, Panchkuan Road New Delhi 110001, India P: +91 11 2336 3013/14 F: +91 11 2336 3015 E: <a href="mailto:delhi@ieema.org">delhi@ieema.org</a>	<b>Bangalore</b> 204, Swiss Complex 33, Race Course Road Bangalore 560001, India P: +91 80 2220 1316/18 F: +91 80 2220 1317 E: <a href="mailto:bangalore@ieema.org">bangalore@ieema.org</a>	<b>Kolkata</b> 503 A, Oswal Chambers 2, Church Lane Kolkata 700001, India P: +91 33 6510 7855 F: +91 33 2213 1326 E: <a href="mailto:kolkata@ieema.org">kolkata@ieema.org</a>
---	---	---

Indian Electrical & Electronics Manufacturers' Association



**IEEMA (PVC)/Instrumentation Cable/2014**

**Effective from: 1<sup>st</sup> July 2014**

**Notes**

- (a) All prices of raw materials are exclusive of modvatable excise/CV duty amount and exclusive of any other central, state or local taxes, octroi, etc.
- (b) All Prices are as on first working day of the month.
- (c) The details of prices are as under:
  1. Price of CC copper rods (in Rs/MT) is ex-works price as quoted by the primary producer.
  2. Price of galvanized steel strip / steel wire (in Rs/MT) is ex-works price as quoted by the manufacturer for Round steel Wire and Flat steel strip (the relevant price of steel strip or steel wire is to be selected depending upon the type of armouring of the cable).

**Price variation formula for 'Instrumentaion Cables'**

**$P = P_o + CuF (Cu - Cuo) + FeF (Fe - Feo)$**

**1. For Pair Instrumentation Over all Screen Cables**

Tables References:

- Cu POS    Copper Factor
- Fe POS    Steel Factor

**2. For Pair Instrumentation Individual and Over all Screen Cables**

Tables References:

- Cu PIS    Copper Factor
- Fe PIS    Steel Factor

**3. For Triad Instrumentation Over all Screen Cables**


Tables References:

- Cu TOS    Copper Factor
- Fe TOS    Steel Factor

**4. For Triad Instrumentation Individual & Overall Screen Cables**

Tables References:

- Cu TIS    Copper Factor
- Fe TIS    Steel Factor

  
**Deputy Director General**  
 Page 2 of 2

## Copper Factors for Instrumentation Cables - CuF

## Cu POS

Pair Instrumentation Over all Screen Cables					
No. of Pairs Cable size in sq.mm	0.5 sq.mm	0.75 sq.mm	1.0 sq.mm	1.5 sq.mm	2.5 sq.mm
1	0.0142	0.0185	0.0233	0.0326	0.0500
2	0.0258	0.0345	0.0440	0.0625	0.0978
3	0.0353	0.0484	0.0626	0.0904	0.1433
4	0.0448	0.0623	0.0811	0.1183	0.1888
5	0.0578	0.0800	0.1022	0.1467	0.2356
6	0.0662	0.0926	0.1210	0.1768	0.2829
7	0.0756	0.1067	0.1378	0.2000	0.3245
8	0.0852	0.1204	0.1582	0.2327	0.3741
9	0.0933	0.1334	0.1734	0.2534	0.4134
10	0.1046	0.1485	0.1959	0.2893	0.4665
11	0.1111	0.1600	0.2089	0.3067	0.5023
12	0.1236	0.1764	0.2333	0.3452	0.5580
13	0.1289	0.1867	0.2445	0.3600	0.5912
14	0.1378	0.2000	0.2623	0.3867	0.6356
15	0.1467	0.2134	0.2800	0.4134	0.6801
16	0.1618	0.2322	0.3080	0.4573	0.7409
17	0.1645	0.2400	0.3156	0.4667	0.7690
18	0.1734	0.2534	0.3334	0.4934	0.8134
19	0.1822	0.2667	0.3512	0.5201	0.8579
20	0.1911	0.2800	0.3689	0.5467	0.9023
21	0.2000	0.2934	0.3867	0.5734	0.9468
22	0.2089	0.3067	0.4045	0.6001	0.9912
23	0.2178	0.3200	0.4223	0.6267	1.0357
24	0.2381	0.3437	0.4575	0.6813	1.1068
25	0.2356	0.3467	0.4578	0.6801	1.1246
26	0.2445	0.3600	0.4756	0.7068	1.1690
27	0.2534	0.3734	0.4934	0.7334	1.2135
28	0.2623	0.3867	0.5112	0.7601	1.2579
29	0.2711	0.4001	0.5290	0.7868	1.3024
30	0.2800	0.4134	0.5467	0.8134	1.3468
31	0.2889	0.4267	0.5645	0.8401	1.3913
32	0.2978	0.4401	0.5823	0.8668	1.4357
33	0.3067	0.4534	0.6001	0.8934	1.4802
34	0.3156	0.4667	0.6179	0.9201	1.5246
35	0.3245	0.4801	0.6356	0.9468	1.5691
36	0.3334	0.4934	0.6534	0.9735	1.6135
37	0.3423	0.5067	0.6712	1.0001	1.6580
38	0.3512	0.5201	0.6890	1.0268	1.7024
39	0.3600	0.5334	0.7068	1.0535	1.7469
40	0.3689	0.5467	0.7245	1.0801	1.7913
41	0.3778	0.5601	0.7423	1.1068	1.8358
42	0.3867	0.5734	0.7601	1.1335	1.8802
43	0.3956	0.5867	0.7779	1.1601	1.9247
44	0.4045	0.6001	0.7957	1.1868	1.9691
45	0.4134	0.6134	0.8134	1.2135	2.0136
46	0.4223	0.6267	0.8312	1.2402	2.0580
47	0.4312	0.6401	0.8490	1.2668	2.1025
48	0.4710	0.6759	0.9010	1.3410	2.2009



### Copper Factors for Instrumentation Cables - CuF

#### Cu PIS

Pair Instrumentation Individual and Over all Screen Cables					
No. of Pairs Cable size in sq.mm	0.5 sq.mm	0.75 sq.mm	1.0 sq.mm	1.5 sq.mm	2.5 sq.mm
1	0.0133	0.0178	0.0222	0.0311	0.0489
2	0.0349	0.0437	0.0531	0.0717	0.1069
3	0.0490	0.0621	0.0763	0.1041	0.1570
4	0.0630	0.0806	0.0994	0.1389	0.2071
5	0.0800	0.1022	0.1245	0.1689	0.2578
6	0.0937	0.1200	0.1484	0.2042	0.3103
7	0.1067	0.1378	0.1689	0.2311	0.3556
8	0.1218	0.1569	0.1948	0.2692	0.4107
9	0.1334	0.1734	0.2134	0.2934	0.4534
10	0.1503	0.1943	0.2417	0.3349	0.5122
11	0.1600	0.2089	0.2578	0.3556	0.5512
12	0.1785	0.2313	0.2882	0.4001	0.6128
13	0.1867	0.2445	0.3023	0.4178	0.6490
14	0.2000	0.2623	0.3245	0.4489	0.6979
15	0.2134	0.2800	0.3467	0.4801	0.7468
16	0.2350	0.3053	0.3812	0.5305	0.8141
17	0.2400	0.3156	0.3912	0.5423	0.8446
18	0.2534	0.3334	0.4134	0.5734	0.8934
19	0.2667	0.3512	0.4356	0.6045	0.9423
20	0.2800	0.3689	0.4578	0.6356	0.9912
21	0.2934	0.3867	0.4801	0.6668	1.0401
22	0.3067	0.4045	0.5023	0.6979	1.0890
23	0.3200	0.4223	0.5245	0.7290	1.1379
24	0.3479	0.4535	0.5673	0.7911	1.2165
25	0.3467	0.4578	0.5690	0.7912	1.2357
26	0.3600	0.4756	0.5912	0.8223	1.2846
27	0.3734	0.4934	0.6134	0.8534	1.3335
28	0.3867	0.5112	0.6356	0.8846	1.3824
29	0.4001	0.5290	0.6579	0.9157	1.4313
30	0.4134	0.5467	0.6801	0.9468	1.4802
31	0.4267	0.5645	0.7023	0.9779	1.5291
32	0.4401	0.5823	0.7245	1.0090	1.5780
33	0.4534	0.6001	0.7468	1.0401	1.6269
34	0.4667	0.6179	0.7690	1.0712	1.6758
35	0.4801	0.6356	0.7912	1.1024	1.7247
36	0.4934	0.6534	0.8134	1.1335	1.7736
37	0.5067	0.6712	0.8357	1.1646	1.8225
38	0.5201	0.6890	0.8579	1.1957	1.8713
39	0.5334	0.7068	0.8801	1.2268	1.9202
40	0.5467	0.7245	0.9023	1.2579	1.9691
41	0.5601	0.7423	0.9246	1.2891	2.0180
42	0.5734	0.7601	0.9468	1.3202	2.0669
43	0.5867	0.7779	0.9690	1.3513	2.1158
44	0.6001	0.7957	0.9912	1.3824	2.1647
45	0.6134	0.8134	1.0135	1.4135	2.2136
46	0.6267	0.8312	1.0357	1.4446	2.2625
47	0.6401	0.8490	1.0579	1.4757	2.3114
48	0.6887	0.8936	1.1186	1.5587	2.4186



Steel Factors for Instrumentation Cables - FeF					
Fe POS					
Pair Instrumentation Over all Screen Cables					
No. of Pairs Cable size in sq.mm	0.5 sq.mm	0.75 sq.mm	1.0 sq.mm	1.5 sq.mm	2.5 sq.mm
1	0.1490	0.1565	0.1635	0.1735	0.1930
2	0.2190	0.2335	0.2470	0.2665	0.2595
3	0.2360	0.2545	0.2690	0.2900	0.2680
4	0.2390	0.2580	0.2715	0.2945	0.2830
5	0.2630	0.2820	0.2420	0.2805	0.3155
6	0.2840	0.3160	0.2805	0.2995	0.3430
7	0.2840	0.2595	0.2805	0.2995	0.3430
8	0.3235	0.2930	0.3030	0.3315	0.3780
9	0.2805	0.3180	0.3290	0.3590	0.4205
10	0.2970	0.3215	0.3455	0.3755	0.4385
11	0.3005	0.3255	0.3490	0.3805	0.4435
12	0.3055	0.3440	0.3690	0.3880	0.4520
13	0.3265	0.3530	0.3780	0.4105	0.4785
14	0.3265	0.3530	0.3780	0.4105	0.4785
15	0.3490	0.3765	0.4015	0.4365	0.5195
16	0.3490	0.3765	0.4015	0.4365	0.5195
17	0.3590	0.4005	0.4140	0.4635	0.5470
18	0.3590	0.4005	0.4265	0.4635	0.5470
19	0.3590	0.4005	0.4265	0.4635	0.5470
20	0.3830	0.4240	0.4535	0.4920	0.5760
21	0.3830	0.4240	0.4535	0.4920	0.5760
22	0.4065	0.4520	0.4785	0.5310	0.6190
23	0.4065	0.4520	0.4810	0.5310	0.6190
24	0.4305	0.4770	0.5070	0.5595	0.6475
25	0.4305	0.4770	0.5070	0.5595	0.6475
26	0.4305	0.4770	0.5070	0.5595	0.6475
27	0.4355	0.4820	0.5245	0.5660	0.6700
28	0.4570	0.5045	0.5345	0.5895	0.6950
29	0.4570	0.5045	0.5345	0.5895	0.6950
30	0.4570	0.5045	0.5345	0.5895	0.6950
31	0.4795	0.5285	0.5595	0.6150	0.7225
32	0.4820	0.5285	0.5595	0.6150	0.7225
33	0.4820	0.5285	0.5595	0.6150	0.7225
34	0.4920	0.5520	0.5835	0.6410	0.7500
35	0.4920	0.5520	0.5835	0.6410	0.7500
36	0.4920	0.5520	0.5835	0.6410	0.7500
37	0.4920	0.5520	0.5835	0.6410	0.7500
38	0.5145	0.5760	0.6225	0.6550	0.7805
39	0.5145	0.5760	0.6225	0.6550	0.7805
40	0.5145	0.5760	0.6225	0.6550	0.7805
41	0.5395	0.6025	0.6475	0.6975	0.8230
42	0.5395	0.6025	0.6475	0.6975	0.8230
43	0.5395	0.6025	0.6475	0.6975	0.8230
44	0.5635	0.6265	0.6735	0.7250	0.8540
45	0.5635	0.6265	0.6760	0.7250	0.8540
46	0.5635	0.6265	0.6760	0.7250	0.8540
47	0.5635	0.6265	0.6760	0.7250	0.8540
48	0.5635	0.6265	0.6760	0.7375	0.8665



Steel Factors for Instrumentation Cables - FeF					
Fe PIS					
Pair Instrumentation Individual and Over all Screen Cables					
No. of Pairs Cable size in sq.mm	0.5 sq.mm	0.75 sq.mm	1.0 sq.mm	1.5 sq.mm	2.5 sq.mm
1	0.1880	0.1980	0.2070	0.2220	0.2410
2	0.2315	0.2460	0.2595	0.2815	0.2755
3	0.2505	0.2690	0.2820	0.2495	0.2830
4	0.2645	0.2830	0.2420	0.2805	0.3155
5	0.2895	0.2730	0.2805	0.3005	0.3430
6	0.2755	0.2980	0.3005	0.3280	0.3730
7	0.2755	0.2980	0.3005	0.3280	0.3730
8	0.2980	0.3215	0.3455	0.3740	0.4230
9	0.3230	0.3490	0.3730	0.4040	0.4685
10	0.3405	0.3655	0.3765	0.4215	0.4885
11	0.3430	0.3690	0.3815	0.4265	0.4945
12	0.3490	0.3765	0.4015	0.4470	0.5160
13	0.3715	0.3990	0.4255	0.4720	0.5420
14	0.3715	0.3990	0.4255	0.4720	0.5420
15	0.3955	0.4240	0.4510	0.5020	0.5720
16	0.3955	0.4240	0.4510	0.5020	0.5720
17	0.4190	0.4495	0.4795	0.5295	0.6150
18	0.4190	0.4495	0.4795	0.5295	0.6150
19	0.4190	0.4495	0.4795	0.5295	0.6150
20	0.4445	0.4770	0.5060	0.5570	0.6450
21	0.4445	0.4895	0.5060	0.5695	0.6450
22	0.4695	0.5045	0.5345	0.5870	0.6885
23	0.4695	0.5045	0.5345	0.5870	0.6885
24	0.4970	0.5310	0.5620	0.6285	0.7210
25	0.4970	0.5310	0.5620	0.6285	0.7210
26	0.4970	0.5310	0.5620	0.6285	0.7210
27	0.5035	0.5495	0.5810	0.6360	0.7410
28	0.5135	0.5610	0.6050	0.6610	0.7690
29	0.5135	0.5610	0.6050	0.6610	0.7690
30	0.5260	0.5610	0.6050	0.6610	0.7690
31	0.5495	0.5845	0.6300	0.6885	0.7990
32	0.5495	0.5845	0.6300	0.6885	0.7990
33	0.5495	0.5845	0.6300	0.6885	0.7990
34	0.5735	0.6225	0.6585	0.7285	0.8405
35	0.5735	0.6225	0.6585	0.7285	0.8405
36	0.5735	0.6225	0.6585	0.7285	0.8405
37	0.5735	0.6225	0.6585	0.7285	0.8405
38	0.5990	0.6485	0.6850	0.7575	0.8740
39	0.5990	0.6485	0.6850	0.7575	0.8740
40	0.5990	0.6485	0.6850	0.7575	0.8740
41	0.6250	0.6775	0.7135	0.7880	0.9180
42	0.6250	0.6775	0.7135	0.7880	0.9180
43	0.6250	0.6775	0.7135	0.7880	0.9180
44	0.6485	0.7050	0.7410	0.8165	0.9495
45	0.6485	0.7050	0.7410	0.8165	0.9495
46	0.6485	0.7050	0.7410	0.8165	0.9495
47	0.6485	0.7050	0.7410	0.8165	0.9495
48	0.6485	0.7050	0.7535	0.8290	0.9620



Indian Electrical & Electronics Manufacturer's Association  
501, Kakad Chambers P +91 22 2493 0532  
132, Dr. A. B. Road, Worli F +91 22 2493 2705  
Mumbai - 400 018. E mumbai@ieema.org  
INDIA. W www.ieema.org

Cir. No. 35/DIV/CAB/05/

✓ 24<sup>th</sup> April 2018

To Members of the Cable Division, Utilities, Railways & Listed purchasing organizations.

**Sub: Correction in PV formulae of LT XLPE Power Cable and addition of factors for HT XLPE Power Cables**

We have recently published revised Price Variation Clause for LT&HT XLPE Power Cables and made it effective from 1<sup>st</sup> November 2017 vide Cir. No.111/DIV/CAB/05 dated 5<sup>th</sup> December 2017.


While replying to a query of a buyer it is observed that the polymer factor for LT XLPE Power Cables (both aluminium and copper) was incorrectly represented by Table P2.

We have now corrected the anomaly by correcting the PV formulae of LT XLPE Aluminium and Copper Insulated Cables (Sl. No. D & E) by representing Polymer factor by Table L2.

We have also worked out factors for XLPE, Copper and Steel for 3 core HT XLPE Power Cables for 500 and 630 sq.mm.

We now enclose complete PV clause of Cable by including all the PV formulae of different types of power cable (Sl. No. A to I), polymer factor Table L2 and updated XL4, H2 and H5 Table of factors for your perusal & record.

We request to replace PV clause of Cable already circulated vide Cir. 111/DIV/CAB/05 dated 5<sup>th</sup> December 2017 with the enclosed PV clause in your records for future use.

  
Senior Director

Encl: as above



Indian Electrical & Electronics Manufacturer's Association  
 501, Kakad Chambers, P +91 22 2493 0532  
 132, Dr. A. B. Road, Worli, F +91 22 2493 2705  
 Mumbai - 400 018. E rumbai@ieema.org  
 INDIA. W www.ieema.org

## IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1<sup>st</sup> November 2017

## Material Price Variation Clause For PVC And XLPE Insulated Cables

The Price quoted/confirmed is based on the input cost of raw materials/components as on the date of quotation, and the same is deemed to be related to the prices of raw materials as specified in the price variation clause given below. In case of any variation in these prices, the price payable shall be subject to adjustment up or down in accordance with the formulae provided in this document.

Terms used in price variation formulae:

P Price payable as adjusted in accordance with above appropriate formula (in Rs/Km)

Po Price quoted/confirmed (in Rs/Km)

## ALUMINIUM

AIF Variation factor for aluminium

AI Price of Aluminium. This price is as applicable of first working day of the month, one month prior to the date of delivery.

Alo Price of aluminium. This price is as applicable on first working day of the month, one month prior to the date of tendering.

## COPPER

CuF Variation factor for copper

Cu Price of CC copper rods. This price is as applicable on first working day of the month, one month prior to the date of delivery.

Cuo Price of CC copper rods. This price is as applicable on first working day of the month, one month prior to the date of tendering.

## PVC COMPOUND

PVCc price of PVC compound. This price is as applicable on first working day of the month, one month prior to the date of delivery.

PVCco Price of PVC compound. This price is as applicable on first working day of the month, one month prior to the date of tendering.

CCFAI Variation factor for PVC compound/Polymer for aluminum conductor cable.

CCFCu Variation factor for PVC compound/Polymer for copper conductor cable.





Indian Electrical & Electronics Manufacturer's Association  
 501, Kakad Chambers  
 132, Dr. A. B. Road, Worli,  
 Mumbai - 400 018.  
 INDIA.  
 P: +91 22 2493 0532  
 F: +91 22 2493 2705  
 E: mumbai@ieema.org  
 W: www.ieema.org

**IEEMA (PVC)/CABLE(R-1)/2017  
 XLPE COMPOUND**

Effective from: 1<sup>st</sup> November 2017

**Cc** price of XLPE compound. This price is as applicable on first working day of the month, one month prior to the date of delivery.

**Cco** Price of XLPE compound. This price is as applicable on first working day of the month, one month prior to the date of tendering.

**XLFAL** Variation factor for XLPE compound for aluminum conductor cable.

**XLFCU** Variation factor for XLPE compound for Copper conductor cable.

**STEEL**

**FeF** Variation factor for steel

**FeW** Variation factor for round wire steel armouring

**Fe** Price of Steel Strips/steel wire. This price is as applicable on the first working day of the month, one month prior to the date of delivery.

**Feo** Price of steel strips/steel wire. This price is as applicable on first working day of the month, one month prior to the date of tendering.

The above prices and indices are as published by IEEMA vide Circular reference IEEMA (PVC)/CABLE R(1)/--/-- prevailing as on 1<sup>st</sup> working day of the month i.e. one month prior to the date of tendering.

The date of delivery is the date on which the cable is notified as being ready for inspection/dispatch (in the absence of such notification, the date of manufacturer's dispatch note is to be considered as the date of delivery) or the contracted delivery date (including any agreed extension thereto), whichever is earlier.

**Notes**

- (a) All prices of raw materials are exclusive of GST amount.
- (b) All prices excluding Aluminium & Copper are as on first working day of the month.
- (c) The details of prices are as under:

1. Price of Aluminium is LME average Cash SELLER Settlement price of Primary Aluminium in US\$ per MT as published by London Metal Bulletin (LME) including Premium for Aluminium Ingot in US\$ per MT is converted in Indian Rs./MT.
2. Price of PVC Compound (in Rs/MT) is the ex-works price, as quoted by the manufacturer.
3. Price of XLPE Compound (in Rs/MT) is the ex-works price, as quoted by the manufacturer.
4. Price of CC copper rods (in Rs/MT) is ex-works price as quoted by the primary producer.
5. Price of galvanized steel strip / steel wire (in Rs/MT) is ex-works price as quoted by the manufacturer for Round steel Wire and Flat steel strip (the relevant price of steel strip or steel wire is to be selected depending upon the type of armouring of the cable).

proud partners in implementation



MISSION PLAN  
2012-2022

HEAD OFFICE - DELHI  
 Rishyamook Building, First Floor, 85 A, Panchsukian Road, New Delhi - 110001, INDIA.  
 P +91 11 2336 3013 /14 • F +91 11 2336 3015 • E delhi@ieema.org • W www.ieema.org

2 page of 22

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1<sup>st</sup> November 217

## Price variation formulae for 'Power Cables'

## ✓ A. Aluminum conductor PVC insulated 1.1 kV power cables

$$P = P_0 + AIF (AL - A_0) + CCFAI (PVCc - PVCc_0) + FeF (Fe - Fe_0)$$

For unarmoured multicore cables (without steel armour); FeF = 0

Table References:

- ✓ ALP Aluminium conductor in single core unarmoured & multicore cables
- ✓ P1 Aluminium conductor aluminium armour in single core armoured cables
- ✓ P2 PVC compound
- ✓ P3 Steel armour

## ✓ B. Copper conductor PVC insulated 1.1 kV power cables

$$P = P_0 + CuF (Cu - Cu_0) + CCFCu (PVCc - PVCc_0) + FeF (Fe - Fe_0) + AIF (Al - Al_0)$$

For steel armoured cables; AIF = 0 For aluminium armoured cables; FeF = 0

For unarmoured cables; FeF, AIF = 0

Tables References:

- ✓ CUP Copper conductor
- ✓ P2 PVC compound
- ✓ P3 Steel armour
- ✓ P4 Aluminium armour

## C. Copper conductor PVC insulated 1.1 kV control cables

$$P = P_0 + CuF (Cu - Cu_0) + CCFCu (PVCc - PVCc_0) + FeF (Fe - Fe_0)$$

For unarmoured cables; FeF = 0

Tables References:

- ✓ CUC Copper conductor
- ✓ P5 PVC compound
- ✓ P6 Steel armour

## ✓ D. Aluminum conductor XLPE insulated 1.1 kV power cables

$$P = P_0 + AIF (AL - A_0) + XLFAL (CC - Cc_0) + CCFAI (PVCc - PVCc_0) + FeF (Fe - Fe_0)$$

For unarmoured multicore cables (without steel armour); FeF = 0

Table References:

- ALP Aluminium conductor in single core unarmoured & multicore cables
- P1 Aluminium conductor aluminium armour in single core armoured cables
- L2 Polymer (CCFAI)
- P3 Steel armour
- XL1 XLPE Compound (XLFAL)

## E. Copper conductor XLPE insulated 1.1 kV power cables

$$P = P_0 + CuF (Cu - Cu_0) + XLFCU (CC - Cc_0) + CCFCu (PVCc - PVCc_0) + FeF (Fe - Fe_0) + AIF (Al - Al_0)$$

For steel armoured cables; AIF = 0 For aluminium armoured cables; FeF = 0



## IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1<sup>st</sup> November 2017

For unarmoured cables; FeF, AIF = 0

Tables References:

✓CUP	Copper conductor
L2	Polymer (CCFCu)
P3	Steel armour
✓P4	Aluminium armour
XL1	XLPE Compound (XLFCu)

## F. Copper conductor XLPE insulated 1.1 kV control cables

$$P = P_o + CuF (Cu - Cu_o) + XLFCU (CC-Cco) + CCFCu (PVCc-PVCco) + FeF (Fe-Fe_o)$$

For unarmoured cables; FeF = 0

Tables References:

CUC	Copper conductor
P5	PVC compound
P6	Steel armour
XL2	XLPE Compound

## ✓ G. For Aluminium conductor XLPE insulated 3.3 to 33 kV power cables

$$P = P_o + AIF (Al - Al_o) + XLFAL (CC-Cco) + CCFAI (PVCc - PVCco) + FeF (Fe - Fe_o)$$

For unarmoured multicore cables (without steel armour); FeF = 0

Table References:

ALP	Aluminium conductor in single core unarmoured & multicore cables
H1	Aluminium conductor + aluminium armour in single core armoured cables
H2	Polymer
H3/H5	Steel armour (Flat/Round)
XL3/XL4	XLPE Compound (Single core /Multicore)

## ✓ H. Copper conductor XLPE Insulated 3.3 to 33 kV power cables

$$P = P_o + CuF (Cu - Cu_o) + XLFCU (CC-Cco) + CCFCu (PVCc - PVCco) + FeF (Fe - Fe_o) + AIF (Al - Al_o)$$

For steel armoured cables; AIF = 0 For aluminium armoured cables; FeF = 0  
For unarmoured cables; FeF, AIF = 0

Table References:

✓CUP	Copper conductor
✓H2	Polymer
✓H3/H5	Steel armour (Flat/Round)
✓H4	Aluminium armour
✓XL3/XL4	XLPE Compound (Single core /Multicore)

## I. Copper conductor XLPE insulated 1.0 and 1.5 kV Solar PV DC cables

$$P = P_o + CuF (Cu - Cu_o)$$

Table CUsdc Copper Conductor

*[Signature]*  
Authorized Signatory

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1<sup>st</sup> November 217

✓ TABLE ALP

VARIATION FACTOR FOR ALUMINIUM (AIF)  
POWER CABLES WITH ALUMINIUM CONDUCTOR  
(EXCLUDING SINGLE CORE ARMOURED CABLES)

Nominal Cross Sectional Area (in Sq. mm.)	1 core	2 core	3 core	3.5 core	4 core
2.5	0.007	0.014	0.021	-	0.028
4	0.011	0.023	0.034	-	0.046
6	0.017	0.034	0.052	-	0.069
10	0.029	0.053	0.087	-	0.116
16	0.046	0.091	0.137	-	0.183
25/16	0.073	0.146	0.219	0.262	0.292
35/16	0.101	0.202	0.302	0.345	0.404
50/25	0.137	0.273	0.410	0.478	0.547
70/35	0.197	0.395	0.593	0.687	0.791
95/50	0.274	0.548	0.821	0.949	1.095
120/70	0.346	0.691	1.035	1.221	1.382
150/70	0.425	0.853	1.279	1.464	1.706
185/95	0.533	1.070	1.605	1.861	2.140
225/120	0.655	1.310	1.965	2.287	2.620
240/120	0.703	1.400	2.099	2.421	2.799
300/150	0.879	1.757	2.635	3.033	3.514
400/185	1.126	2.249	3.374	3.873	4.498
500	1.418	2.838	4.256	-	5.675
630	1.828	3.663	5.494	-	7.326
800	2.340	4.679	7.018	-	9.357
1000	2.951	5.890	8.934	-	11.779

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1<sup>st</sup> November 217

TABLE CUP

VARIATION FACTOR FOR COPPER CONDUCTOR (CUF)  
POWER CABLES WITH COPPER CONDUCTOR

Nominal Cross Sectional Area (in Sq. mm.)	1 core	2 core	3 core	3.5 core	4 core
2.5	0.023	0.046	0.069	-	0.092
4	0.036	0.076	0.112	-	0.151
6	0.056	0.112	0.171	-	0.227
10	0.095	0.174	0.286	-	0.382
16	0.151	0.299	0.451	-	0.602
25/16	0.240	0.480	0.720	0.862	0.960
35/16	0.332	0.664	0.993	1.135	1.329
50/25	0.451	0.898	1.348	1.572	1.799
70/35	0.648	1.299	1.950	2.260	2.602
95/50	0.901	1.802	2.700	3.121	3.601
120/70	1.138	2.273	3.407	4.016	4.545
150/70	1.398	2.806	4.207	4.815	5.611
185/95	1.753	3.519	5.279	6.121	7.038
225/120	2.154	4.309	6.463	7.522	8.617
240/120	2.312	4.605	6.904	7.963	9.206
300/150	2.891	5.779	8.667	9.976	11.558
400/185	3.703	7.397	11.097	12.738	14.794
500	4.664	9.334	13.998	-	18.665
630	6.012	12.048	18.070	-	24.095
800	7.696	15.389	23.082	-	30.775
1000	9.706	19.372	29.055	-	38.741

TABLE CUsdc

VARIATION FACTOR FOR COPPER CONDUCTOR (CUF)  
1.0 & 1.5KV Solar PV DC Cables with Copper Conductor

Cable Size in sq.mm.	Copper content in MT/km
2.5	0.023
4	0.038
6	0.058
10	0.090

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1<sup>st</sup> November 217

TABLE CUC

VARIATION FACTOR FOR COPPER CONDUCTOR (CUF) ✓  
CONTROL CABLES WITH COPPER CONDUCTOR

No of Cores	Core size 1.5 sq mm	Core size 2.5 sq mm
2	0.026	0.047
3	0.039	0.070
4	0.052	0.094
5	0.065	0.117
6	0.078	0.141
7	0.091	0.164
8	0.110	0.182
9	0.117	0.205
10	0.130	0.235
12	0.157	0.282
14	0.183	0.329
16	0.209	0.376
18	0.246	0.410
19	0.248	0.446
20	0.260	0.456
24	0.313	0.563
27	0.352	0.634
30	0.391	0.704
37	0.483	0.869
44	0.573	1.033
52	0.678	1.221
61	0.796	1.432

IEEMA (PVC)/CABLE(R-1)/2017  
TABLE P1

Effective from: 1<sup>st</sup> November 2017

VARIATION FACTOR FOR ALUMINIUM (AIF)  
ALUMINIUM ARMoured SINGLE CORE PVC INSULATED 1.1 KV CABLES

Nominal cross sectional area (in Sq.mm)	Aluminium factor for Aluminium armoured cable with aluminium conductor
4	0.0685
6	0.0795
10	0.1017
16	0.1303
25	0.1693
35	0.2090
50	0.2597
70	0.3360
95	0.4567
120	0.5443
150	0.6427
185	0.7743
240	0.9737
300	1.2582
400	1.5502
500	1.8958
630	2.3650
800	2.9306
1000	3.7666

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1<sup>st</sup> November 217

TABLE P2

VARIATION FACTOR FOR PVC COMPOUND ( CCFAl/CCFCu)  
PVC INSULATED 1.1 KV POWER CABLES WITH COPPER/ALUMINIUM CONDUCTOR

Nominal cross Sectional Area (in Sq. mm)	1 core		2 core		3 core		3.5 core		4 core	
	Unarm	Unarm	arm	Unarm	arm	Unarm	arm	Unarm	arm	
2.5	0.079	0.125	0.139	0.141	0.157	-	-	0.161	0.179	
4	0.094	0.140	0.156	0.164	0.182	-	-	0.188	0.209	
6	0.101	0.154	0.171	0.179	0.199	-	-	0.198	0.220	
10	0.114	0.194	0.216	0.214	0.238	-	-	0.249	0.277	
16	0.142	0.234	0.246	0.279	0.290	-	-	0.328	0.345	
25	0.171	0.288	0.303	0.364	0.383	0.422	0.444	0.443	0.466	
35	0.189	0.321	0.338	0.403	0.429	0.489	0.515	0.498	0.524	
50	0.211	0.411	0.433	0.508	0.535	0.613	0.645	0.647	0.681	
70	0.241	-	-	0.613	0.645	0.707	0.744	-	-	
95	0.284	-	-	0.795	0.811	0.908	0.927	-	-	
120	0.339	-	-	0.866	0.884	1.024	1.045	-	-	
150	0.388	-	-	1.070	1.092	1.289	1.315	-	-	
185	0.450	-	-	1.310	1.337	1.499	1.530	-	-	
225	0.521	-	-	1.586	1.618	1.840	1.878	-	-	
240	0.534	-	-	1.649	1.683	1.990	2.031	-	-	
300	0.653	-	-	2.007	2.048	2.361	2.409	-	-	
400	0.770	-	-	2.437	2.487	2.616	2.669	-	-	
500	0.936	-	-	3.117	3.181	3.687	3.762	-	-	
630	1.175	-	-	-	-	-	-	-	-	
800	1.433	-	-	-	-	-	-	-	-	
1000	1.642	-	-	-	-	-	-	-	-	

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1<sup>st</sup> November 2017

TABLE P3

VARIATION FACTOR FOR STEEL (FeF)  
PVC INSULATED 1.1 KV POWER CABLES WITH COPPER/ALUMINIUM CONDUCTOR

Nominal Cross sectional Area (in Sq. mm)	2 core	Shape	3 core	Shape	3 ½ core	Shape	4 core	Shape
4	0.305	W	0.335	W	-	-	0.363	W
6	0.348	W	0.363	W	-	-	0.407	W
10	0.392	W	0.407	W	-	-	0.293	F
16	0.235	F	0.293	F	-	-	0.323	F
25	0.293	F	0.352	F	0.382	F	0.382	F
35	0.323	F	0.382	F	0.411	F	0.440	F
50	0.382	F	0.440	F	0.469	F	0.499	F
70	0.411	F	0.499	F	-	F	0.587	F
95	0.499	F	0.587	F	0.616	F	0.645	F
120	0.528	F	0.616	F	0.675	F	0.731	F
150	0.587	F	0.675	F	0.731	F	0.790	F
185	0.645	F	0.761	F	0.820	F	0.879	F
240	0.731	F	0.879	F	0.937	F	0.996	F
300	0.820	F	0.966	F	1.055	F	1.113	F
400	0.937	F	1.083	F	1.172	F	1.231	F
500	1.055	F	1.231	F	1.348	F	1.406	F
630	1.172	F	-	-	-	-	-	-

IEEMA (PVC)/CABLE(R-1)/2017  
TABLE P3 (Additional)

Effective from: 1<sup>st</sup> November 2017

VARIATION FACTOR FOR ROUND WIRE 'W' STEEL (FeF)  
PVC INSULATED 1.1 KV POWER CABLES WITH COPPER/ALUMINIUM CONDUCTOR

Nominal Cross Sectional Area (in sq. mm)	2 Core	3 Core	3.5 Core	4 Core
1.5	0.247	0.259		0.288
2.5	0.273	0.289		0.329
4	0.305	0.335		0.363
6	0.348	0.363		0.407
10	0.392	0.407		0.533
16	0.439	0.523	0.014	0.573
25	0.526	0.625	0.664	0.685
35	0.591	0.685	0.729	0.761
50	0.661	0.790	0.864	1.108
70	0.745	1.122	1.200	1.256
95	1.085	1.286	1.376	1.443
120	1.147	1.386	1.479	1.562
150	1.267	1.526	1.684	2.173
185	1.403	2.090	2.315	2.421
240	1.994	2.397	2.641	2.722
300	2.180	2.642	3.670	3.842
400	2.987	3.728	4.126	4.292
500	3.517	4.226	5.958	6.301
630	4.774	6.018	6.737	7.141

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1<sup>st</sup> November 217

TABLE P4

VARIATION FACTOR FOR ALUMINIUM (AIF)  
PVC INSULATED 1.1 KV POWER CABLES WITH COPPER CONDUCTOR

Nominal Cross Sectional Area (in Sq. mm)	Aluminium Factor for Aluminium armoured cable with copper conductor
4	0.058
6	0.063
10	0.073
16	0.084
25	0.096
35	0.108
50	0.123
70	0.139
95	0.183
120	0.198
150	0.218
185	0.241
240	0.271
300	0.379
400	0.424
500	0.478
630	0.537
800	0.591
1000	0.816

TABLE P5

VARIATION FACTOR FOR PVC COMPOUND (CCFCu)  
PVC INSULATED CONTROL CABLES WITH COPPER CONDUCTOR

No of cores	Core size 1.5 sq mm		Core size 2.5 sq mm	
	Unarm	Arm	Unarm	Arm
2	0.118	0.121	0.125	0.139
3	0.121	0.131	0.141	0.157
4	0.137	0.152	0.161	0.179
5	0.157	0.174	0.187	0.206
6	0.179	0.199	0.234	0.260
7	0.179	0.199	0.234	0.260
8	0.193	0.215	0.292	0.325
9	0.216	0.241	0.300	0.335
10	0.236	0.262	0.303	0.337
12	0.249	0.277	0.334	0.371
14	0.311	0.327	0.389	0.409
16	0.344	0.362	0.435	0.458
18	0.352	0.371	0.474	0.500
19	0.375	0.395	0.476	0.501
20	0.391	0.412	0.519	0.546
24	0.457	0.481	0.584	0.615
27	0.491	0.517	0.631	0.664
30	0.529	0.557	0.706	0.743
37	0.615	0.647	0.835	0.879
44	0.739	0.778	1.019	1.026
52	0.845	0.889	1.100	1.158
61	0.952	1.002	1.246	1.312

IEEMA (PVC)/CABLE(R-1)/2017  
TABLE P6

Effective from: 1<sup>st</sup> November 217

VARIATION FACTOR FOR STEEL (FeF)  
PVC INSULATED CONTROL CABLES WITH COPPER CONDUCTOR

No of cores	Core size 1.5 sq mm	Shape of armour	Core size 2.5 sq mm	Shape of armour
2	0.243	W	0.277	W
3	0.257	W	0.289	W
4	0.277	W	0.314	W
5	0.303	W	0.342	W
6	0.329	W	0.379	W
7	0.329	W	0.379	W
8	0.341	W	0.456	W
9	0.383	W	0.275	F
10	0.408	W	0.325	F
12	0.289	F	0.342	F
14	0.306	F	0.360	F
16	0.317	F	0.372	F
18	0.332	F	0.350	F
19	0.343	F	0.397	F
20	0.368	F	0.400	F
24	0.398	F	0.475	F
27	0.414	F	0.478	F
30	0.425	F	0.503	F
37	0.461	F	0.548	F
44	0.507	F	0.601	F
52	0.556	F	0.641	F
61	0.585	F	0.685	F

IEEMA (PVC)/CABLE(R-1)/2017  
TABLE P6 (Additional)

Effective from: 1<sup>st</sup> November 217

VARIATION FACTOR FOR ROUND WIRE 'W' STEEL (FeF).  
PVC INSULATED CONTROL CABLES WITH COPPER CONDUCTOR

No. of Cores	Core size 1.5 sq mm	Core size 2.5 sq mm
2	0.243	0.273
3	0.257	0.289
4	0.277	0.314
5	0.303	0.342
6	0.329	0.379
7	0.329	0.379
8	0.341	0.456
9	0.383	0.508
10	0.408	0.535
12	0.510	0.572
14	0.546	0.625
16	0.581	0.660
19	0.608	0.696
24	0.714	0.819
25	0.679	0.798
27	0.732	0.837
28	0.696	0.815
30	0.758	0.881
33	0.747	0.883
37	0.820	1.217
44	0.926	1.355
48	1.122	1.308
50	1.122	1.308
52	1.149	1.361
56	1.202	1.388
61	1.299	1.520

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1<sup>st</sup> November 217

TABLE L2

VARIATION FACTOR FOR POLYMER (CCFAI / CCFCu)  
XLPE INSULATED 1.1 KV POWER CABLES WITH COPPER / ALUMINIUM CONDUCTOR

Nominal Cross Sectional Area (In Sq. mm)	1 core		2 core		3 core		3.5 core		4 core	
	Unarm.	Unarm	Arm	Unarm	Arm	Unarm	Arm	Unarm	Arm	
2.5	0.055	0.163	0.175	0.166	0.177	-	-	0.177	0.188	
4	0.075	0.201	0.204	0.205	0.213	-	-	0.218	0.213	
6	0.085	0.213	0.234	0.205	0.230	-	-	0.242	0.232	
10	0.082	0.252	0.280	0.217	0.251	-	-	0.285	0.298	
16	0.089	0.278	0.341	0.289	0.246	-	-	0.300	0.279	
25	0.101	0.307	0.278	0.276	0.247	0.295	0.264	0.331	0.290	
35	0.109	0.330	0.319	0.305	0.270	0.328	0.292	0.368	0.319	
50	0.124	0.482	0.685	0.348	0.311	0.372	0.335	0.422	0.394	
70	0.146	0.354	0.335	0.469	0.397	0.489	0.420	0.528	0.464	
95	0.163	0.436	0.389	0.504	0.441	0.544	0.471	0.591	0.523	
120	0.176	0.475	0.421	0.556	0.498	0.599	0.538	0.722	0.656	
150	0.217	0.510	0.490	0.690	0.611	0.717	0.633	0.840	0.762	
185	0.236	0.631	0.608	0.836	0.738	0.854	0.756	1.007	0.899	
240	0.273	0.750	0.726	1.002	0.842	1.079	0.952	1.238	1.119	
300	0.303	0.919	0.887	1.161	1.012	1.170	1.031	1.457	1.414	
400	0.372	1.093	1.040	1.376	1.283	1.545	1.379	1.778	1.626	
500	0.413	1.342	-	1.568	1.400	1.806	1.456	-	-	
630	0.469	1.546	-	-	-	-	-	-	-	
800	0.569	-	-	-	-	-	-	-	-	
1000	0.667	-	-	-	-	-	-	-	-	

225 removed ↓

L2 LL R2

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1<sup>st</sup> November 217

TABLE XL1  
VARIATION FACTOR FOR XLPE COMPOUND ( XLFAL/XLFUCU)  
XLPE INSULATED 1.1 KV POWER CABLES WITH COPPER/ALUMINIUM CONDUCTOR

Nominal cross Sectional Area (in.Sq. mm)	1 core		2 core		3 core		3.5 core		4 core	
	Unarm	Arm	Unarm	Arm	Unarm	arm	Unarm	Arm	Unarm	arm
2.5	0.007	0.010	0.014	0.014	0.021	0.021			0.028	0.028
4	0.009	0.012	0.018	0.018	0.027	0.027			0.036	0.036
6	0.010	0.015	0.022	0.022	0.033	0.033			0.043	0.043
10	0.013	0.018	0.025	0.025	0.039	0.039			0.053	0.053
16	0.016	0.023	0.034	0.034	0.049	0.049			0.065	0.065
25	0.021	0.030	0.048	0.048	0.070	0.070	0.084	0.084	0.093	0.093
35	0.025	0.035	0.059	0.059	0.084	0.084	0.099	0.099	0.112	0.112
50	0.033	0.044	0.075	0.075	0.108	0.108	0.130	0.130	0.144	0.144
70	0.042	0.054	0.095	0.095	0.137	0.137	0.160	0.160	0.179	0.179
95	0.048	0.062	0.110	0.110	0.160	0.160	0.190	0.190	0.211	0.211
120	0.060	0.076	0.138	0.138	0.200	0.200	0.239	0.239	0.266	0.266
150	0.078	0.095	0.180	0.180	0.259	0.259	0.296	0.296	0.344	0.344
185	0.097	0.116	0.224	0.224	0.324	0.324	0.369	0.369	0.430	0.430
240	0.116	0.137	0.266	0.266	0.388	0.388	0.446	0.446	0.518	0.518
300	0.138	0.164	0.325	0.325	0.467	0.467	0.540	0.540	0.620	0.620
400	0.175	0.214	0.357	0.357	0.536	0.536	0.619	0.619	0.714	0.714
500	0.217	0.260	0.440	0.440	0.660	0.660	0.769	0.769	0.880	0.880
630	0.265	0.318	0.542	0.542	0.814	0.814	0.941	0.941	1.085	1.085
800	0.323	0.389								
1000	0.375	0.444								

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1<sup>st</sup> November 2017

**TABLE XL2**  
**VARIATION FACTOR FOR XLPE COMPOUND (XLFCU)**  
**XLPE INSULAYTED CONTROL CABLES WITH COPPER CONDUCTOR**

No of cores	Core size 1.5 sq mm		Core size 2.5 sq mm	
	Unarm	Arm	Unarm	Arm
2	0.010	0.010	0.012	0.012
3	0.016	0.016	0.018	0.018
4	0.021	0.021	0.025	0.025
5	0.026	0.026	0.031	0.031
6	0.031	0.031	0.037	0.037
7	0.036	0.036	0.043	0.043
8	0.036	0.036	0.043	0.043
9	0.042	0.042	0.049	0.049
10	0.052	0.052	0.061	0.061
12	0.062	0.062	0.074	0.074
14	0.073	0.073	0.086	0.086
16	0.083	0.083	0.098	0.098
18	0.094	0.094	0.110	0.110
19	0.099	0.099	0.116	0.116
20	0.104	0.104	0.123	0.123
24	0.125	0.125	0.147	0.147
27	0.140	0.140	0.165	0.165
30	0.156	0.156	0.184	0.184
37	0.192	0.192	0.227	0.227
44	0.229	0.229	0.270	0.270
52	0.270	0.270	0.319	0.319
61	0.317	0.317	0.374	0.374

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1<sup>st</sup> November 217

TABLE XL3

VARIATION FACTOR FOR XLPE (XLFAI/XLFCU)

SINGLE CORE ARMoured / UNARMoured XLPE INSULATED 3.3 to 33 KV POWER CABLES WITH CU / AL CONDUCTOR

Nominal Cross Sectional Area (in Sq. mm.)	XLPE Factor for Armoured/ Unarmoured Cable with AL / CU Conductor					
	3.3 KV	6.6 KV (E)	11 KV (E)/ 6.6 KV (UE)	11 KV (UE)	22 KV (E)	33 KV (E)
25	0.110	0.131	0.170	0.279		
35	0.122	0.137	0.175	0.284	0.317	0.522
50	0.135	0.151	0.191	0.307	0.341	0.563
70	0.155	0.172	0.215	0.342	0.379	0.615
95	0.174	0.193	0.241	0.377	0.417	0.670
120	0.192	0.212	0.262	0.407	0.449	0.713
150	0.209	0.229	0.283	0.437	0.481	0.757
185	0.228	0.250	0.308	0.471	0.518	0.809
240	0.255	0.279	0.343	0.519	0.569	0.883
300	0.280	0.322	0.372	0.560	0.613	0.943
400	0.326	0.392	0.420	0.625	0.683	1.041
500	0.388	0.461	0.469	0.694	0.757	1.142
630	0.467	0.520	0.529	0.777	0.845	1.265
800	0.567	0.593	0.602	0.874	0.949	1.407
1000	0.656	0.665	0.660	0.955	1.036	1.525

Note : XLPE factors include Semicons for Conductor & Insulation screen

TABLE - XL4

VARIATION FACTOR FOR XLPE (CCF1A/ CCF1Cu)

3 CORE XLPE INSULATED 3.3 to 33 KV POWER CABLES WITH COPPER / ALUMINIUM CONDUCTOR

Nominal Cross Sectional Area (in Sq. mm)	3.3 KV	6.6 KV (E)	6.6 KV (UE) / 11 KV (E)	11 KV (UE)	22 KV (E)	33 KV (E)
	ARM	ARM	ARM	ARM	ARM	ARM
25	0.315	0.394	0.511	0.838		
35	0.339	0.427	0.545	0.880	0.982	1.638
50	0.378	0.474	0.600	0.957	1.065	1.751
70	0.435	0.541	0.679	1.067	1.183	1.916
95	0.489	0.604	0.755	1.171	1.295	2.071
120	0.537	0.661	0.822	1.265	1.396	2.210
150	0.585	0.719	0.890	1.359	1.497	2.350
185	0.642	0.784	0.968	1.468	1.614	2.513
240	0.717	0.873	1.074	1.615	1.773	2.732
300	0.781	1.006	1.167	1.744	1.928	2.919
400 ✓	0.886 ✓	1.227 ✓	1.314 ✓	1.948 ✓	2.130 ✓	3.229 ✓
500	0.956	1.421	1.445	2.148	2.381	3.538
630	1.129	1.582	1.609	2.382	2.630	3.940

Note : XLPE factors include Semicons for Conductor & Insulation screen

Add 1/2

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1<sup>st</sup> November 217

**TABLE H1**  
**VARIATION FACTOR FOR ALUMINIUM (AIF)**  
**ALUMINIUM ARMoured SINGLE CORE XLPE INSULATED 3.3 TO 33 KV CABLES**

Nominal Cross Sectional Area (in Sq. mm.)	Aluminium Factor for Aluminium Armoured Cable with Aluminium Conductor					
	3.3 KV	6.6 KV (E)	11 KV (E)/ 6.6 KV (UE)	11 KV (UE)	22 KV (E)	33 KV (E)
35	0.251	0.284	0.301	0.344	0.358	0.473
50	0.312	0.336	0.352	0.397	0.408	0.672
70	0.385	0.409	0.423	0.469	0.501	0.723
95	0.476	0.500	0.518	0.637	0.656	0.856
120	0.561	0.586	0.601	0.726	0.744	0.949
150	0.653	0.678	0.696	0.823	0.842	1.050
185	0.773	0.797	0.893	0.949	0.965	1.183
240	0.997	1.063	1.083	1.139	1.154	1.387
300	1.209	1.271	1.283	1.333	1.307	1.753
400	1.438	1.556	1.565	1.620	1.636	2.046
500	1.873	1.901	1.910	2.110	2.128	2.484
630	2.337	2.361	2.369	2.580	2.595	2.978
800	3.007	3.071	3.080	3.145	3.163	3.588
1000	3.737	3.741	3.749	3.804	3.822	4.565

**TABLE H2**  
**VARIATION FACTOR FOR POLYMER (CCFAI / CCFCu)**  
**3 CORE XLPE INSULATED 3.3 TO 33 KV POWER CABLES WITH COPPER / ALUMINIUM CONDUCTOR**

Nominal Cross Sectional Area (in Sq. mm)	3.3 KV ARM	6.6 KV (E) ARM	6.6 KV (UE) / 11 KV (E) ARM	11 KV (UE) ARM	22 KV (E) ARM	33 KV (E) ARM
35	0.374	0.990	1.142	1.604	1.782	-
50	0.445	1.119	1.260	1.834	2.046	2.864
70	0.547	1.290	1.396	2.011	2.284	3.219
95	0.594	1.440	1.647	2.269	2.428	3.367
120	0.732	1.692	1.877	2.498	2.715	3.646
150	0.812	1.906	2.061	2.767	2.931	3.927
185	0.960	2.086	2.406	3.028	3.180	4.166
240	1.130	2.484	2.744	3.398	3.580	4.589
300	1.219	2.912	3.161	3.840	4.016	5.029
400	1.313	3.530	3.664	4.353	4.666	5.736
500	1.652	3.925	3.971	4.621	4.878	5.913
630	1.949	4.487	4.982	5.225	5.477	6.696

Fillers added in PVC consumption

Added →  
Added →

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1<sup>st</sup> November 217

TABLE H3  
VARIATION FACTOR FOR STEEL (FeF)  
XLPE INSULATED 3.3 TO 33 KV POWER CABLES WITH COPPER / ALUMINIUM CONDUCTOR

Nominal Cross Sectional Area Sq. mm.	3.3 KV	6.6 KV (E)	11 KV (E) / 6.6 KV (UE)	11 KV (UE)	22 KV (E)	33 KV (E)
25	0.551	0.604	0.656	0.814		
35	0.645	0.645	0.731	0.879	0.937	-
50	0.675	0.703	0.761	0.937	0.966	1.181
70	0.761	0.761	0.849	0.996	1.055	1.289
95	0.820	0.849	0.907	1.083	1.113	1.348
120	0.879	0.907	0.966	1.142	1.172	1.406
150	0.966	0.966	1.055	1.201	1.259	1.494
185	1.025	1.055	1.113	1.259	1.318	1.553
240	1.142	1.142	1.231	1.377	1.406	1.641
300	1.231	1.259	1.318	1.465	1.524	1.758
400	1.348	1.406	1.435	1.582	1.641	1.876

IEEMA (PVC)/CABLE(R-1)/2017

Effective from: 1<sup>st</sup> November 217

**TABLE H4**  
**VARIATION FACTOR FOR ALUMINIUM (AIF)**

XLPE INSULATED SINGLE CORE 3.3 TO 33 KV POWER CABLES WITH COPPER CONDUCTOR


Nominal Cross Sectional Area (in Sq. mm.)	Aluminium Factor for Aluminium Armoured Cable with Copper Conductor					
	3.3 KV	6.6 KV (E)	11 KV (E)/ 6.6 KV (UE)	11 KV (UE)	22 KV (E)	33 KV (E)
35	0.153	0.187	0.204	0.247	0.258	0.372
50	0.179	0.203	0.220	0.262	0.275	0.425
70	0.196	0.219	0.233	0.278	0.311	0.444
95	0.213	0.237	0.254	0.373	0.392	0.470
120	0.228	0.253	0.268	0.393	0.410	0.488
150	0.243	0.269	0.287	0.414	0.432	0.504
185	0.261	0.285	0.381	0.437	0.455	0.526
240	0.324	0.389	0.410	0.465	0.480	0.556
300	0.365	0.428	0.440	0.490	0.510	0.737
400	0.432	0.471	0.480	0.536	0.552	0.783
500	0.489	0.517	0.526	0.726	0.744	0.844
630	0.544	0.568	0.572	0.787	0.801	0.902
800	0.706	0.787	0.797	0.862	0.880	0.982
1000	0.824	0.865	0.867	0.923	0.940	1.324

**TABLE - H5**  
**VARIATION FACTOR FOR STEEL (FeW)**

XLPE INSULATED 3.3KV TO 33 KV POWER CABLES WITH COPPER / ALUMINIUM CONDUCTOR

Nominal Cross Sectional Area in Sq. mm	3.3/3.3 KV	3.3/6.6 KV	11 KV (E) / 6.6 KV (UE)	11 KV (UE)	22 KV (E)	33 KV (E)
25	1.258	1.457	1.612	2.509	1.503	--
35	1.361	1.569	1.853	2.644	2.797	2.517
50	1.682	1.687	2.321	2.800	2.921	4.569
70	2.033	1.979	2.503	3.219	3.347	4.809
95	2.202	2.507	2.718	4.019	4.200	5.437
120	2.371	2.675	2.882	4.241	4.416	6.713
150	2.870	2.847	3.265	4.447	4.621	6.976
185	3.121	3.309	4.148	4.726	5.289	7.356
240	3.758	4.227	4.442	5.442	6.651	7.718
300	4.099	5.024	5.182	6.894	7.084	8.187
400	5.750	6.572	6.658	7.433	7.657	8.760
500	6.716	6.777	6.861	7.588	7.797	8.830
630	7.492	7.465	7.177	8.209	8.386	9.413

*Added* →  
*Added* →

	<b>PROJECT ENGINEERING MANAGEMENT</b>	<b>GENERAL CONDITIONS OF CONTRACT (GCC)</b>  <b>Revision no. 07</b>	<b>ANNEXURES</b>
---	---	---	------------------

## ANNEXURE– VIII

### INTEGRITY PACT

#### Between

Bharat Heavy Electricals Ltd. (BHEL), a company registered under the Companies Act 1956 and having its registered office at “BHEL House”, Siri Fort, New Delhi – 110049 (India) hereinafter referred to as “The Principal”, which expression unless repugnant to the context or meaning hereof shall include its successors or assigns of the ONE PART

#### and

\_\_\_\_\_, (description of the party along with address), hereinafter referred to as “The Bidder/ Contractor” which expression unless repugnant to the context or meaning hereof shall include its successors or assigns of the OTHER PART

#### Preamble

The Principal intends to award, under laid-down organizational procedures, contract/s for

\_\_\_\_\_. The Principal values full compliance with all relevant laws of the land, rules and regulations, and the principles of economic use of resources, and of fairness and transparency in its relations with its Bidder(s)/ Contractor(s).

In order to achieve these goals, the Principal will appoint Independent External Monitor(s), who will monitor the tender process and the execution of the contract for compliance with the principles mentioned above.

#### **Section 1 – Commitments of the Principal**

1.1 The Principal commits itself to take all measures necessary to prevent corruption and to observe the following principles: -

1.1.1 No employee of the Principal, personally or through family members, will in connection with the tender for, or the execution of a contract, demand, take a promise for or accept, for self or third person, any material or immaterial benefit which the person is not legally entitled to.


1.1.2 The Principal will, during the tender process treat all Bidder(s) with equity and reason. The Principal will in particular, before and during the tender process, provide to all Bidder(s) the same information and will not provide to any Bidder(s) confidential / additional information through which the Bidder(s) could obtain an advantage in relation to the tender process or the contract execution.

1.1.3 The Principal will exclude from the process all known prejudiced persons.

1.2 If the Principal obtains information on the conduct of any of its employees which is a penal offence under the Indian Penal Code 1860 and Prevention of Corruption Act 1988 or any other statutory penal enactment, or if there be a substantive suspicion in this regard, the Principal will inform its Vigilance Office and in addition can initiate disciplinary actions.

#### **Section 2 – Commitments of the Bidder(s)/ Contractor(s)**

2.1 The Bidder(s)/ Contractor(s) commit himself to take all measures necessary to prevent corruption. He commits

	<b>PROJECT ENGINEERING MANAGEMENT</b>	<b>GENERAL CONDITIONS OF CONTRACT (GCC)</b>  <b>Revision no. 07</b>	<b>ANNEXURES</b>
---	---	---	------------------

himself to observe the following principles during his participation in the tender process and during the contract execution.

2.1.1 The Bidder(s)/ Contractor(s) will not, directly or through any other person or firm, offer, promise or give to the Principal or to any of the Principal's employees involved in the tender process or the execution of the contract or to any third person any material, immaterial or any other benefit which he / she is not legally entitled to, in order to obtain in exchange any advantage of any kind whatsoever during the tender process or during the execution of the contract.

2.1.2 The Bidder(s)/ Contractor(s) will not enter with other Bidder(s) into any illegal or undisclosed agreement or understanding, whether formal or informal. This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to introduce cartelization in the bidding process.

2.1.3 The Bidder(s)/ Contractor(s) will not commit any penal offence under the relevant IPC/ PC Act; further the Bidder(s)/ Contractor(s) will not use improperly, for purposes of competition or personal gain, or pass on to others, any information or document provided by the Principal as part of the business relationship, regarding plans, technical proposals and business details, including information contained or transmitted electronically.

2.1.4 Foreign Bidder(s)/ Contractor(s) shall disclose the name and address of agents and representatives in India and Indian Bidder(s)/ Contractor(s) to disclose their foreign principals or associates. The Bidder(s)/ Contractor(s) will, when presenting his bid, disclose any and all payments he has made, and is committed to or intends to make to agents, brokers or any other intermediaries in connection with the award of the contract.

2.2 The Bidder(s)/ Contractor(s) will not instigate third persons to commit offences outlined above or be an accessory to such offences.

2.3 The Bidder(s)/ Contractor(s) shall not approach the Courts while representing the matters to IEMs and will await their decision in the matter.

### **Section 3 – Disqualification from tender process & exclusion from future contracts**

If the Bidder(s)/ Contractor(s), before award or during execution has committed a transgression through a violation of Section 2 above, or acts in any other manner such as to put his reliability or credibility in question, the Principal is entitled to disqualify the Bidder(s)/ Contractor(s) from the tender process or take action as per the separate "Guidelines on Banning of Business dealings with Suppliers/ Contractors". framed by the Principal.


### **Section 4 – Compensation for Damages**

4.1 If the Principal has disqualified the Bidder from the tender process prior to the award according to Section 3, the Principal is entitled to demand and recover the damages equivalent Earnest Money Deposit/Bid Security.

4.2 If the Principal has terminated the contract according to Section 3, or if the Principal is entitled to terminate the contract according to section 3, the Principal shall be entitled to demand and recover from the Contractor liquidated damages equivalent to 5% of the contract value or the amount equivalent to Security Deposit/Performance Bank Guarantee, whichever is higher.

### **Section 5 – Previous Transgression**

5.1 The Bidder declares that no previous transgressions occurred in the last 3 years with any other company in any country conforming to the anti-corruption approach or with any other Public Sector Enterprise in India that could justify his exclusion from the tender process.

	<b>PROJECT ENGINEERING MANAGEMENT</b>	<b>GENERAL CONDITIONS OF CONTRACT (GCC)</b>  <b>Revision no. 07</b>	<b>ANNEXURES</b>
---	---	---	------------------

5.2 If the Bidder makes incorrect statement on this subject, he can be disqualified from the tender process or the contract, if already awarded, can be terminated for such reason.

**Section 6 – Equal treatment of all Bidders/ Contractors/ Sub-contractors**

6.1 The Principal will enter into agreements with identical conditions as this one with all Bidders and Contractors. In case of sub-contracting, the Principal contractor shall be responsible for the adoption of IP by his sub-contractors and shall continue to remain

responsible for any default by his sub-contractors.

6.2 The Principal will disqualify from the tender process all bidders who do not sign this pact or violate its provisions.

**Section 7 – Criminal Charges against violating Bidders / Contractors / Sub-contractors**

If the Principal obtains knowledge of conduct of a Bidder, Contractor or Subcontractor, or of an employee or a representative or an associate of a Bidder, Contractor or Subcontractor which constitutes corruption, or if the Principal has substantive suspicion in this regard, the Principal will inform the Vigilance Office.

**Section 8 –Independent External Monitor(s)**

8.1 The Principal appoints competent and credible Independent External Monitor for this Pact. The task of the Monitor is to review independently and objectively, whether and to what extent the parties comply with the obligations under this agreement.

8.2 The Monitor is not subject to instructions by the representatives of the parties and performs his functions neutrally and independently. He reports to the CMD, BHEL.


8.3 The Bidder(s)/ Contractor(s) accepts that the Monitor has the right to access without restriction to all contract documentation of the Principal including that provided by the Bidder(s)/ Contractor(s). The Bidder(s)/ Contractor(s) will grant the monitor, upon his request and demonstration of a valid interest, unrestricted and unconditional access to his contract documentation. The same is applicable to Sub-contractor(s). The Monitor is under contractual obligation to treat the information and documents of the Bidder(s)/ Contractor(s) / Sub-contractor(s) with confidentiality in line with Non-disclosure agreement.

8.4 The Principal will provide to the Monitor sufficient information about all meetings among the parties related to the contract provided such meetings could have an impact on the contractual relations between the Principal and the Contractor. The parties offer to the Monitor the option to participate in such meetings.

8.5 The role of IEMs is advisory, would not be legally binding and it is restricted to resolving issues raised by an intending bidder regarding any aspect of the tender which allegedly restricts competition or bias towards some bidders. At the same time, it must be understood that IEMs are not consultants to the Management. Their role is independent in nature and the advice once tendered would not be subject to review at the request of the organization.

8.6 For ensuring the desired transparency and objectivity in dealing with the complaints arising out of any tendering process, the matter should be examined by the full panel of IEMs jointly as far as possible, who would look into the records, conduct an investigation, and submit their joint recommendations to the Management.

8.7 The IEMs would examine all complaints received by them and give their recommendations! views to CMD, BHEL, at the earliest. They may also send their report directly to the CVO and the Commission, in case of suspicion of serious

	<b>PROJECT ENGINEERING MANAGEMENT</b>	<b>GENERAL CONDITIONS OF CONTRACT (GCC)</b>  <b>Revision no. 07</b>	<b>ANNEXURES</b>
---	---	---	------------------

irregularities requiring legal! administrative action. IEMs will tender their advice on the complaints within 10 days as far as possible.

8.8The CMD, BHEL shall decide the compensation to be paid to the Monitor and its terms and conditions.

8.9IEM should examine the process integrity, they are not expected to concern themselves with fixing of responsibility of officers. Complaints alleging mala fide on the part of any officer of the organization should be looked into by the CVO of the concerned organization.

8.10If the Monitor has reported to the CMD, BHEL, a substantiated suspicion of an offence under relevant Indian Penal Code! Prevention of Corruption Act, and the CMD, BHEL has not, within reasonable time, taken visible action to proceed against such offence or reported it to the Vigilance Office, the Monitor may also transmit this information directly to the Central Vigilance Commissioner, Government of India.

8.11The number of Independent External Monitor(s) shall be decided by the CMD, BHEL.

8.12The word 'Monitor' would include both singular and plural.

**Section 9 – Pact Duration**

9.1This Pact shall be operative from the date IP is signed by both the parties till the final completion of contract for successful bidder and for all other bidders 6 months after the contract has been awarded. Issues like warranty! guarantee etc. should be outside the purview of IEMs.

9.2If any claim is made / lodged during this time, the same shall be binding and continue to be valid despite the lapse of this pact as specified as above, unless it is discharged/ determined by the CMD, BHEL.

**Section 10 – Other Provisions**

10.1This agreement is subject to Indian Laws and jurisdiction shall be registered office of the Principal, i.e. New Delhi.

10.2Changes and supplements as well as termination notices need to be made in writing. Side agreements have not been made.

10.3If the Contractor is a partnership or a consortium, this agreement must be signed by all partners or consortium members.

10.4Should one or several provisions of this agreement turn out to be invalid, the remainder of this agreement remains valid. In this case, the parties will strive to come to an agreement to their original intentions.

10.5 Only those bidders/ contractors who have entered into this agreement with the Principal would be competent to participate in the bidding. In other words, entering into this agreement would be a preliminary qualification.

-----  
 For & On behalf of the Principal  
 (Office Seal)

-----  
 For & On behalf of the Bidder/ Contractor  
 (Office Seal)

Place-----  
 Date-----  
**SHRI  
 PRAKASH  
 YADAV**

Digitally signed by SHRI PRAKASH YADAV  
 DN: c=IN, o=BHARAT HEAVY ELECTRICALS LIMITED,  
 ou=POWER SECTOR-PROJECT ENGINEERING  
 MANAGEMENT (PS-PS&L), postalCode=201301, st=UTTAR  
 PRADESH,  
 2.5.4.20=88e111c0d40203ac5af3703732a80511e95fb3b86  
 14c29694b18090c3591aa85,  
 serialNumber=37DE274D01715FEA705EE5677BEA2CDDFA1  
 04E598,  
 serialNumber=51874E6D31DA4E2307DD62E682B40C2B  
 17708AA7C37FE1F32A463C515C99298, cn=SHRI  
 PRAKASH YADAV  
 Date: 2023.03.16 10:07:13 +05'30'

Witness: \_\_\_\_\_  
 (Name & Address) \_\_\_\_\_

Witness: \_\_\_\_\_  
 (Name & Address) \_\_\_\_\_



**CORPORATE QUALITY ASSURANCE**  
**SUB-VENDOR QUESTIONNAIRE**

<i>i.</i>	<i>Item/Scope of Sub-contracting</i>	
<i>ii.</i>	<i>Address of the registered office</i>	<i>Details of Contact Person</i> <i>(Name, Designation, Mobile, Email)</i>
<i>iii.</i>	<i>Name and Address of the proposed Sub-vendor's works where item is being manufactured</i>	<i>Details of Contact Person:</i> <i>(Name, Designation, Mobile, Email)</i>
<i>iv.</i>	<i>Annual Production Capacity for proposed item/scope of sub-contracting</i>	
<i>v.</i>	<i>Annual production for last 3 years for proposed item/scope of sub-contracting</i>	
<i>vi.</i>	<b><i>Details of proposed works</i></b>	
<i>1.</i>	<i>Year of establishment of present works</i>	
<i>2.</i>	<i>Year of commencement of manufacturing at above works</i>	
<i>3.</i>	<i>Details of change in Works address in past (if any)</i>	
<i>4.</i>	<i>Total Area</i>	
	<i>Covered Area</i>	
<i>5.</i>	<i>Factory Registration Certificate</i>	<i>Details attached at Annexure – F2.1</i>
<i>6.</i>	<i>Design/ Research &amp; development set-up</i> <i>(No. of manpower, their qualification, machines &amp; tools employed etc.)</i>	<i>Applicable / Not applicable if manufacturing is as per Main Contractor/purchaser design)</i> <i>Details attached at Annexure – F2.2</i> <i>(if applicable)</i>
<i>7.</i>	<i>Overall organization Chart with Manpower Details</i> <i>(Design/Manufacturing/Quality etc)</i>	<i>Details attached at Annexure – F2.3</i>
<i>8.</i>	<i>After sales service set up in India, in case of foreign sub-vendor</i> <i>(Location, Contact Person, Contact details etc.)</i>	<i>Applicable / Not applicable</i>  <i>Details attached at Annexure – F2.4</i>
<i>9.</i>	<i>Manufacturing process execution plan with flow chart indicating various stages of manufacturing from raw material to finished product including outsourced process, if any</i>	<i>Details attached at Annexure – F2.5</i>
<i>10.</i>	<i>Sources of Raw Material/Major Bought Out Item</i>	<i>Details attached at Annexure – F2.6</i>
<i>11.</i>	<i>Quality Control exercised during receipt of raw material/BOI, in-process , Final Testing, packing</i>	<i>Details attached at Annexure – F2.7</i>



**CORPORATE QUALITY ASSURANCE**  
**SUB-VENDOR QUESTIONNAIRE**

12.	<b>Manufacturing facilities</b> <i>(List of machines, special process facilities, material handling etc.)</i>	<b>Details attached at Annexure – F2.8</b>			
13.	<b>Testing facilities</b> <i>(List of testing equipment)</i>	<b>Details attached at Annexure – F2.9</b>			
14.	<b>If manufacturing process involves fabrication then-</b>	<b>Applicable / Not applicable</b>			
	<b>List of qualified Welders</b>	<b>Details attached at Annexure – F2.10</b>			
	<b>List of qualified NDT personnel with area of specialization</b>	<b>(if applicable)</b>			
15.	<b>List of out-sourced manufacturing processes with Sub-Vendors' names &amp; addresses</b>	<b>Applicable / Not applicable</b>  <b>Details attached at Annexure. –F2.11</b> <b>(if applicable)</b>			
16.	<b>Supply reference list including recent supplies</b>	<b>Details attached at Annexure – F2.12</b> <b>(as per format given below)</b>			
<b>Project/ package</b>	<b>Customer Name</b>	<b>Supplied Item (Type/Rating/Model /Capacity/Size etc)</b>	<b>PO ref no/date</b>	<b>Supplied Quantity</b>	<b>Date of Supply</b>
17.	<b>Product satisfactory performance feedback letter/certificates/End User Feedback</b>	<b>Attached at annexure - F2.13</b>			
18.	<b>Summary of Type Test Report (Type Test Details, Report No, Agency, Date of testing) for the proposed product (similar or higher rating)</b> <b>Note:- Reports need not to be submitted</b>	<b>Applicable / Not applicable</b>  <b>Details attached at Annexure – F2.14</b> <b>(if applicable)</b>			
19.	<b>Statutory / mandatory certification for the proposed product</b>	<b>Applicable / Not applicable</b>  <b>Details attached at Annexure – F2.15</b> <b>(if applicable)</b>			
20.	<b>Copy of ISO 9001 certificate (if available)</b>	<b>Attached at Annexure – F2.16</b>			
21.	<b>Product technical catalogues for proposed item (if available)</b>	<b>Details attached at Annexure – F2.17</b>			
<b>Name:</b>		<b>Desig:</b>		<b>Sign:</b>	
<b>Date:</b>					

**Company's Seal/Stamp:-**