

SEQUENCE OF TAPING (EXCLUDING ICP)		
TAPE LAYER	1 TO 2	IT: 10 REDUCED LENGTH AS SHOWN (1/2 OVERLAP)
TAPE LAYER	3 TO 11	IT: 10 END TO END (1/2 OVERLAP)
		MICA INSIDE GLASS OUTS
		MICA INSIDE GLASS OUTS

NOTE:- APPROX. DEVELOPED LENGTH OF BAR IS 7940 mm

## DETAILS OF STATOR BAR FOR INSULATION TAPING

0-EMT-0215

Dt: 22-01-2011