



**PROJECT INFORMATION & SITE-SPECIFIC
DATA FOR TRACKER SYSTEM FOR
DEVELOPMENT OF 900MW (3X300MW) GRID
CONNECTED SOLAR PV PROJECT AT
FATEHGARH, RAJASTHAN**

PISSD- FATEHGARH

Rev No: 00

COPYRIGHT AND CONFIDENTIAL

*The information on this document is the property of Bharat Heavy
Electricals Limited. It must not be used directly or indirectly in
anyway detrimental to the interest to the company.*

**PROJECT INFORMATION
&
SITE-SPECIFIC DATA
FOR
TRACKER SYSTEM
FOR
900MW (3X300MW) GRID
CONNECTED SOLAR PV
PROJECT
AT
FATEHGARH, RAJASTHAN**

Revision
details: 00

Prepared by: VKC

Digitally signed by VIJAY KUMAR CHOUDHARY
DN: c=IN, o=BHARAT HEAVY ELECTRICALS
LIMITED, ou=MATERIALS
MANAGEMENT, postalCode=560012,
l=Bangalore, st=Karnataka, street=PROF C N R
RAO CIRCLE IISC POST MALLESWARAM
BANGALORE KARNATAKA PIN 560012,
title=0209,
2.5.4.20=92a0853bfb88f64eb03466422799d65
c7c8333f552c1dedc359c92aafbbab998,
serialNumber=e098519ae7110419655a7dfe5d
96d6792130d0edc8ac724ed64c080f30a55b,
email=vijayk.choudhary@bhel.in, cn=VIJAY
KUMAR CHOUDHARY
Date: 2025.04.30 13:58:06 +05'30'

Checked & Approved by:
PM

PUNAM
MISHRA-
SDGM

Digitally signed by PUNAM MISHRA-
SDGM
DN: cn=PUNAM MISHRA-SDGM,
o=BHEL, ou=SDGM,
email=punammishra@bhel.in, c=US
Date: 2025.04.30 15:19:08 +05'30'

Date:
30.04.2025



PROJECT INFORMATION & SITE-SPECIFIC DATA FOR TRACKER SYSTEM FOR DEVELOPMENT OF 900MW (3X300MW) GRID CONNECTED SOLAR PV PROJECT AT FATEHGARH, RAJASTHAN

PISSD- FATEHGARH

Rev No: 00

1.0 INTRODUCTION

This project information & Site-Specific data for the project is supplementary information to the technical specification PS-439-1426 (latest Revision). The details given in this section will supersede over any information written elsewhere in the specification, if contradicts otherwise read in conjugation.

2.0 PROJECT INFORMATION:

Name of the Project	Development of 900MW (3x300MW) grid Connected solar PV project at Fatehgarh, Rajasthan
Plant Capacity	300 MW for each of the three blocks/projects at ISTS Point of Interconnection.
Location of Site	Deora, Fatehgarh Tehsil, Jaisalmer District, Rajasthan
Nearest Town	Jaisalmer (~80 kms)
Nearest Highway/Major Road	National Highway 11
Nearest Railways Station	Jaisalmer Railway Station (~80 kms)
Nearest Commercial Airport	Jaisalmer Airport, Jaisalmer -- ~80 kms Jodhpur Airport, Jodhpur-- ~300kms
Indicative Coordinate	26°22'9.51"N, 70°51'55.40"E

3.0 AREA AVAILABILITY: As per Vicinity Map

Land will be provided by End Customer on “as is where is basis” (Approx. 5 acres/MW). Bidder is requested to make detailed site visit and access the requirement of work. The details are given for preliminary information only. Land will be, in general level with an average slope of 10% and local slope of up to 15%. Hence, Bidder has to design the tracker system for up to average of 10% of ground slope, (15%) local along North-South direction.

For Area Auto Cad Drawing and KMZ File, please put an e-mail to vijayk.choudhary@bhel.in / palanikumar@bhel.in mentioning tender reference.

4.0 SITE SPECIFIC TECHNICAL DATA:

Corrosive category	Non-coastal (Minimum C3)
PV Module	Min. 600 Wp Bifacial



**PROJECT INFORMATION & SITE-SPECIFIC
DATA FOR TRACKER SYSTEM FOR
DEVELOPMENT OF 900MW (3X300MW) GRID
CONNECTED SOLAR PV PROJECT AT
FATEHGARH, RAJASTHAN**

PISSD- FATEHGARH

Rev No: 00

PV Module Characteristic*	2384 mm x 1134mm 33.8 kg (weight) 15.85 A (Isc) 14.97 A (Imp) Bifacial gain of 5% to be considered over and above Isc value mentioned above for component and cable sizing
PV Module Hole distance*	For 600Wp 400 mm / 1400 mm(long edge) 1082 to 1099 mm (short edge)
No. of Module/String	28 Nos.
Additional Parameters*	Bifaciality factor – 80% Rear Shading factor - 5% Rear mismatch factor – 10%
Minimum Pitch	6.0 m for all Plots Considering minimum 600 Wp Modules
Thermal Loss Factor (Uc, Uv)	Uc-29 Watts/m ² -K Uv-0.0 Watts/m ² -K
Tracker	1P Single axis E-W Tracker
Design Clearance for Tracker	The minimum design clearance (at the highest tilt angle) between the lower edge of the modules and the developed ground level shall be 400 mm for Single Axis Tracker based system. Minimum 400 mm clearance to be maintain at module edge with maximum angle.
Rainfall	Heaviest rainfall in one hour (in mm): 48.8 mm Or As per Nearest city / town (as mentioned in Appendix-A of IRC:SP:13-2004.)
Seismic data & design criteria	Seismic Zone 5, Provisions of IS 1893 (Part 1) shall be followed.
Basic Wind Speed for Design	47 M/s.
Design Wind Pressure, min, Pd	890 N/m ²
Comprehensive AMC	10 Years from Project COD
Tentative DC Capacity of the Project	3 x 390 MWp *

Bidder to submit tentative array layout & Basic proposed design including Type of tables, Bill of Material, design loads, pile reactions etc. for the project in line technical specification & details given in this document along with offer. Electrical Equipment like PCUs, Transformers, HT Panel are to be placed in between arrays. 19 Nos of IR rooms each consists of 1 No of 17.6 MVA Inverter



**PROJECT INFORMATION & SITE-SPECIFIC
DATA FOR TRACKER SYSTEM FOR
DEVELOPMENT OF 900MW (3X300MW) GRID
CONNECTED SOLAR PV PROJECT AT
FATEHGARH, RAJASTHAN**

PISSD- FATEHGARH

Rev No: 00

transformer + 4 PCU+1 HT PANEL for 300 MW. The approx. Size of the block shall be 35 M X 35 M. Bidder to prepare array layout considering the same.

* Above Block DC capacity is considering DC:AC ratio 1.3 and nominal module Wp of 600 Wp. Even in case of change in nominal Wp of supplied PV module, the number of PV modules for erection shall remain same as calculated above and the DC capacity of the project shall be revised accordingly.

In this project, End Customer will supply the PV Module. End Customer will try to provide the exact PV Module characteristics including datasheet and other documents by 7 to 9 months after the award of LOA to Tracker Bidder. There might be slight changes in the dimensions, weight and Isc as per the actual PV Module compared to the inputs provided above. Tracker bidder to suitably design the Tracker system to consider such minor changes.

5.0 DELIVERY SCHEDULE:

Sr. No.	Item Description	Delivery Schedule in Months for all Bidders for Each block quoted
A. Design Submission & Approval		From date of firm PO
1	Design & Approval of complete Tracker systems along with all its accessories, MMS including Foundation	1
B. Supply (Progressively)		
2	Tracker System & Module mounting arrangement along with all accessories, tools & Consumables and Mandatory Spares as per final BOQ of approved design. #	Minimum 50 MWp per Month starting after 1 Month from Manufacturing Clearance & all supplies to be complete within 8 Months of Manufacturing Clearance
C. Works and services (Progressively)		After 2 months from Manufacturing Clearance
1	Demonstration of erection methodology and supervision of erection during complete erection of Tracking system	8
		From Completion of Erection Works
2	Commissioning, trial run and acceptance test of Tracking system.	2



**PROJECT INFORMATION & SITE-SPECIFIC
DATA FOR TRACKER SYSTEM FOR
DEVELOPMENT OF 900MW (3X300MW) GRID
CONNECTED SOLAR PV PROJECT AT
FATEHGARH, RAJASTHAN**

PISSD- FATEHGARH

Rev No: 00

Tracker System supplies to be made in complete sets of per MWp as per final BOQ of approved design.

6.0 MANDATORY SPARES REQUIREMENT OF PROJECT:

Following mandatory spares are required for this project:

Sr. No.	Item Description	Quantity of Spares w.r.to final BOQ of approved design.
1	Tracker motor	0.25% of total population for each type.
2	Battery pack (if applicable)	0.25% of total population for each type.
3	Control box (with all components including cards)	0.25% of total population for each type.
4	Bearings (if applicable)	0.25% of total population for each type.
5	All type of sensors	0.25% of total population for each type.
6	Driving mechanism	0.25% of total population for each type.

The BOQ of Mandatory spares shall also be submitted for approval to BHEL/End Customer with design documents.

7.0 SPECIAL TECHNICAL CONDITIONS FOR PROJECT:

7.1. Painting of Steel Surfaces embedded in Concrete:

For the portion of Steel surfaces completely embedded in Concrete as reinforcement or otherwise for foundation systems, the surface shall be prepared by Manual Cleaning and provided with Primer Coat of Chlorinated Rubber based Zinc Phosphate Primer of Minimum 50 Micron Dry Film Thickness (DFT). However, For proprietary member of tracker-based MMS, Bidders proposal w.r.t. corrosion protection would be accepted subject to OEM certification.

7.2. Foundation System:

7.2.1. Top of concrete/ height of collar for MMS foundation shall be minimum 150 mm above Finish ground level. The proposed foundation system for MMS shall be based on findings/results of the approved geo technical investigation report.

Following kind of foundation may be provided:

1. Short pile foundation (Min. 300 mm dia.)



**PROJECT INFORMATION & SITE-SPECIFIC
DATA FOR TRACKER SYSTEM FOR
DEVELOPMENT OF 900MW (3X300MW) GRID
CONNECTED SOLAR PV PROJECT AT
FATEHGARH, RAJASTHAN**

PISSD- FATEHGARH

Rev No: 00

2. Rock anchor with concrete collar (Min. 700 sq.cm.)

3. Isolated, strip or raft foundation

4. Concrete ballast foundation

7.2.2. In desert areas where sand erosion is anticipated, depth of pile shall be increased beyond designed depth by minimum 300 mm or envisaged depth of erosion, whichever is higher.



7.2.3. Testing of piles and interpretation of pile load test results shall be carried out as per the stipulations of IS: 2911 (Part-4). Contractor shall obtain approval for the pile load test scheme before undertaking the pile load test.

7.3. Since the site is located in a desert area, sandstorms are common. Therefore, the dust-proof design should consider the deposition of sand particles on sensitive electronic equipment or sensors.

ENCLOSURES:

1. Vicinity Map and Block Layout

LAYOUT : 900 MW (3 X 300 MW) Solar PV Projects at Fatehgarh



Notes:

1. General
 - a. The tender drawings shall be read in conjunction with the provision of Technical Specifications.
 - b. The details shown in drawing are suggestive and for tender purpose only.
 - c. Land would be handed over to Bidders after leveling if required to arrive at an average 10% ground slope (15% local) along North-South direction as per provisions of tender. However, if required minor provisions w.r.t leveling shall be included in EPC Bidder scope only in local areas.
 - d. Leveling of land, if applicable would be done in parallel and would not be considered as obstruction to progress w.r.t Engg. Design, procurement and construction at site (where land is already in order).
 - e. The Boundary demarcation is for reference purpose only however the actual boundaries will be finalized based on the Layout finalization after detailed Engg.
2. Reference Data for Project Site
 - a. Bidder shall conduct the topographical survey (optional) and Geo-technical investigation to finalize the Layout & Foundations as per the actual topography & Geo-technical Data.
 - b. Layout of Roads shown in the Tender drawings is for the reference purpose only. Bidders are advised to visit site so as to access the actual site approachability.
 - d. The land provided will be free from trees, obstructions.
3. Site Specific Considerations
 - a. All Temporary facilities for project development during construction including any road construction, fencing, leveling etc. is in Bidder Scope.
 - b. All Internal Road & drains are deemed to be in Scope of Work of bidder.
 - c. All arrangements as necessary to take up the project construction work, are in bidder's scope as per provisions of Tender Documents.
 - d. Water and Construction power are under the scope of Bidder and hence are to be considered by bidder for the given projects, as per their respective requirements, while planning for the project site activities.
 - e. Location has been marked for area reserved for Solar Project. However, the actual location may vary to a some extent.

FOR TENDER PURPOSE ONLY

 \wedge

Note:

1. AREA MARKED IS SUBJECT TO MINOR MODIFICATIONS AT SITE
2. LAND WILL BE PROVIDED TO THE TUNE OF 5 ACRE/MW HOWEVER THE SAME MAY DECREASE MARGINALLY DUE TO ACTUAL SITE CONDITIONS.

Vicinity Map and Block Layout

BALANCE OF SYSTEM PACKAGE FOR DEVELOPMENT OF 900MW (3X300MW) GRID CONNECTED SOLAR PV PROJECT AT FATEHGARH, RAJASTHAN

PREPARED BY	CHECKED BY		APPROVED BY	DATE	SIZE	SCALE	DRG. NO.	
SSSG	CIVIL	ELE.	RRM	06.04.2025	A0	NTS	5787-004(BOS1)-POC-A-001	R0
	SSSG	RR						