

## PRE-QUALIFYING (PQ) CRITERIA FOR VENDORS

### PROJECT – KALWAKURTHY LIS STAGE -1 (UNIT#3)


**P.I.NO. : 241525368**


- 1) Vendor/ OEM should have supplied similar type of Magnetic float type level indicator / gauge in Hydro Power Station / any other industry with following parameters in last 8 years (from tender opening date Part-1).


- (a) Center to Center distance: **750 mm or more**
- (b) Working Pressure : **16 kg/cm<sup>2</sup> or more**

Vendor shall furnish unpriced PO copy and Delivery Challan / Invoice with Approved Drawing / Bill of Material or any other relevant documentary evidence as proof of supplying Magnetic float level indicator with above parameters.

- 2) The Vendor should be authorized dealer of offered Magnetic float level indicator and submit the authorization letter from OEM. It is not applicable for OEM.
- 3) The OEM of Magnetic float level indicator should have ISO certificate

  
अमित पाण्डेय/AMIT PANDEY  
उप महाप्रबंधक / Dy. General Manager  
एच.पी.ई. विभाग / H.P.E. Division  
बी.एच.ई.एल., भोपाल/BHEL, BHOPAL

  
मनीष साहू / MANISH SAHU  
वरिष्ठ उप महाप्रबंधक/Sr.Dy.General Manager  
एच.पी.ई. विभाग/HPE Division  
बी.एच.ई.एल., भोपाल/BHEL, BHOPAL

  
विशाल कुमार नामदेव/V.K. NAMDEO  
वरिष्ठ प्रबंधक / Senior Manager  
एच.पी.ई. विभाग/HPE Division  
बी.एच.ई.एल., भोपाल/BHEL, BHOPAL