| CLAUSE NO. | TECHNICAL REQUIREMENTS |
|---------------------------|---|
| 3.02.00 | Material , |
| | Structural Steel (including embedded Steel) shall be straight, sound, free from twists, cracks, flaw, laminations and all other defects. |
| 3.02.01 | Mild Steel |
| | a) Rolled sections and plates up to and including 20mm thickness shall conform to grade designation E250A semi killed of IS: 2062. Plates beyond 20mm thickness and up to 40mm thickness shall conform to grade designation E250B killed and controlled rolling conforming to IS:2062. Plates beyond 40mm thickness, shall conform to grade designation E250B killed, normalizing rolling as per IS:2062. Plates beyond 40mm shall be ultrasonically tested as per ASTM-A578 level B. |
| ~ | b) Pipes shall conform to IS: 1161. |
| | c) Hollow (square and rectangular) steel sections shall be hot formed conforming to IS: 4923 and shall be of minimum Grade Yst 240. |
| | d) Chequered plate shall conform to IS 3502 and shall be minimum 6, mm thick excluding projection. Steel for chequered plate-shall conform to grade E250A semi killed of IS: 2062. |
| 3.02.02 | Medium and High Tensile Steel |
| • | a) Rolled sections and plates up to and including 20mm thickness shall conform to grade designation E350 semi killed of IS: 2062. Plates beyond 20mm thickness and up to 40mm thickness shall conform to grade designation E350 killed and controlled rolling conforming to IS:2062. Plates beyond 40mm thickness, shall conform to grade designation E350 killed, normalizing rolling as per IS:2062. Plates beyond 40mm shall be ultrasonically tested as per ASTM-A578 level B. |
| 3.02.03 | All other Materials shall be as per applicable Standards and Codes. |
| 3.02.04 | All Materials brought for incorporation in works shall be of best quality as per IS, unless specified otherwise. |
| 3.03.00 | Loading |
| 3.03.01 | Dead Loads |
| | Dead Loads are permanent Loads which shall include the weight of Structure complete with finishes, fixtures, partitions, etc. and shall be taken as per IS:875 (Part-I). |
| 3.03.02 | Imposed Loads |
| | (a) Imposed Loads in different areas shall include Live Loads, Erection, Operation and Maintenance Loads. |
| | (b) Equipment Loads (which constitute all Loads of Equipment to be supported, as given by Equipment Supplier), Pipe Loads (Static, Friction and Dynamic), Cable / Ducts Loads, Ash Loads, Dust Load, wherever applicable, are not included in the Imposed Loads as furnished below and these Loads shall be considered in addition to Imposed Loads. |
| | (2x660MW) / SOLAPUR STPP TECHNICAL SPECIFICATION PART.R G Markeling |
| MEJA TPP-I (2 x 8) PHA | SECTION-VI SECTION-VI SELI (2 x660MW) SELI (2 x660MW) SERIOR PACKAGE SECTION-VI BID DOC NO.: CS-9575/ 9571/ 0370V CIVIL WORKS O360/ 9586-102(R)-2 |

r