


BHEL-PEM-WSE
PRE-QUALIFICATION CRITERIA

	PROJECT: 2X660 MW ENNORE SEZ SUPERCRITICAL THERMAL POWER PROJECT PRE-QUALIFICATION REQUIREMENT PACKAGE: Condensate Polishing Unit	PE-PQ-412-155-A001	
		DATE	16.11.2023
		REV NO	00

A)	The Bidder should have designed, supplied, erected and commissioned at least one (1) Condensate Polishing Plant of mixed bed, deep bed type consisting of service vessel of minimum capacity of 500 M3/hr. The plant shall have external regeneration system, incorporating the same resin separation and regeneration process as proposed by the Bidder for this package. The above plant should have been in successful operation for a period of at least one (1) year as on date of bid opening.
B)	<p>The Bidder who do not meet the qualification requirements stipulated at (A) above, may also participate provided the Bidder is a Contractor in water treatment plant and has executed at least one (1) number ion exchange based demineralising plant of minimum capacity of 60 Cu.m/hr consisting of maximum two (2) streams and associates for this bid with an Associate who in turn fully meets the requirements stipulated at (A) above.</p> <p>In such a case, the Bidder shall be required to furnish a letter of support from Collaborator / Associate for successful performance of Condensate Polishing Plant, as per the format enclosed in Annexure-I. This letter of support should be submitted to Employer prior to the placement of order on approved sub-vendor.</p>

Notes:

- 1) The supplier has to submit performance certificate in English from end user along with copy of Purchase Order, meeting above mentioned pre-qualifying requirement.
- 2) Bidder to submit design documents to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate/purchase order.
- 3) In case documents submitted for meeting PQR are in language other than English, notarized English translation shall also be submitted.
- 4) Bidder shall provide all necessary data such as type, design, make, capacity, duty conditions, date of commissioning/ operation etc.
- 5) Notwithstanding anything stated above, BHEL/ Customer reserves the right to assess the capabilities and capacity of the bidders to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL/ Customer.
- 6) Final acceptance of Bidder is subject to Customer approval.

**FORMAT FOR FILLING THE DETAILS OF PROVENNESS
LETTER OF SUPPORT FOR SATISFACTORY PERFORMANCE OF
(EQUIPMENT/SYSTEM NAME) FOR ENNORE 2X660MW)**

TO

[EMPLOYER'S NAME & ADDRESS]

Sub: Letter of Technical Support submitted From (name of the Associate*/ Collaborator*/ Technology provider* / Licensor* / Holding Company*) undertaking the responsibility for satisfactory performance of(Name of the equipment/system*).

Dear Sirs,

1. In accordance with the Award of the Contract by (Name of the Contractor) to M/s. (Name of the sub-vendor), we, the aforesaid Associate*/Collaborator*/Technology provider*/Licensor*/Holding Company, (M/s) shall be fully responsible for the satisfactory performance of the(Name of the equipment/system*).
2. Further, the manner of achieving the objective set forth in point 1 above shall be as follows
For (Name of the equipment/system*):
 - (a) We shall be fully responsible for design, engineering & commissioning and extending all necessary support for putting in to satisfactory operation and carrying out the Guarantee Tests for(Name of the equipment/system*) to the satisfaction of the Employer.
 - (b) We shall depute technical experts to Bidder's/sub-vendor's works for supervision during manufacturing, assembly, inspection, as and when required by Employer. We shall participate in site erection, commissioning and final testing (as and when necessary) of the.....(Name of the equipment/system*).
 - (c) We shall participate in Technical Co-ordination meetings (TCMs) from time to time, as and when required by Employer.
 - (d) We shall promptly carry out all the corrective measures and shall promptly provide corrected design and shall undertake replacements, rectifications or modifications to the equipment/system* as and when required by Employer in case the equipment/system* fails to demonstrate successful performance as per contract at site.
3. We, the Associate*/Collaborator*/Technology provider*/Licensor*/Holding company* do hereby undertake and confirm that this Letter of Technical Support shall be valid for a period of seven (7) years or up to the end of defect liability period of the contract, whichever is later.

Signature of the Authorised Representative:.....

For M/s

(Associate*/Collaborator*/Technology provider*/Licensor*/Holding company)

Name

Designation

Date:.....

Common Seal of the Company

***: Strike off whichever is not applicable.**

Signature of authorized signatory.....