SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

BHEL NIT Terms and conditions

Project: Pre-Bid Tie up with GIS OEM for 400kV GIS required in 400kV GIS Package (Package-II) at KPS 3 (HVDC), South Olpad (HVDC) and Extn. of existing KPS3 (GIS) station including civil works associated with ±500kV, 2500 MW KPS-3 (HVDC) and South Olpad (HVDC) Scheme associated with Transmission System for Evacuation of Power from potential renewable energy zone in Khavda area of Gujarat under Phase-V (8GW): Part C through Tariff based Competitive (TBCB) route prior to RfP bid submission by POWERGRID to BPC.

Tender due date: 11-12-24 at 14:00/16:00 Hrs

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

Background of the tender:

Bharat Heavy Electricals Limited (BHEL) (A Government of India Enterprise) incorporated under the Companies Act, 1956, having its Registered office at BHEL House, Siri Fort, New Delhi intends to participate in the tender invited by M/s POWERGRID for 400kV GIS Package (Package-II) at KPS 3 through tariff based competitive bidding (TBCB) route.

For addressing the above tender, BHEL wish to have a tender specific pre bid tie-up with a 400kV GIS Manufacturer who meets the Qualification requirement as outlined in this tender documents (Technical specification).

BHEL, therefore, invites sealed bids from eligible bidders for this project as per terms & conditions specified in the tender documents.

The qualified, lowest evaluated Bidder having requisite capacity and capability to perform the contract for the aforesaid tender as per the provisions of the Bidding Documents shall be pre-selected, for the scope of work contained in the Bidding Documents, for associating with BHEL for addressing the tender invited by M/s POWERGRID.

A legally enforceable undertaking (JDU) (jointly with the GIS Manufacturer) to guarantee quality, timely supply, performance and warranty obligations as specified for the equipment(s) is to be submitted.

An MOU shall be signed with the pre-selected GIS manufacturer for the relevant scope of work. In case BHEL becomes successful Bidder and receives the LOA from M/s POWERGRID, this MOU / Agreement shall be converted into definite contract agreement between BHEL & GIS manufacturer (bidder) after award of job by POWERGRID.

However, BHEL reserves the right to cancel/withdraw this process even after signing of MOU and shall bear no liability whatsoever consequent upon such a decision in exceptional circumstances like-

- a) Major change in scope from Customer end wrt scope defined in NIT.
- b) End customer cancels the tender.
- c) Order is not awarded to BHEL by end customer.
- d) End Customer puts the tender on HOLD.
- e) In-ordinate delay in finalization of tender by end customer and BHEL decide to not to extend the bid validity to end customer.
- f) Major change in Govt policy/ Statutory variation etc.
- g) Any other condition of above nature.

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

- 1. In case any discrepancy between the requirements mentioned under special terms & conditions and general terms & conditions, special terms and conditions shall prevail.
- 2. For any technical clarification, kindly contact Sh. Manvender Singh Pundir, Sr. Manager (TBEM)

BHEL, Transmission Business Group

5Th Floor, Plot No: 25, Sector-16A, Noida-201301, UP, India

Phone: +91 (0) 0120- 6748512 E-mail: <u>manvender@bhel.in</u>

3. For any commercial clarification, kindly contact Sh. Gaurav Agarwal, Sr. Manager (TBMM);

BHEL, Transmission Business Group

5Th Floor, Plot No: 25, Sector-16A, Noida-201301, UP, India

Phone: +91 (0) 0120- 6748543 E-mail: gaurav.agarwal@bhel.in

- 4. Bidder to submit offer directly to NIC portal (https://eprocurebhel.co.in/nicgep/app) or through TENDER BOX email on tbmmtenderbox@bhel.in for part-1 bid (i.e. technocommercial bid) & tbmmtender.pricebidbox@bhel.in for Part-2 (i.e. PRICE BID). Bidder may also visit https://www.bhel.com. No other mode for submission of tender is acceptable.
- 5. PROPOSED DELIVERY PLAN: Supply of GIS within 24 Months from the date of placement of Purchase Order (PO)/ Letter of Intent (LOI) and subsequent supervision during ETC within 12 months. Vendor to examine their best possible delivery plan & mention in ACTIVITY SCHEDULE. The same shall be submitted along with commercial offer duly signed and stamped by authorized person. In case, BHEL's delivery requirement is not met by vendor(s), then a chance may be given to all such vendors to review their quoted delivery schedule in line with BHEL's delivery requirement.
- 6. **PRICE ADJUSTMENT/PRICE BASIS**: Firm. PV is not applicable.
- Permissible Technical & Commercial Deviations: No permissible technical & commercial deviation has been envisaged. Bidder to strictly follow the same, else offer is liable for rejection. Formats for compliance are enclosed.
- 8. **Type of tender:** This tender is an open tender but not a global tender and only **CLASS-I** suppliers as defined under the DPIIT order no. P-45021/2/2017-PP (BE-II) dated 04.06.2020 **are eligible to bid in this tender. Bids received from CLASS-II & Non-Local supplier shall be rejected.**
- 9. Compliance of General Financial Rules (GFRs): Please refer clause mentioned at Annexure-1 and Certification at Annexure-2 / Annexure-3 (whichever is applicable) regarding restrictions under Rule 144 (xi) of General Financial Rules (GFRs), 2017. Bidder to comply with the clause and submit the certification. Non-compliance/ Non-submission of certification will lead to rejection of Offer.

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

- 10. **Mandatory tender documents:** Bidder shall submit the following documents along with commercial offer. Bidder to strictly follow the same else offer is liable for rejection.
 - Compliance of General Financial Rules (GFRs): Annexure-2 or 3 (whichever is applicable).
 - Local content certificate: Format is enclosed as Annexure-A. Bidder must fill the local content in percentage.
 - MoP (Ministry of Power) compliance: Bidder to comply the MOP circular dated 02-07-2020 and its subsequent amendment, if any, in prescribed format (Annexure-B). Non-compliance/ Non-submission will lead to rejection of Offer.
 - Integrity pact: Format is enclosed as Annexure-C.
- 11. Quantity Variation (Clause No. 39 of GTC): BHEL shall have the right for variation in quantities of items within ± 20% of the total Purchase Order / Contract value at the time of placement of PO or award of Contract on overall basis or during Contract execution stage for all amendments together within TWO years from the date of original Purchase Order or till completion of supplies, whichever is earlier. The quantities of individual items may vary up to any extent or may get deleted unless otherwise specified in the technical specifications. No compensation is payable due to variation in the quantities and the Supplier / Contractor shall be bound to accept the same at the contracted prices / rates. PO amendment due to optional items (unit reference items for addition/deletion), if required, shall be in addition to the above variation clause.
- 12. **PRE-QUALIFYING REQUIREMENT**: Bidder must comply the following, else the offer is liable for rejection.
 - Technical PQR (Annexure-G), as attached with technical specification. Documents required for PQR shall be submitted along with the offer.
 - Financial PQR as under:

Bidder should have a minimum average audited annual turnover / Sales Value of INR 75 Crs for the three financial years 2020-21, 2021-22 & 2022-23 or 2021-22, 2022-23 & 2023-24 and shall submit Audited Profit & Loss Account and Balance Sheet as proof of Average Annual Turnover. Bidder should have earned profit in at least one year during three financial years as mentioned above. The Financial statements must be signed by the owner and the auditor. Auditors seal, Name, Membership No., Firm Registration No. & firm name (if applicable), UDIN and the capacity in which he is signing (Proprietor/Partner), must be mentioned on the Profit & Loss A/c and Balance Sheet.

Note:

- (1). Bidder must submit all supporting documents along with their offer. No deviation against this enquiry is acceptable, else offer shall be rejected.
- (2). All documents (including third party documents/supporting documents) in language other than English, certified translated copy in English language should also be furnished.
- (3). Offers will be scrutinized based on the qualifying requirements and only those who are technically and financially capable to execute the job and who fulfil the prequalifying requirements (PQR) are eligible to quote against above NIT.

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

IMPORTANT INSTRUCTION TO BIDDER - I:

- a. PRE-BID MEETING: shall be conducted within 3-7 days of floating of NIT.
- b. **OPENING OF BIDS (PART-I & II):** Bidder are not authorized to attend the opening of Part-I & Part-II bid for this tender.
- c. PROJECT STATUS: Domestic.

d. REGARDING VENDOR ACCEPTANCE:

- The GIS manufacturer must meet the techno-commercial Qualification requirement as stipulated in technical specification and any subsequent amendment.
- The GIS manufacturer must not be Banned or Delisted or Black Listed by any Government Department / Public Sector Undertaking on due date of submission of bid. The bidder will give a written confirmation in this regard along with the bid.
- e. **PLACEMENT OF ORDER:** This tender is for tender specific pre bid tie-up only. The Purchase Order shall be placed to the successful GIS Manufacturer/bidder for execution of relevant scope of work contained in this Bidding Documents only if BHEL receives the order from the end customer (M/s POWERGRID).

PO/LOI shall be placed on L1 bidder for main GIS & separate PO/LOI for mandatory spares and separate PO/LOI for maintenance equipment & tools & tackles (as applicable) shall be placed. However, evaluation shall be done based on overall quantity as per NIT. Total cost for this purpose shall include cost of scope of work as mentioned in NIT along with applicable taxes & duties, and other services etc. (if applicable). GST input credit available to BHEL shall be reduced from prices while determining L1 status.

Price breakup/ Billing Break-up (including mandatory spares), if any, required during execution of project shall be done only for account purpose and must be supported by logical relationship with original quoted prices.

Note- In PO, Unit reference items (supply & services) shall be mentioned under Terms and conditions as "Optional Items". In case of requirement of these items for any addition/deletion, same shall be confirmed through suitable PO amendment.

f. INLAND FREIGHT & INSURANCE: Supplier must ensure availability of their authorized person at site/store for supervision of unloading for every LOT of dispatch. The Freight & Insurance, to be paid by vendor on behalf of BHEL, will be reimbursed on submission of requisite documents. Proof of transit insurance should be submitted along with dispatch documents.

Note: Transit Insurance policy shall be in Bidder's scope and that should also have a provision of 30 days extended cover at site/ store. **Place of store is POWERGRID Navinal (Mundra) project site / store.**

g. MQP Requirement: As per specification.

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

h. GeM ID seller: GeM seller ID is mandatory for the bidders and must be mentioned in their offer. In case at the time of submission of offer GeM seller ID is not available with bidder, then successful tenderer should ensure to have GeM Seller ID prior to award of contract. Department of Expenditure (DOE) OM no. 6/9/2020-PPD dated 24.08.2020 may be referred in this regard.

13. MOU & its validity:

An MOU (as per BHEL's format, enclosed as **Annexure-F**) shall be signed with the pre-selected GIS manufacturer (techno-commercially Qualified, Lowest evaluated bidder, (subject to establishment of Price Reasonability by BHEL) for the relevant scope for the entire package/scope. This MOU shall, inter-alia, bind both BHEL and the pre-selected GIS manufacturer for associating and maintaining strict confidentiality by the pre-selected GIS manufacturer of the prices, terms and conditions.

This MOU shall be the binding on the bidder and is not to be changed thereafter and shall remain in force for 6 months from the date of signing of MOU or till the validity of the bid or till the date extended (if any) as per mutual consent, whichever is later.

The MOU / Agreement shall be converted into definite contract agreement between BHEL & GIS manufacturer (bidder) after award of job by POWERGRID.

Bid Bond: Within 30 days of signing the MOU, 1% of the value of MOU shall be taken from the supplier as bid bond in the form of bank guarantee or security deposit etc, in order to ensure the supplier's continued commitment during the validity period of the MOU.

BHEL and supplier should have an agreement for the extent of price reduction during RA/negotiation with end customer (if required). In the event of price reduction during negotiation by BHEL with the customer, the corresponding reduction will be passed on to the supplier as per above referred agreement.

14. **Deed of Joint Undertaking**: Bidder to submit Joint Deed of Undertaking (duly signed) as per enclosed format along with their offer.

Enclosures (Annexure-I):

FORM OF JOINT DEED OF UNDERTAKING BY THE COLLABORATOR/ PARENT/ PRINCIPAL COMPANY OF SUBSIDIARY COMPANY/ JV COMPANY/ GROUP COMPANY ALONGWITH THE BIDDER/MANUFACTURER {applicable to Bidder/GIS OEM Qualifying through Route-2 & Route-3 of the Qualification Requirement}.

FORM OF DEED OF JOINT UNDERTAKING TO BE EXECUTED BY THE BIDDER/CONTRACTOR ALONGWITH INDIAN GIS MANUFACTURER WHO HAS BEEN ASSOCIATED FOR SOURCING OF GIS EQUIPMENT

Confirmation Letter:

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

In case Bidder wish to Qualify through Route 2 & Route-3 of Qualification requirement, a confirmation letter from the Collaborator(s)/parent/principal company, stating that the Collaborator(s)/parent/principal company shall furnish performance guarantee for an amount of 10 % of the ex-works cost of such equipment(s), shall be submitted along with the bid. This performance guarantee shall be in addition to Contract Performance Guarantee to be submitted by the bidder/GIS OEM (refer BG clause of NIT).

15. IMPORTANT INSTRUCTION TO BIDDER - II;

- **a.** Packing as per specification is applicable. However, bidder to ensure proper packing to avoid any damage & packing of spares should be separated.
- b. Validity of PERFORMANCE BG: It should be valid for 90 (ninety) days beyond the date of completion of all contractual obligations of the supplier, including warranty obligations.
- c. BHEL /Customer or both may witness the inspection as per approved QAP.
- d. The unit prices of Supply and Services for addition/ deletion (i.e. optional items) and type test charges (if applicable), as mentioned in BOQ of section-1 of technical specification shall be considered for evaluation.
- e. Order shall be awarded on ex- works basis for indigenous bidder.
- f. Unloading of material at site is not in the scope of bidder.
- g. The deputation of manpower for supervision of Erection, Testing & Commissioning shall be done within 14 days of intimation by BHEL. The vendor shall submit a check list mentioning the pre-requisite conditions required to be fulfilled by BHEL site for starting the site activities. Upon compliance of the pre-requisite conditions as per check list and intimation to the vendor, the vendor shall depute the required manpower to site within 14 (fourteen) days of intimation.
- h. The bidder has to ensure that the spare parts should be available for minimum 10 years from the date of commissioning.
- 16. **VALIDITY OF OFFER (Clause no.14 of GTC)**: The overall validity of bid shall be 09 months from the date of opening of techno-commercial bids, including the validity of MOU.
- 17. **DEFECT LIABILITY PERIOD (GUARANTEE SPECIFIC CLAUSE):** The equipment / material supplied and services rendered (if applicable) shall be guaranteed to be free from all defects and faults in design & engineering, material, workmanship & manufacture and in full conformity with the Purchase Order / Contract, Technical Specifications & approved drawings / data sheets, if any for:
 - (i) In case GIS OEM qualifies through Route-1 Twelve (12) months from the date of Taking Over/Completion of Facilities.
 - (ii) In case GIS OEM qualifies through Route-2 or Route-3 Forty-Eight (48) months from the date of Taking Over/Completion of Facilities.

Note: The defect Liability period starts from the date of Taking over/Completion of facilities. Scheduled date of Taking over/Completion of facilities as per tender is 35 Months from the date of NOA. However, date of actual Taking Over/ Completion of facilities may be different during

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

Contract execution stage, hence the defect liability period will start from the date of actual Taking Over/ Completion of facilities and accordingly the performance security to be extended by the vendor time to time till ninety (90) days beyond the actual Defect Liability Period.

The defective equipment / material / component shall be replaced free of cost at site. Freight & Insurance during transit shall also be in the scope of the supplier / contractor. Any expenditure for dismantling and re-erection of the replaced equipment / material / component shall be to supplier's / contractor's account. All replacements during the guarantee period shall be delivered at site promptly and satisfactorily within a period not more than 45 days (or any other time period as informed by BHEL, without affecting the project commissioning schedule) from the date of reporting the defect / rejection etc.

In the event of the supplier / contractor failing to replace the defective equipment / material / component within the time period mentioned above, the same shall be considered as breach of the contract and BHEL may proceed as per provision mentioned in this NIT without prejudice to any other rights under the contract.

If the Facilities or any part thereof cannot be used by reason of any defect and/or making good of such defect, the Defect Liability Period of the Facilities or such part, as the case may be, shall be extended by a period equal to the period during which the Facilities or such part cannot be used because of any of the aforesaid reasons.

Upon correction of the defects in the Facilities or any part thereof by repair/replacement, such repair/replacement shall have the Defect Liability Period extended by a period of 2 years from the time of such repair/replacement of the facilities or any part thereof or up to the expiry of period mentioned above, whichever is later.

Note- Notes as mentioned in GTC shall be applicable.

18. LATENT DEFECT (Clause no. 6 of GTC):

At the end of the Defect Liability Period, the Contractor's Liability ceases except for latent defects. The Contractor's liability for latent defects warranty shall be limited to period of ten (10) years from the end of Defect Liability Period. For the purpose of this clause, the latent defects shall be the defects inherently lying within the material or arising out of design deficiency, which do not manifest themselves during the Defect Liability Period.

19. Liquidated Damages clause (Clause no. 13 of GTC):

LD shall be levied for delay in execution of Purchase Order as per below:

If the Vendor fails to comply with the Time for Completion mentioned in Purchase Order, then the Vendor shall pay to the BHEL a sum equivalent to 0.05% (zero point zero five percent) of the total Purchase Order value* for the whole of the scope of work (or a part for which a separate time for completion is agreed) as liquidated damages for such default and not as a penalty, without prejudice to the BHEL's other remedies under the Contract, for each day which shall elapse between the relevant Time for Completion and the date stated in Purchase Order subject

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

to the limit of five percent (5%) of total Purchase Order value* for the whole of the scope of work (or a part for which a separate time for completion is agreed).

The vendor agree that the sum specified above is not a penalty but a genuine pre-estimate of the loss/damage which will be suffered by the BHEL for default on the part of the Vendor and said amount will be payable without proof of actual loss or damage caused by such default.

The vendor shall submit a check list mentioning the pre-requisite conditions required to be fulfilled by BHEL site for starting the site activities. Upon compliance of the pre-requisite conditions as per check list and intimation to the vendor, the vendor shall depute the required manpower to site within 14 (fourteen) days of intimation. After reaching at site, the vendor representative will prepare a joint Minutes of meeting with BHEL site in which it will be mentioned that BHEL has completed the pre-requisite conditions as per check list and GIS erection, testing & commissioning activities can be started from the specified date. This date will be taken a start date/ zero date for start of GIS erection testing & commissioning activities.

The BHEL may, without prejudice to any other method of recovery, deduct the amount of such damages from any monies due or to become due to the Vendor. The payment or deduction of such damages shall not relieve the Vendor from his obligation to complete the Works, or from any other of his obligations and liabilities under the Contract.

Note:

- 1) LD shall be calculated as per activity schedule of NIT.
- 2) In case of Services, delays (if any) shall be certified by concern site in-charge.
- 3) * Total Purchase Order Value for considering Liquidity Damages (LD)= Total Ex-works +F&I +Total Service charges (excluding GST).

20. PERFORMANCE SECURITY (Clause No. 07 of GTC):

A) To ensure due performance of the contract, Supplier shall arrange to submit Performance Bank Guarantee (PBG) or Security Deposit (SD), hereafter referred as Performance Security to BHEL, on a non-judicial stamp paper of appropriate value within 28 days from placement of Purchase Order (PO)/ LOI, of an amount equivalent to **10% (Ten percent)** of the PO Ex-works value, with a validity upto 90 (ninety) days beyond the date of completion of all contractual obligations of the supplier, including warranty obligations. The same shall be extended by the vendor time to time till 90 (ninety) days beyond the actual Defect Liability Period, as may be required under the Contract.

BG for Main supply items, Maintenance equipment and Spares shall be submitted separately.

Bidder agrees to submit performance security required for execution of the contract within the time period mentioned. In case of delay in submission of performance security, enhanced performance security which would include interest (SBI rate + 6%) for the delayed period, shall be submitted by the bidder. Further, if performance security is not submitted till such time the first bill becomes due, the amount of performance security due shall be recovered as per terms defined in NIT I contract, from the bills along with due interest.

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

Modes of deposit:

Performance security may be furnished in the following forms:

• Local cheques of Scheduled Banks (subject to realization)/ Pay Order/Demand Draft/ Electronic Fund Transfer in favor of BHEL -TBG, Noida.

Bank Account details for submission of performance security through EFT mode.

NAME OF THE COMPANY	BHARAT HEAVY ELECTRICALS LTD
ADDRESS OF THE COMPANY	TRANSMISSION BUSINESS GROUP, 5TH FLOOR, BHEL TOWER, PLOT NO. 25, SECTOR-16A, NOIDA – 201301 (U.P.)
NAME OF BANK	STATE BANK OF INDIA
NAME OF BANK BRANCH	CAG-II NEW DELHI (17313)
CITY	NEW DELHI
ACCOUNT NUMBER	00000030206227732
ACCOUNT TYPE	CASH CREDIT
IFSC CODE	SBIN0017313

- Bank Guarantee from Scheduled Banks / Public Financial Institutions as defined in the Companies Act. Bank Guarantee shall be submitted as per BHEL format.
- Fixed Deposit Receipt issued by Scheduled Banks / Public Financial Institutions as defined in the Companies Act (FDR should be in the name of the vendor, a/c BHEL).
- Securities available from Indian Post offices such as National Savings Certificates, Kissan Vikas Patras etc. (held in the name of vendor furnishing the security and duly endorsed/hypothecated/pledged, as applicable, in favor of BHEL).
- Insurance Surety Bond.

Important Notes:

- The performance security should remain valid for a period of 60 days beyond the date of completion of all contractual obligations of the supplier including warranty/Guarantee obligations.
- Performance security shall be refunded to the vendor without interest, after he duly performs and completes the contract in all respects but not later than 90(sixty) days of completion of all such obligations including the warranty under the contract.
- BHEL will not be liable or responsible in any manner for the collection of interest or renewal of the documents or in any other matter connected therewith.
- The Performance Security shall not carry any interest.

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

- Value of the Bank Guarantee (at the time of submission) shall remain unchanged for any subsequent variations in Purchase Order value up to ± 20%. Beyond this variation of ± 20%, the Supplier shall arrange to enhance or may reduce the value of the Bank Guarantee accordingly for the total variation promptly.
- In case delay in submission of Performance BG, enhanced Performance BG which would include interest (SBI rate + 6%) for delayed period to be submitted.

Forfeiture of performance security:

The performance security will be forfeited and credited to BHEL's account in the event of a Breach of contract by the vendor.

ADDITIONAL PERFORMANCE BG (by GIS OEM/Parent Company to POWERGRID):

- **B)** GIS Manufacturer shall furnish performance guarantee for an amount of two (2)% of the GIS Portion. This performance guarantee shall be in addition to the Contract Performance security to be submitted by the Bidder/GIS OEM. Total price of items in Supply, F&I and Installation schedules mentioned under Activity titled "GIS portion" in BPS (of end Customer's Contract) shall be considered for calculation of amount of CPG to be furnished by GIS manufacturer.
- **C)** In case GIS Manufacturer meets the QR through Route-2 or Route-3 as specified in Annexure-A (BDS): A confirmation letter from the Collaborator(s)/parent/principal company stating that the Collaborator(s)/parent/principal company shall furnish performance guarantee for an amount of 10 % of the ex-works cost (of end Customer's Contract) of such equipment(s). This performance guarantee shall be in addition to Contract Performance Guarantee to be submitted by the bidder/GIS OEM (as mentioned above at "A") and additional CPG to be submitted by GIS OEM (as mentioned above at "B").

Note: CPBG as per A is to be submitted to BHEL and CPBGs as per B & C are to be submitted to POWERGRID / SPV of POWERGRID.

Enclosures (Annexure-J)-

- FORM OF BANK GUARANTEE FOR CONTRACT PERFORMANCE (TO BE SUBMITTED BY COLLABORATOR / PARENT/ PRINCIPAL COMPANY). {applicable to Bidder/GIS OEM Qualifying through Route-2 & Route-3 of the Qualification Requirement}.
- 2. FORM OF INSURANCE SURETY BOND FOR CONTRACT PERFORMANCE (TO BE SUBMITTED BY COLLABORATOR / PARENT/ PRINCIPAL COMPANY) {applicable to Bidder/GIS OEM Qualifying through Route-2 & Route-3 of the Qualification Requirement}.
- 3. FORM OF BANK GUARANTEE FOR CONTRACT PERFORMANCE (TO BE SUBMITTED BY INDIAN GIS MANUFACTURER)
- 4. FORM OF INSURANCE SURETY BOND FOR CONTRACT PERFORMANCE (TO BE SUBMITTED BY INDIAN GIS MANUFACTURER).

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

- 5. FORM OF BANK GUARANTEE FOR CONTRACT PERFORMANCE (TO BE SUBMITTED BY COLLABORATOR / PARENT/ PRINCIPAL COMPANY) {applicable to Bidder/GIS OEM Qualifying through Route-2 & Route-3 of the Qualification Requirement}.

 (Applicable in case award is placed by POWERGRID on behalf of SPV)
- FORM OF BANK GUARANTEE FOR CONTRACT PERFORMANCE (TO BE SUBMITTED BY INDIAN GIS MANUFACTURER) (Applicable in case award is placed by POWERGRID on behalf of SPV)
- 7. FORM OF INSURANCE SURETY BOND FOR CONTRACT PERFORMANCE (TO BE SUBMITTED BY COLLABORATOR / PARENT/ PRINCIPAL COMPANY) {applicable to Bidder/GIS OEM Qualifying through Route-2 & Route-3 of the Qualification Requirement}. (Applicable in case award is placed by POWERGRID on behalf of SPV)
- 8. FORM OF INSURANCE SURETY BOND FOR CONTRACT PERFORMANCE (TO BE SUBMITTED BY INDIAN GIS MANUFACTURER).

Annexure-H:

CONFIRMATION IN REGARD TO DESIGN & TYPE TEST (To be furnished in case bidder/GIS OEM is proposing to qualify through Note-4 under Route -1 of QR).

Validity of BG shall be upto ninety (90) days beyond the Defect Liability Period. The same shall be extended by the vendor time to time till ninety (90) days beyond the actual Defect Liability Period, as may be required under the Contract.

- 21. **PRICE BID FORMAT:** Bidder to quote their best prices strictly in BHEL's prescribed format of NIT, else their offer shall be liable to be rejected. Bidder has to mention "quoted" (in each applicable cell) in UN-PRICED BID. In case that cell is Not Applicable, "NA" must be mentioned in that particular cell. Prices shall be mentioned in Price bid schedule only. In case during detailed engineering stage, wherever, it is mentioned as NA (not applicable), is to be supplied, bidder shall supply the same without any cost and delivery implication to BHEL.
- 22. REVERSE AUCTION (clause no. 33 of GTC)- NOT APPLICABLE
- 23. TERMS OF PAYMENT: (i) clause no 3.1 to 3.5 of GTC are not applicable in this NIT:-
 - (ii) Following clause shall be applicable in place of existing clause no 3.2,3.5 of GTC;
 - 3.2 For supply & supervision works in scope of the supplier;

23.A.1:

Interest Bearing Advance (Optional*):

Two and half percent (2.5%) of the Total Ex-works price component of Main Equipment/Materials (excluding Mandatory Spares) shall be paid as an interest-bearing initial advance after placement of Purchase Order within 60 days from the date of submission of:

- (a) Acknowledgement and acceptance of PO by vendor,
- (b) Invoice,

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

- (c) An unconditional & irrevocable Bank Guarantee in favour of the BHEL for 110% (one hundred ten percent) of the amount of Advance,
- (d) Performance Bank Guarantee in line with STC Clause 20.

Provided further that the Invoice for advance payment along with all supporting documents is submitted by the Vendor to the BHEL within 3 months from the date of Purchase Order. In case the Vendor does not submit the requisite documents including applicable Bank Guarantee(s) within the aforesaid period, the advance shall not be payable. The Vendor shall, within 7 days from the date of receipt of Advance, furnish an Advance Receipt Voucher to the BHEL, as prescribed under the GST Law.

Note: * This payment is an optional payment. The Vendor has the option of taking the interest-bearing initial advance or otherwise.

Interest rate applicable on advance payment to the Vendor shall be shall be the repo rate (on the date of release of advance) plus 4%. The interest rate shall be valid till the advance amount is fully repaid. Recovery of advances along with the interest shall be made from the first bill to the maximum extent possible and balance amount (if any) in subsequent bill. It is the BHEL's understanding that as per extant provisions, GST is not payable on interest paid on the amount of Advance. The Vendor is, however, advised to check the position from their own sources. If payable, the same shall be to the Vendor's account and BHEL shall not reimburse any GST on this account.

Further, the Vendor shall submit the certificate of Tax Deduction at Source (TDS) on interest within 3 months from the end of the quarter in which adjustment of advance has been made for claiming refund from BHEL. No claim for refund will be entertained after end of the aforesaid period of 3 months. Further, while submitting the TDS Certificate the details of PO No, Project, Quarter etc to which the TDS certificate pertains, shall also be submitted tallying the amount with the TDS Certificate.

In case, the Vendor opts not to take interest bearing advance as above, it would be mandatory for him to submit the document listed at SI. No. (d) above within twenty eight (28) days of issuance of PO as per clause 20 of STC.

23.A.2.

Interest Bearing Engineering Advance (Optional**):

Further advance of Two and half percent (2.5%) of the Total Ex-works price component of Main Equipment/Materials (excluding Mandatory Spares) shall be paid as an interest-bearing interim advance within 60 days from the date of fulfilment of following:

- a) Issuance of 1st MFC by BHEL.
- d) Detailed Invoice
- c) Submission of an unconditional & irrevocable Bank Guarantee in favour of the BHEL for 110% (one hundred ten percent) of the amount of Interim Engineering Advance.

The Vendor shall, within 7 days from the date of receipt of Advance, furnish an Advance Receipt Voucher to the BHEL, as prescribed under the GST Law.

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

Note: ** This payment is an optional payment. The Vendor has the option of taking the interest-bearing Engineering advance or otherwise.

Interest rate applicable on advance payment to the Vendor shall be shall be the repo rate (on the date of release of advance) plus 4%. The interest rate shall be valid till the advance amount is fully repaid. Recovery of advances along with the interest shall be made from the first bill to the maximum extent possible and balance amount (if any) in subsequent bill. It is the BHEL's understanding that as per extant provisions, GST is not payable on interest paid on the amount of Advance. The Vendor is, however, advised to check the position from their own sources. If payable, the same shall be to the Vendor's account and BHEL shall not reimburse any GST on this account.

Further, the Vendor shall submit the certificate of Tax Deduction at Source (TDS) on interest within 3 months from the end of the quarter in which adjustment of advance has been made for claiming refund from BHEL. No claim for refund will be entertained after end of the aforesaid period of 3 months. Further, while submitting the TDS Certificate the details of PO No, Project, Quarter etc to which the TDS certificate pertains, shall also be submitted tallying the amount with the TDS Certificate.

23.A.3:

65% of Total Ex-Works price component of Main Equipment/Materials (70% for Mandatory Spares) along with 100% GST and 100% F&I Charges payment shall be paid progressively within 60 days (45 days for micro & Small) starting from the date of receipt of complete GST invoice along with documents in 3 sets (original + 2 copies) as follows:

- · LR / GR.
- Material Receipt Certificate issued by BHEL Site Official (to be arrange by BHEL-TBG**).
- . GST Compliant Tax Invoice
- Packing List (Case-wise)
- · Copy of Transit Insurance Certificate from underwriters.
- Material Inspection Clearance Certificate (MICC) issued by BHEL Quality Management
- Guarantee Certificate
- · Copy of Performance Bank Guarantee (PBG)
- · Certificate of acceptance of Type Test Reports issued by BHEL Engineering management wherever specifically mentioned in the Purchase Order.

^ In case, the vendor opts not to take interest bearing initial advance {or has opted to take interest bearing initial advance but the advance payment has become inadmissible for the reason specified in A.1 above} and interest-bearing engineering advance then this payment shall be 70% instead of 65%. Further, in case, the Contractor opts not to take interest bearing initial advance, but takes interest bearing engineering advance, then this payment shall be 67.5% instead of 65% and in case, the Contractor opts to take interest bearing initial advance, but does not take interest bearing engineering advance, then this payment shall be 67.5%, instead of 65%.

** MRC shall be issued by BHEL site within 7-10 working days from the date of receipt of last consignment of each lot of dispatch (as per Invoice) at site and submission of following undertaking by vendor-

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

"Boxes shall be opened in the presence of vendor's representative and in case of any shortage/damage found inside the factory packed boxes during verification, then vendor shall supply the same without any financial implications to BHEL."

23.B: Twenty percent (20%) of the Ex-works price of Main Equipment/ materials shall be paid, on receipt and storage at site and on physical joint verification*** of received consignment at store/ site, within 60 days (45 days for micro & Small) from the date of receipt of complete invoice. However, for Mandatory Spares, balance thirty percent (30%) payment of the Ex-works price component shall be released on receipt & storage of the same at site, physical joint verification and taking over by the Customer's representative. Following documents (original+ 2 copies) will be required for payment-

- Invoice.
- Joint verification reports**** as per packing list by BHEL site & Bidder's authorized representative.
- Certificate from BHEL site for Spares handing over to Customer (applicable for Mandatory spares only).

Note: Payment shall be made based on joint inspection of supplied material. Therefore, Joint verification reports should mention all tax invoice nos and nos of boxes corresponding to original packing list / invoice.

*** The joint verification of received consignment shall be done within 90 days from the date of receipt of last consignment of each lot of dispatch. The repacking of GIS boxes after Joint verification shall be done by GIS OEM to ensure safe keeping of material during storage.

**** Joint Verification Report (JVR) shall be issued by BHEL site only for the purpose of payment, however, this does not absolve the vendor from his responsibility for completion of supplies in all respect as per Contract.

23.C: Final Payment-

Balance 10% (Ten percent) of the Ex-works price component of Main Equipment/Materials shall be paid (on pro-rata basis) as per the following:

1) **5% (Five percent)** on Successful completion of Supervision of Erection, Testing including HV Testing & Commissioning of individual bays.

Payment shall be made within 60 days (45 days for micro & Small) from date of receipt of invoice. Following documents (original + 2 copies) will be required for payment-

- Invoice
- Certificate for completion of HV Test from BHEL site.
- 2) **Last 5% (Five percent)** on proof of submission of required number of reproducible, O&M Manuals, approved drawings, data sheets, test report, pamphlets and manuals of mandatory spares, maintenance & testing equipment and on successful completion of Supervision activity.

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

Payment shall be made within 60 days (45 days for micro & Small) from date of receipt of invoice. Following documents (original + 2 copies) will be required for payment-

- Invoice.
- Final engineering documentation certificate by BHEL Engg group
- Successful completion certificate of supervision of ETC at site issued by BHEL site.

Note: In case of Completion of Supervision of Erection, Testing including HV Testing & Commissioning & issuance of taking over certificate by end Customer gets delayed beyond 09 months from the date of receipt of last equipment at site, for the reasons not attributable to supplier, supplier may claim above payments of supply portion (23.C.1 & 23.C.2) by furnishing following documents.

- a) Invoice
- b) Certificate issued by BHEL site in charge, confirming that the equipment have been received in good condition and delay in completion of Supervision of Erection, Testing including HV Testing & Commissioning is not attributable to supplier (to be arranged by BHEL TBG).
- c) Bank Guarantee of equivalent value initially valid for 12 months from the date of submission of invoice. In case of Supervision of Erection, Testing including HV Testing & Commissioning is not successfully completed before expiry of Bank Guarantee, BG shall be kept suitably extended till successful completion of Supervision of Erection, Testing including HV Testing & Commissioning. The bank guarantee shall, however, be released within one month of successful commissioning.

3.5 For Charges for Supervision of Erection, Testing & Commissioning at Site:

100% Payment **for Supervision of Erection, Testing & Commissioning** along with applicable GST shall be made on pro-rata basis/ activity wise, within 60 days (45 days for micro & Small) from the date of receipt of complete GST compliant Tax invoice along with Certificate of Supervision completion of respective activity issued by BHEL Site Official / Construction Management in 3 sets (Original + 2 copies).

24. MODE OF PAYMENT: Mode of payment against clause no.23.A.3 & 23.B shall be through irrevocable Letter of Credit (ILC) in favor of the vendor through BHEL's Bank. All charges related to ILC shall be in vendor's account. ILC shall be opened at the time of FAT with 3months validity. Amount of ILC shall be equal to the value of materials offered for inspection. Usance period of ILC will be 60 days starting from the date of receipt of complete documents as per NIT including BOE in BHEL's bank.

Mode of payment for all other supply payments, payment for Supervision of ETC, Training charges etc, shall be made direct to the Vendor by BHEL (through NEFT/RTGS) and no L/C shall be established by BHEL for such payments.

25. **VALIDITY OF PURCHASE ORDER:** 3 years from the date of PO or upto completion of Contract execution, whichever is earlier.

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

26. Promotion of MAKE IN INDIA:

For this procurement, the local content to categorize a supplier as class-I local supplier / class-II local supplier / Non-Local supplier and purchase preference to class I local supplier, is as defined in Public Procurement (Preference to Make in India), Order 2017 dated 04.06.2020, issued by DPIIT & subsequent order No. A-1/2021-FSC-Part-(5) dated 16.11.2021 of MOP. In case of subsequent orders issued by the nodal ministry, changing the definition of local content for the items of the NIT, the same shall be applicable even if issued after issue of this NIT but before opening of part II bids against this NIT.

Note: Bidder to specify the percentage of local content as per the format as per Annexure-

27. **INTEGRITY PACT: INTEGRITY PACT (Refer clause no. 34 of GTC):** Bidders shall have to enter into Integrity Pact with BHEL, duly signed with seal in original as per **ANNEXURE-C** of NIT, failing which bidder's offer shall be liable for rejection.

The Integrity Pact shall be issued as part of the bidding documents and shall be returned by the bidder along with the techno-commercial bid, duly signed by the authorized official of the bidder/ vendor/ vendor and authorized official of BHEL will form part of the Purchase order/ contract. Only those bidders who have entered into such an IP with BHEL would be competent to participate in the bidding. In other words entering into this pact would be a preliminary qualification.

Name of Independent External monitors to be considered (IEM):

SN	IEM	Email
1.	Shri Otem Dai, IAS (Retd.)	iem1@bhel.in
2.	Shri Bishwamitra Pandey, IRAS (Retd.)	Iem2@bhel.in
3.	Shri Mukesh Mittal, IRS (Retd.)	Iem3@bhel.in

28. INDEMNITY (AGAINST PATENTS / TRADEMARKS ETC):

The vendor shall at all times indemnify the purchaser against all claims which may be made in respect of supply from any "rights protected" source protected by way of patent registration of design or trade mark. In the event of any claim in respect of an alleged breach of patents registered design or trademark being made against the purchaser, purchaser shall notify the seller of the same and the seller shall be at liberty, but entirely at their own expenses, to conduct negotiation for settlement or deal with any litigation that may arise there from.

29. INVOLVEMENT OF REPRESENTATIVE:

Bidder must be GIS manufacturer. Purchase Orders will be placed on successful bidder directly for total supplies and services subject to prior approval by BHEL/end Customer.

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

In a tender, either the Indian agent on behalf of the Principal/OEM or Principal/OEM itself can submit bid but both cannot submit bid simultaneously for the same item/product in the same tender.

If an agent submits bid on behalf of the Principal/OEM, the same agent shall not submit a bid on behalf of another Principal/OEM in the same tender for the same item/product.

30. ADDITIONAL /EXTRA ITEM REQUIRED AT SITE DUE TO DAMAGE REPORTED AT SITE/ THEFT FOR COMPLETION OF PROJECT:

In case of additional requirement of any item specified in BOQ, whether due to damages / theft or any other reason, during contract (i.e. till expiry of contract i.e end of guarantee period), GIS OEM shall ensure supply of same at unit Price mentioned in purchase order main BOQ (supply and service portion) or BOQ for addition /deletion (if any).

- 31. ARBITRATION (Clause No. 19 of GTC): This clause shall be read as per Annexure-D.
- 32. **Breach of contract, remedies and termination:** In the event of a breach of Contract by the supplier, the Performance Bank Guarantee will be forfeited and credited to BHEL's account.

(A) Breach of contract and Termination:

Following conditions shall be considered as breach of contract:

- a) Non-supply of material/ non-completion of work by the vendor within scheduled delivery/ completion period as per contract or as extended from time to time.
- b) The vendor fails to perform as per the activity schedule and there are sufficient reasons even before expiry of the delivery/ completion period to justify that supplies shall be inordinately delayed beyond contractual delivery/ completion period.
- c) The vendor delivers equipment/ material not of the contracted quality.
- d) The vendor fails to replace the defective equipment/ material/ component as per quarantee clause.
- e) Withdrawal from or abandonment of the work by the vendor before completion as per contract.
- f) Assignment, transfer, subletting of Contract without BHEL's written permission resulting in termination of Contract or part thereof by BHEL.
- g) Non-compliance to any contractual condition or any other default attributable to Contractor/ Vendor.
- h) Termination of Contract on account of any other reason(s) attributable to Vendor.

In case of breach of contract, BHEL reserve the right to terminate the Purchase Order/ Contract either in whole or in part thereof without compensation to the vendor.

(B) Remedies for breach of contract:

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

In case of Breach of Contract, BHEL shall recover 10% amount of the contract value from the vendor in following manners:

- (i) Forfeiture/ encashment of Security instruments (Performance security, EMD etc.) available against the said contract.
- (ii) In case the value of security instruments available is less than 10% of the contract value, the balance amount shall be recovered from other financial remedies (i.e. available bills of the vendor, retention amount etc with BHEL-TBG or any other units of BHEL.
- (iii) Demand notice for deposit of balance recovery amount shall sent to the vendor, if security instruments or financial remedies are insufficient to affect the complete recovery.
- (iv) In case recovery is not possible from security instruments or from financial remedies mentioned above, legal remedies shall be pursued.

Important Notes:

- (1) The balance scope shall be got done independently without Risk & Cost of the failed vendor.
- (2) Further, levy of liquidated damages, debarment, termination, de-scoping, short-closure, etc., shall be applied as per provisions of the contract.

32.1 Liquidated Damage in case of termination of contract:

In case of termination of contract, LD shall be calculated as below:

LD against delay in executed Work/ Supply shall be calculated in line with LD clause of the contract for the delay attributable to supplier. For this purpose, contract value shall be taken as Executed Value of work/supply for the purpose of limiting maximum LD value.

Method for calculation of "LD against delay in executed Work/ supply" is given below:

- a) Let the time period from scheduled date of start of work till termination of contract excluding the period of Hold (if any) not attributable to contractor/ supplier = T1
- b) Let the value of executed work/ supply till the time of termination of contract = X
- c) Let the Total Executable Value of work/ supply for which inputs/ fronts were made available to contractor/ supplier and were planned for execution till termination of contract = Y
- d) Delay in executed work/ supply attributable to contractor/ supplier i.e. T2 = [1-(X/Y)] x T1
- e) LD shall be calculated in line with LD clause of the Contract for the delay attributable to supplier taking "X" as Contract Value and "T2" as delay attributable to contractor/ supplier.

Note: In case portion of service/ supply is withdrawn, no LD shall be applicable for portion of service/ supply withdrawn.

- 33. **HEALTH, SAFETY AND ENVIRONMENT (HSE) OF BHEL:** BHEL has their own Health, safety and environment. HSE policy is enclosed for bidder's reference.
- 34. **Prevention for cartel formation**: formal or informal with other Bidder(s). This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to introduce cartelization in

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

the bidding process. In case, the Bidder is found having indulged in above activities, suitable action shall be taken by BHEL as per extant policies/ guidelines.

35. CONFIDENTIALITY CLAUSE (Clause No.42 of GTC): In addition to the content of said clause of GTC, following is also included under this clause-

Seller and Buyer (as to information disclosed, the "Disclosing Party") may each provide the other party (as to information received, the "Receiving Party") with Confidential Information in connection with this Contract. "Confidential Information" means (a) information that is designated in writing as "confidential" or "proprietary" by Disclosing Party at the time of written disclosure, and (b) information that is orally designated as "confidential" or "proprietary" by Disclosing Party at the time of oral or visual disclosure and is confirmed to be "confidential" or "proprietary" in writing within twenty (20) days after the oral or visual disclosure. In addition, prices for Products and Services shall be considered Seller's Confidential Information. Receiving Party agrees: (i) to use the Confidential Information only in connection with the Contract and use of Products and Services, (ii) to take reasonable measures to prevent disclosure of the Confidential Information to third parties, and (iii) not to disclose the Confidential Information to a competitor of Disclosing Party. each Disclosing Party warrants that it has the right to disclose the information that it discloses. Neither Buyer nor Seller shall make any public announcement about the Contract without prior written approval of the other party.

The obligations shall not apply, however, regarding each receiving Party hereunder, to any information which:

- 1. was in that receiving Party's possession without an obligation to confidentiality prior to receipt from the disclosing Party;
- 2. is at the time of disclosure already in the public domain or subsequently becomes available to the public through no breach of this Agreement by that receiving Party;
- 3. is lawfully obtained by that receiving Party from a third party without an obligation to confidentiality, provided such third party is not, to that receiving Party's knowledge, in breach of any obligation to confidentiality relating to such information;
- 4. is developed by that receiving Party independently of any Confidential Information; or
- 5. is approved for release by written agreement of the disclosing Party;
- 6. is required by any applicable stock exchange listing rules or under the indian companies act. 1956;
- information which is required to be disclosed for compliance with applicable law, rule, regulation
 or court order or other compulsory process of a court, arbitral tribunal or any other government
 body.
- 36. **No nuclear use:** Products and Services sold by Seller are not intended for use in connection with any nuclear facility or activity, and Buyer warrants that it shall not use or permit others to

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

use Products or Services for such purposes, without the advance written consent of Seller. If, in breach of this, any such use occurs, Seller (and its parent, affiliates, suppliers and subcontractors) disclaims all liability for any nuclear or other damage, injury or contamination, and, in addition to any other rights of Seller, Buyer shall indemnify and hold Seller (and its parent, affiliates, suppliers and subcontractors) harmless against all such liability. Consent of Seller to any such use, if any, will be conditioned upon additional terms and conditions that Seller determines to be acceptable for protection against nuclear liability.

- 37. Force Majeure (Clause No.24 of GTC): In addition to the content of said clause of GTC, Pandemic, COVID-19, etc. are also included under this clause.
- 38. Bidder to submit the duly filled and signed Indemnification Agreement format (as per enclosed **Annexure-K**).
- 39. Bidder to submit the POA (Power of Attorney) for submission of tender along with bid.
- 40. Following confirmation to be provided by vendor:

"We confirm that we have quoted as per specified price format provided along with this tender".

Note: BHEL reserves the right to cancel this enquiry at any point of time.

NAME & SEAL OF TENDERER

SUPPLY & SERVICES OF 400kV GIS AND ASSOCIATED EQUIPMENTS FOR POWERGRID's 400kV GIS Package (Package-II) at KPS 3 Tender/Project

Enclosures:

- a) Activity Schedule, Commercial & Technical deviation Sheet.
- b) Instruction of DPIIT (**Annexure-1**), **Annexure-2/3** (Compliance regarding restrictions under Rule 144 (xi) of General Financial Rules (GFRs), 2017).
- c) Format for declaration of minimum local content (Annexure-A).
- d) Format for compliance of MoP order dated 02-07-2020 (Annexure-B).
- e) Format of Integrity pact (Annexure-C).
- f) Arbitration clause (Annexure-D).
- g) Format of Performance BG.
- h) Copy of HSE policy.
- i) Details of Packing list of GIS Module (Annexure-E).
- j) MOU format (Annexure-F)
- k) General Terms and Condition of NIT.
- I) BHEL'S PRICE BID FORMAT.
- m) All required documents/ credentials meeting BHEL's Technical PQR shall be submitted by GIS OEM/bidder as per **Annexure-G**.
- n) Confirmation in regard to Design & Type test (**Annexure-H**)
- o) JDU formats (Annexure-I)
- p) Customer's BG format (**Annexure-J**)
- q) Indemnification Agreement format (Annexure-K)



TENDER ENQUIRY NO.

DATED:

SCHEDULE OF COMMERCIAL DEVIATION

The following are the deviations/ variations exception from the General Terms and Conditions:

SL. No.	CLAUSE NO. OF GENERAL TERMS AND CONDITION	STATEMENT OF DEVIATION

In case, this schedule is not submitted, it will be presumed that the equipment/ material to be supplied under this contract is deemed to be in compliance with the Special Terms and Conditions & General Terms and Conditions.

- If there is NIL deviation, even then the format to be filled as **NIL DEVIATION**.

Note:1 Continuation Sheets of like size and format may be used as per the Bidder's Requirement and shall be annexed to this scheduled.

Note.2 Deviations (if nay) shall be mentioned in this format only. Deviations mentioned elsewhere, shall not be considered.

NAME & SEAL OF TENDERER



TENDER ENQUIRY NO.

DATED:

SCHEDULE OF TECHNICAL DEVIATION

The following are the deviations/ variations exception from the Specification:

SL. No.	CLAUSE NO. OF GENERAL TERMS AND CONDITION	STATEMENT OF DEVIATION/ VARIATIONS/EXCEPTIONS

In case, this schedule is not submitted, it will be presumed that the equipment/ material to be supplied under this contract is deemed to be In compliance with the Special Terms and Conditions & General Terms and Conditions & Specifications.

If there is NIL deviation, even then the format to be filled as **NIL DEVIATION**.

Note 1: Continuation Sheets of like size and format may be used as per the Bidder's Requirement and shall be annexed to this scheduled.

Note.2 Deviations (if nay) shall be mentioned in this format only. Deviations mentioned elsewhere, shall not be considered.

NAME & SEAL OF TENDERER

Note:

Activity Schedule for PO-1 (Main Supply Items & Service Items and/ or any other item not covered in PO-2 & PO-3)

SI. NO.	Activity	ACTIVITY TIME IN WEEKS	REMARKS IF ANY
A. Supply			
1	Order acknowledgement by vendor	1 Week	Supplier scope. PO date shall be considered as Zero Date.
2	Inputs to vendor from BHEL after issue of PO	2 Weeks	BHEL scope.
3	Submission of Documents necessary for getting manufacturing clearance like Drawings, Data sheet etc.		Supplier scope. To be quoted considering proposed delivery plan mentioned in STC.
4	Review and Approval of documents from BHEL/Customer and issue of manufacturing clearance.	6 Weeks	BHEL scope.
5	Manufacturing time (after Manufacturing Clearance from BHEL) along with Inspection Call (ie. Time from Manufacturing Clearance date and inspection date mentioned in inspection call)		Supplier scope. To be quoted inline with proposed delivery plan mentioned in STC.
6	BHEL/ customer Inspection & dispatch clearance	2 Weeks	BHEL scope
7	Dispatch	2 Weeks	Supplier scope
	Total time for supply		
B. Service	s at site		
8	Joint checking including surveying, levelling and marking of GIS Hall/ building floor and other associated GIB/ equipment foundations		BHEL/Supplier scope. The date on which site is declared ready jointly by vendor & BHEL site for ETC activities of GIS, shall be considered as Zero date.
9	Supervision of installation of GIS Bays and its associated work including LCC, cable trays, cabling and earthing work		BHEL/Supplier scope.
11	Testing and pre-commissioning of GIS Bays and its associated work including LCC, cable trays, cabling and earthing work		Supplier scope.
12	HV testing and commissioning of GIS		Supplier scope.
	Total time for service		
	TOTAL COMPLETION TIME (SUPPLY+SERVICES)		

^{1.} Supplier must ensure the completeness and correctness of the requisite drawings/documents before submission for approval.

2. Inspection call should be raised Two (02) weeks in advance before inspection date. Inspection call should be given in the prescribed format only (enclosed). Inspection calls not in the prescribed format shall not be entertained.

3.Delay in activity pertaining to BHEL, not attributable to vendor, as listed above shall be added, if required in case of time extension and Delivery date will be re-fixed accordingly based on bidder's request & delay analysis.

Activity Schedule for PO-2 (Mandatory Spares)

SI. NO.	Activity	ACTIVITY TIME IN WEEKS	REMARKS IF ANY
1	Order acknowledgement by vendor	1 Week	Supplier scope. PO date shall be considered as Zero Date.
2	Inputs to vendor from BHEL after issue of PO	2 Weeks	BHEL scope.
3	Submission of Documents necessary for getting manufacturing clearance like Drawings, Data sheet etc.		Supplier scope. To be quoted considering proposed delivery plan mentioned in STC.
4	Review and Approval of documents from BHEL/Customer and issue of manufacturing clearance.	6 Weeks	BHEL scope.
5	Manufacturing time (after Manufacturing Clearance from BHEL) along with Inspection Call (ie. Time from Manufacturing Clearance date and inspection date mentioned in inspection call)		Supplier scope. To be quoted inline with proposed delivery plan mentioned in STC.
6	BHEL/ customer Inspection & dispatch clearance	2 Weeks	BHEL scope
7	Dispatch	2 Weeks	Supplier scope
	Total time for supply		
1. Supplier must ensure the completeness and correctness of the requisite drawings/documents before submission for approval. 2. Inspection call should be raised Two (02) weeks in advance before inspection date. Inspection call should be given in the prescribed format only (enclosed). Inspection calls not in the prescribed format shall not be entertained. 3. Delay in activity pertaining to BHEL, not attributable to vendor, as listed above shall be added, if required in case of time extension and Delivery date will be re-fixed accordingly based on bidder's request & delay analysis.			

Activity Schedule for PO-3 (TOOLS AND TESTING & MAINTENANCE EQUIPMENT)

SI. NO.	Activity	ACTIVITY TIME IN WEEKS	REMARKS IF ANY
1	Order acknowledgement by vendor	1 Week	Supplier scope. PO date shall be considered as Zero Date.
2	Inputs to vendor from BHEL after issue of PO	2 Weeks	BHEL scope.
3	Submission of Documents necessary for getting manufacturing clearance like Drawings, Data sheet etc.		Supplier scope. To be quoted considering proposed delivery plan mentioned in STC.
4	Review and Approval of documents from BHEL/Customer and issue of manufacturing clearance.	6 Weeks	BHEL scope.
5	Manufacturing time (after Manufacturing Clearance from BHEL) along with Inspection Call (ie. Time from Manufacturing Clearance date and inspection date mentioned in inspection call)		Supplier scope. To be quoted inline with proposed delivery plan mentioned in STC.
6	BHEL/ customer Inspection & dispatch clearance	2 Weeks	BHEL scope
7	Dispatch	2 Weeks	Supplier scope
	Total time for supply		
1. Supplier must ensure the completeness and correctness of the requisite drawings/documents before submission for approval. 2. Inspection call should be raised Two (02) weeks in advance before inspection date. Inspection call should be given in the prescribed format only (enclosed). Inspection calls not in the prescribed format shall not be entertained. 3. Delay in activity pertaining to BHEL, not attributable to vendor, as listed above shall be added, if required in case of time extension and Delivery date will be re-fixed accordingly based on bidder's request & delay analysis.			

ANNEXURE-1

CLAUSES FOR NEW TENDERS:

- I. Any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority.
- II. "Bidder" (including the term 'tenderer', 'consultant' or 'service provider' in certain contexts) means any person or firm or company including any member of a consortium or joint venture (that is an association of several persons, or firms or companies), every artificial juridical person not failing in any of the descriptions of bidders stated hereinbefore, including any agency branch or office controlled by such person, participating in a procurement process.
- III. "Bidder from a country which shares a land border with India" for the purpose of this Order means:
 - a. An entity Incorporated, established or registered in such a country; or
 - b. A subsidiary of an entity Incorporated, established or registered in such a country; or
 - c. An entity substantially controlled through entitles incorporated, established or registered in such a country; or
 - d. An entity whose beneficial owner is situated in such a country, or
 - e. An Indian (or other) agent of such an entity; or
 - f. A natural person who is a citizen of such a country; or
 - g. A consortium or joint venture where any member of the consortium or joint venture falls under any of the above
- IV. The *beneficial owner* for the purpose of (iii) above will be as under:
 - 1. In case of a company or Limited Liability Partnership, the beneficial owner is the natural person(s), who, whether acting alone or together, or through one or more juridical person, has a controlling ownership interest or who exercises control through other means. Explanation
 - a. "Controlling ownership interest" means ownership of or entitlement to more than twenty-five per cent. of shares or capital or profits of the company;
 - b. "Control" shall include the right to appoint majority of the directors or to control
 the management or policy decisions including by virtue of their shareholding
 or management rights or shareholder's agreements or voting agreements;
 - 2. In case of a partnership firm, the beneficial owner is the natural person(s) who, whether acting alone or together, or through one or more juridical person, has ownership of entitlement to more than fifteen percent of capital or profits of the partnership;
 - 3. In case of an unincorporated association or body of individuals, the beneficial owner is the natural person(s), who, whether acting alone or together, or through one or more juridical person, has ownership of or entitlement to more than fifteen percent of the property or capital or profits of such association or body of Individuals;
 - 4. Where no natural person is Identified under (1) or (2) or (3) above the beneficial owner is the relevant natural person who holds the position of senior managing official;
 - 5. In case of a trust, the identification of beneficial owner(s) shall include identification of the author of the trust, the trustee, the beneficiaries with fifteen percent or more interest in the trust and any other natural person exercising ultimate effective control over the trust through a chain of control or ownership.

- V. An Agent is a person employed to do any act for another or to represent another in dealings with third person.
- VI. The successful bidder shall not be allowed to sub-contract works to any contractor from a country which shares a land border with India unless such contractor is registered with the Competent Authority.
- * The above clause is not applicable to the bidders from those countries (even if sharing a land border with India) to which the GoI has extended lines of credit or in which the GoI is engaged in development projects.
- * List of countries to which lines of credit have been extended or in which development projects are undertaken are available on the Ministry of External affairs website (https://www.mea.gov.in/)

Annexure-2

Compliance to be submitted in INR 100/- non judicial stamp paper

Sub: Compliance to Government of India order OM No.6/18/2019-PPD dated 23.07.2020 regarding restrictions under Rule 144 (XI) of the General Financial Rules (GFRs), 2017

SI No.	Description	Bidder's confirmation
1	We, M/shave read the clause regarding restrictions on procurement from a bidder of a country which shares a land border with India; We hereby certify that we are not from such a country.	Agreed

(Note: Non-compliance of above said GoI Order and its subsequent amendment, (if any), by any bidder(s) shall lead for commercial rejection of their bids by BHEL)

Bidder's authorized signatory with stamp & seal

Annexure-3

Compliance to be submitted in INR 100/- non judicial stamp paper

Sub: Compliance to Government of India order OM No.6/18/2019-PPD dated 23.07.2020 regarding restrictions under Rule 144 (XI) of the General Financial Rules (GFRs), 2017

S.N.	Description	Bidder's confirmation
1	We, M/shave read the clause regarding restrictions on procurement from a bidder of a country which shares a land border with India. We are from such a country which shares a land border with India & have been registered with the Competent Authority as specified in above said order. We hereby certify that we fulfil all requirements in this regard and are eligible to be considered. Evidence of valid registration by the Competent Authority is attached.	Agreed

(Note: Non-compliance of above said GoI Order and its subsequent amendment, (if any), by any bidder(s) shall lead for commercial rejection of their bids by BHEL)

Bidder's authorized signatory with stamp & seal

Annexure-A

Item Name :	
Enquiry No. :	
Project :	
Type of project	Transmission / Thermal (Coal or Gas) / Hydro
Applicable percentage of	Bidder to indicate local content in percentage
Local Content	

Certificate from statutory auditor or cost auditor of the company (in the case of companies) or from a practicing cost accountant or practicing chartered accountant (in respect of suppliers other than companies) giving the percentage of Local Content, in line with PPP-MII order, if applicable [to be submitted on the letter head of the issuer.]

Dear Sir.

We have read and understood the provisions of "Public Procurement (Preference to Make in India) Order, 2017" dated 15/06/2017, its revision dated 28/05/2018 and any subsequent modifications/Amendments, if any [hereinafter, "PPP-MII Order"] issued by Department of Industrial Policy and Promotion (DIPP), Ministry of Commerce and Industry, Government of India.

In line with the provisions of the PPP-MII Order, M/s.[Enter the name of the Bidder] [hereinafter, "Local Supplier"] have submitted an Affidavit of self-certification to M/s. Bharat Heavy Electricals Limited [hereinafter, BHEL] regarding Local Content in Goods/Services/Works to be supplied by the Local Supplier for(Enter the name of the Equipment/Item for Project).], wherein they have agreed to abide by the terms and conditions of the PPP-MII Order.

Further, in line with the PPP-MII Order, the statutory auditor or cost auditor of the company (in the case of companies) or a practicing cost accountant or practicing chartered accountant (in respect of suppliers other than companies) shall provide a certificate giving the percentage of Local Content in the Goods/Service/Works to be supplied by the Local Supplier for(Enter the name of the Equipment/Item for Project).

For and on behalf of,	Date:

Authorised persons

Firm Reg No: Membership No.

Note: This is a guiding format. In case the bidder submits the certificate in a format different from the above, the same may be considered provided it meets the intent and purpose, as may be ascertained by BHEL.

Annexure-B

Vendor Compliance format in bidder letter head

In view of by order No. 25-111612018-PG, Dated 02.07.2020 of Ministry of Power, GOI

Enquiry No/ PO No & Date
Project
Name of items/Package

This is to certify that all equipment, components, and parts imported for use in the Power Supply System and Network are in strict compliance to directions issued by Ministry of Power, Govt. of India vide order No. 25-111612018-PG dated 02.07.2020. The imported component(s), part or assembly item(s) does not carry any malware/Trojan etc.

Note: Non-compliance of MoP Order and its subsequent amendment(s), (if any), by vendor shall lead to rejection of their offer or cancellation of contract, which is awarded by BHEL.

Bidder's authorized signatory with stamp & seal

BHEL-IP AA:SSP:IP:R02 dtd 10.07.2018

INTEGRITY PACT

Between

Bharat Heavy Electricals Ltd. (BHEL), a company registered under the Companies Act 1956 and having its registered office at "BHEL House", Siri Fort, New Delhi - 110049 (India) hereinafter referred to as "The Principal", which expression unless repugnant to the context or meaning hereof shall include its successors or assigns of the ONE PART

and
along with address), hereinafter referred to as "The Bidder/ Contractor" which expression unless repugnant to the context or meaning hereof shall include its successors or assigns of the OTHER PART
<u>Preamble</u>
The Principal intends to award, under laid-down organizational procedures, contract/s for
. The Principal values full compliance with all relevant laws of the land, rules and regulations, and the principles of economic use of resources, and of fairness and transparency in its relations with its Bidder(s)/ Contractor(s).

In order to achieve these goals, the Principal will appoint Independent External Monitor(s), who will monitor the tender process and the execution of the contract for compliance with the principles mentioned above.

Section 1- Commitments of the Principal

- 1.1 The Principal commits itself to take all measures necessary to prevent corruption and to observe the following principles:-
- 1.1.1 No employee of the Principal, personally or through family members, will in connection with the tender for, or the execution of a contract, demand, take a promise for or accept, for self or third person, any material or immaterial benefit which the person is not legally entitled to.
- 1.1.2 The Principal will, during the tender process treat all Bidder(s) with equity and reason. The Principal will in particular, before and during the tender process, provide to all Bidder(s) the same information and will not provide to any Bidder(s) confidential/additional information through which the Bidder(s) could obtain an advantage in relation to the tender process or the contract execution.
- 1.1.3 The Principal will exclude from the process all known prejudiced persons.
- 1.2 If the Principal obtains information on the conduct of any of its employees which is a penal offence under the Indian Penal Code 1860 and Prevention of Corruption Act 1988 or any other statutory penal enactment, or if there be a substantive suspicion in this regard, the Principal will inform its Vigilance Office and in addition can initiate disciplinary actions:

Section 2 - Commitments of the Bidder(s)/ Contractor(s)

- 2.1 The Bidder(s)/ Contractor(s) commit himself to take all measures necessary to prevent corruption. He commits himself to observe the following principles during his participation in the tender process and during the contract execution.
- 2.1.1 The Bidder(s)/ Contractor(s) will not, directly or through any other person or firm, offer, promise or give to the Principal or to any of the Principal's employees involved in the tender process or the execution of the contract or to any third person any material, immaterial or any other benefit which he/ she is not legally entitled to, in order to obtain in exchange any advantage of any kind whatsoever during the tender process or during the execution of the contract.
- 2.1.2 The Bidder(s)/ Contractor(s) will not enter with other Bidder(s) into any illegal or undisclosed agreement or understanding, whether formal or informal. This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to introduce cartelization in the bidding process.
- 2.1.3 The Bidder(s)/ Contractor(s) will not commit any penal offence under the relevant Indian Penal Code (IPC) and Prevention of Corruption Act; further the Bidder(s)/ Contractor(s) will not use improperly, for purposes of competition or personal gain, or pass on to others, any information or document provided by the Principal as part of the business relationship, regarding plans, technical proposals and business details, including information contained or transmitted electronically.
- 2.1.4 Foreign Bidder(s)/ Contractor(s) shall disclose the name and address of agents and representatives in India and Indian Bidder(s)/ Contractor(s) to disclose their foreign principals or associates. The Bidder(s)/ Contractor(s) will, when presenting his bid, disclose any and all payments he has made, and is committed to or intends to make to agents, brokers or any other intermediaries in connection with the award of the contract.
- 2.2 The Bidder(s)/ Contractor(s) will not instigate third persons to commit offences outlined above or be an accessory to such offences.
- 2.3 The Bidder(s)/ Contractor(s) shall not approach the Courts while representing the matters to IEMs and will await their decision in the matter.

Section 3 - Disqualification from tender process and exclusion from future contracts

If the Bidder(s)/ Contractor(s), before award or during execution has committed a transgression through a violation of Section 2 above, or acts in any other manner such as to put his reliability or credibility in question, the Principal is entitled to disqualify the Bidder(s)/ Contractor(s) from the tender process or take action as per the separate "Guidelines on Banning of Business dealings with Suppliers/ Contractors", framed by the Principal.

Section 4 - Compensation for Damages

- 4.1 If the Principal has disqualified the Bidder from the tender process prior to the award according to Section 3, the Principal is entitled to demand and recover the damages equivalent Earnest Money Deposit/ Bid Security.
- 4.2 If the Principal has terminated the contract according to Section 3, or if the Principal is entitled to terminate the contract according to section 3, the Principal shall be entitled to

demand and recover from the Contractor liquidated damages equivalent to 5% of the contract value or the amount equivalent to Security Deposit/ Performance Bank Guarantee, whichever is higher.

Section 5 - Previous Transgression

- 5.1 The Bidder declares that no previous transgressions occurred in the last 3 years with any other company in any country conforming to the anti-corruption approach or with any other Public Sector Enterprise in India that could justify his exclusion from the tender process.
- 5.2 If the Bidder makes incorrect statement on this subject, he can be disqualified from the tender process or the contract, if already awarded, can be terminated for such reason.

Section 6 - Equal treatment of all Bidders/ Contractors / Sub-contractors

- 6.1 The Principal will enter into agreements with identical conditions as this one with all Bidders and Contractors. In case of sub-contracting, the Principal contractor shall be responsible for the adoption of IP by his sub-contractors and shall continue to remain responsible for any default by his sub-contractors:
- 6.2 The Principal will disqualify from the tender process all bidders who do not sign this pact or violate its provisions.

Section 7 - Criminal Charges against violating Bidders/ Contractors /Subcontractors

If the Principal obtains knowledge of conduct of a Bidder, Contractor or Subcontractor, or of an employee or a representative or an associate of a Bidder, Contractor or Subcontractor which constitutes corruption, or if the Principal has substantive suspicion in this regard, the Principal will inform the Vigilance Office.

Section 8 - Independent External Monitor(s)

- 8.1 The Principal appoints competent and credible Independent External Monitor for this Pact. The task of the Monitor is to review independently and objectively, whether and to what extent the parties comply with the obligations under this agreement.
- 8.2 The Monitor is not subject to instructions by the representatives of the parties and performs his functions neutrally and independently. He reports to the CMD, BHEL.
- 8.3 The Bidder(s)/ Contractor(s) accepts that the Monitor has the right to access without restriction to all contract documentation of the Principal including that provided by the Bidder(s)/ Contractor(s). The Bidder(s)/ Contractor(s) will grant the monitor, upon his request and demonstration of a valid interest, unrestricted and unconditional access to his contract documentation. The same is applicable to Sub-contractor(s). The Monitor is under contractual obligation to treat the information and documents of the Bidder(s)/ Contractor(s) / Sub-contractor(s) with confidentiality in line with Non- disclosure agreement.
- 8.4 The Principal will provide to the Monitor sufficient information about all meetings among the parties related to the contract provided such meetings could have an impact on the contractual relations between the Principal and the Contractor. The parties offer to the Monitor the option to participate in such meetings.

- 8.5 The role of IEMs is advisory, would not be legally binding and it is restricted to resolving issues raised by an intending bidder regarding any aspect of the tender which allegedly restricts competition or bias towards some bidders. At the same time, it must be understood that IEMs are not consultants to the Management. Their role is independent in nature and the advice once tendered would not be subject to review at the request of the organization.
- 8.6 For ensuring the desired transparency and objectivity in dealing with the complaints arising out of any tendering process, the matter should be examined by the full panel of IEMs jointly as far as possible, who would look into the records, conduct an investigation, and submit their joint recommendations to the Management.
- 8.7 The IEMs would examine all complaints received by them and give their recommendations/ views to CMD, BHEL, at the earliest. They may also send their report directly to the CVO and the Commission, in case of suspicion of serious irregularities requiring legal/ administrative action. IEMs will tender their advice on the complaints within 10 days as far as possible.
- 8.8 The CMD, BHEL shall decide the compensation to be paid to the Monitor and its terms and conditions.
- 8.9 IEM should examine the process integrity, they are not expected to concern themselves with fixing of responsibility of officers. Complaints alleging mala fide on the part of any officer of the organization should be looked into by the CVO of the concerned organisation.
- 8.10 If the Monitor has reported to the CMD, BHEL, a substantiated suspicion of an offence under relevant Indian Penal Code/ Prevention of Corruption Act, and the CMD, BHEL has not, within reasonable time, taken visible action to proceed against such offence or reported it to the Vigilance Office, the Monitor may also transmit this information directly to the Central Vigilance Commissioner, Government of India.
- 8.11 The number of Independent External Monitor(s) shall be decided by the CMD, BHEL.
- 8.12 The word 'Monitor' would include both singular and plural.

Section 9 - Pact Duration

- 9.1 This Pact shall be operative from the date IP is signed by both the parties till the final completion of contract for successful bidder and for all other bidders 6 months after the contract has been awarded. Issues like warranty / guarantee etc. should be outside the purview of IEMs.
- 9.2 If any claim is made/ lodged during currency of IP, the same shall be binding and continue to be valid despite the lapse of this pact as specified above, unless it is discharged/ determined by the CMD, BHEL.

Section 10 - Other Provisions

10.1 This agreement is subject to Indian Laws and jurisdiction shall be registered office of the Principal, i.e. New Delhi.

AA:SSP:IP:R02 dtd 10.07.2018

BHEL-IP

- 10.2 Changes and supplements as well as termination notices need to be made in writing. Side agreements have not been made.
- 10.3 If the Contractor is a partnership or a consortium, this agreement must be signed by all partners or consortium members.
- 10.4 Should one or several provisions of this agreement turn out to be invalid, the remainder of this agreement remains valid. In this case, the parties will strive to come to an agreement to their original intentions.
- 10.5 Only those bidders / contractors who have entered into this agreement with the Principal would be competent to participate in the bidding. In other words, entering into this agreement would be a preliminary qualification.

5 N	
For & On behalf of the Principal	For & On behalf of the Bidder/
	Contractor
(Office Seal)	(Office Seal)
Place	
Date	
Witness:	Witness:
(Name & Address)	(Name & Address)

CLAUSE NO. 19 OF GTC: ARBITRATION CLAUSE SHALL BE READ AS BELOW:

(A) CONCILIATION (MODEL CONCILIATION CLAUSE FOR CONDUCTING CONCILIATION PROCEEDINGS UNDER THE BHEL CONCILIATION SCHEME, 2018)

The Parties agree that if at any time (whether before, during or after the arbitral or judicial proceedings), any Disputes (which term shall mean and include any dispute, difference, question or disagreement arising in connection with construction, meaning, operation, effect, interpretation or breach of the agreement, contract or the Memorandum of Understanding (whichever is inapplicable), which the Parties are unable to settle mutually), arise inter-se the Parties, the same may, be referred by either party to Conciliation to be conducted through Independent Experts Committee to be appointed by competent authority of BHEL from the BHEL Panel of Conciliators.

Notes:

- 1. No serving or a retired employee of BHEL/Administrative Ministry of BHEL shall be included in the BHEL Panel of Conciliators.
- 2. Any other person(s) can be appointed as Conciliator(s) who is/are mutually agreeable to both the parties from outside the BHEL Panel of Conciliators.

The proceedings of Conciliation shall broadly be governed by Part-III of the Arbitration and Conciliation Act 1996 or any statutory modification thereof and as provided in **Annexure-A to this GCC (Enclosed).**

The Annexure-A together with it's appendices will be treated as if the same is part and parcel hereof and shall be as effectual as if set out herein in these GCC."

(B) ARBITRATION (WITH SOLE ARBITRATOR)

- 1.1. Except as provided elsewhere in this Contract, in case amicable settlement is not reached between the Parties, in respect of any dispute or difference; arising out of the formation, breach, termination, validity or execution of the Contract; or, the respective rights and liabilities of the Parties; or, in relation to interpretation of any provision of the Contract; or, in any manner touching upon the Contract, then, either Party may, by a notice in writing to the other Party refer such dispute or difference to the Sole Arbitrator and such Arbitrator appointed by Head of the BHEL Unit/Region/Division issuing the Contract.
- 1.2. The Arbitrator shall pass a reasoned award and the award of the Arbitrator shall be final and binding upon the Parties.
- 1.3. Subject as aforesaid, the provisions of Arbitration and Conciliation Act 1996 (India) and amended in 2015 and further amendment passed in 2019 or statutory modifications or re-enactments thereof and the rules made thereunder and for the time being in force shall apply to the arbitration proceedings under this clause. The seat of arbitration shall be New Delhi. The language of arbitration shall be English and the documents shall be submitted in English.
- 1.4. The cost of arbitration shall initially be borne equally by the Parties subject to the final apportionment of the cost of the arbitration in the award of the Arbitrator.
- 1.5. Notwithstanding the existence or any dispute or differences and/or reference for the arbitration, the Contractor shall proceed with and continue without hindrance the performance of its

CLAUSE NO. 19 OF GTC: ARBITRATION CLAUSE SHALL BE READ AS BELOW:

obligations under this Contract with due diligence and expedition in a professional manner except where the Contract has been terminated by either Party in terms of this Contract.

1.6. SETTLEMENT OF COMMERCIAL DISPUTES BETWEEN CPSES INTER SE AND CPSE(S) AND GOVERNMENT DEPARTMENT(S)/ ORGANISATION(S) – ADMINISTRATIVE MECHANISM FOR RESOLUTION OF CPSES DISPUTES (AMRCD) – REGARDING

Vide Dept. of Public Enterprises OM No. F. No. 4(1)/2013-DPE(GM)/FTS-1835 dated 22.05.2018 it has been conveyed that "To make the mechanism more effective and binding on the disputing parties, a new mechanism namely Administrative Mechanism for resolution of CPSEs Disputes (AMRCD) having two level (tier) structure has been evolved in consultation with various stakeholders to replace the existing PMA mechanism which stands wound up from the date of issue of this OM." Accordingly, the existing Permanent Machinery of Arbitration (PMA) stands wound up with effect from 22.05.2018 and cases relating to disputes or differences relating to the interpretation and application of the provisions of commercial contract(s) between CPSEs / Port Trust / Central or State Government Department / Organisations (excluding disputes concerning Railways, Income Tax, Customs and Excise Departments) shall be taken up by either party for its resolution through Administrative Mechanism for Resolution of CPSEs Disputes (AMRCD).

(C) JURISDICTION AND GOVERNING LAWS

The Courts at New Delhi shall have exclusive jurisdiction over any matter arising out of or in connection with this Contract. This Contract shall be construed as per and be governed by the Laws of India.

Annexure-A

ANNEXURE TO MODEL CONCILIATION CLAUSE FOR CONDUCT OF CONCILIATION UNDER THE BHEL CONCILIATION SCHEME, 2018

BRIEF PROCEDURE FOR CONDUCT OF CONCILIATION PROCEEDINGS

- 1. The proceedings of Conciliation shall broadly be governed by Part-III of the Arbitration and Conciliation Act 1996 or any statutory modification thereof and as provided herein:
- 2. The party desirous of resorting to Conciliation shall send an invitation/notice in writing to the other party to conciliate specifying all points of Disputes with details of the amount claimed. The party concerned shall not raise any new issue thereafter. Parties shall also not claim any interest on claims/counter-claims from the date of notice invoking Conciliation till the conclusion of the Conciliation proceedings.
- 3. The party receiving the invitation/notice for Conciliation shall within 30 days of receipt of the notice of Conciliation intimate its consent for Conciliation along with its counter-claims, if any.
- 4. The Conciliation in a matter involving claim or counter-claim (whichever is higher) up to Rs 5 crores shall be carried out by sole Conciliator nominated by BHEL while in a matter involving claim or counter-claim (whichever is higher) of more than Rs 5 crores Conciliation shall be carried out by 3 Conciliators nominated by BHEL.
- 5. The Parties shall be represented by only their duly authorized in-house executives/officers and neither Party shall be represented by a Lawyer.
- 6. The first meeting of the IEC shall be convened by the IEC by sending appropriate communication/notice to both the parties as soon as possible but not later than 30 days from the date of his/their appointment. The hearings in the Conciliation proceeding shall ordinarily be concluded within two (2) months and, in exceptional cases where parties have expressed willingness to settle the matter or there exists possibility of settlement in the matter, the proceedings may be extended by the IEC by a maximum of further 2 months with the consent of the Parties subject to cogent reasons being recorded in writing.
- 7. The IEC shall thereafter formulate recommendations for settlement of the Disputes supported by reasons at the earliest but in any case within

- 15 days from the date of conclusion of the last hearing. The recommendations so formulated along with the reasons shall be furnished by the IEC to both the Parties at the earliest but in any case within 1 month from the date of conclusion of the last hearing.
- 8. Response/modifications/suggestions of the Parties on the recommendations of the IEC are to be submitted to the IEC within time limit stipulated by the IEC but not more than 15 days from the date of receipt of the recommendations from the IEC.
- 9. In the event, upon consideration, further review of the recommendations is considered necessary, whether by BHEL or by the other Party, then, the matter can be remitted back to the IEC with request to reconsider the same in light of the issues projected by either/both the Parties and to submit its recommendations thereon within the following 15 days from the date of remitting of the case by either of the Parties.
- 10. Upon the recommendations by the Parties, with or without modifications, as considered necessary, the IEC shall be called upon to draw up the Draft Settlement Agreement in terms of the recommendations.
- 11. When a consensus can be arrived at between the parties only in regard to any one or some of the issues referred for Conciliation the draft Settlement Agreement shall be accordingly formulated in regard to the said Issue(s), and the said Settlement Agreement, if signed, by the parties, shall be valid only for the said issues. As regards the balance issues not settled, the parties may seek to resolve them further as per terms and conditions provided in the contract.
- 12. In case no settlement can be reached between the parties, the IEC shall by a written declaration, pronounce that the Conciliation between the parties has failed and is accordingly terminated.
- 13. Unless the Conciliation proceedings are terminated in terms of para 22 (b), (c) & (d) herein below, the IEC shall forward his/its recommendations as to possible terms of settlement within one (1) month from the date of last hearing. The date of first hearing of Conciliation shall be the starting date for calculating the period of 2 months.

- 14. In case of 3 members IEC, 2 members of IEC present will constitute a valid quorum for IEC and meeting can take place to proceed in the matter after seeking consent from the member who is not available. If necessary, videoconferencing may be arranged for facilitating participation of the members. However, the IEC recommendations will be signed by all members. Where there is more than one (1) Conciliator, as a general rule they shall act jointly. In the event of differences between the Members of IEC, the decision/recommendations of the majority of the Members of IEC shall prevail and be construed as the recommendation of the IEC.
- 15. The Draft Settlement Agreement prepared by the IEC in terms of the consensus arrived at during the Conciliation proceedings between the Parties shall be given by the IEC to both the parties for putting up for approval of their respective Competent Authority.
- 16. Before submitting the draft settlement agreement to BHEL's Competent Authority viz. the Board Level Committee on Alternative Dispute Resolution (BLCADR) for approval, concurrence of the other party's Competent Authority to the draft settlement agreement shall be obtained by the other party and informed to BHEL within 15 days of receipt of the final draft settlement agreement by it. Upon approval by the Competent Authority, the Settlement Agreement would thereafter be signed by the authorized representatives of both the Parties and authenticated by the members of the IEC.
- 17. In case the Draft Settlement Agreement is rejected by the Competent Authority of BHEL or the other Party, the Conciliation proceedings would stand terminated.
- 18. A Settlement Agreement shall contain a statement to the effect that each of the person(s) signing thereto (i) is fully authorized by the respective Party(ies) he/she represents, (ii) has fully understood the contents of the same and (iii) is signing on the same out of complete freewill and consent, without any pressure, undue influence.
- 19. The Settlement Agreement shall thereafter have the same legal status and effect as an arbitration award on agreed terms on the substance of the dispute rendered by an arbitral tribunal passed under section 30 of the Arbitration and Conciliation Act, 1996.
- 20. Acceptance of the Draft Settlement Agreement/recommendations of the Conciliator and/or signing of the Settlement Agreement by BHEL shall

however, be subject to withdrawal/closure of any arbitral and/or judicial proceedings initiated by the concerned Party in regard to such settled issues.

- 21. Unless otherwise provided for in the agreement, contract or the Memorandum of Understanding, as the case may be, in the event of likelihood of prolonged absence of the Conciliator or any member of IEC, for any reason/incapacity, the Competent Authority/Head of Unit/Division/Region/Business Group of BHEL may substitute the Conciliator or such member at any stage of the proceedings. Upon appointment of the substitute Conciliator(s), such reconstituted IEC may, with the consent of the Parties, proceed with further Conciliation into the matter either de-novo or from the stage already reached by the previous IEC before the substitution.
- 22. The proceedings of Conciliation under this Scheme may be terminated as follows:
 - a. On the date of signing of the Settlement agreement by the Parties; or,
 - b. By a written declaration of the IEC, after consultation with the parties, to the effect that further efforts at conciliation are no longer justified, on the date of the declaration; or,
 - c. By a written declaration of the Parties addressed to the IEC to the effect that the Conciliation proceedings are terminated, on the date of the declaration; or,
 - d. By a written declaration of a Party to the other Party and the IEC, if appointed, to the effect that the Conciliation proceedings are terminated, on the date of the declaration.
 - e. On rejection of the Draft Settlement Agreement by the Competent Authority of BHEL or the other Party.
- 23. The Conciliator(s) shall be entitled to following fees and facilities:

S1 No	Particulars	Amount				
1	Sitting fees	Each Member shall be paid a Lump				
		Sum fee of Rs 75,000/- for the whole				
		case payable in terms of paragraph				
		No. 27 herein below.				
2	Towards drafting of	In cases involving claim and/or				
	settlement	counter-claim of up to Rs 5crores.				
	agreement	Rs 50,000/- (Sole Conciliator)				

S1 No	Particulars	Amount
		In cases involving claim and/or counter-claim of exceeding Rs 5 crores but less than Rs 10 crores. Rs 75,000 (per Conciliator) In cases involving claim and/or counter-claim of more than Rs 10 crores. Rs 1,00,000/- (per Conciliator) Note: The aforesaid fees for the drafting of the Settlement Agreement shall be paid on Signing of the Settlement Agreement after approval of the Competent Authority or Rejection of the proposed Settlement Agreement by the Competent Authority of BHEL.
3	Secretarial expenses	Rs 10,000/- (one time) for the whole case for Conciliation by a Sole Member IEC. Where Conciliation is by multi member Conciliators –Rs 30,000/- (one time)- to be paid to the IEC
4	Travel and transportation and stay at outstation i) Retired Senior Officials of other Public Sector Undertakings (pay scale wise equivalent to or more than E-8 level of BHEL)	As per entitlement of the equivalent officer (pay scale wise) in BHEL.
	Others	As per the extant entitlement of whole time Functional Directors in BHEL.

S1 No	Particulars	Amount				
		Ordinarily, the IEC Member(s) would				
		be entitled to travel by air Economy				
		Class.				
5	Venue for meeting	Unless otherwise agreed in the				
		agreement, contract or the				
		Memorandum of Understanding, as				
		the case may be, the venue/seat of				
		proceedings shall be the location of				
		the concerned Unit / Division /				
		Region / Business Group of BHEL.				
		Without prejudice to the seat/venue				
		of the Conciliation being at the				
		location of concerned BHEL Unit /				
		Division / Region / Business Group,				
		the IEC after consulting the Parties				
		may decide to hold the proceedings				
		at any other place/venue to facilitate				
		the proceedings. Unless, Parties				
		agree to conduct Conciliation at				
		BHEL premises, the venue is to be				
		arranged by either Party alternately.				

- 24. The parties will bear their own costs including cost of presenting their cases/evidence/witness(es)/expert(s)on their behalf. The parties agree to rely upon documentary evidence in support of their claims and not to bring any oral evidence in IEC proceedings.
- 25. If any witness(es) or expert(s) is/are, with the consent of the parties, called upon to appear at the instance of the IEC in connection with the matter, then, the costs towards such witness(es)/expert(s) shall be determined by the IEC with the consent of the Parties and the cost so determined shall be borne equally by the Parties.
- 26. The other expenditures/costs in connection with the Conciliation proceedings as well as the IEC's fees and expenses shall be shared by the Parties equally.
- 27. Out of the lump sum fees of Rs 75,000/- for Sitting Fees, 50% shall be payable after the first meeting of the IEC and the remaining 50% of the Sitting Fees shall be payable only after termination of the conciliation proceedings in terms of para 22 hereinabove.

- 28. The travelling, transportation and stay at outstation shall be arranged by concerned Unit as per entitlements as per Serial No. 3 of the Table at para 23 above, and in case such arrangements are not made by the BHEL Unit, the same shall be reimbursed to the IEC on actuals limited to their entitlement as per Serial No. 4 of the Table at Para 23 above against supporting documents. The IEC Member(s) shall submit necessary invoice for claiming the fees/reimbursements.
- 29. The Parties shall keep confidential all matters relating to the conciliation proceedings. Confidentiality shall extend also to the settlement agreement, except where its disclosure is necessary for purposes of its implementation and enforcement or as required by or under a law or as per directions of a Court/Governmental authority/regulatory body, as the case may be.
- 30. The Parties shall not rely upon or introduce as evidence in any further arbitral or judicial proceedings, whether or not such proceedings relate to the Disputes that is the subject of the Conciliation proceedings:
 - a. Views expressed or suggestions made by the other party in respect of a possible settlement of the Disputes;
 - b. admissions made by the other party in the course of the Conciliator proceedings;
 - c. proposals made by the Conciliator;
 - d. The fact that the other Party had indicated his willingness to accept a proposal for settlement made by the Conciliator.
- 31. The Parties shall not present the Conciliator(s) as witness in any Alternative Dispute Resolution or Judicial proceedings in respect of a Disputes that is/was the subject of that particular Conciliation proceeding.
- 32. None of the Conciliators shall act as an arbitrator or as a representative or counsel of a Party in any arbitral or judicial proceeding in respect of a Disputes that is/was the subject of that particular Conciliation proceeding.
- 33. The Parties shall not initiate, during the Conciliation proceedings, any arbitral or judicial proceedings in respect of a Disputes that is the subject matter of the Conciliation proceedings except that a Party may initiate arbitral or judicial proceedings where, in his opinion, such proceedings are necessary for preserving his rights including for preventing expiry of period of limitation. Unless terminated as per the provisions of this Scheme, the Conciliation proceedings shall continue

notwithstanding the commencement of the arbitral or judicial proceedings and the arbitral or judicial proceedings shall be primarily for the purpose of preserving rights including preventing expiry of period of limitation.

34. The official language of Conciliation proceedings under this Scheme shall be English unless the Parties agree to some other language.

Format 2 to BHEL Conciliation Scheme, 2018

FORMAT FOR SEEKING CONSENT FOR REFERRING THE DISPUTES TO CONCILIATION THROUGH IEC

To,
M/s. (Stakeholder's name)
Sub: Resolution of the Disputes through conciliation by Independent Expert Committee (IEC).
Ref: Contract No/MoU/Agreement/LOI/LOA& date
Sir,
With reference to above referred Contract/MoU/Agreement/LOI/LOA, you have raised certain Disputes/claims. Vide your letter dated you have requested BHEL to refer the Disputes/claims to IEC for Conciliation.
We are enclosing herewith Format (3) for giving consent and the terms and conditions of BHEL Conciliation Scheme, 2018 governing conciliation through IEC. You are requested to give your unconditional consent to the said terms and conditions of the Scheme by returning the same duly sealed and signed on each page. On receipt of your consent, matter will be put to the Competent Authority for consideration and decision.
Please note that BHEL has also certain claims against you (if applicable). BHEL reserves its right to agree or not to agree conciliation of the said disputes through BHEL and this letter is being issued without prejudice to BHEL's rights and contentions available under the contract and law.
Yours faithfully
Representative of BHEI

To,

Format 3 to BHEL Conciliation Scheme, 2018 FORMAT FOR GIVING CONSENT BY CONTRACTOR/VENDOR/CUSTOMER/COLLABORATOR/CONSORTI UM PARTNERSFOR REFERRING THE DISPUTES TO CONCILIATION THROUGH IEC

BHEL	,						
	esolution of i	Disputes throu _! C).	gh Conciliatio	n by Indepe	endent Expert		
Ref: 0	Contract/MoU	/Agreement/LO	I/LOA No &	date			
		oove referred cor are still unpaid	•	,	nvoices/claims		
SL.	Claim	Bill	Amount of	Amount	Outstanding		
no.	Description	submitted	the	received	Amount		
		to BHEL	bill/claim	from			
		(no.		BHEL			
		and date)					
	rdingly we request to IEC for C	uest you to kind onciliation.	lly refer the Di	sputes in re	espect of above		
We hereby agree and give our unconditional consent to the terms and conditions of BHEL Conciliation Scheme, 2018 governing conciliation through IEC. We have signed the same on each page and enclosed it for your consideration.							

Page 10 of 11

Date

Yours faithfully,

(Signature with stamp)

Name, with designation

Authorized Representative of Contractor

Format 5 to BHEL Conciliation Scheme, 2018 STATEMENT OF CLAIMS/COUNTER CLAIMS TO BE SUBMITTED TO THE IEC BY BOTH THE PARTIES

I. CIII OIIOIOEV OI LIIC DISDUICS	1.	Chronology	of th	ne Dispute	s
-----------------------------------	----	------------	-------	------------	---

- 2. Brief of the Contract/MoU/Agreement/LOI/LOA
- 3. Brief history of the Disputes:
- 4. Issues:
- 5. Details of Clam(s)/Counter Claim(s):

SI. No.	Description of claim(s)/Counter Claim	Amount (in INR)Or currency applicable in the contract	Relevant contract clause

6. Basis/Ground of claim(s)/counter claim(s) (along with relevant clause of contract)

Note— The Statement of Claims/Counter Claims may ideally be restricted to maximum limit of 20 pages. Relevant documents may be compiled and submitted along with the statement of Claims/Counter Claims. The statement of Claims/Counter Claims is to be submitted to all IEC members and to the other party by post as well as by email.

ANNEXURE-E

DETAILS OF PACKAGES

S. N.	Discriptions	ESTIMATED QUANTITY
1	NO OF PACKAGES/CASES	
<u>2</u>	SIZE (MAXIMUM & MINIMUM)	
<u>3</u>	WEIGHT	
4	NOS OF COC CONTAINERS (TYPES & QTY), IF ANY	

Note:

- 1. The above is required only to facilate the store at site.
- 2. Bidder to submit standard storage instrcution along with offer.

To	be	signed	on	Non-	-Judicial	stamp	pa	per	of	Rs	100.

MEMORANDUM OF UNDERSTANDING

Pre Bid Tie-up with GIS Manufacturer for

Supply and Erection Supervision for 400 kV GIS equipment for POWERGRID's tender for Pre-bid tie up for 400kV GIS Package (Package-II) at KPS 3 (HVDC), South Olpad (HVDC) and Extn. of existing KPS3 (GIS) station including civil works associated with ±500kV, 2500 MW KPS-3 (HVDC) and South Olpad (HVDC) Scheme associated with Transmission System for Evacuation of Power from potential renewable energy zone in Khavda area of Gujarat under Phase-V (8GW): Part C through Tariff based Competitive (TBCB) route prior to RfP bid submission by POWERGRID to BPC.

BETWEEN

BHARAT HEAVY ELECTRICALS LIMITED

AND

<< Name of GIS Sub Contractor >>

Date: _____

Memorandum of Understanding

For Project/Tender Details: BHEL TENDER DETAILS TO BE FILLED BY TBMM

This Memorandum of Understanding (hereinafter referred to as "MOU") is made on theday of Two thousand and Twenty Four.
BETWEEN:
M/s Bharat Heavy Electricals Limited, Transmission Business Group-Noida, a company incorporated under th laws of Companies Act 1956 and having its Registered Office at BHEL HOUSE, SIRI FORT, NEW DELHI 110049 (INDIA), (hereinafter called "BHEL (1st Party)", which expression shall unless repugnant to the context of meaning thereof, include its successors and permitted assigns),
AND
M/s
("BHEL" and "" are individually referred to as the "Party" and collectively as the "Parties")

WHEREAS

- 1. M/s. **Power Grid Corporation of India Ltd (M/s POWERGRID).** (here in after referred to as "POWERGRID") has issued the following tender document to BHEL (here in after referred to as the "Tender"):
 - a. POWERGRID Tender Name: Pre-bid tie up for 400kV GIS Package (Package-II) at KPS 3 (HVDC), South Olpad (HVDC) and Extn. of existing KPS3 (GIS) station including civil works associated with ±500kV, 2500 MW KPS-3 (HVDC) and South Olpad (HVDC) Scheme associated with Transmission System for Evacuation of Power from potential renewable energy zone in Khavda area of Gujarat under Phase-V (8GW): Part C through Tariff based Competitive (TBCB) route prior to RfP bid submission by POWERGRID to BPC.
 - b. POWERGRID Tender Specification Reference: CC/T/W-GIS/DOM/A06/24/14461
- 2. BHEL intends to participate in above "Tender" as an EPC bidder and wish to enter into a pre-bid Tie-up with qualified GIS OEM (2nd Party) for scope as defined in its NIT as detailed below:
 - a. BHEL NIT Name: TO BE FILLED BY TBMM
 - b. BHEL NIT Specification Reference: TO BE FILLED BY TBMM

3.	M/s who are the established and reputed manufacturer of Gas Insulated Switchgear (GIS) up to
1.	Based on the offers received by BHEL and subsequent Techno-commercial evaluation, M/s
5.	Accordingly, M/s(GIS OEM, 2 nd Party) authorize M/s. Bharat Heavy Electricals Limited to offer its GIS equipment against the tender invited by M/s POWERGRID for
	"Pre-bid tie up for 400kV GIS Package (Package-II) at KPS 3 (HVDC), South Olpad (HVDC) and Extn. of existing KPS3 (GIS) station including civil works associated with ±500kV, 2500 MW KPS-3 (HVDC) and South Olpad (HVDC) Scheme associated with Transmission System for Evacuation of Power from potential renewable energy zone in Khavda area of Gujarat under Phase-V (8GW): Part C through Tariff based Competitive (TBCB) route prior to RfP bid submission by POWERGRID to BPC"
5.	This Memorandum of Understanding is accordingly being executed between the parties prior to submission of bid by BHEL as EPC contractor to M/s POWERGRID.
7.	The Parties have decided to enter into this MoU which sets forth their respective rights and obligations with respect to the Project and each other and mutually agreed upon the following.
3.	SCOPE OF WORK
	i. The broad Scope of Work to be performed by M/s (GIS OEM, 2 nd Party) shall include 400 kV GIS equipment related scope including Design, Engineering, procurement, manufacturing, supply, supervision of Erection/Installation, Testing, Commissioning/ Commissioning assistance as applicable and any other associated activities/scopes as outlined in the technical specification. However, in case of any further scope of Supply & services required for overall completion of the above package shall be as per the details finalized on the basis of resulting contracts with M/s POWERGRID.
i	 i. All other work except which have specifically been agreed upon by Ms will be executed by M/s BHEL as EPC contractor including a. Overall Engineering & Project management. b. Planning, monitoring, scheduling and reporting. c. Procurement and Supply of balance Equipment including in-house manufactured items. d. Participation in Progress review meeting. e. Erection, Testing & Commissioning including Civil Works. However, Ms(GIS manufacturer) would support BHEL and will provide requisite assistance, inputs for the above as and when required by BHEL without any reservation.
ii	i. Each Party shall be responsible for and shall co-operate with each other in obtaining and maintaining respective permits, licenses and other authorizations required for the performance of its Scope of Work, except those which are required to be obtained by M/s POWERGRID.
i	v. It will be the sole responsibility of M/sto submit the requisite details in the prescribed format duly signed and authorized as per requirement of tender document so as to meet the qualifying requirement as an acceptable GIS manufacturer.
).	Responsibilities of BHEL i. BHEL shall submit its competitive bid as EPC contractor against the tender issued by M/s POWERGRID in association with the M/s(400 kV GIS OEM as sub-contractor) based on its finalized bid

for the scope of work to be executed by the GIS OEM (2nd Party).

ii. In case BHEL is awarded NOA by POWERGRID for the Project, BHEL shall place a Purchase Order on the GIS OEM (2nd Party) forBHEL TENDER DETAILS TO BE ENTERED BY TBMM) for 400 kV GIS related scope as outlined in this MOU.

10. Responsibilities of M/s(GIS OEM, 2nd Party)

- i. M/s undertakes to support and associate with BHEL as Sub-contractor in its bid preparation for the scope of work related to 400 kV GIS equipment.
- ii. In the event, BHEL is not awarded the NOA by POWERGRID), M/s..... shall not have any claim whatsoever on M/s BHEL and the MOU shall stand terminated.
- iii. The GIS OEM (2nd Party) undertakes that breach of any of the above responsibilities / obligations on his / its part shall amount to his/its disqualification.
- iv. In the event, Purchase Order is placed by BHEL on the GIS OEM (2nd Party), the GIS OEM (2nd Party) undertakes to maintain the highest standard of professional and ethical competence, integrity and also maintain strict confidentiality of all the reports, discussions, data, information such as maps, diagrams, plans, statistics, plans, designs, reports, drawings and supporting records or material documents or software furnished by BHEL and further the GIS OEM (2nd Party) shall neither use the same for purposes unrelated to this tender nor disclose or share with any third party without the consent of BHEL.

11. Exchange of Information & Completeness

Each Party shall exchange with the other Party in a timely manner all necessary information required by the other Party, so as to give full and timely effect to the provisions of the MOU.

12. Amendments

This MOU shall be amended only with the mutual agreement of both the Parties which shall be in writing and signed by the duly authorized representatives of both the Parties.

13. Terms of MOU

The MOU shall remain in force till issue of Purchase Order by BHEL (in the event of BHEL emerging successful in its EPC bid submitted to POWERGRID and POWERGRID winning the TBCB bid as Transmission Service Provider) on the M/S ----- (GIS OEM, 2nd Party). These activities are anticipated to take about nine (09) months from the date of signing of MOU.

All terms and conditions of BHEL's NIT as agreed, minutes of meetings between BHEL, and _____shall also form part of the resulting contracts between BHEL and _____subsequent to finalization of tender by M/s POWERGRID.

Both parties hereby confirm their consent to an approval of the above terms and conditions evidenced by its signatures on its Memorandum.

This MOU shall be valid from the date of its execution by both the Parties, and continue to be in force for the Term (stated herein above) until terminated under the circumstances specified herein. This MOU shall terminate upon the occurrence of any of the following, whichever is earliest:

- a) By mutual Agreement;
- b) In the event the BHEL is awarded the LOI by the POWERGRID and this MOU is substituted with a Purchase Order placed by BHEL on M/S ---- (GIS OEM, 2nd Party);
- c) In the event BHEL is not awarded the NOA by POWERGRID, under such circumstances, BHEL shall terminate this MOU by issuing a written notice to M/S---- (GIS OEM, 2nd Party) and such termination shall be effective from the date of such notice;
- d) On expiry of validity of the bid submitted by M/S ----- (GIS OEM, 2nd Party) in response to the NIT (Details to be put by TBMM).
- e) In the event the GIS OEM (2nd Party) commits any breach in performance of any of the responsibilities specified in Clause-10 of this MOU
- 14. The failure of any Party to enforce at any time any of the provisions of this MOU shall in no way be construed to be a waiver of such provision, nor in any way affect the validity of this MOU or any part hereof.

a. M/s. Bharat Heavy Electricals Limited, Transmission Business Group,

19. In witness whereof BHEL and M/s.

these present on the DAY, month and year first mentioned above.

CONTACT DETAILS OF TBMM OFFCIAL

15. This MOU is being entered into on the understanding that each Party shall carry its own risks and costs and therefore, neither Party shall have any claims on the other Party for any reason whatsoever under this MOU.

(If there is an apprehension that any dispute may arise in future the following clause may be added) However, in case any dispute arising out the subject MOU, the same shall be resolved/adjudicated by appointing sole arbitrator referring the dispute to Delhi International Arbitration Centre, High Court of Delhi, in terms of Arbitration and Conciliation Act 1996 and amendments made therein time to time. The fee and proceeding of arbitration shall be as per DIAC.

Further, the court at New Delhi shall have the exclusive jurisdiction to adjudicate any dispute arising out this MOU.

16. Any correspondence/notice to be given hereunder by any Party to the other Party shall be sent by Registered Letter / Speed Post / Facsimile / Courier at the address mentioned below:

		5th Floor, BHEL Sadan, Plot No. 25
		Sector-16A, Noida-201301, U.P
		E-mail id:@bhel.in Mob. No:
	b.	M/S (GIS OEM)
		Name:
		Address :
		E-mail id:
		Mob. No:
17.		expenses towards formulation and implementation of this MOU and other activities related to the MOU and ng execution of this MOU shall be borne by the respective Parties as applicable.
18.		ny terms / clauses of this MOU are determined by a court of competent jurisdiction to be invalid or inforceable, such determination shall not affect the validity or enforceability of any other part or clause of this U.

For				
Bharat Heavy Electricals Limited				
Signature:				
Name:				
Designation:				
Address:				
M/s. Bharat Heavy Electricals Limited,				
Transmission Business Group,				
5th Floor, BHEL Sadan, Plot No-25, Sector-16A, Noida-				
201301, U.P				
Witness-1				
Witness-2				

through their authorized representatives have executed

Annexure-A (BDS)

TECHNICAL QUALIFYING CRITERIA FOR 400kV GIS

Qualifying Requirements for 400kV GIS Package (Package-II) at KPS 3 (HVDC), South Olpad (HVDC) and Extn. of existing KPS3 (GIS) station including civil works associated with ±500kV, 2500 MW KPS-3 (HVDC) and South Olpad (HVDC) Scheme associated with Transmission System for Evacuation of Power from potential renewable energy zone in Khavda area of Gujarat under Phase-V (8GW): Part C through Tariff based Competitive (TBCB) route; Spec No: CC/T/W-GIS/DOM/A06/24/14461

Funding: Domestic

Mode of Procurement: DCB

QUALIFICATION OF THE BIDDER

Qualification of Bidder will be based on meeting the minimum pass/fail criteria specified below regarding the Bidder's Technical Experience and Financial Position as demonstrated by the Bidder's responses in the corresponding Bid Schedules. Technical experience and financial resources of any proposed subcontractor shall not be taken into account in determining the Bidder's compliance with the qualifying criteria. The bid can be submitted by an individual firm or a Joint Venture of two or more firms (specific requirements for Joint Ventures are given under Para 3.0 below).

POWERGRID/BHEL may assess the capacity and capability of the bidder, to successfully execute the scope of work covered under the package within stipulated completion period. This assessment shall interalia include (i) document verification; (ii) bidders work/manufacturing facilities visit; (iii) manufacturing capacity, details of works executed, works in hand, anticipated in future & the balance capacity available for present scope of works; (iv) details of plant and machinery, manufacturing and testing facilities, manpower and financial resources; (v) details of quality systems in place; (vi) past experience and performance; (vii) customer feedback; (viii) banker's feedback etc.

1.0 TECHNICAL QUALIFICATION CRITERIA

1) The GIS must be offered from Indian manufacturer, who meets the requirement mentioned at Route-1 or Route-2 or Route-3 mentioned below.

2) A legally enforceable undertaking (By GIS Manufacturer jointly with BHEL) (as per enclosed format in bidding document) to guarantee quality, timely supply, performance and warranty obligations as specified for the equipment(s) is submitted along with the bid stating that GIS Manufacturer shall furnish performance guarantee for an amount of two (2) % of the GIS Portion**. This performance guarantee shall be in addition to the Contract Performance security to be submitted by the Bidder.

3) Bidder must meet the any of the following qualification Route-1, 2 or 3.

Route-1:

1.1 The Bidder must have designed, manufactured, type tested (as per IEC or equivalent standard), supplied and supervised erection & commissioning of at least two (2) nos. Gas Insulated Switchgear (GIS) circuit breaker bays@ of 345kVor above voltage class in one (1) Substation or Switchyard during the last seven (7) years and these bays must be in satisfactory operation# for at least two (2) years as on the on the Originally scheduled last date of bid submission (soft copy) i.e. 04.11.2024

Route-2:

1.2 The Bidder, who has established manufacturing & testing facility in India for 345kV or above voltage level

gradini Samming

Page 1 of 3

Annexure-A (BDS)

TECHNICAL QUALIFYING CRITERIA FOR 400kV GIS

GIS but not meeting the requirement stipulated in para 1.1 above, shall also be considered provided that:

- a) The Bidder must have manufactured, at least one (1) no. 345kV or above voltage class GIS circuit breaker bays@ based on technological support of the collaborator(s), provided that the collaborator(s) meets the requirement stipulated in para 1.1 above. Further bidder must have either supplied or type tested above CB bay (as per IEC or equivalent standard) as on the originally scheduled last date of bid submission mentioned above, i.e., 04.11.2024
- b) Further, the bidder shall also submit the following along with the bid:
- i. A legally enforceable undertaking (jointly with the Collaborator(s) to guarantee quality, timely supply, performance and warranty obligations as specified for the equipment(s).
- ii. A confirmation letter from the Collaborator(s) stating that the Collaborator(s) shall furnish performance guarantee for an amount of 10 % of the ex-works cost of such equipment(s). This performance guarantee shall be in addition to Contract Performance Guarantee to be submitted by the bidder.
- iii. A valid collaboration agreement for technology transfer / license to design, manufacture, test and supply 345kV or above voltage level GIS equipment in India.

Route-3:

- 1.3 The Bidder, who has established manufacturing & testing facility in India for 345kV or above voltage level GIS as Subsidiary/JVC/Group company by its parent/principal but not meeting the requirement stipulated in para 1.1 above, shall also be considered provided that:
 - a) The Bidder must have manufactured, at least one (1) no. 345kV or above voltage class GIS circuit breaker bays@ based on technological support of the parent/principal, provided that the parent/principal meets the requirement stipulated in para 1.1 above. Further bidder must have either supplied or type tested above CB bay (as per IEC or equivalent standard) as on the originally scheduled last date of bid submission mentioned above, i.e., 04.11.2024.
 - b) Further, the bidder shall also submit the following along with the bid:
 - A legally enforceable undertaking (jointly with the parent/principal company) to guarantee quality, timely supply, performance and warranty obligations as specified for the equipment(s).
 - ii. A confirmation letter from the parent/principal company stating that the parent/principal company shall furnish performance guarantee for an amount of 10% of the ex-works cost of such equipment(s). This performance guarantee shall be in addition to Contract Performance Guarantee to be submitted by the bidder.
 - iii. A valid collaboration agreement for technology transfer / license to design, manufacture, test and supply 345kV or above voltage level GIS equipment in India.

Route-4

-deleted-

Note:-

Krolin Sommit

Sale

Page 2 of 3

Annexure-A (BDS)

TECHNICAL QUALIFYING CRITERIA FOR 400kV GIS

- 1. (#) Satisfactory operation means certificate issued by the Employer certifying the operation without any adverse remark.
- 2. (@) For the purpose of qualifying requirement, one no. of circuit breaker bay shall be considered as a bay used for controlling a line or a transformer or a reactor or a bus section or a bus coupler and comprising of at least one circuit breaker, one disconnector and three nos. of single phase CTs / Bushing CTs.
- 3. In case bidder is a holding company, the technical experience referred to in Route-1, 2, 3 & 4 above as the case may be shall be of that holding company only (i.e. excluding its subsidiary/group companies). In case bidder is a subsidiary of a holding company, the technical experience referred to in Route-1, 2, 3 & 4 above as the case may be shall be of that subsidiary company only (i.e. excluding its holding company).
- 4. In case bidder is qualifying through Route-1, type test reports of Collaborator/ Parent Company/ Subsidiary Company/ Group Company shall also be acceptable, for which a confirmation shall be furnished along with the bid as per format attached in the bidding documents.
- 5. ** Total price of items in supply, F&I and installation schedules mentioned under Activity titled "GIS portion" in BPS shall be considered for calculation of amount of CPG to be furnished by GIS manufacturer

4.0 The bidder shall furnish documentary evidence in support of the qualifying requirement stipulated as above.

Prepared by:

Checked by:

Approved by:

400kV GIS Package (Package-II) at KPS 3 (HVDC), South Olpad (HVDC) and Extn. of existing KPS3 (GIS) station including civil works associated with ±500kV, 2500 MW KPS-3 (HVDC) and South Olpad (HVDC) Scheme associated with Transmission System for Evacuation of Power from potential renewable energy zone in Khavda area of Gujarat under Phase-V (8GW): Part C through Tariff based Competitive (TBCB) route.

Spec. No. CC/T/W-GIS/DOM/A06/24/14461

(Qualifying Requirement Da	ta)
----------------------------	-----

To:

Bidders's Name & Address:		Contract Services
Name:		Power Grid Corporation of India Ltd. "Saudamini", Plot No. 2, Sector 29
Address:		Gurugram (Haryana) - 122001

Dear Sir,

In support of the Qualification Requirements (QR) for bidders, stipulated in Annexure-A (BDS) of the Section - III (BDS), Volume-I & Additional Information required as per ITB clause 9.3(c) of the Bidding Documents, we furnish herewith our QR data/details along with other information, as follows herewith our stipulations have been reproduced in italics for ready reference, however, in case of any discrepancy the QR as given in BDS shall prevail).

*	We have submitted bid as individual firm.
*	We have submitted bid as joint venture of following firms:

(* delete whichever is not applicable)

[For details regarding Qualification Requirements of a Joint Venture, please refer para 4.0 below.]

We are furnishing the following details/document in support of Qualifying requirement for the subject package.

- A Attached copies of original documents defining:
- a) The constitution or legal status;
- b) The principal place of business;

NIT	87018	Enquiry	No.	61Q2500406	Dated:	29-11-202	4

- The place of incorporation (for bidders who are corporations); or the place of registration and the nationality of the Owners (for applicants who are partnerships or individually-owned Annexure-G c) firms).
- Attached original & copies of the following documents: В
- Written power of attorney of the signatory of the Bid to commit the bidder. a)
- Joint Venture Agreement. b)

GENERAL INFORMATION

Bidder is required to provide general information as per the following format.

[Where the Bidder proposes to use named subcontractor(s) for critical components of the works or for work contents in excess of ten (10) percent of the bid price, the following information should also be supplied for the subcontractor(s)].

			In case of Joint Venture			
S No.	Particulars	Bidder/Lead Partner	For Other Partner(s)	For Other Partner(s)		
1	Name of the Firm					
2	Head Office/ Registered Office Address					
3	Telephone					
4	Fax					
5	Contact Person					
6	Place of Incorporation/ Registration					
7	Year of Incorporation/ Registration					
8	Nationality of					
	Owner (i)					
	Owner (ii)					
	Owner (iii)					

Annexure-G

TECHNICAL EXPERIENCE

1.1	Route-1:
	The Bidder must have designed, manufactured, type tested (as per IEC or equivalent standard), supplied and supervised erection & commissioning of at least two (2) nos. Gas Insulated Switchgear (GIS) circuit breaker bays@ of 345kVor above voltage class in one (1) Substation or Switchyard during the last seven (7) years and these bays must be in satisfactory operation# for at least two (2) years as on the on the Originally scheduled last date of bid submission (soft copy) i.e. 04.11.2024.
1.2	Route-2:
	The Bidder, who has established manufacturing & testing facility in India for 345kV or above voltage level GIS but not meeting the requirement stipulated in para 1.1 above, shall also be considered provided that:
	a)The Bidder must have manufactured, at least one (1) no. 345kV or above voltage class GIS circuit breaker bays@ based on technological support of the collaborator(s), provided that the collaborator(s) meets the requirement stipulated in para 1.1 above. Further bidder must have either supplied or type tested above CB bay (as per IEC or equivalent standard) as on the originally scheduled last date of bid submission mentioned above.
	b)Further, the bidder shall also submit the following along with the bid:
	i. A legally enforceable undertaking (jointly with the Collaborator(s) to guarantee quality, timely supply, performance and warranty obligations as specified for the equipment(s).
	ii. A confirmation letter from the Collaborator(s) stating that the Collaborator(s) shall furnish performance guarantee for an amount of 10 % of the ex-works cost of such equipment(s). This performance guarantee shall be in addition to Contract Performance Guarantee to be submitted by the bidder.
	iii. A valid collaboration agreement for technology transfer / license to design, manufacture, test and supply 345kV or above voltage level GIS equipment in India.

NIT_87018_Enquiry No. 61Q2500406 Dated: 29-11-2024 T.3 | Route-3: **Annexure-G** The Bidder, who has established manufacturing & testing facility in India for 345kV or above voltage level GIS as Subsidiary/JVC/Group company by its parent/principal but not meeting the requirement stipulated in para 1.1 above, shall also be considered provided that: a)The Bidder must have manufactured, at least one (1) no. 345kV or above voltage class GIS circuit breaker bays@ based on technological support of the parent/principal, provided that the parent/principal meets the requirement stipulated in para 1.1 above. Further bidder must have either supplied or type tested above CB bay (as per IEC or equivalent standard) as on the originally scheduled last date of bid submission mentioned above. b)Further, the bidder shall also submit the following along with the bid: i.A legally enforceable undertaking (jointly with the parent/principal company) to guarantee quality, timely supply, performance and warranty obligations as specified for the equipment(s). ii.A confirmation letter from the parent/principal company stating that the parent/principal company shall furnish performance guarantee for an amount of 10% of the ex-works cost of such equipment(s). This performance guarantee shall be in addition to Contract Performance Guarantee to be submitted by the bidder. iii.A valid collaboration agreement for technology transfer/license to design, manufacture, test and supply 345kV or above voltage level GIS equipment in India. 1.4 Route-4 In case, the bidder is not a GIS manufacturer, he shall also be considered provided: i. The bidder must have erected and commissioned at least two (02) nos. GIS circuit breaker bays of 345kV or above voltage class in one (01) new GIS substation or switchyard during last seven (07) years and these bays must be in satisfactory operation# for at least two (02) years as on the originally scheduled last date of bid submission mentioned above. ii. The GIS must be offered from Indian manufacturer, who meets the requirement mentioned at Route-1 or Route-2 or Route-3 above.

iii. A legally enforceable undertaking (jointly with the GIS Manufacturer) (as per enclosed format in Section VI, Volume-I of bidding document) to guarantee quality, timely supply, performance and warranty obligations as specified for the equipment(s) is submitted along with the bid stating that GIS Manufacturer shall furnish performance guarantee for an amount of two (2) % of the GIS Portion**. This performance guarantee shall be in addition to the Contract Performance security to be submitted by the Bidder.

VIT 87018 Eng	uiry No. 61Q2500406 Dated: 29-11-2024
	Note:- Annexure-G
	1.(#) Satisfactory operation means certificate issued by the Employer certifying the operation without any adverse remark.
	2.(@) For the purpose of qualifying requirement, one no. of circuit breaker bay shall be considered as a bay used for controlling a line or a transformer or a reactor or a bus section or a bus coupler and comprising of at least one circuit breaker, one disconnector and three nos. of single phase CTs / Bushing CTs.
	3.In case bidder is a holding company, the technical experience referred to in Route-1, 2, 3 & 4 above as the case may be shall be of that holding company only (i.e. excluding its subsidiary/group companies). In case bidder is a subsidiary of a holding company, the technical experience referred to in Route-1, 2, 3 & 4 above as the case may be shall be of that subsidiary company only (i.e. excluding its holding company).
	4.In case bidder is qualifying through Route-1, type test reports of Collaborator/ Parent Company/ Subsidiary Company/ Group Company shall also be acceptable, for which a confirmation shall be furnished along with the bid as per format attached in the bidding documents.
	5.** Total price of items in supply, F&I and installation schedules mentioned under Activity titled "GIS portion" in BPS shall be considered for calculation of amount of CPG to be furnished by GIS manufacturer

Using the following format, each Bidder (individual firms or partners of a joint venture) is requested to list the experience as detailed above, on the basis of which the Bidder wishes to qualify. The information is to be summarised using following format for each experience of the Bidder or of each Partner of a Joint Venture.

(The bidder shall attach documentary evidence, such as copies of utility certificates for completed contracts and copies of award letters etc. for ongoing contracts in support of his experience as listed in the following proforma for each Contract with the help of "Attach" Buttons provided in table given below).

NIT_{-}	_87018_	_Enquiry	No.	61Q2500406	Dated:	29-11-2024

Format-A:

Format-A:

Format for the Bidder/ Lead Partner/ Partners of JV in case of Joint Venture/Indian GIS Manufacturer in support of meeting the requirement of para 1.1, Annexure-A to BDS, Section-III, Volume-I of the Bidding Documents)

	Bidder's Name :	
	Single Firm/Lead Partner/Other Partners of a JV/Indian GIS Manufacturer	
1	Name of Contract Undertaken	
2	Contract Reference No. & Date of Award	
3	Name and Address of the Employer/Utility for whom the Contract was executed by the firm/Partner of a JV	
	E-mail ID	
	Telephone No.	
	Fax No.	

VIT 87018 Eng	uiry No. 61Q2500406 Dated: 29-11-2024				
- 4(a)(i)	Voltage Level of GIS Substation commissioned under the Contract			Δ.	nnexure-G
	(Indicate 345kV or above class only)				
	No. of GIS Circuit Breaker equipped bays under the above contract				
	(Indicate nos. of GIS Circuit Breaker equipped bays of 345kV or above voltage level where one no. of circuit				
	breaker bay shall be considered as a bay used for controlling a line or a transformer or a reactor or a bus section				
	or a bus coupler and comprising of at least one circuit breaker, one disconnector and three nos. of single phase				
	CTs/Bushing CTs)				
	Name of the substation or switchyard				
(a)(ii)	No. of years, the above Substation have been in operation as on the Originally scheduled last date of bid				
	submission (soft copy)				
	Scope of work involved under the Contract	□bi	п		П
		Design	Manufacture	Design	Manufacture
	(Tick whichever is/are applicable)				
	NOTE: type test reports of Collaborator/ Parent Company/ Subsidiary Company/ Group Company shall also	Type Testing	Supply	Type Testing	Supply
	be acceptable, for which a confirmation shall be furnished along with the bid as per format attached in the				
	bidding documents (Attachment-30 in Volume-III)				
		Supervision of E	rection & Commissioning	Supervision of E	rection & Commissioning
	Whether Undertaking (as per enclosed format in Section-VI, Sample Forms and Procedures of bidding				
	document) for above is enclosed with the bid				
	Details of documents uploaded in support of the above stated experience				

NIT 8	37018	Enguiry	No.	61Q2500406	Dated: 2	9-11-2024
-------	-------	---------	-----	------------	----------	-----------

Format-B: Annexure-G

Format in support of meeting the requirement of para 1.2 (Route-2) of Annexure-A to BDS, Section-III, Volume-I of the Bidding Documents)

	Name of the Indian Bidder not meeting the requirement stipultaed in Clause 1.1 of Annexure-A (BDS), but has	
	established manufacturing and testing facilities in India for 345kV or above Gas Insulated Switchgear (GIS):	
1	Whether 345kV or above voltage level GIS Circuit Breaker bay manufactured by bidder have been supplied or	
1	, , , , , , , , , , , , , , , , , , , ,	
	Type tested	
A	if Type tested, details of Type test Report	
В	Details of GIS supplied by them	
i	Name of Contract Undertaken for manufacturing 345kV or above voltage level GIS bays	
ii	Contract Reference No. & Date of Award	
iii	Name and Address of the Employer/Utility for whom 345kV or above voltage level GIS bays were supplied by	
	the Bidder	
	E-mail ID	
	Telephone No.	
	Fax No.	

NIT_87018_Er	nq _l iry No. 61Q2500406 Dated: 29-11-2024	-		
iv	No. of 345kV or above GIS Circuit Breaker bays under the contract			Annexure-G
	Name of the substation or switchyard			
	Whether 345kV or above voltage level GIS Circuit breaker bays, as mentioned above, has been manufactured based on technological support of the Collaborator under the Contract.			
	If Yes, indicate the Name of Collaborator(s)			
	No. of years, the above GIS Subatation(s) are in operation as on the Originally scheduled last date of bid submission (soft copy).			
	Scope of work involved under the Contract for the above 345kV or above GIS bay as per IEC as on the Originally scheduled last date of bid submission (soft copy).	Manufactured	Supply	☐Type Testing
	(Tick whichever is/are applicable)			
	Details of documents uploaded in support of the above stated experience			

	uiry No. 61Q2500406 Dated: 29-11-2024 Format-C: Format in support of meeting the requirement of para 1.2(Route-2) (as applicable) Annexure-A to BDS, Section	Annexure-G n-III, Volume-I of the Bidding Documents)
	Name of the Collaborator (refer para 1.2), if applicable :	
	Name of the 345kV or above GIS Equipment Manufacturer (refer para 1.2), if applicable :	
1	Name of Contract Undertaken	
2	Contract Reference No. &	
2	Date of Award	
3	Name and Address of the Employer/Utility for whom the Contract was executed by the firm/Partner of a JV	
	E-mail ID	
	Telephone No.	
	Fax No.	

NIT_87018_Enq 4(a)(i)	uiry No. 61Q2500406 Dated: 29-11-2024 No. of 345kV or above GIS Circuit Breaker bays under the above contract		Annexure-G
	(Indicate nos. of GIS Circuit Breaker bays of 345kV or above where one no. of circuit breaker bay shall be considered as a bay used for controlling a line or a transformer or a reactor or a bus section or a bus coupler and comprising of at least one circuit breaker, one disconnector and three nos. of single phase CTs/Bushing CTs)		
	Name of the substation or switchyard		
	No. of years, the above GIS CB bays are in operation as on the Originally scheduled last date of bid submission (soft copy).		
	Scope of work involved under the Contract as per IEC (Tick whichever is/are applicable)	Clesign Manufacture Type Testing Supply Supervision of Erection & Comm.	Design Manufacture Type Testing Supply Supervision of Erection & Comm.
	Whether Joint Deed of Undertaking executed between The Bidder and 345kV or above GIS Equipment		
	Manufaturer has been enclosed with bid? (in line with para 1.2 of Annexure-A (BDS)		
	Manufaturer has been enclosed with bid? (in line with para 1.2 of Annexure-A (BDS) Whether confirmation letter from the Collaborator(s) stating that the Collaborator(s) shall furnish performance guarantee for an amount of 10% of the ex-works cost of such equipment(s) has been enclosed with bid? (in line with para 1.2 of Annexure-A (BDS)		
	Whether confirmation letter from the Collaborator(s) stating that the Collaborator(s) shall furnish performance guarantee for an amount of 10% of the ex-works cost of such equipment(s) has been enclosed with bid?		

Annexure-G

Format in support of meeting the requirement of para 1.3 (Route-3) of Annexure-A to BDS, Section-III, Volume-I of the Bidding Documents)

	Name of the Indian established as Subsidiary/JVC/Group company by its parent/principal	<u>_</u>
		Subsidiary
		_
		Group Company
		Group Company
	Whether bidder have established manufacturing and testing facilities in India for 345kV or above voltage level	
	GIS	
1	Whether 345kV or above voltage level GIS Circuit Breaker bay manufactured by bidder have been supplied or	
	Type tested based on Technological support of their Parent/ Principal Company	
A	if Type tested, details of Type test Report	
В	Details of GIS supplied by them	
i	Name of Contract Undertaken for manufacturing 345kV or above voltage level GIS bays	
1	Tvalle of Contract Oridertaken for manufacturing 545k v of above voltage level GIS bays	
ii	Contract Reference No. & Date of Award	
iii	Name and Address of the Employer/Utility for whom 345kV or above voltage level GIS bays were supplied by	
	the Bidder	
	E-mail ID	
	Telephone No.	
	Fax No.	
iv	No. of 345kV or above GIS Circuit Breaker bays under the above contract	
	Name of the substation or switchyard	
	Whether 345kV or above voltage level GIS Circuit breaker bays, as mentioned above, has been manufactured	
	based on technological support of the Parent/ Principal Company under the Contract.	
	If Yes, indicate the Name of Parent/ Principal Company(s)	

NIT 87018 Enqui	iry No. 61Q2500406 Dated: 29-11-2024 No. of years, the above AIS/GIS Subatation(s) are in operation as on the Originally scheduled last date of bid		
No. of years, the above AIS/GIS Subatation(s) are in operation as on the Originally scheduled la submission (soft copy).			Annexure-G
Scope of work involved under the Contract for the above 345kV GIS bay as per IEC as on the Original			
S	scheduled last date of bid submission (soft copy).	Manufactured Supply	Type Testing
((Tick whichever is/are applicable)		
Ī	Details of documents uploaded in support of the above stated experience		
<u> </u>	Format-E:		
I	Format in support of meeting the requirement of para 1.3(Route-3) (as applicable) Annexure-A to BDS, Section	n-III, Volume-I of the Bidding Do	cuments)
_			
l N	Name of the Parent Company/ Principal (refer para 1.3), if applicable:	0	
1	value of the Parent Company Principal (refer para 1.5), if applicable.	U	
1	Name of the 345kV or above voltage level GIS Equipment Manufacturer (refer para 1.3), if applicable :		
	• • • • • • • • • • • • • • • • • • • •		
1 1	Name of Contract Undertaken		
2 (Contract Reference No. &		
	Date of Award		
3	Name and Address of the Employer/Utility for whom the Contract was executed by the firm/Partner of a JV		
	E-mail ID		
	Telephone No.		
	Fax No.		
	Tux No.		

NIT_87018_Enq 4(a)(i)	uiry No. 61Q2500406 Dated: 29-11-2024 No. of 345kV or above GIS Circuit Breaker bays under the above contract			Anı	nexure-G
	(Indicate nos. of GIS Circuit Breaker bays of 345kV or above where one no. of circuit breaker bay shall be considered as a bay used for controlling a line or a transformer or a reactor or a bus section or a bus coupler and comprising of at least one circuit breaker, one disconnector and three nos. of single phase CTs / Bushing CTs)				
	Name of the substation or switchyard				
(a)(ii)	No. of years, the above GIS CB bays are in operation as on the Originally scheduled last date of bid submission (soft copy).				
	Scope of work involved under the Contract as per IEC (Tick whichever is/are applicable)	Design Type Testing Supervision of Erec	Manufacture Supply ttion & Comm.	Design Type Testing Supervision	Manufacture Supply of Erection & Comm.
	Whether Joint Deed of Undertaking executed between The Bidder and 345kV GIS Equipment Manufaturer has been enclosed with bid? (in line with para 1.3 of Annexure-A (BDS)				
	Whether confirmation letter from the parent/principal company stating that the parent/principal company shall furnish performance guarantee for an amount of 10% of the ex-works cost of such equipment(s) has been enclosed with bid? (in line with para 1.3 of Annexure-A (BDS)				
	Whether valid collaboration agreement for technology transfer / license to design, manufacture, test and supply 345kV GIS equipment in India has been enclosed with bid ? (in line with para 1.3 of Annexure-A (BDS)				
	Details of documents uploaded in support of the above stated experience				

Format-F:
Format in support of meeting the requirement of para 1.4(Route-4) (as applicable) Annexure-A to BDS, Section-III, Volume-I of the Bidding Documents)

	Bidder's Name :	
1	Name of Contract Undertaken	
2	Contract Reference No. & Date of Award	
3	Name and Address of the Employer/Utility for whom the Contract was executed by the firm	
	E-mail ID	
	Telephone No.	
	Fax No.	

(Indicate 345kV or above class only) No. of GIS Circuit Breaker equipped bays under the above contract (Indicate nos. of GIS Circuit Breaker equipped bays of 345kV or above voltage level where one no. of circuit		Annexure-
(Indicate nos. of GIS Circuit Breaker equipped have of 345kV or above voltage level where one no. of circuit		
breaker bay shall be considered as a bay used for controlling a line or a transformer or a reactor or a bus section or a bus coupler and comprising of at least one circuit breaker, one disconnector and three nos. of single phase CTs/Bushing CTs)		
Name of the substation or switchyard i) No. of years, the above Substation have been in operation as on the Originally scheduled last date of bid submission (soft copy).		
Scope of work involved under the Contract		
	Erection Gommissioning	Erection Commission
(Tick whichever is/are applicable)		
Whether Undertaking (Jointly with the GIS Manufacturer) (as per enclosed format in Section-VI, Sample Forms and Procedures of bidding document) for above is enclosed with the bid		
Details of documents uploaded in support of the above stated experience		

Attachment-29

400kV GIS Package (Package-II) at KPS 3 (HVDC), South Olpad (HVDC) and Extn. of existing KPS3 (GIS) station including civil works associated with ±500kV, 2500 MW KPS-3 (HVDC) and South Olpad (HVDC) Scheme associated with Transmission System for Evacuation of Power from potential renewable energy zone in Khavda area of Gujarat under Phase-V (8GW): Part C through Tariff based Competitive (TBCB) route; Spec No: CC/T/W-GIS/DOM/A06/24/14461.

CONFIRMATION IN REGARD TO DESIGN & TYPE TEST

(To be furnished in case bidder is proposing to qualify through Note-4 under Route -1 of QR)

This is to certify that kV GIS CB bay(s), manufactured and supplied by the Bidder from their Indian works, is having same design as that of GIS CB bay manufactured and duly Type tested (as per relevant IEC) by the Collaborator/ Parent Company/ Subsidiary Company/ Group Company. Further, the design Know-how has been transferred by the Collaborator/ Parent Company/ Subsidiary Company/ Group Company to the Bidder and based on the same, the Bidder has supplied the said GIS bay(s) from its Indian works.

Further, it is confirmed that the type test reports of the GIS Equipment offered under the subject package shall be submitted to POWERGRID during detailed Engineering as per the requirements of Technical specification, in the event of award of contract.

AUTHORISED SIGNATORY FOR...... (Name of the bidder)

	(THE BIDDER)
Power of Attorney Holder	Key Managerial Person
Signature	Signature
Name	Name
Office Address	Office Address
AUTHORISED SIGNATORY FOR Company/ Subsidiary Company/ Group (COLLABORATOR)	•
Key Managerial Person	
Signature	
Name	
Office Address	

21. FORM OF JOINT DEED OF UNDERTAKING BY THE COLLABORATOR/ PARENT/ PRINCIPAL COMPANY OF SUBSIDIARY COMPANY/ JV COMPANY/ GROUP COMPANY ALONGWITH THE BIDDER/MANUFACTURER {applicable to Bidder Qualifying through Route-2 & Route-3 of the Qualification Requirement}

(ON NON-JUDICIAL STAMP PAPER OF APPROPRIATE VALUE)

THIS DEED OF UNDERTAKING executed this day of Tw Thousand and by M/s, a Company incorporated under the law
of
incorporated under the laws of
laws of
Companies Act of 1956 having its registered office at
WHEREAS the "Employer" invited Bid as per its Specification No for th execution of(insert name of the package alongwith project name)
AND WHEREAS Clause No, Section, of, Vol forming part of the Bid Documents inter-alia stipulates that the Bidder / Manufacturer alongwith it Collaborator/ Parent/Principal Company must fulfill the Qualifying Requirements for the * and be jointly and severally bound and responsible for the successful performance of the * offered in the event the Bid submitted by the Bidder is accepted by the Employer resulting in a Contract.
of the Bid Documents inter-alia stipulates that the Bidder / Manufacturer alongwith it Collaborator/ Parent/Principal Company must fulfill the Qualifying Requirements for th * and be jointly and severally bound and responsible for the successful performance of the * offered in the event the Bid submitted by the Bidder is

NOW THEREFORE THIS UNDERTAKING WITNESSETH as under:

- In consideration of the award of Contract by the Employer to the Bidder (hereinafter referred to as the "Contract") we, the Collaborator/ Parent/Principal Company and the Bidder/Contractor/manufacturer do hereby declare that we shall be jointly and severally bound unto the (insert name of the Employer), for the successful performance of the *...... and shall be fully responsible for the design, manufacture, testing, supply on FOR destination delivery at site basis and supervision of unloading at site, storage, erection, testing & commissioning and successful performance of the *...... in accordance with the Contract Specifications.
- 2.0 Without in any way affecting the generality and total responsibility in terms of this Deed of Undertaking, the Collaborator/ Parent/Principal Company in particular hereby agrees to depute their technical experts from time to time to the Bidder's/ Contractor's/ Manufacturer's Works/ Employer's Project site as mutually considered necessary by the Employer, Bidder/ Contractor/ Manufacturer and the Collaborator/ Parent/Principal Company to ensure:

- (ii) Proper design, engineering, manufacture, testing, supply transportation and delivery at site and supervision of unloading at site, storage, erection, testing & commissioning and successful performance of the equipment in accordance with Contract Specifications and
- (iii) If necessary, the Collaborator/ Parent/Principal Company shall advise the Manufacturer/ Contractor suitable modifications of designs and implement necessary corrective measures to discharge the obligations under the contract.

3.0 We further confirm that

The Parent/ Principal Company shall have a minimum equity participation of 51% in the Indian Subsidiary Company for a lock-in period of seven (7) years from the date of incorporation of Indian Subsidiary Company or upto the end of defect liability period of the contract whichever is later.

(OR)

The Parent/ Principal Company and the Group Company shall have a common source of control, directly or indirectly, so as to exercise a minimum equity participation of 26% or appoint more than 50% of members of Board of Directors in the Group Company. The promoter of the Group Company shall maintain the minimum equity participation in the Group Company for a lock-in period of seven (7) years from the date of incorporation of Group Company or upto the end of defect liability period of the contract whichever is later.

(OR)

The Parent/ Principal Company shall have a minimum equity participation of 26% in the Joint Venture Company for a lock-in period of seven (7) years from the date of incorporation of Joint Venture Company or upto the end of Defect Liability Period of the contract, whichever is later.

The Indian GIS Manufacturer shall have a minimum equity participation of 51% in the Joint Venture Company for a lock-in period of seven (7) years from the date of incorporation of Joint Venture Company or upto the end of Defect Liability Period of the contract, whichever is later.

(applicable in case bidder is a Subsidiary Company/ Group Company/ JV Company (JVC) who intends to meet the Financial Position requirement specified in the Qualification requirement based on its Parent/ Principal Company)

- 4.0 This Deed of Undertaking shall be construed and interpreted in accordance with the laws of India and the Courts in Delhi shall have exclusive jurisdiction in all matters arising under the Undertaking.
- 5.0 We, the Collaborator/ Parent/Principal Company and Bidder/ Contractor/ Manufacturer agree that this Undertaking shall be irrevocable and shall form an integral part of the Contract and further agree that this Undertaking shall continue to be enforceable till the Employer discharges it. It shall become operative from the effective date of Contract.

IN WITNESS WHEREOF the Collaborator/ Parent/Principal Company, and the Bidder/Contractor/Manufacturer have through their Authorized Representatives executed these presents and affixed Common seals of their respective Companies, on the day, month and year first above mentioned.

WITNESS	(For Collaborator/ Parent/Principal Company)					
Signature	1 7/					
Name	(Signature of the authorized representative)					
Office Address	Name					
	Common Seal of Company					
WITNESS	(For Bidder)					
Signature Name	(Signature of the authorized representative)					
Office Address	Name					
	Common Seal of Company					

Annexure-I

WITNESS	(For Manufa	(For Manufacturer)				
Signature	(Signature	of	the	authorized		
Name		representative)				
Office Address	Name		•••••			
	Common	Seal	of	Company		

Note:

- 1. For the purpose of executing the Deed of Joint Undertaking, the non-judicial stamp papers of appropriate value shall be purchased in the name of executant(s).
- 2. The Undertaking shall be signed on all the pages by the authorised representatives of each of the partners and should invariably be witnessed.
- 3. This Deed of Joint Undertaking duly certified by the Company Secretary shall be submitted alongwith the bid. Further, the Deed of Joint Undertaking attested by Notary Public of the place(s) of the respective executant(s) or registered with the Indian Embassy/High Commission in that country shall be submitted by the bidder within ten (10) days from the date of intimation of post-bid discussion.
- 4. In the event the Bidder is a Manufacturer and the Collaboration is between Collaborator and the Bidder, then the Joint deed of undertaking shall be modified accordingly.
- 5. *The name(s) of equipment for which Joint deed of undertaking is to be submitted is to be inserted viz.,345kV GIS etc.
- 6. The manufacturer may be having ongoing collaboration agreement or had collaboration agreement in the past with the collaborator.

(Annexure-1 to Indemnification Agreement)

22. FORM OF DEED OF JOINT UNDERTAKING TO BE EXECUTED BY THE BIDDER/CONTRACTOR ALONGWITH INDIAN GIS MANUFACTURER WHO HAS BEEN ASSOCIATED FOR SOURCING OF GIS EQUIPMENT { STIPULATED IN CLAUSE NO. 1.4(iii), ROUTE-4 OF ANNEXURE-A (BDS) }

(ON NON-JUDICIAL STAMP PAPER OF APPROPRIATE VALUE)

its Registered Office at	hereinafter called the "Bidder/Contractor"
which expression shall include its successors, adm	inistrators, executors and permitted assigns
and M/s, registered	d under the Indian Companies Act of 1956 or
2013, as the case may be, and having its Regis	
hereinafter called the "GIS Manufacturer" which	-
administrators, executors and permitted assigns, in	
, a Company incorporated under the	1
registered office at(insert registered add	
called the "Employer" which expression shall incl	ude its successors, executors and permitted
assigns)	
MILEDE AC (1 "E1" :: 1- 1 D: 1: 1- C	and a straight of the second of
WHEREAS the "Employer" invited Bid as per its Sp	
of (insert name of the package alongwith project nam	τ)
AND WHEREAS Clause No, Section	of Vol forming part
of the Bidding Documents inter-alia stipulates that	O I
provided the Bidder meets the requirement and	
sourcing of GIS equipment, who meets the stipula	
submits a Deed of Joint Undertaking jointly execu	ated by the Bidder/Contractor and its GIS
Manufacturer in which the Bidder and its GIS Man	ufacturer are jointly and severally bound and
responsible for the successful performance of the	GIS Portion of the Contract specified in the
Bidding Documents in the event the Bid submitted	by the Bidder is accepted by the Employer
resulting in a Contract.	

AND WHEREAS the Bidder has submitted its Bid to the Employer based on above stipulation and has agreed to furnish this Deed of Undertaking to be enforceable in the event of the award of the Contract by the Employer.

AND WHEREAS the Bidder and **GIS Manufacturer** are executing an irrevocable Deed of Joint Undertaking that they shall be held jointly and severally liable and bound unto the Employer for successful performance of the GIS portion of the Contract fully meeting the stipulated technical requirements, guaranteed parameters and characteristics as per bidding documents, in the event the Bid submitted by the Bidder is accepted by the Employer resulting in a Contract.

NOW THEREFORE, THIS UNDERTAKING WITHNESSETH AS UNDER:

In consideration of the award of Contract by the Employer to the Bidder / Contractor (hereinafter referred to as the "Contract") we, the Bidder/Contractor and the GIS Manufacturer do hereby agree and undertake that we shall be jointly and severally responsible to the Employer for design, erection, testing and commissioning of complete GIS portion of the Contract and perform all obligations including the technical guarantee for the complete package..

- 2.0 In case of any breach of the Contract committed by the Contractor, we, the GIS Manufacturer do hereby undertake, declare and confirm that we shall be fully responsible for design, manufacturing, erection, testing and commissioning of complete GIS portion under the Contract and undertake to carry out all obligation and responsibilities under this Deed of Joint Undertaking in order to discharge the Contractor's obligations and responsibilities stipulated in the Contract with respect to GIS portion of the Contract. Further, if the Employer sustains any loss or damage on account of any breach with respect to GIS portion of the Contract, we, the GIS Manufacturer and the Contractor jointly and severally undertake to promptly indemnify, and pay such losses/damages caused to the Employer on its written demand without any demur, reservation, contest or protest in any manner whatsoever.
- 3.0 Without in any way affecting the generality and total responsibility in terms of this Deed of Undertaking, the Bidder/Contractor hereby agrees to ensure the following:
 - (i) The **GIS Manufacturer** will be fully responsible for design, engineering, manufacture, erection, testing, commissioning and putting into satisfactory operation of complete GIS portion to the satisfaction of the Employer.

Further, the **GIS Manufacturer** shall depute their technical experts from time to time to the Contractor's works/Employer's project site as required by Employer and agreed to by the Contractor/—Associate **GIS Manufacturer** to facilitate the successful performance of switchyard with respect to GIS portion as stipulated in the Contract.

Further, the **GIS Manufacturer** shall ensure proper design, engineering, manufacture, erection, testing, commissioning and successful performance of GIS portion covered under the said Contract in accordance with the stipulations of the Contract specifications and if necessary the **GIS Manufacturer** shall advise the Contractor suitably modifications of design and implement necessary corrective measure to discharge the obligations under the Contract.

- (ii) In the event the **GIS Manufacturer** and the Contractor fail to demonstrate successful performance of GIS Portion, the **GIS Manufacturer** and the Contractor shall promptly carry out all the corrective measures at their own expenses and shall promptly provide corrected designs to the Employer.
- (iii) The Contractor and GIS Manufacturer will be fully responsible for the quality of all equipment/main assemblies/components manufactured at their works or at their vendor's works or fabricated/constructed at site, and their repairs or replacement if necessary for incorporation on the switchyard with respect to GIS portion of the Contract and timely delivery thereof the meet the completion schedule under the Contract.
- (iv) In case of any issue related to failure and repair of GIS equipment, the Bidder / Contractor and the **GIS Manufacturer** shall ensure the following:
 - a. The **GIS Manufacturer**'s Service Engineer(s) shall be deputed to concerned site within 24 Hours plus actual journey time to attend the problem after receiving the information of the same from Employer.
 - b. The **GIS Manufacturer** shall ensure readily availability in their Indian works at least one no. of each type of GIS Module used in the installation under the Contract.

- 4.0 This Deed of Undertaking shall be construed and interpreted in accordance with the laws of India and the Courts in Delhi shall have exclusive jurisdiction in all matters arising under the Undertaking.
- As a security, the **GIS Manufacturer** shall apart from the Contractor's performance guarantee, furnish a Contract Performance Guarantee from its Bank in favour of the Employer in a form acceptable to the Employer. The value of such guarantee shall be equivalent to **02%** (**Two Percent**) of the **price of GIS portion** (i.e. **Total price of items in Supply, F&I and Installation schedules under Activity titled "GIS portion" in Price Schedules**) awarded by the Employer to the Bidder/Contractor and it shall be part of guarantee towards the faithful performance/compliance of this Deed of Undertaking in terms of the Contract. The guarantee shall be unconditional, irrevocable and valid for the entire period of the Contract, namely till the end of the Defect Liability Period under the Contract. The Bank Guarantee/ Insurance Surety Bond amount shall be payable to the Employer on demand without any reservation or demur. This shall be in addition to the Contract Performance Guarantee to be furnished by the Contractor.

We further agree that this undertaking shall be without any prejudice to the various liabilities of the Bidder / Contractor, including the Contract Performance Security as well as other obligations of the Bidder / Contractor in terms of the Contract.

6.0 We, the **GIS Manufacturer** and Bidder/Contractor agree that this Undertaking shall be irrevocable and shall form an integral part of the Contract and further agree that this Undertaking shall continue to be enforceable till the Employer discharges it. It shall become operative from the effective date of Contract.

IN WITNESS WHEREOF the Contractor and the **GIS Manufacturer** have through their Authorized Representatives executed these presents and affixed Common seals of their respective Companies on the day, month and year first above mentioned.

WITNESS	[For Bidder/Contractor]	
Signature	(Signature of the representative)	authorized
Name	Name	
Office Address	Common Seal of	Company
WITNESS	[For GIS Manufacturer]	
Signature	(Signature of the representative)	authorized
Name	Name	
Office Address	Common Seal of	Company

Note:

- 1. For the purpose of executing the Deed of Undertaking, the non-judicial stamp papers of appropriate value shall be purchased in the name of executant.
- 2. The Undertaking shall be signed on all the pages by the authorized representative(s) of the Bidder and the **GIS Manufacturer** and should invariably be witnessed.

23.a FORM OF BANK GUARANTEE FOR CONTRACT PERFORMANCE (TO BE SUBMITTED BY COLLABORATOR / PARENT/ PRINCIPAL COMPANY)

(For the purpose of verification/confirmation of this Bank Guarantee by the Employer, the Bank shall indicate 2 official email ids of the authorized signatories from Issuing Branch and also of the designated higher office (Corporate Office, Zonal Office etc) in the covering letter of the Bank forwarding the Bank Guarantee.)

Bank Guarantee No	Date
NOA/Contract No	
[Name of Contract]	
To: [Name and address of the Employer]	
Dear Ladies and/or Gentlemen,	
We refer to the Contract ("the Contract")	
vide notification of award issued on (insert date of the note to M/s(Name of Contractor)	otification of award)by you
(or)	
signed onbetween you Contract) between you Contractor)	u and M/s (Name o
having its Principal place of business at(Address of ConRegistered Office at(Registered address of Contractor)	("the
Whereas, the Contractor has agreed to supply the	encipal place of business and of Office at

A	n	n	_	v		•	Δ.	
_		•	c	•	u	•	Ξ.	•

We undertake to make payment under this Letter of Guarantee upon receipt by us of your first written demand signed by your duly authorized officer declaring the Contractor/Manufacturer/Collaborator/Parent/Principal Company to be in default under the Contract and without cavil or argument any sum or sums within the above named limits, without your need to prove or show grounds or reasons for your demand and without the right of the Contractor/Manufacturer/Collaborator/Parent/Principal Company to dispute or question such demand.

Our liability under this Letter of Guarantee shall be to pay to you whichever is the lesser of the sum so requested or the amount then guaranteed hereunder in respect of any demand duly made hereunder prior to expiry of the Letter of Guarantee, without being entitled to inquire whether or not this payment is lawfully demanded.

Except for the documents herein specified, no other documents or other action shall be required, notwithstanding any applicable law or regulation.

Our liability under this Letter of Guarantee shall become null and void immediately upon its expiry, whether it is returned or not, and no claim may be made hereunder after such expiry or after the aggregate of the sums paid by us to you shall equal the sums guaranteed hereunder, whichever is the earlier.

All notices to be given under shall be given by registered (airmail) posts to the addressee at the address herein set out or as otherwise advised by and between the parties hereto.

We hereby agree that any part of the Contract may be amended, renewed, extended, modified, compromised, released or discharged by mutual agreement between you and the Collaborator/Parent/Principal Company, and this security may be exchanged or surrendered without in any way impairing or affecting our liabilities hereunder without notices to us and without the necessity for any additional endorsement, consent or guarantee by us, provided, however, that the sum guaranteed shall not be increased or decreased.

No action, event or condition which by any applicable law should operate to discharge us from liability hereunder shall have any effect and we hereby waive any right we may have to apply such law so that in all respects our liability hereunder shall be irrevocable and, except as stated herein, unconditional in all respects.

Notwithstanding anything contained herein:

Note:

1. For the purpose of executing the Bank Guarantee, the non-judicial stamp papers of appropriate value shall be purchased in the name of Bank who issues the 'Bank Guarantee'.

Name____

Address

email _____

Contact Number(s): Tel._____Mobile____

- 2. The Bank Guarantee shall be signed on all the pages by the Bank Authorities indicating their POA nos. and should invariably be witnessed.
- 3. @ Insert name of the Equipment
- 4. # Applicable when the Contractor is not manufacturing the equipment himself.
- 5. The Bank Guarantee should be in accordance with the proforma as provided. However, in case the issuing bank insists for additional paragraph regarding applicability of ICC publication No: 758, the following may be added at the end of the proforma of the Bank

Guarantee [i.e., end paragraph of the Bank Guarantee preceding the signature(s) of the issuing authority(ies) of the Bank Guarantee]:

"This Guarantee is subject to Uniform Rules for Demand Guarantee, ICC publication No. 758 except that article 15(a) is hereby excluded."

6. At the time of issuance of the Bank Guarantee (including its extensions) through SFMS facility, the issuing bank will input the IFSC code of Beneficiary Bank as mentioned at GCC clause 9.4 in SCC in their Trade Finance Portal.

Additional paragraph regarding issuance of the Bank Guarantee through SFMS Platform (if applicable), the following should be added at the end of the proforma of the Bank Guarantee [i.e., end paragraph of the Bank Guarantee preceding the signature(s) of the issuing authority(ies) of the Bank Guarantee]:

"This Guarantee has been issued using SFMS Platform and the requisite communication in this regard has been forwarded to the Beneficiary Bank."

23.b FORM OF INSURANCE SURETY BOND FOR CONTRACT PERFORMANCE (TO BE SUBMITTED BY COLLABORATOR / PARENT / PRINCIPAL COMPANY)

(To be stamped in accordance with Stamp Act of India)

	Insurance Surety Bond No.:
NOA/Contract No	Date:
[Name of Contract]	
To: [Name and address of the Employer]	
, , ,	
Dear Ladies and/or Gentlemen,	
We refer to the Contract ("the Contract")	
vide notification of award issued on (inset to M/s(Name of Contractor),	
(or)	
signed on(insert date of the Contract) Contractor),	between you and M/s (Name of
having its Principal place of business at	Contractor) ("the te brief scope of work) for the
Whereas, the Contractor has agreed to supply the	having its Principal place of business at
By this letter we, the undersigned,(insert not (or Company) organized under the laws of	and having its Registered/Head of the Insurer) do hereby irrevocably i.e., 10% (Ten Percent) of the Ex-works afacturer/Contractor under the Contract until

We undertake to make payment under this **Insurance Surety Bond** upon receipt by us of your first written demand signed by your duly authorized officer declaring the Contractor/Manufacturer/Collaborator/ Parent/Principal Company to be in default under the Contract and without cavil or argument any sum or sums within the above named limits, without your need to prove or show grounds or reasons for your demand and without the right of the Contractor/Manufacturer/Collaborator/ Parent/Principal Company to dispute or question such demand.

Our liability under this **Insurance Surety Bond** shall be to pay to you whichever is the lesser of the sum so requested or the amount then guaranteed hereunder in respect of any demand duly made hereunder prior to expiry of the Letter of Guarantee, without being entitled to inquire whether or not this payment is lawfully demanded.

Except for the documents herein specified, no other documents or other action shall be required, notwithstanding any applicable law or regulation.

Our liability under this **Insurance Surety Bond** shall become null and void immediately upon its expiry, whether it is returned or not, and no claim may be made hereunder after such expiry or after the aggregate of the sums paid by us to you shall equal the sums guaranteed hereunder, whichever is the earlier.

All notices to be given under shall be given by registered (airmail) posts to the addressee at the address herein set out or as otherwise advised by and between the parties hereto.

We hereby agree that any part of the Contract may be amended, renewed, extended, modified, compromised, released or discharged by mutual agreement between you and the Collaborator/Parent/Principal Company, and this security may be exchanged or surrendered without in any way impairing or affecting our liabilities hereunder without notices to us and without the necessity for any additional endorsement, consent or guarantee by us, provided, however, that the sum guaranteed shall not be increased or decreased.

No action, event or condition which by any applicable law should operate to discharge us from liability hereunder shall have any effect and we hereby waive any right we may have to apply such law so that in all respects our liability hereunder shall be irrevocable and, except as stated herein, unconditional in all respects.

Notwithstanding anything contained herein:

1.	Our liability under this Insurance Surety Bond shall not exceed (value in
	figures)[(value in words)].
2.	This Insurance Surety Bond shall be valid upto(validity date)
3.	We are liable to pay the guaranteed amount or any part thereof under this Insurance Surety
	Bond only & only if we receive a written claim or demand on or before (validity
	date)"

[Signature of the a	uthorised signatory(ies)]
Signature	
Name	
Designation	
POA Number	
Contact Number(s): Tel	Mobile
Fax Number email Common Seal of the Bank	
Signature	Witness:
Name	
Address	
Contact Number(s): Tel	Mobile
email	

Note:

- 1. The Insurance Surety Bond should be on Non-Judicial stamp paper/e-stamp paper of appropriate value as per Stamp Act prevailing in the state(s) where the Insurance Surety Bond is submitted or is to be acted upon or the rate prevailing in State where the Insurance Surety Bond is executed, whichever is higher. The Stamp Paper/e-stamp paper shall be purchased in the name of Bidder/Insurer issuing the Insurance Surety Bond.
- 2. The Insurance Surety Bond shall be signed on all the pages by the Insurer Authorities and should invariably be witnessed.
- 3. @ Insert name of the Equipment
- 4. # Applicable when the Contractor is not manufacturing the equipment himself.
- 5. The Insurance Surety Bond shall be from an Insurer as per guidelines issued by Insurance Regulatory and Development Authority of India (IRDAI) as amended from time to time.
- 6. The Employer shall be the Creditor, the Bidder shall be the Principal debtor and the Insurance company/Insurer shall be the Surety in respect of the Insurance Surety Bond to be issued by the Insurer.
- 7. While getting the Insurance Surety Bond issued, Contractors/ Suppliers are required to ensure compliance to the points mentioned in Form of Insurance Surety Bond.

24.a FORM OF BANK GUARANTEE FOR CONTRACT PERFORMANCE (TO BE SUBMITTED BY INDIAN GIS MANUFACTURER) (REQUIRED TO BE SUBMITTED IN LINE WITH ROUTE-4, OF ANNEXURE-A (BDS))

(For the purpose of verification/confirmation of this Bank Guarantee by the Employer, the Bank shall indicate 2 official email ids of the authorized signatories from Issuing Branch and also of the designated higher office (Corporate Office, Zonal Office etc) in the covering letter of the Bank forwarding the Bank Guarantee.)

Bank Guarantee No	Date
Contract No	
[Name of Contract]	
To: [Name and address of the Employer]	
Dear Ladies and/or Gentlemen,	
We refer to the Contract ("the Contract") signed on between you and M/s	, having its Principal place of and Registered Office at ("the cope of work) for the
Whereas, the Contractor and M/s	Manufacturer)
By this letter we, the undersigned,(insert name & ad (which expression shall include its successors, administra under the laws of	itors, executors and assigns) organized istered/Head Office at(insert irrevocably guarantee payment to you e price of GIS portion (i.e. Total price Activity titled "GIS portion" in Price

We undertake to make payment under this Letter of Guarantee upon receipt by us of your first written demand signed by your duly authorized officer declaring the Contractor/ GIS Manufacturer to be in default under the Contract and without cavil or argument any sum or sums within the above named limits, without your need to prove or show grounds or reasons for your

demand and without the right of the Contractor/ GIS Manufacturer to dispute or question such demand.

Our liability under this Letter of Guarantee shall be to pay to you whichever is the lesser of the sum so requested or the amount then guaranteed hereunder in respect of any demand duly made hereunder prior to expiry of the Letter of Guarantee, without being entitled to inquire whether or not this payment is lawfully demanded.

Except for the documents herein specified, no other documents or other action shall be required, notwithstanding any applicable law or regulation.

Our liability under this Letter of Guarantee shall become null and void immediately upon its expiry, whether it is returned or not, and no claim may be made hereunder after such expiry or after the aggregate of the sums paid by us to you shall equal the sums guaranteed hereunder, whichever is the earlier.

All notices to be given under shall be given by registered (airmail) posts to the addressee at the address herein set out or as otherwise advised by and between the parties hereto.

We hereby agree that any part of the Contract may be amended, renewed, extended, modified, compromised, released or discharged by mutual agreement between you and the Contractor/GIS Manufacturer, and this security may be exchanged or surrendered without in any way impairing or affecting our liabilities hereunder without notices to us and without the necessity for any additional endorsement, consent or guarantee by us, provided, however, that the sum guaranteed shall not be increased or decreased.

No action, event or condition which by any applicable law should operate to discharge us from liability hereunder shall have any effect and we hereby waive any right we may have to apply such law so that in all respects our liability hereunder shall be irrevocable and, except as stated herein, unconditional in all respects.

"Notwithstanding anything contained herein:

1. Our liability under this Bank Guarantee shall not exceed _______ (value in figures)_____ [______ (value in words)______].

2. This Bank Guarantee shall be valid upto ______ (validity date)______.

3. We are liable to pay the guaranteed amount or any part thereof under this Bank Guarantee only & only if we receive a written claim or demand on or before ______ (validity date)_____."

For and on behalf of the Bank

[Signature of the authorised signatory(ies)]

Signature	

Name	
Designation_	
POA Number_	
Contact Number(s): Tel	_Mobile
Fax Number_	
email	
Common Seal of the Bank_	
	Witness:
Signature_	
Name_	
Address	
Contact Number(s): Tel	_Mobile
email	

Note:

- 1. For the purpose of executing the Bank Guarantee, the non-judicial stamp papers of appropriate value shall be purchased in the name of Bank who issues the 'Bank Guarantee'.
- 2. The Bank Guarantee shall be signed on all the pages by the Bank Authorities indicating their POA nos. and should invariably be witnessed.
- 3. The Bank Guarantee should be in accordance with the proforma as provided. However, in case the issuing bank insists for additional paragraph for limitation of liability, the following may be added at the end of the proforma of the Bank Guarantee [i.e., end paragraph of the Bank Guarantee preceding the signature(s) of the issuing authority(ies) of the Bank Guarantee]:
- 4. The Bank Guarantee should be in accordance with the proforma as provided. However, in case the issuing bank insists for additional paragraph regarding applicability of ICC publication No: 758, the following may be added at the end of the proforma of the Bank Guarantee [i.e., end paragraph of the Bank Guarantee preceding the signature(s) of the issuing authority(ies) of the Bank Guarantee]:

[&]quot;This Guarantee is subject to Uniform Rules for Demand Guarantee, ICC publication No. 758 except that article 15(a) is hereby excluded."

24.b FORM OF INSURANCE SURETY BOND FOR CONTRACT PERFORMANCE (TO BE SUBMITTED BY INDIAN GIS MANUFACTURER) (REQUIRED TO BE SUBMITTED IN LINE WITH ROUTE-4, OF ANNEXURE-A (BDS))

(To be stamped in accordance with Stamp Act of India)

Insurance Su	arety Bond No.:
	Date:
Contract No	
[Name of Contract]	
To: [Name and address of the Employer]	
Dear Ladies and/or Gentlemen,	
We refer to the Contract ("the Contract") signed on	, having its Principal place of and Registered Office at ("the work) for the
Whereas, the Contractor and M/s	requisite for qualification of the g declaring that they are jointly supply of GIS and that the GIS nce Guarantee for the faithful nt to 02% (Two Percent) of the nd Installation schedules under contract, in addition to Contract he value of the Contract to be
By this letter we, the undersigned,(insert name & address (or Company) organized under the laws of	and having its Registered/Head r) do hereby irrevocably % (Two Percent) of the price of lation schedules under Activity ntil ninety (90) days beyond the
We undertake to make navment under this Insurance Surety B	and upon receipt by us of your

We undertake to make payment under this **Insurance Surety Bond** upon receipt by us of your first written demand signed by your duly authorized officer declaring the Contractor/ GIS Manufacturer to be in default under the Contract and without cavil or argument any sum or sums within the above named limits, without your need to prove or show grounds or reasons for your demand and without the right of the Contractor/ GIS Manufacturer to dispute or question such demand.

Our liability under this **Insurance Surety Bond** shall be to pay to you whichever is the lesser of the sum so requested or the amount then guaranteed hereunder in respect of any demand duly

made hereunder prior to expiry of the Letter of Guarantee, without being entitled to inquire whether or not this payment is lawfully demanded.

Except for the documents herein specified, no other documents or other action shall be required, notwithstanding any applicable law or regulation.

Our liability under this **Insurance Surety Bond** shall become null and void immediately upon its expiry, whether it is returned or not, and no claim may be made hereunder after such expiry or after the aggregate of the sums paid by us to you shall equal the sums guaranteed hereunder, whichever is the earlier.

All notices to be given under shall be given by registered (airmail) posts to the addressee at the address herein set out or as otherwise advised by and between the parties hereto.

We hereby agree that any part of the Contract may be amended, renewed, extended, modified, compromised, released or discharged by mutual agreement between you and the Contractor/GIS Manufacturer, and this security may be exchanged or surrendered without in any way impairing or affecting our liabilities hereunder without notices to us and without the necessity for any additional endorsement, consent or guarantee by us, provided, however, that the sum guaranteed shall not be increased or decreased.

No action, event or condition which by any applicable law should operate to discharge us from liability hereunder shall have any effect and we hereby waive any right we may have to apply such law so that in all respects our liability hereunder shall be irrevocable and, except as stated herein, unconditional in all respects.

"Notwithstanding anything contained herein:

1.	Our liability under this Insurance Surety Bond shall not exceed (value in figures) [(value in words)].
2.	This Insurance Surety Bond shall be valid upto(validity date)
3.	We are liable to pay the guaranteed amount or any part thereof under this Insurance Surety Bond only & only if we receive a written claim or demand on or before (validity date)"
	For and on behalf of the Insurer
	[Signature of the authorised signatory(ies)]
	Signature
	Name
	Designation

		Annexure-J
POA Number_		
Contact Number(s): Tel	_Mobile_	
Fax Number_		
email		
Common Seal of the Bank_		
		Witness:
Signature_		
Name_		
Address		
Contact Number(s): Tel	_Mobile_	

email ____

Note:

- 1. The Insurance Surety Bond should be on Non-Judicial stamp paper/e-stamp paper of appropriate value as per Stamp Act prevailing in the state(s) where the Insurance Surety Bond is submitted or is to be acted upon or the rate prevailing in State where the Insurance Surety Bond is executed, whichever is higher. The Stamp Paper/e-stamp paper shall be purchased in the name of Bidder/Insurer issuing the Insurance Surety Bond.
- 2. The Insurance Surety Bond shall be signed on all the pages by the Insurer Authorities and should invariably be witnessed.
- 3. The Insurance Surety Bond shall be from an Insurer as per guidelines issued by Insurance Regulatory and Development Authority of India (IRDAI) as amended from time to time.
- 4. The Employer shall be the Creditor, the Bidder shall be the Principal debtor and the Insurance company/Insurer shall be the Surety in respect of the Insurance Surety Bond to be issued by the Insurer.
- 5. While getting the Insurance Surety Bond issued, Contractors/ Suppliers are required to ensure compliance to the points mentioned in Form of Insurance Surety Bond.

29(c). FORM OF BANK GUARANTEE FOR CONTRACT PERFORMANCE (TO BE SUBMITTED BY COLLABORATOR / PARENT / PRINCIPAL COMPANY)

(Applicable in case award is placed by POWERGRID on behalf of SPV)

(For the purpose of verification/confirmation of this Bank Guarantee by the Employer, the Bank shall indicate 2 official email ids of the authorized signatories from Issuing Branch and also of the designated higher office (Corporate Office, Zonal Office etc)in the covering letter of the Bank forwarding the Bank Guarantee.)

Bank Guarantee No	Date
NOA/Contract No	
[Name of Contract]	
To: [Name and address of the Employer]	
Dear Ladies and/or Gentlemen,	
We refer to the Contract ("the Contract")	
vide notification of award issued on (insert date of Power Grid Corporation of India Ltd., having its Register Area, Katwaria Sarai, New Delhi - 110 016 ("the Emplo	red Office at B-9, Qutab Institutional byer"/"POWERGRID") on behalf of
(or)	
signed on(insert date of the Contract) betw India Ltd., having its Registered Office at B-9, Qutab Inst Delhi – 110 016 ("the Employer"/"POWERGRID") on beh (hereinafter referred to as 'Owner'), and M	titutional Area, Katwaria Sarai, New alf of(Name of the SPV)
having its Principal place of business at(Address Registered Office at(Registered address of Contractor Contractor") concerning(Indicate brief so complete execution of the (insert name of Package along)	r) ("the cope of work) for the
Whereas, the Contractor has agreed to supply the	its Principal place of business at egistered Office at(Registered (hereinafter referred to as the (Name of Collaborator/Parent/Principal ss at(Address of Collaborator/d Office at(Registered address

Δ	n	n	_	v		ro	- I
м	т	п	ш	ж	u	re	-

Company having agreed to furnish a Contract Performance Guarantee for the faithful performance/compliance of the Deed of Undertaking equivalent to 10% (Ten Percent) of the Exworks cost of@................. to be supplied by the Manufacturer/Contractor under the Contract, in addition to Contract Performance Guarantee equivalent to 10% (Ten Percent) of the value of the Contract to be provided by the Contractor for the faithful performance of the entire Contract.

We undertake to make payment under this Letter of Guarantee upon receipt by us of your first written demand signed by the Employer's duly authorized officer or the authorized officer of Owner declaring the Contractor/Manufacturer/Collaborator/Parent/Principal Company to be in default under the Contract and without cavil or argument any sum or sums within the above named limits, without your need to prove or show grounds or reasons for your demand and without the right of the Contractor/Manufacturer/Collaborator/Parent/Principal Company to dispute or question such demand.

Our liability under this Letter of Guarantee shall be to pay to **the Owner / Employer** whichever is the lesser of the sum so requested or the amount then guaranteed hereunder in respect of any demand duly made hereunder prior to expiry of the Letter of Guarantee, without being entitled to inquire whether or not this payment is lawfully demanded.

Except for the documents herein specified, no other documents or other action shall be required, notwithstanding any applicable law or regulation.

Our liability under this Letter of Guarantee shall become null and void immediately upon its expiry, whether it is returned or not, and no claim may be made hereunder after such expiry or after the aggregate of the sums paid by us to **the Owner / Employer** shall equal the sums guaranteed hereunder, whichever is the earlier.

All notices to be given under shall be given by registered (airmail) posts to the addressee at the address herein set out or as otherwise advised by and between the parties hereto.

We hereby agree that any part of the Contract may be amended, renewed, extended, modified, compromised, released or discharged by mutual agreement between **the Owner/Employer** and the Collaborator/ Parent/Principal Company, and this security may be exchanged or surrendered without in any way impairing or affecting our liabilities hereunder without notices to us and without the necessity for any additional endorsement, consent or guarantee by us, provided, however, that the sum guaranteed shall not be increased or decreased.

No action, event or condition which by any applicable law should operate to discharge us from liability hereunder shall have any effect and we hereby waive any right we may have to apply such law so that in all respects our liability hereunder shall be irrevocable and, except as stated herein, unconditional in all respects.

N	Jotwitl	nstanding	anything	contained	herein:

1.	Our liability under this Bank Guarantee shall not exceed (value in figures) [(value in words)].
2.	This Bank Guarantee shall be valid upto(validity date)
3.	We are liable to pay the guaranteed amount or any part thereof under this Bank Guarantee only & only if we receive a written claim or demand on or before (validity date)"
	For and on behalf of the Bank
	[Signature of the authorised signatory(ies)]
	Signature
	Name
	Designation
	POA Number
	Contact Number(s): TelMobile
	Fax Number
	email
	Common Seal of the Bank
	Witness:
	Signature
	Name
	Address
	Contact Number(s): TelMobile
	email

Note:

- 1. For the purpose of executing the Bank Guarantee, the non-judicial stamp papers of appropriate value shall be purchased in the name of Bank who issues the 'Bank Guarantee'.
- 2. The Bank Guarantee shall be signed on all the pages by the Bank Authorities indicating their POA nos. and should invariably be witnessed.
- 3. @ Insert name of the Equipment
- 4. # Applicable when the Contractor is not manufacturing the equipment himself.
- 5. The Bank Guarantee should be in accordance with the proforma as provided. However, in case the issuing bank insists for additional paragraph regarding applicability of ICC

publication No: 758, the following may be added at the end of the proforma of the Bank Guarantee [i.e., end paragraph of the Bank Guarantee preceding the signature(s) of the issuing authority(ies) of the Bank Guarantee]:

"This Guarantee is subject to Uniform Rules for Demand Guarantee, ICC publication No. 758 except that article 15(a) is hereby excluded."

6. At the time of issuance of the Bank Guarantee (including its extensions) through SFMS facility, the issuing bank will input the IFSC code of Beneficiary Bank as mentioned at GCC clause 9.4 in SCC in their Trade Finance Portal.

Additional paragraph regarding issuance of the Bank Guarantee through SFMS Platform (if applicable), the following should be added at the end of the proforma of the Bank Guarantee [i.e., end paragraph of the Bank Guarantee preceding the signature(s) of the issuing authority(ies) of the Bank Guarantee]:

"This Guarantee has been issued using SFMS Platform and the requisite communication in this regard has been forwarded to the Beneficiary Bank."

29(d). FORM OF BANK GUARANTEE FOR CONTRACT PERFORMANCE (TO BE SUBMITTED BY INDIAN GIS MANUFACTURER) (REQUIRED TO BE SUBMITTED IN LINE WITH ROUTE-4, OF ANNEXURE-A (BDS))

(Applicable in case award is placed by POWERGRID on behalf of SPV)

(For the purpose of verification/confirmation of this Bank Guarantee by the Employer, the Bank shall indicate 2 official email ids of the authorized signatories from Issuing Branch and also of the designated higher office (Corporate Office, Zonal Office etc) in the covering letter of the Bank forwarding the Bank Guarantee.)

Bank Guarantee No	Date
Contract No	
[Name of Contract]	
To: [Name and address of the Employer]	
Dear Ladies and/or Gentlemen,	
We refer to the Contract ("the Contract")	
vide notification of award issued on (insert da Power Grid Corporation of India Ltd., having its Reg Area, Katwaria Sarai, New Delhi - 110 016 ("the E (Name of the SPV) (hereinafter (Name of Contractor)	gistered Office at B-9, Qutab Institutional mployer"/"POWERGRID") on behalf of
(or)	
signed on(insert date of the Contract)	o Institutional Area, Katwaria Sarai, New a behalf of(<i>Name of the SPV</i>)
having its Principal place of business at(Ad Registered Office at(Registered	ered address of Contractor) ("the Contractor") concerning
Whereas, the Contractor and M/s	GIS Manufacturer)

Performance Guarantee equivalent to **10**% **(Ten Percent)** of the value of the Contract to be provided by the Contractor for the faithful performance of the entire Contract.

We undertake to make payment under this Letter of Guarantee upon receipt by us of your first written demand signed by **the Employer's duly authorized officer or the authorized officer of Owner** declaring the Contractor/ GIS Manufacturer to be in default under the Contract and without cavil or argument any sum or sums within the above named limits, without your need to prove or show grounds or reasons for your demand and without the right of the Contractor/ GIS Manufacturer to dispute or question such demand.

Our liability under this Letter of Guarantee shall be to pay to **the Owner/Employer** whichever is the lesser of the sum so requested or the amount then guaranteed hereunder in respect of any demand duly made hereunder prior to expiry of the Letter of Guarantee, without being entitled to inquire whether or not this payment is lawfully demanded.

Except for the documents herein specified, no other documents or other action shall be required, notwithstanding any applicable law or regulation.

Our liability under this Letter of Guarantee shall become null and void immediately upon its expiry, whether it is returned or not, and no claim may be made hereunder after such expiry or after the aggregate of the sums paid by us to **the Owner / Employer** shall equal the sums guaranteed hereunder, whichever is the earlier.

All notices to be given under shall be given by registered (airmail) posts to the addressee at the address herein set out or as otherwise advised by and between the parties hereto.

We hereby agree that any part of the Contract may be amended, renewed, extended, modified, compromised, released or discharged by mutual agreement between **the Owner/Employer** and the Contractor/ GIS Manufacturer, and this security may be exchanged or surrendered without in any way impairing or affecting our liabilities hereunder without notices to us and without the necessity for any additional endorsement, consent or guarantee by us, provided, however, that the sum guaranteed shall not be increased or decreased.

No action, event or condition which by any applicable law should operate to discharge us from liability hereunder shall have any effect and we hereby waive any right we may have to apply

2.

"Notwithstanding anything contained herein:

Annexure-J

such law so that in all respects our liability hereunder shall be irrevocable and, except as stated herein, unconditional in all respects.

1. Our liability under this Bank Guarantee shall not exceed _____ (value in

	figures)[(value in words)].
2.	. This Bank Guarantee shall be valid upto	(validity date)
3.		r any part thereof under this Bank Guarantee only demand on or before (validity date,
		For and on behalf of the Bank
		[Signature of the authorised signatory(ies)]
		Signature
		Name
		Designation
		POA Number
	Contact Number	(s): TelMobile
		Fax Number
		email
	Com	mon Seal of the Bank
		Witness
		Signature
		Name
		Address
	Contact Number	(s): TelMobile
		email
	Guarantee, the non-judicial stamp papers of the name of Bank who issues the 'Bank	

The Bank Guarantee shall be signed on all the pages by the Bank Authorities indicating

their POA nos. and should invariably be witnessed.

- 3. The Bank Guarantee should be in accordance with the proforma as provided. However, in case the issuing bank insists for additional paragraph for limitation of liability, the following may be added at the end of the proforma of the Bank Guarantee [i.e., end paragraph of the Bank Guarantee preceding the signature(s) of the issuing authority(ies) of the Bank Guarantee]:
- 4. The Bank Guarantee should be in accordance with the proforma as provided. However, in case the issuing bank insists for additional paragraph regarding applicability of ICC publication No: 758, the following may be added at the end of the proforma of the Bank Guarantee [i.e., end paragraph of the Bank Guarantee preceding the signature(s) of the issuing authority(ies) of the Bank Guarantee]:

"This Guarantee is subject to Uniform Rules for Demand Guarantee, ICC publication No. 758 except that article 15(a) is hereby excluded."

30(c). FORM OF INSURANCE SURETY BOND FOR CONTRACT PERFORMANCE (TO BE SUBMITTED BY COLLABORATOR / PARENT/ PRINCIPAL COMPANY)

(Applicable in case award is placed by POWERGRID on behalf of SPV)

(To be stamped in accordance with Stamp Act of India)

	Insurance Surety Bond No.: Date:
NOA/Contract No	
[Name of Contract]	
To: [Name and address of the Employer]	
Dear Ladies and/or Gentlemen,	
We refer to the Contract ("the Contract")	
Power Grid Corporation of India Ltd., having Area, Katwaria Sarai, New Delhi - 110 016	nsert date of the notification of award)by M/s. its Registered Office at B-9, Qutab Institutional ("the Employer"/"POWERGRID") on behalf of einafter referred to as 'Owner') to M/s
(or)	
India Ltd., having its Registered Office at B-9 Delhi – 110 016 ("the Employer"/"POWERGR) between M/s. Power Grid Corporation of P, Qutab Institutional Area, Katwaria Sarai, New ID") on behalf of (Name of the SPV) er'), and M/s (Name of Contractor)
Registered Office at(Registered address	(Address of Contractor)
	the

accordance with the Contract Specifications and that the Collaborator/ Parent/Principal Company having agreed to furnish a Contract Performance Guarantee for the faithful performance/compliance of the Deed of Undertaking equivalent to 10% (Ten Percent) of the Exworks cost of@................. to be supplied by the Manufacturer/Contractor under the Contract, in addition to Contract Performance Guarantee equivalent to 10% (Ten Percent) of the value of the Contract to be provided by the Contractor for the faithful performance of the entire Contract.

We undertake to make payment under this **Insurance Surety Bond** upon receipt by us of your first written demand signed by **the Employer's duly authorized officer or the authorized officer of Owner** declaring the Contractor/Manufacturer/Collaborator/ Parent/Principal Company to be in default under the Contract and without cavil or argument any sum or sums within the above named limits, without your need to prove or show grounds or reasons for your demand and without the right of the Contractor/Manufacturer/Collaborator/ Parent/Principal Company to dispute or question such demand.

Our liability under this **Insurance Surety Bond** shall be to pay to **the Owner / Employer** whichever is the lesser of the sum so requested or the amount then guaranteed hereunder in respect of any demand duly made hereunder prior to expiry of the Letter of Guarantee, without being entitled to inquire whether or not this payment is lawfully demanded.

Except for the documents herein specified, no other documents or other action shall be required, notwithstanding any applicable law or regulation.

Our liability under this **Insurance Surety Bond** shall become null and void immediately upon its expiry, whether it is returned or not, and no claim may be made hereunder after such expiry or after the aggregate of the sums paid by us to **the Owner / Employer** shall equal the sums guaranteed hereunder, whichever is the earlier.

All notices to be given under shall be given by registered (airmail) posts to the addressee at the address herein set out or as otherwise advised by and between the parties hereto.

We hereby agree that any part of the Contract may be amended, renewed, extended, modified, compromised, released or discharged by mutual agreement between **the Owner/Employer** and the Collaborator/ Parent/Principal Company, and this security may be exchanged or surrendered without in any way impairing or affecting our liabilities hereunder without notices

Annexure-J

to us and without the necessity for any additional endorsement, consent or guarantee by us, provided, however, that the sum guaranteed shall not be increased or decreased.

No action, event or condition which by any applicable law should operate to discharge us from liability hereunder shall have any effect and we hereby waive any right we may have to apply such law so that in all respects our liability hereunder shall be irrevocable and, except as stated herein, unconditional in all respects.

Notwithstanding anything contained herein:

1.		this Insurance Surety Bond shall not exceed (va	ilue in
	figures)	_ [
2.	This Insurance Su	ety Bond shall be valid upto(validity date)	
3.		the guaranteed amount or any part thereof under this Insurance 5 f we receive a written claim or demand on or before (v	
		For and on behalf of the In	nsurer
		[Signature of the authorised signator	ry(ies)]
		Signature	
		Name	
		Designation	
		POA Number	
		Contact Number(s): TelMobile Fax Number	
		email	
		Common Seal of the Bank	
			itness:
		Signature	
		Name	
		Address	
		Contact Number(s): TelMobile	
		email	
No	to:	CIIIIII	

- The Insurance Surety Bond should be on Non-Judicial stamp paper/e-stamp paper of 1. appropriate value as per Stamp Act prevailing in the state(s) where the Insurance Surety Bond is submitted or is to be acted upon or the rate prevailing in State where the Insurance Surety Bond is executed, whichever is higher. The Stamp Paper/e-stamp paper shall be purchased in the name of Bidder/Insurer issuing the Insurance Surety Bond.
- 2. The Insurance Surety Bond shall be signed on all the pages by the Insurer Authorities and should invariably be witnessed.
- @ Insert name of the Equipment 3.

- 4. # Applicable when the Contractor is not manufacturing the equipment himself.
- 3. The Insurance Surety Bond shall be from an Insurer as per guidelines issued by Insurance Regulatory and Development Authority of India (IRDAI) as amended from time to time.
- 4. The Employer shall be the Creditor, the Bidder shall be the Principal debtor and the Insurance company/Insurer shall be the Surety in respect of the Insurance Surety Bond to be issued by the Insurer.
- 5. While getting the Insurance Surety Bond issued, Contractors/ Suppliers are required to ensure compliance to the points mentioned in Form of Insurance Surety Bond.

Annexure-J

30(d). FORM OF INSURANCE SURETY BOND FOR CONTRACT PERFORMANCE (TO BE SUBMITTED BY INDIAN GIS MANUFACTURER) (REQUIRED TO BE SUBMITTED IN LINE WITH ROUTE-4, OF ANNEXURE-A (BDS))

(Applicable in case award is placed by POWERGRID on behalf of SPV)

(To be stamped in accordance with Stamp Act of India)

	Insurance Surety Bond No.:
	Date:
Contract No	
[Name of Contract]	
To: [Name and address of the Employer]	
Dear Ladies and/or Gentlemen,	
We refer to the Contract ("the Contract")	
Power Grid Corporation of India Ltd., having Area, Katwaria Sarai, New Delhi – 110 016	nsert date of the notification of award)by M/s its Registered Office at B-9, Qutab Institutional ("the Employer"/"POWERGRID") on behalf of einafter referred to as 'Owner') to M/s
(Name of Contractor),	, .
(or)	
`	ID") on behalf of(Name of the SPV) er'), and M/s(Name of Contractor)
Registered Office at	(Address of Contractor)and
Principal place of business at(Add Registered Office at(Registered add (hereinafter referred to as the "GIS Manufact Bidder/Contractor, have submitted a deed of and severally bound and responsible for the q Manufacturer having agreed to furnish a C	(Name of GIS Manufacturer), having its ress of GIS Manufacturer) and dress of GIS and that the gisting that they are jointly juality and timely supply of GIS and that the GIS contract Performance Guarantee for the faithful ertaking equivalent to Two Percent (02%) of the in Supply, F&I and Installation schedules under

We undertake to make payment under this **Insurance Surety Bond** upon receipt by us of your first written demand signed by **the Employer's duly authorized officer or the authorized officer of Owner** declaring the Contractor/ GIS Manufacturer to be in default under the Contract and without cavil or argument any sum or sums within the above named limits, without your need to prove or show grounds or reasons for your demand and without the right of the Contractor/ GIS Manufacturer to dispute or question such demand.

Our liability under this **Insurance Surety Bond** shall be to pay to **the Owner / Employer** whichever is the lesser of the sum so requested or the amount then guaranteed hereunder in respect of any demand duly made hereunder prior to expiry of the Letter of Guarantee, without being entitled to inquire whether or not this payment is lawfully demanded.

Except for the documents herein specified, no other documents or other action shall be required, notwithstanding any applicable law or regulation.

Our liability under this **Insurance Surety Bond** shall become null and void immediately upon its expiry, whether it is returned or not, and no claim may be made hereunder after such expiry or after the aggregate of the sums paid by us to **the Owner / Employer** shall equal the sums guaranteed hereunder, whichever is the earlier.

All notices to be given under shall be given by registered (airmail) posts to the addressee at the address herein set out or as otherwise advised by and between the parties hereto.

We hereby agree that any part of the Contract may be amended, renewed, extended, modified, compromised, released or discharged by mutual agreement between **the Owner/Employer** and the Contractor/ GIS Manufacturer, and this security may be exchanged or surrendered without in any way impairing or affecting our liabilities hereunder without notices to us and without the necessity for any additional endorsement, consent or guarantee by us, provided, however, that the sum guaranteed shall not be increased or decreased.

No action, event or condition which by any applicable law should operate to discharge us from liability hereunder shall have any effect and we hereby waive any right we may have to apply such law so that in all respects our liability hereunder shall be irrevocable and, except as stated herein, unconditional in all respects.

"N	Iotwithstanding anything contained herein:
1.	Our liability under this Insurance Surety Bond shall not exceed (value in figures) [(value in words)].
2.	This Insurance Surety Bond shall be valid upto(validity date)
3.	We are liable to pay the guaranteed amount or any part thereof under this Insurance Surety Bond only & only if we receive a written claim or demand on or before (validity date)"
	For and on behalf of the Insurer
	[Signature of the authorised signatory(ies)]
	Signature
	Name
	Designation
	POA Number
	Contact Number(s): TelMobile
	Fax Number
	email
	Common Seal of the Bank
	Witness:
	Signature
	Name
	Address
	Contact Number(s): TelMobile
	email

Note:

- 1. The Insurance Surety Bond should be on Non-Judicial stamp paper/e-stamp paper of appropriate value as per Stamp Act prevailing in the state(s) where the Insurance Surety Bond is submitted or is to be acted upon or the rate prevailing in State where the Insurance Surety Bond is executed, whichever is higher. The Stamp Paper/e-stamp paper shall be purchased in the name of Bidder/Insurer issuing the Insurance Surety Bond.
- 2. The Insurance Surety Bond shall be signed on all the pages by the Insurer Authorities and should invariably be witnessed.

Annexure-J

- 3. The Insurance Surety Bond shall be from an Insurer as per guidelines issued by Insurance Regulatory and Development Authority of India (IRDAI) as amended from time to time.
- 4. The Employer shall be the Creditor, the Bidder shall be the Principal debtor and the Insurance company/Insurer shall be the Surety in respect of the Insurance Surety Bond to be issued by the Insurer.
- 5. While getting the Insurance Surety Bond issued, Contractors/ Suppliers are required to ensure compliance to the points mentioned in Form of Insurance Surety Bond.

INDEMNIFICATION AGREEMENT

This Indemnification Agreement is executed at [●] on this the [●] day of [●] 2024

BY AND BETWEEN

Bharat Heavy Electricals Ltd., a Company incorporated under Companies Act, 1956 having its registered office at BHEL House, Siri Fort, Asiad Village, New Delhi – 110049 and the executing office at TBG, BHEL 5th Floor, BHEL Sadan, Plot No. 25, Sector-16A, Noida-201301, U.P., (which expression shall, unless repugnant to the context or meaning thereof, be deemed to mean and include its legal representatives, nominees, permitted assigns and successors) (hereinafter referred to as "FIRST PARTY/BHEL"),

AND

(Associate Name / GIS OEM), a Company incorporated under Companies Act, 1956/2013 having CIN No. [●] and its registered office/principal place of business at [●] through its duly authorized signatory [●] duly authorized vide Board Resolution dated [●] (which expression shall, unless it be repugnant to the context of meaning thereof, be deemed to include its successors and permitted assignees) (hereinafter referred to as the "SECOND PARTY/ GIS OEM NAME")

"FIRST PARTY", and "SECOND PARTY" are individually referred to as "Party" and collectively as "Parties".

WHEREAS

- (A) The First Party is planning to bid for (Employer) enquiry no. CC/T/W-GIS/DOM/A06/24/14461 for the execution of 400kV GIS Package (Package-II) at KPS 3 (HVDC), South Olpad (HVDC) and Extn. of existing KPS3 (GIS) station including civil works associated with ±500kV, 2500 MW KPS-3 (HVDC) and South Olpad (HVDC) Scheme associated with Transmission System for Evacuation of Power from potential renewable energy zone in Khavda area of Gujarat under Phase-V (8GW): Part C through Tariff based Competitive (TBCB) route prior to RfP bid submission by POWERGRID to BPC (hereinafter referred to as "The Project").
- (B) As per Clause No. 1 of Annexure A of BDS, Section III, of Vol.— I forming part of the Bidding Documents, the First Party meets the requirement under route 4 and the Second Party meets the requirements under route 1/2/3 for 400 kV GIS Scope.
- (C) In order to participate in the bidding process, The First Party has invited a tender from the qualified GIS manufacturers with a proposal to declare the Second Party as an associate for Design, Manufacture, Supply & Supervision of Erection, Testing & Commissioning of 400 kV Gas Insulated Switchgear (GIS) and accessories for execution of the Project.
- (D) The Second Party has agreed to the said proposal and submitted its bid to the first party. The first party selected the second party as the qualified associate through their standard tendering process.
- (E) In line with the POWERGRID's tender qualifying requirements, for GIS manufacturer to quote as an associate, the associate has to sign a Joint Deed of Undertaking (JDU) with the First Party (<u>Attached as Annexure 1 with the present agreement</u>). As per Clause 2 of the JDU, the Associate has to undertake to be jointly and severally liable and bound unto the Employer for successful performance of the GIS portion of the Contract along with the EPC bidder.

- (F) The Parties have therefore agreed that the First Party, as the EPC contractor/Sole Bidder, shall be solely responsible for Supply, Civil and Services portion defined in bidding document by POWERGRID, whereas the scope of the Second Party shall be limited only to Design, Manufacture, Supply and Supervision of Erection, Testing and Commissioning of GIS. The clear responsibility of individual Parties, in terms of the POWERGRID tender, shall form integral part of this Indemnification Agreement. The scope of work of the parties is annexed to this Indemnification Agreement and marked as Annexure-2.
- (G) The Parties have agreed to execute this Indemnification Agreement in order to safeguard each other against any loss or damage arising out of any demands/disputes/claims/litigation, etc. that may be raised by POWERGRID or their representatives owing to of any shortfall or deficiency in work carried out by the parties in their respective scope of work as per Annexure-2 during the execution of the Project.
- (H) Accordingly, the parties now wish to set out the mutual responsibilities towards each other arising out of their scope of work as delineated in Annexure-2 before, during, and after the execution of the Project.
- (I) The Parties agree, confirm, undertake and certify that they have all the requisite approvals and permissions including approval of their respective Boards and there is nothing restricting them to execute this Indemnification Agreement and its enforceability under the applicable laws of India.

Now therefore, in Consideration of premises, mutual agreements, covenants and conditions set forth in this Indemnification Agreement, it is hereby agreed by and between the Parties as follows:-

- 1. The above Preamble/Recital shall be considered as an integral part of this Indemnification Agreement.
- 2. The First Party undertakes and agrees that in the event of the contract being awarded to the First Part (as sole bidder under Route-4 category of POWERGRID), the Second Party shall not be liable to POWERGRID for any breach committed by the First Party in relation to the First Party's scope of work in terms of the requirements mentioned in Clause 2 of the JDU.
- 3. The Second Party undertakes and agrees that in the event of the contract being awarded to the First Part (as sole bidder under Route-4 category of POWERGRID), the First Party shall not be liable to POWERGRID for any breach committed by the Second Party in relation to the Second Party's scope of work in terms of the requirements mentioned in Clause 2 of the JDU.
- 4. The First Party undertakes and agrees not to carry out any obligations and responsibilities under the JDU in order to discharge the obligations and responsibilities of the Second Party stipulated in the Contract/Tender with respect to Second Party's scope of work related to Design, Manufacture, Supply & Supervision of Erection, Testing & Commissioning of 400 kV GIS and accessories and more particularly delineated in Annexure-2.
- 5. The Second Party undertakes and agrees not to carry out any obligation and responsibilities under the JDU in order to discharge the obligations and responsibilities of the First Party stipulated in the Contract/Tender with respect to First Party's scope

- of work related to remaining Supply, Civil and Services Portion and more particularly delineated in Annexure-2.
- 6. The First Party hereby irrevocably undertakes and agrees to indemnify and hold the Second Party harmless from and against all actions, proceedings, claims, liabilities, penalties, demands, litigations, costs and losses whatsoever, incurred or suffered or to be incurred or to be suffered by the Second Party on account of any shortfall or deficiency in work carried out by the First Party in its scope as per Annexure-2 during the execution of the Project.
- 7. The Second Party hereby irrevocably undertakes and agrees to indemnify and hold the First Party harmless from and against all actions, proceedings, claims, liabilities, penalties, demands, litigations, costs and losses whatsoever, incurred or suffered or to be incurred or to be suffered by the First Party on account of any shortfall or deficiency in work carried out by the Second Party in its scope as per Annexure-2 during the execution of the Project.
- 8. The First Party and Second Party jointly agree to safeguard each other against any loss or damage arising out of any demands/disputes/claims/litigation, etc. that may be raised by POWERGRID or their representatives owing to of any shortfall or deficiency in work carried out by the parties in their respective scope of work as per Annexure-2 during the execution of the Project.
- 9. All or any dispute, controversy, claim or disagreement arising out of or touching upon or in relation to the terms of this Indemnification Agreement, breach, invalidity, including the interpretation and validity thereof and the respective rights and obligations of the Parties hereof, shall be referred to arbitration which shall be governed by the Arbitration and Conciliation Act, 1996. The Parties shall mutually appoint a sole arbitrator to resolve the dispute or differences, failing which it shall be appointed in accordance with Arbitration and Conciliation Act, 1996. The venue of arbitration shall be New Delhi. The arbitration proceedings shall be conducted as per laws of India and under the Arbitration and Conciliation Act, 1996 in India. The arbitration proceedings shall be conducted in the English language. The costs of the arbitration shall be shared by the Parties equally. The award passed by the Sole Arbitrator shall be final, binding and conclusive between the Parties.
- 10. This Indemnification Agreement shall be interpreted and governed in all respects by the laws of India and the Courts at New Delhi shall have the exclusive jurisdiction to entertain and try any dispute or matter relating to or arising out of this Indemnification Agreement.
- 11. If any provision of this Indemnification Agreement is invalid or unenforceable or prohibited by law, it shall be treated for all purposes as severed from this Indemnification Agreement and ineffective to the extent of such invalidity or unenforceability, without affecting in any manner the remaining provisions hereof, which shall continue to be valid and binding.
- 12. This Indemnification Agreement constitutes the entire agreement between the parties pertaining to the subject matter hereof. No variation of this Indemnification Agreement shall be binding on any of the Parties unless, and to the extent that such variation is recorded in a written document executed amongst the Parties.
- 13. This Indemnification Agreement is intended to inure for the benefit of both the Parties and this Indemnification Agreement shall be binding on both the Parties.

14. Any demand, notice or communication under this Indemnification Agreement shall be in writing and shall be hand delivered or by post or by facsimile or e-mail to the party receiving such communication at the address specified herein or such other address as either party may in future specify to other party.

Give Address; emails; fax details

15. This Indemnification Agreement is entered amongst the parties hereto on a principalto-principal basis. Nothing contained in this Indemnification Agreement shall be construed or deemed to create any principal-agent relationship.

In Witness whereof the Parties have signed this Indemnification Agreement on the day, month and year first above written through their respective Authorized Representative/s.

For Rharat Heavy Flectricals Limited

Witnesses:	For, Bharat Heavy Electricals Limited (First Party)
1.	
	(Authorized Representative)
2.	For, (Second Party)
	(Authorized Representative)

<u>ANNEXURE-1 to Indemnification Agreement: FORM OF DEED OF JOINT UNDERTAKING</u>
<u>TO BE EXECUTED BY THE BIDDER/CONTRACTOR ALONGWITH INDIAN GIS</u>
<u>MANUFACTURER.</u>

ANNEXURE-2 to Indemnification Agreement

Division of Scope between "FIRST PARTY" and "SECOND PARTY"

Scope of Second Party (Associate / GIS OEM)

Design, Manufacture, Supply (incl. F&I), Testing & Commissioning, Supervision of Erection, and Warranty/Guarantee Obligations for items as per attached "ANNEXURE_BOQ_400 kV GIS Pkg-II" and BHEL Technical Specifications or any subsequent amendment of the same issued by BHEL in line with requirement of M/s POWERGRID tender.

ANNEXURE_BOQ_400 kV GIS Pkg-II to be furnished by TBEM

Scope of First Party (BHEL)

All the remaining scope (apart from the scope of Second Party identified above) defined in bidding document and subsequent amendments issued by M/s POWERGRID.

Price bid format (Un-priced)

Item Wise BoQ

Tender Inviting Authority: BHEL TBG NOIDA Name of Work: Powergrid's GIS pkg-II at KPS3

Enquiry/NIT No:

Name of the	
Bidder/ Bidding	
Firm / Company :	

JMBER#	TEXT #	TEXT #	NUMBER#	TEXT#	TEXT #	NUMBER#	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER#	NUMBER#	NUMBER#		TEXT#
SI. No.	Item Description	Item Code / Make	Quantity	Units	Quoted Currency in INR / Other Currency	Unit RATE In Figures To be entered by the Bidder in Rs. P	GST (in Percentage)	GST Amount (Unit Rate*Quantity* GST) Rs. P	Unit Freight & Insurance Charges in Rs. P	GST (in Percentage)	GST Amount on F&I (Unit Rate*Quantity*G ST) Rs. P	HSN / SAC Code	TOTAL Ex-Works + F & I AMOUNT excluding GST in Rs. P	TOTAL Ex-Works + F & I AMOUNT including GST in Rs. P	TOTAL AMOUNT In Words	
1	2	3	4	5	12	13	14	15	16	20	21	51	53	54		55
1.1.01	1. 400kV GIS AC station at KPS3 (HVDC) SUPPLY- GIS: 400kV, 63KA FOR 1S, GAS INSULATED SWITCHGEAR (GIS) AS PER TS (item sl. No. 1.1.01-1.1.12) 400kV, 3150A, 63KA, Single phase, SF6 Gas Insulated Bus Duct (GIB) outside GIS Hall alongwith associated support structure	item1	2500	Mtr	INR			0.00			0.00		0.000	0.00	10 INR Zero Only	
.1.02	420kV, 3150 A, 63 kA, SF6 GIS Converter feeder bay module as per Section-Project, Technical specification	item2	2	SET	INR			0.00			0.00		0.000	0.00	INR Zero Only	
1.1.03	420kV, 3150 A, 63 kA, SF6 GIS Tie bay module (of Converter Feeder) as per Section-Project, Technical specification	item3	2	SET	INR			0.00			0.00		0.000	0.00	00 INR Zero Only	
1.1.04	420kV, 3150 A, 63 kA, SF6 GIS Line feeder bay module as per Section-Project, Technical specification	item4	4	SET	INR			0.00			0.00		0.000	0.00	100 INR Zero Only	
.1.05	420kV, 3150 A, 63 kA, SF6 GIS Tie bay module as per Section-Project, Technical specification	item5	4	SET	INR			0.00			0.00		0.000	0.00	INR Zero Only	
.1.06	420kV, 3150 A, 63 kA, SF6 GIS Reactor feeder bay module as per Section-Project, Technical specification	item6	2	SET	INR			0.00			0.00		0.000	0.00	INR Zero Only	
1.1.07	420kV, 3150 A, 63 kA, SF6 GIS Transformer feeder bay module as per Section-Project, Technical specification	item7	2	SET	INR			0.00			0.00		0.000	0.00	INR Zero Only	
.1.08	420kV, 4000 A, 63 kA, SF6 GIS Bus sectionaliser module as per Section-Project, Technical specification	item8	2	SET	INR			0.00			0.00		0.000	0.00	INR Zero Only	
.1.09	420kV, 4000 A, 63 kA, SF6 GIS Busbar module as per Section-Project, Technical specification	item9	4	SET	INR			0.00			0.00		0.000	0.00	INR Zero Only	
.1.10	420kV GIS Interface Module for Future Extension of Bus Bar As per TS	item10	4	SET	INR			0.00			0.00		0.000	0.00	INR Zero Only	
.1.11	420KV, 3150A, 63kA Single Phase SF6 to Air bushing connecting GIS to AIS alongwith support structure	item11	30	EA	INR			0.00			0.00		0.000	0.00	INR Zero Only	
1.1.12	Local Control Cubicle (LCC)	item12	18	SET	INR			0.00			0.00		0.000		INR Zero Only	
1.2.01	SUPPLY- GIS: SPECIAL TOOLS AND TESTING & MAINTENANCE INSTRUMENTS AS PER TS (Item sl. No: 1.2.01-1.2.03): SF6 Gas Processing unit	item13	1	Set	INR			0.00			0.00		0.000	0.00	INR Zero Only	
1.2.02	Gas Analyzer [Dew Point Meter]	item14	1	Set	INR			0.00			0.00		0.000		100 INR Zero Only	
.2.03	SF6 gas leak detector SPARES- GIS: 400KV, 63KA FOR 1S, GAS	item15	1	Set	INR			0.00			0.00		0.000		00 INR Zero Only 100 INR Zero Only	
1.3.01	INSULATED SWITCHGEAR (GIS) AS PER TS (Item sl. No. 1.3.01-1.3.52): 400KV GIS-SF6 GAS PRESSURE RELIEF DEVICE ASSEMBLY OF EACH TYPE with 'O' Rings	item16	1	SET	INVIN			0.00			0.00		3.000	0.00	NAME AND SHIP	
1.3.02	SF6 PRESSURE GAUGE CUM SWITCH /DENSITY MONITORS AND PRESSURESWITCH AS APPLICABLE, OF EACH TYPE-400KV GIS	item17	2	SET	INR			0.00			0.00		0.000	0.00	INR Zero Only	
1.3.03	COUPLING DEVICE FOR PRESSURE GAUGE CUM SWITCH FOR CONNECTINGGAS HANDLING PLANT OF EACH TYPE-400KV GIS	item18	2	SET	INR			0.00			0.00		0.000	0.00	INR Zero Only	

Price bid format (Un-priced)

Item Wise BoQ

Tender Inviting Authority: BHEL TBG NOIDA

Name of Work: Powergrid's GIS pkg-II at KPS3

Enquiry/NIT No:

Name of the
Bidder/ Bidding
Firm / Company :

PRICE SCHEDULE

relevent columns, else the bidder is liable to be rejected for this tender. Bidders are allowed to enter the Bidder Name and Values only)

NUMBER #	TEXT #	TEXT #	NUMBER #	TEXT #	TEXT #	NUMBER #	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER#	NUMBER #	NUMBER #		TEXT#
SI. No.	Item Description	Item Code / Make	Quantity	Units	Quoted Currency in INR / Other Currency	Unit RATE In Figures To be entered by the Bidder in Rs. P	GST (in Percentage)	GST Amount (Unit Rate*Quantity* GST) Rs. P	Unit Freight & Insurance Charges in Rs. P	GST (in Percentage)	GST Amount on F&I (Unit Rate*Quantity*G ST) Rs. P	HSN / SAC Code	TOTAL Ex-Works + F & I AMOUNT excluding GST in Rs. P	TOTAL Ex-Works + F & I AMOUNT including GST in Rs. P	TOTAL AMOUNT In Words	
1	2	3	4	5	12	13	14	15	16	20	21	51	53	54		55
1.3.04	RUBBER GASKETS, 'O' RINGS AND SEALS FOR SF6 GAS FOR GISENCLOSURE OF EACH TYPE- 400KV GIS	item19	3	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only	
1.3.05	400KV GIS-MOLECULAR FILTER FOR SF6 GAS WITH FILTER BAGS (3 % OF TOTALWEIGHT)	item20	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only	
1.3.06	CONTROL VALVES FOR SF6 GAS OF EACH TYPE- 400KV GIS	item21	3	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only	
1.3.07	400KV GIS-SF6 GAS (5 % OF TOTAL GAS QUANTITY)	item22	1	LOT	INR			0.00			0.00		0.000	0.000	INR Zero Only	
1.3.08	LOCKING DEVICE TO KEEP THE DIS- CONNECTORS (ISOLATORS)AND EARTHING/FAST EARTHING SWITCHES IN CLOSE OR OPEN POSITION IN CASEOF REMOVAL OF THE DRIVING MECHANISM-400KV GIS	item23	3	SET	INR			0.00			0.00		0.000	0.000	O INR Zero Only	
1.3.09	UHF PD SENSORS OF EACH TYPE ALONG WITH BNC CONNECTOR FOR 420KV GIS	item24	5	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only	
1.3.10	400KV GIS-SUPPORT INSULATORS (GAS THROUGH) OF EACH TYPE (COMPLETE WITHMETAL RING ETC.) ALONG WITH ASSOCIATED CONTACTS AND SHIELDS	item25	3	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only	
1.3.11	400KV GIS-GAS BARRIERS OF EACH TYPE (COMPLETE WITH METAL RING ETC.)ALONG WITH ASSOCIATED CONTACTS AND SHIELDS	item26	3	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only	
1.3.12	420KV, 3150A, 63kA Single phase SF6 to Air bushing of each type	item27	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only	
1.3.13	LCC SPARES - AUX. RELAYS, CONTACTORS, PUSH BUTTONS, SWITCHES, LAMPS, ANNUNCIATION WINDOWS, MCB, FUSES, TIMERS, TERMINAL BLOCKS ETC. OF EACHTYPE & RATING-400kV GIS	item28	2	SET	INR			0.00			0.00		0.000	0.000	D INR Zero Only	
1.3.14	400KV GIS-ONE POLE OF 3150A CIRCUIT BREAKER WITHOUT PIR WITHINTERRUPTER, MAIN CIRCUIT, ENCLOSURE AND OPERATING MECHANISM COMPLETEIN ALL RESPECT	item29	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only	
1.3.15	400KV GIS-ONE POLE OF 4000A CIRCUIT BREAKER WITHOUT PIR WITHINTERRUPTER, MAIN CIRCUIT, ENCLOSURE AND OPERATING MECHANISM COMPLETEIN ALL RESPECT	item30	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only	
1.3.16	Trip coil assembly with resistor for420kV GIS Circuit Breaker (asapplicable)	item31	3	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only	
.3.17	Closing coil assembly with resistor for 420kV GIS Circuit Breaker (asapplicable)	item32	3	SET	INR			0.00			0.00		0.000		INR Zero Only	
.3.18	Ferrules, Joints & Coupling of each type for CB	item33	1	SET	INR			0.00			0.00		0.000		INR Zero Only	
.3.19	Window slope/ observing glass each type	item34	3	SET	INR			0.00			0.00		0.000		INR Zero Only	
1.3.20	RELAYS, POWER CONTACTORS, PUSH BUTTONS, TIMERS & MCBS ETC. (ASAPPLICABLE) OF EACH TYPE FOR 400KV GIS CIRCUIT BREAKER	item35	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only	
1.3.21	Auxiliary switch assembly of each type for 420kV GIS Circuit Breaker	item36	3	SET	INR			0.00			0.00		0.000		INR Zero Only	
1.3.22	400KV GIS CIRCUIT BREAKER-OPERATION COUNTER Each Type	item37	3	SET	INR			0.00			0.00		0.000		INR Zero Only	
1.3.23	400KV GIS CIRCUIT BREAKER-HYDRAULIC OPERATING MECHANISM WITH DRIVEMOTOR (FOR HYDRAULIC OPERATED MECHANISM, IF APPLICABLE)	item38	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only	

Validate	

Print

Help

Item Wise BoQ

Tender Inviting Authority: BHEL TBG NOIDA

Name of Work: Powergrid's GIS pkg-II at KPS3

Enquiry/NIT No:

Name of the
Bidder/ Bidding
Firm / Company:

PRICE SCHEDULE

				(This BOQ	template must not	t be modified/replaced by the bidder and the	e same should be uplo	aded after filling th	e relevent columns, else the bidder is liabl	e to be rejected for th	is tender. Bidders ar	re allowed to enter the	Bidder Name and Values only)		
NUMBER #	TEXT #	TEXT #	NUMBER #	TEXT #	TEXT #	NUMBER#	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER#	NUMBER #	NUMBER #	TEXT#
SI. No.	Item Description	Item Code / Make	Quantity	Units	Quoted Currency in INR / Other Currency	Unit RATE In Figures To be entered by the Bidder in Rs. P	GST (in Percentage)	GST Amount (Unit Rate*Quantity* GST) Rs. P	Unit Freight & Insurance Charges in Rs. P	GST (in Percentage)	GST Amount on F&I (Unit Rate*Quantity*G ST) Rs. P	HSN / SAC Code	TOTAL Ex-Works + F & I AMOUNT excluding GST in Rs. P	TOTAL Ex-Works + F & I AMOUNT including GST in Rs. P	S
1	2	3	4	5	12	13	14	15	16	20	21	51	53	54	55
1.3.24	HYDRAULIC FILTER OF EACH TYPE (FOR HYDRAULIC OPERATED MECHANISM, IFPPLICABLE)-400KV GIS CIRCUIT BREKAER	item39	1	SET	INR			0.00			0.00		0.000	,	
1.3.25	400KV GIS CIRCUIT BREAKER- HOSE PIPE OF EACH TYPE (AS APPLICABLE) (FORHYDRAULIC OPERATED MECHANISM, IF APPLICABLE)	item40	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.26	400KV GIS CIRCUIT BREAKER - N2 ACCUMULATOR (FOR HYDRAULIC OPERATEDMECHANISM, IF APPLICABLE)	item41	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.27	VALVES OF EACH TYPE (FOR HYDRAULIC OPERATED MECHANISM, IFAPPLICABLE)-400KV GIS CIRCUIT BREKAER	item42	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.28	PIPE LENGTH (COPPER & STEEL) OF EACH SIZE & TYPE (FOR HYDRAULICOPERATED MECHANISM, IF APPLICABLE)-400KV GIS CIRCUIT BREKAER	item43	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.29	PRESSURE SWITCHES OF EACH TYPE (FOR HYDRAULIC OPERATED MECHANISM, IFAPPLICABLE)-400KV GIS CIRCUIT BREKAER	item44	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.30	PRESSURE GAUGE WITH COUPLING DEVICE OF EACH TYPE (FOR HYDRAULICOPERATED MECHANISM, IF APPLICABLE)-400KV GIS CIRCUIT BREKAER	item45	1	SET	INR			0.00			0.00		0.000	,	
1.3.31	400KV GIS CIRCUIT BREAKER-HYDRAULIC OIL (5% OF TOTAL OIL QUANTITY)(FOR HYDRAULIC OPERATED MECHANISM, IF APPLICABLE)	item46	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.32	PRESSURE RELIEF DEVICE OF EACH TYPE (FOR HYDRAULIC OPERATED MECHANISM,IF APPLICABLE)-400KV GIS CIRCUIT BREKAER	item47	1	SET	INR			0.00			0.00		0.000	·	
1.3.33	400KV GIS CIRCUIT BREAKER-COMPLETE SPRING OPERATING MECHANISMINCLUDING CHARGING MECHANISM ETC. (FOR SPRING OPERATED MECHANISM, IFAPPLICABLE) of each type	item48	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.34	switch including maincircuit, enclosure, driving mechanismand support insulator etc., complete inall respect (Note 1- The contractorshall supply spare for disconnectorswitch to ensure one to one replacement of all disconnector switch supplied asmain equipment without any requirement of modification in fittings at site tocover all different types of disconnector switch supplied. In case, quantity of supplied dis-connectorswitch types (for one to one replacement) are more than the quantitymentioned in BPS for spare, thecontractor shall supply these additional types of disconnector switch without any additional price implication to POWERGRID and quantities of these additional type of disconnector switch are deem to be included in the quantities mentioned in BPS for spare disconnector. Note 2 - Incase, Dis-connector Switch (DS) & EarthSwitch (ES) is provided in a sameen closure with common operating mechanism, then the module comprising Dis-connector & Earth switch insingle enclosure with common	item49	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	

Price bid format (Un-priced)

Validate

Item Wise BoQ

Tender Inviting Authority: BHEL TBG NOIDA

Name of Work: Powergrid's GIS pkg-II at KPS3

Name of the
Bidder/ Bidding
Firm / Company:

				(This BOQ	template must not	t be modified/replaced by the bidder and the	e same should be uploa	aded after filling th	e relevent columns, else the bidder is liabl	e to be rejected for t	his tender. Bidders a	re allowed to enter the	e Bidder Name and Values only)		
NUMBER#	TEXT#	TEXT #	NUMBER#	TEXT #	TEXT #	NUMBER#	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER#	NUMBER #	NUMBER #	TEXT#
SI. No.	Item Description	Item Code / Make	Quantity	Units	Quoted Currency in INR / Other Currency	Unit RATE In Figures To be entered by the Bidder in Rs. P	GST (in Percentage)	GST Amount (Unit Rate*Quantity* GST) Rs. P	Unit Freight & Insurance Charges in Rs. P	GST (in Percentage)	GST Amount on F&I (Unit Rate*Quantity*G ST) Rs. P	HSN / SAC Code	TOTAL Ex-Works + F & I AMOUNT excluding GST in Rs. P	TOTAL Ex-Works + F & I AMOUNT including GST in Rs. P	TOTAL AMOUNT In Words
1.3.35	400KV GIS- SINGLE PHASE MAINTENANCE EARTHING SWITCH INCLUDING MAINCIRCUIT, ENCLOSURE, DRIVING MECHANISM AND SUPPORT INSULATOR ETC., COMPLETE IN ALL RESPECT (NOTE 1 - IN CASE, DIS-CONNECTOR SWITCH (DS) & EARTH SWITCH (ES) IS PROVIDED IN A SAME ENCLOSURE WITH COMMONOPERATING MECHANISM, THEN THE MODULE COMPRISING OF DIS-CONNECTOR & EARTH SWITCH IN SINGLE ENCLOSURE WITH COMMON OPERATING MECHANISM IS TOBE PROVIDED UNDER THE HEAD OF SPARE DIS- CONNECTOR ONLY. NOTE 2 - INCASE, DIS- CONNECTOR SWITCH (DS) & EARTH SWITCH (ES) IS PROVIDED IN ASAME ENCLOSURE WITH SEPARATE OPERATING MECHANISM, THEN THE MODULECOMPRISING OF DIS-CONNECTOR & EARTH SWITCH IN SINGLE ENCLOSURE WITHSEPARATE OPERATING MECHANISM IS TO BE PROVIDED UNDER THE HEAD OF SPAREDIS- CONNECTOR ONLY.)	item50	1	SET SET	INR	13	14	0.00	16	20	0.00	51	53		INR Zero Only
1.3.36	400KV GIS - SINGLE PHASE FAST EARTHING SWITCH INCLUDING MAIN CIRCUIT, ENCLOSURE, DRIVING MECHANISM AND SUPPORT INSULATOR ETC., COMPLETE INALL RESPECT (NOTE 1 - IN CASE, DISCONNECTOR SWITCH (DS) & EARTHSWITCH (ES) IS PROVIDED IN A SAME ENCLOSURE WITH COMMON OPERATINGMECHANISM, THEN THE MODULE COMPRISING OF DIS-CONNECTOR & EARTH SWITCHIN SINGLE ENCLOSURE WITH COMMON OPERATING MECHANISM IS TO BE PROVIDEDUNDER THE HEAD OF SPARE DISCONNECTOR ONLY. NOTE 2 - IN CASE, DISCONNECTOR SWITCH (DS) & EARTH SWITCH (ES) IS PROVIDED IN A SAMEENCLOSURE WITH SEPARATE OPERATING MECHANISM, THEN THE MODULECOMPRISING OF DIS-CONNECTOR & EARTH SWITCH IN SINGLE ENCLOSURE WITHSEPARATE OPERATING MECHANISM IS TO BE PROVIDED UNDER THE HEAD OF SPAREDIS-CONNECTOR ONLY.)	item51	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
1.3.37	OPEN/CLOSE CONTACTOR ASSEMBLY, TIMERS, KEY INTERLOCK, INTERLOCKINGCOILS, RELAYS, PUSH BUTTONS, INDICATING LAMPS, POWER CONTACTORS, RESISTORS, FUSES, MCBS & DRIVE CONTROL CARDS ETC. (AS APPLICABLE) ONEOF EACH TYPE FOR ONE COMPLETE MOM BOX FOR 400KV GIS DISCONNECTORSWITCH	item52	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only



Item Wise BoQ

Tender Inviting Authority: BHEL TBG NOIDA Name of Work: Powergrid's GIS pkg-II at KPS3

Enquiry/NIT No:

Name of the
Bidder/ Bidding
Firm / Company :

PRICE SCHEDULE

Price bid format (Un-priced)

				(This BOQ	template must not	t be modified/replaced by the bidder and the	same should be uplo	aded after filling th	PRICE SCHEDULE e relevent columns, else the bidder is liable	to be rejected for the	his tender. Bidders ar	re allowed to enter the	Bidder Name and Values only)		
NUMBER #	TEXT #	TEXT #	NUMBER #	TEXT #	TEXT #	NUMBER #	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER#	NUMBER#	NUMBER #	TEXT#
SI. No.	Item Description	Item Code / Make	Quantity	Units	Quoted Currency in INR / Other Currency	Unit RATE In Figures To be entered by the Bidder in Rs. P	GST (in Percentage)	GST Amount (Unit Rate*Quantity* GST) Rs. P	Unit Freight & Insurance Charges in Rs. P	GST (in Percentage)	GST Amount on F&I (Unit Rate*Quantity*G ST) Rs. P	HSN / SAC Code	TOTAL Ex-Works + F & I AMOUNT excluding GST in Rs. P	TOTAL Ex-Works + F & I AMOUNT including GST in Rs. P	
1	2	3	4	5	12	13	14	15	16	20	21	51	53	54	55
1.3.38	OPEN/CLOSE CONTACTOR ASSEMBLY, TIMERS, KEY INTERLOCK, INTERLOCKINGCOILS, RELAYS, PUSH BUTTONS, INDICATING LAMPS, POWER CONTACTORS, RESISTORS, FUSES, MCBS & DRIVE CONTROL CARDS ETC. (AS APPLICABLE) ONEOF EACH TYPE FOR ONE COMPLETE MOM BOX FOR 400KV GIS MAINTENANCE EARTHSWITCH	item53	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.39	OPEN/CLOSE CONTACTOR ASSEMBLY, TIMERS, KEY INTERLOCK, INTERLOCKINGCOILS, RELAYS, PUSH BUTTONS, INDICATING LAMPS, POWER CONTACTORS, RESISTORS, FUSES, MCBS & DRIVE CONTROL CARDS ETC. (AS APPLICABLE) ONEOF EACH TYPE FOR ONE COMPLETE MOM BOX FOR 400KV GIS FAST EARTHINGSWITCH	item54	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.40	LIMIT SWITCHES AND AUX. SWITCHES FOR ONE COMPLETE MOM BOX FORDISCONNECTOR-400KV GIS	item55	2	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.41	LIMIT SWITCHES AND AUX. SWITCHES FOR ONE COMPLETE MOM BOX FORMAINTENANCE EARTHING SWITCH-400KV GIS	item56	2	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.42	LIMIT SWITCHES AND AUX. SWITCHES FOR ONE COMPLETE MOM BOX FOR FASTEARTHING SWITCH (IF APPLICABLE)-400KV GIS	item57	2	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.43	DRIVE MECHANISM FOR 400KV GIS DISCONNECTOR SWITCH	item58	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.44	DRIVE MECHANISM FOR 400KV GIS MAINTENANCE EARTH SWITCH	item59	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.45	DRIVE MECHANISM FOR 400KV GIS FAST EARTHING SWITCH	item60	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.46	MOTOR FOR DRIVE MECHANISM FOR 400KV GIS DISCONNECTOR SWITCH	item61	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.47	MOTOR FOR DRIVE MECHANISM FOR 400KVGIS MAINTENANCE EARTH SWITCH	item62	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.48	MOTOR FOR DRIVE MECHANISM FOR 400KV GIS FAST EARTHING SWITCH	item63	1	SET	INR		_	0.00			0.00		0.000	0.000 INR Zero Only	
1.3.49	400KV GIS- SINGLE PHASE OF CURRENT TRANSFORMER (3 CORES, TYPE-CTA)WITH ASSOCIATED ENCLOSURE AND PRIMARY CONDUCTOR COMPLETE IN ALLRESPECT	item64	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.50	400KV GIS- SINGLE PHASE OF CURRENT TRANSFORMER (2 CORES, TYPE-CTB)WITH ASSOCIATED ENCLOSURE AND PRIMARY CONDUCTOR COMPLETE IN ALLRESPECT	item65	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.51	GIS SPARES: 400KV GIS- SINGLE PHASE VT WITH ASSOCIATED ENCLOSURE COMPLETE IN ALL RESPECT	item66	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
1.3.52	GIS SPARES: 400KV GIS- SINGLE PHASE LA WITH ASSOCIATED ENCLOSURE COMPLETE IN ALL RESPECT	item67	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	

NIT_87018_Enquiry No. 61Q2500406 Dated: 29-11-2024 Price bid format (Un-priced)

Item Wise BoQ

Tender Inviting Authority: BHEL TBG NOIDA Name of Work: Powergrid's GIS pkg-II at KPS3

Enquiry/NIT No:

Name of the Bidder/ Bidding Firm / Company :
Bidder/ Bidding
Firm / Company :

PRICE SCHEDULE

relevent columns, else the bidder is liable to be rejected for this tender. Bidders are allowed to enter the Bidder Name and Values only)

NUMBER#	TEXT #	TEXT #	NUMBER#	TEXT #	TEXT #	NUMBER #	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER#	NUMBER #	NUMBER #	TEXT#
SI. No.	Item Description	Item Code / Make	Quantity	Units	Quoted Currency in INR / Other Currency	Unit RATE In Figures To be entered by the Bidder in Rs. P	GST (in Percentage)	GST Amount (Unit Rate*Quantity* GST) Rs. P	Unit Freight & Insurance Charges in Rs. P	GST (in Percentage)	GST Amount on F&I (Unit Rate*Quantity*G ST) Rs. P	HSN / SAC Code	TOTAL Ex-Works + F & I AMOUNT excluding GST in Rs. P	TOTAL Ex-Works + F & I AMOUNT including GST in Rs. P	TOTAL AMOUNT In Words
1	2	3	4	5	12	13	14	15	16	20	21	51	53	54	55
2.1.01	2. 400kV GIS AC station at KPS-3 STATION (EXTN) SUPPLY- GIS: 400kV, 63KA FOR 1S, GAS INSULATED SWITCHGEAR (GIS) AS PER TS (Item sl. No. 2.1.01-2.1.08): 400KV, 3150A, 63KA, Single phase,SF6 Gas Insulated Bus Duct (GIB) outside GIS Hall alongwith associated support structure	item68	3000	Mtr	INR			0.00			0.00		0.000	0.00(INR Zero Only
2.1.02	420kV, 3150 A, 63 kA, SF6 GIS Line feeder bay module as per Section-Project, Technical specification	item69	4	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
2.1.03	420kV, 3150 A, 63 kA, SF6 GIS Tie bay module as per Section-Project, Technical specification	item70	4	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
2.1.04	420kV, 4000 A, 63 kA, SF6 GIS Bus extension as per Section-Project, Technical specification	item71	4	SET	INR			0.00			0.00		0.000		INR Zero Only
2.1.05	400KV, 4000A, 63KA, Single phase,SF6 Gas Insulated Bus Duct (GIB) outside GIS Hall alongwith associated support structure	item72	60	Mtr	INR			0.00			0.00		0.000	0.000	INR Zero Only
2.1.06	420kV GIS Interface Module for Future Extension of Bus Bar As per TS	item73	4	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
2.1.07	420KV, 3150A, 63kA Single Phase SF6 to Air bushing connecting GIS to AIS alongwith support structure	item74	12	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
2.1.08	Local Control Cubicle (LCC)	item75	8	SET	INR			0.00			0.00		0.000		INR Zero Only
3.1.01	3. 400kV AC GIS Extension South Olpad SUPPLY- GIS: 400KV, 63KA FOR 1S, GAS INSULATED SWITCHGEAR (GIS) AS PER TS (Item sl. No. 3.1.01-3.1.07): 400KV, 3150A, 63KA, Single phase,SF6 Gas Insulated Bus Duct (GIB) outside GIS Hall alongwith associated support structure	item76	600	Mtr	INR			0.00			0.00		0.000	0.000	INR Zero Only
	420kV, 3150A, 63 kA, SF6 GIS Converter feeder bay module as per Section-Project, Technical specification	item77	2	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
	420kV, 3150A, 63 kA, SF6 GIS Tie bay module (of Converter Feeder) as per Section-Project, Technical specification	item78	2	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.1.04	420kV, 4000 A, 63 kA, SF6 GIS Bus extension as per Section-Project, Technical specification	item79	2	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.1.05	420kV GIS Interface Module for Future Extension of Bus Bar As per TS	item80	2	SET	INR			0.00			0.00		0.000		INR Zero Only
	420KV, 3150A, 63kA Single Phase SF6 to Air bushing connecting GIS to AIS alongwith associated support structure	item81	6	SET	INR			0.00			0.00		0.000		INR Zero Only
3.2.01	Local Control Cubicle (LCC) SUPPLY- GIS: SPECIAL TOOLS AND TESTING & MAINTENANCE INSTRUMENTS AS PER TS (Item SI. No. 3.2.01-3.2.03): SF6 Gas Processing unit	item82	1	SET Set	INR			0.00			0.00		0.000 0.000		INR Zero Only INR Zero Only
3.2.02	Gas Analyzer [Dew Point Meter]	item84	1	Set	INR			0.00			0.00		0.000	0.000	INR Zero Only

Price bid format (Un-priced)

Item Wise BoQ

Tender Inviting Authority: BHEL TBG NOIDA

Name of Work: Powergrid's GIS pkg-II at KPS3

Enquiry/NIT No:

Name of the
Bidder/ Bidding
Firm / Company :

MBER#	TEXT #	TEXT #	NUMBER #	TEXT #	TEXT #	NUMBER#	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER#	NUMBER#	NUMBER #	TEXT#
SI. No.	Item Description	Item Code / Make	Quantity	Units	Quoted Currency in INR / Other Currency	Unit RATE In Figures To be entered by the Bidder in Rs. P	GST (in Percentage)	GST Amount (Unit Rate*Quantity* GST) Rs. P	Unit Freight & Insurance Charges in Rs. P	GST (in Percentage)	GST Amount on F&I (Unit Rate*Quantity*G ST) Rs. P	HSN / SAC Code	TOTAL Ex-Works + F & I AMOUNT excluding GST in Rs. P	TOTAL Ex-Works + F & I AMOUNT including GST in Rs. P	TOTAL AMOUNT In Words
1	2	3	4	5	12	13	14	15	16	20	21	51	53	54	55
3.3.01	SPARES- GIS: 400KV, 63KA FOR 1S, GAS INSULATED SWITCHGEAR (GIS) AS PER TS (Item sl. No. 3.3.01-3.3.52): 400KV GIS-SF6 GAS PRESSURE RELIEF DEVICE ASSEMBLY OF EACH TYPE with 'O' Rings	item86	1	SET	INR			0.00			0.00		0.000		INR Zero Only
3.3.02	SF6 PRESSURE GAUGE CUM SWITCH /DENSITY MONITORS AND PRESSURESWITCH AS APPLICABLE, OF EACH TYPE-400KV GIS	item87	2	SET	INR			0.00			0.00		0.000	0.000	0 INR Zero Only
3.3.03	COUPLING DEVICE FOR PRESSURE GAUGE CUM SWITCH FOR CONNECTINGGAS HANDLING PLANT OF EACH TYPE-400KV GIS	item88	2	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.04	RUBBER GASKETS, 'O' RINGS AND SEALS FOR SF6 GAS FOR GISENCLOSURE OF EACH TYPE- 400KV GIS	item89	3	SET	INR			0.00			0.00		0.000	0.000	NR Zero Only
3.3.05	400KV GIS-MOLECULAR FILTER FOR SF6 GAS WITH FILTER BAGS (3 % OF TOTALWEIGHT)	item90	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.06	CONTROL VALVES FOR SF6 GAS OF EACH TYPE- 400KV GIS	item91	3	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.07	400KV GIS-SF6 GAS (5 % OF TOTAL GAS QUANTITY)	item92	1	LOT	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.08	LOCKING DEVICE TO KEEP THE DIS- CONNECTORS (ISOLATORS)AND EARTHING/FAST EARTHING SWITCHES IN CLOSE OR OPEN POSITION IN CASEOF REMOVAL OF THE DRIVING MECHANISM-400KV GIS	item93	3	SET	INR			0.00			0.00		0.000	0.000	0 INR Zero Only
3.3.09	UHF PD SENSORS OF EACH TYPE ALONG WITH BNC CONNECTOR FOR 420KV GIS	item94	5	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.10	400KV GIS-SUPPORT INSULATORS (GAS THROUGH) OF EACH TYPE (COMPLETE WITHMETAL RING ETC.) ALONG WITH ASSOCIATED CONTACTS AND SHIELDS	item95	3	SET	INR			0.00			0.00		0.000	0.000	0 INR Zero Only
3.3.11	400KV GIS-GAS BARRIERS OF EACH TYPE (COMPLETE WITH METAL RING ETC.)ALONG WITH ASSOCIATED CONTACTS AND SHIELDS	item96	3	SET	INR			0.00			0.00		0.000	0.000	NR Zero Only
3.3.12	420KV, 3150A, 63kA Single phase SF6 to Air bushing of each type	item97	1	SET	INR			0.00			0.00		0.000		INR Zero Only
3.3.13	LCC SPARES - AUX. RELAYS, CONTACTORS,PUSH BUTTONS, SWITCHES,LAMPS,ANNUNCIATION WINDOWS, MCB, FUSES,TIMERS, TERMINAL BLOCKS ETC. OF EACHTYPE & RATING-400kV GIS	item98	2	SET	INR			0.00			0.00		0.000	0.000	0 INR Zero Only
3.3.14	400KV GIS-ONE POLE OF 3150A CIRCUIT BREAKER WITHOUT PIR WITHINTERRUPTER, MAIN CIRCUIT, ENCLOSURE AND OPERATING MECHANISM COMPLETEIN ALL RESPECT	item99	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.15	400KV GIS-ONE POLE OF 4000A CIRCUIT BREAKER WITHOUT PIR WITHINTERRUPTER, MAIN CIRCUIT, ENCLOSURE AND OPERATING MECHANISM COMPLETEIN ALL RESPECT	item100	1	SET	INR			0.00			0.00		0.000	0.000	O INR Zero Only
3.3.16	Trip coil assembly with resistor for420kV GIS Circuit Breaker (asapplicable)	item101	3	SET	INR			0.00			0.00		0.000		INR Zero Only
3.3.17	Closing coil assembly with resistor for 420kV GIS Circuit Breaker (asapplicable)	item102	3	SET	INR			0.00			0.00		0.000		INR Zero Only
3.3.18	Ferrules, Joints & Coupling of each type for CB	item103	1	SET	INR			0.00			0.00		0.000	0.000	0 INR Zero Only

Price bid format (Un-priced)

Validate

Print

Item Wise BoQ

Tender Inviting Authority: BHEL TBG NOIDA

Name of Work: Powergrid's GIS pkg-II at KPS3

Enquiry/NIT No:

Name of the
Bidder/ Bidding
Firm / Company:

PRICE	SCHE

This BOQ template must not be modified/replaced by the bidder and the same should be uploaded after filling the relevent columns, else the bidder is liable to be rejected for this tender. Bidders are allowed to enter the Bidder Name and Values only)

NUMBER #	TEXT #	TEXT #	NUMBER#	TEXT #	TEXT #	NUMBER #	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER#	NUMBER#	NUMBER #	TEXT #
SI. No.	Item Description	Item Code / Make	Quantity	Units	Quoted Currency in INR / Other Currency	Unit RATE In Figures To be entered by the Bidder in Rs. P	GST (in Percentage)	GST Amount (Unit Rate*Quantity* GST) Rs. P	Unit Freight & Insurance Charges in Rs. P	GST (in Percentage)	GST Amount on F&I (Unit Rate*Quantity*G ST) Rs. P	HSN / SAC Code	TOTAL Ex-Works + F & I AMOUNT excluding GST in Rs. P	TOTAL Ex-Works + F & I AMOUNT including GST in Rs. P	TOTAL AMOUNT In Words
1	2	3	4	5	12	13	14	15	16	20	21	51	53	54	55
3.3.20	RELAYS, POWER CONTACTORS, PUSH BUTTONS, TIMERS & MCBS ETC. (ASAPPLICABLE) OF EACH TYPE FOR 400KV GIS CIRCUIT BREAKER	item105	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.21	Auxiliary switch assembly of each type for 420kV GIS Circuit Breaker	item106	3	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.22	400KV GIS CIRCUIT BREAKER-OPERATION COUNTER Each Type	item107	3	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.23	400KV GIS CIRCUIT BREAKER-HYDRAULIC OPERATING MECHANISM WITH DRIVEMOTOR (FOR HYDRAULIC OPERATED MECHANISM, IF APPLICABLE)	item108	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.24	HYDRAULIC FILTER OF EACH TYPE (FOR HYDRAULIC OPERATED MECHANISM, IFPPLICABLE)-400KV GIS CIRCUIT BREKAER	item109	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.25	400KV GIS CIRCUIT BREAKER- HOSE PIPE OF EACH TYPE (AS APPLICABLE) (FORHYDRAULIC OPERATED MECHANISM, IF APPLICABLE)	item110	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.26	400KV GIS CIRCUIT BREAKER - N2 ACCUMULATOR (FOR HYDRAULIC OPERATEDMECHANISM, IF APPLICABLE)	item111	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.27	VALVES OF EACH TYPE (FOR HYDRAULIC OPERATED MECHANISM, IFAPPLICABLE)-400KV GIS CIRCUIT BREKAER	item112	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.28	PIPE LENGTH (COPPER & STEEL) OF EACH SIZE & TYPE (FOR HYDRAULICOPERATED MECHANISM, IF APPLICABLE)-400KV GIS CIRCUIT BREKAER	item113	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.29	PRESSURE SWITCHES OF EACH TYPE (FOR HYDRAULIC OPERATED MECHANISM, IFAPPLICABLE)-400KV GIS CIRCUIT BREKAER	item114	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.30	PRESSURE GAUGE WITH COUPLING DEVICE OF EACH TYPE (FOR HYDRAULICOPERATED MECHANISM, IF APPLICABLE)-400KV GIS CIRCUIT BREKAER	item115	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.31	400KV GIS CIRCUIT BREAKER-HYDRAULIC OIL (5% OF TOTAL OIL QUANTITY)(FOR HYDRAULIC OPERATED MECHANISM, IF APPLICABLE)	item116	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.32	PRESSURE RELIEF DEVICE OF EACH TYPE (FOR HYDRAULIC OPERATED MECHANISM,IF APPLICABLE)-400KV GIS CIRCUIT BREKAER	item117	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only
3.3.33	400KV GIS CIRCUIT BREAKER-COMPLETE SPRING OPERATING MECHANISMINCLUDING CHARGING MECHANISM ETC. (FOR SPRING OPERATED MECHANISM, IFAPPLICABLE) of each type	item118	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only

Validate	

Item Wise BoQ

Tender Inviting Authority: BHEL TBG NOIDA

Name of Work: Powergrid's GIS pkg-II at KPS3

Enquiry/NIT No:

Name of the
Bidder/ Bidding
Firm / Company :

				(This BOQ	template must no	t be modified/replaced by the bidder and the	same should be uplo	oaded after filling th	ne relevent columns, else the bidder is liab	le to be rejected for t	his tender. Bidders a	e allowed to enter the	e Bidder Name and Values only)		
NUMBER #	TEXT#	TEXT #	NUMBER #	TEXT#	TEXT #	NUMBER#	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER#	NUMBER#	NUMBER #	TEXT #
SI. No.	Item Description	Item Code / Make	Quantity	Units	Quoted Currency in INR / Other Currency	Unit RATE In Figures To be entered by the Bidder in Rs. P	GST (in Percentage)	GST Amount (Unit Rate*Quantity* GST) Rs. P	Unit Freight & Insurance Charges in Rs. P	GST (in Percentage)	GST Amount on F&I (Unit Rate*Quantity*G ST) Rs. P	HSN / SAC Code	TOTAL Ex-Works + F & I AMOUNT excluding GST in Rs. P	TOTAL Ex-Works + F & I AMOUNT including GST in Rs. P	DUNT in Words
1	2	3	4	5	12	13	14	15	16	20	21	51	53	54	55
3.3.34	switch including maincircuit, enclosure, driving mechanismand support insulator etc., complete inall respect (Note 1- The contractorshall supply spare for disconnectorswitch to ensure one to one replacement of all disconnector switch supplied asmain equipment without any requirement of modification in fittings at site tocover all different types of disconnector switch supplied. In case, quantity of supplied dis-connectorswitch types (for one to onereplacement) are more than the quantitymentioned in BPS for spare, thecontractor shall supply theseadditional types of disconnector switch without any additional priceimplication to POWERGRID and quantities of these additional type of disconnector switch are deem to beincluded in the quantities mentioned in BPS for spare disconnector. Note 2 - Incase, Dis-connector Switch (DS) & EarthSwitch (ES) is provided in a sameenclosure with common operatingmechanism, then the module comprising Dis-connector & Earth switch insingle enclosure with common	item119	1	SET	INR			0.00			0.00		0.000		
3.3.35	400KV GIS- SINGLE PHASE MAINTENANCE EARTHING SWITCH INCLUDING MAINCIRCUIT, ENCLOSURE, DRIVING MECHANISM AND SUPPORT INSULATOR ETC., COMPLETE IN ALL RESPECT (NOTE 1 - IN CASE, DIS-CONNECTOR SWITCH (DS) & EARTH SWITCH (ES) IS PROVIDED IN A SAME ENCLOSURE WITH COMMONOPERATING MECHANISM, THEN THE MODULE COMPRISING OF DIS-CONNECTOR &EARTH SWITCH IN SINGLE ENCLOSURE WITH COMMON OPERATING MECHANISM IS TOBE PROVIDED UNDER THE HEAD OF SPARE DIS- CONNECTOR ONLY. NOTE 2 - INCASE, DIS- CONNECTOR SWITCH (DS) & EARTH SWITCH (ES) IS PROVIDED IN ASAME ENCLOSURE WITH SEPARATE OPERATING MECHANISM, THEN THE MODULECOMPRISING OF DIS-CONNECTOR & EARTH SWITCH IN SINGLE ENCLOSURE WITHSEPARATE OPERATING MECHANISM IS TO BE PROVIDED UNDER THE HEAD OF SPAREDIS- CONNECTOR ONLY.)	item120	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero	Only

Price bid format (Un-priced)

Validate

Print

elp Item Wise BoQ

Tender Inviting Authority: BHEL TBG NOIDA

Name of Work: Powergrid's GIS pkg-II at KPS3

Enquiry/NIT No:

Name of the
Bidder/ Bidding
Firm / Company :

				(TIIIS BOQ		be modified/replaced by the bidder and the										
∕IBER#	TEXT #	TEXT #	NUMBER #	TEXT #	TEXT#	NUMBER #	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER#	NUMBER #	NUMBER #		TEXT#
SI. No.	Item Description	Item Code / Make	Quantity	Units	Quoted Currency in INR / Other Currency	Unit RATE In Figures To be entered by the Bidder in Rs. P	GST (in Percentage)	GST Amount (Unit Rate*Quantity* GST) Rs. P	Unit Freight & Insurance Charges in Rs. P	GST (in Percentage)	GST Amount on F&I (Unit Rate*Quantity*G ST) Rs. P	HSN / SAC Code	TOTAL Ex-Works + F & I AMOUNT excluding GST in Rs. P	TOTAL Ex-Works + F & I AMOUNT including GST in Rs. P	TOTAL AMOUNT In Words	
1	2	3	4	5	12	13	14	15	16	20	21	51	53	54		55
3.3.36	400KV GIS - SINGLE PHASE FAST EARTHING SWITCH INCLUDING MAIN CIRCUIT, ENCLOSURE, DRIVING MECHANISM AND SUPPORT INSULATOR ETC., COMPLETE INALL RESPECT (NOTE 1 - IN CASE, DISCONNECTOR SWITCH (ES) IS PROVIDED IN A SAME ENCLOSURE WITH COMMON OPERATINGMECHANISM, THEN THE MODULE COMPRISING OF DIS-CONNECTOR & EARTH SWITCHING SINGLE ENCLOSURE WITH COMMON OPERATING MECHANISM IS TO BE PROVIDED UNDER THE HEAD OF SPARE DISCONNECTOR ONLY. NOTE 2 - IN CASE, DISCONNECTOR SWITCH (DS) & EARTH SWITCH (ES) IS PROVIDED IN A SAMEENCLOSURE WITH SEPARATE OPERATING MECHANISM, THEN THE MODULECOMPRISING OF DIS-CONNECTOR & EARTH SWITCH IN SINGLE ENCLOSURE WITH SEPARATE OPERATING MECHANISM, THEN THE MODULECOMPRISING OF DIS-CONNECTOR & EARTH SWITCH IN SINGLE ENCLOSURE WITH SEPARATE OPERATING MECHANISM IS TO BE PROVIDED UNDER THE HEAD OF SPAREDIS-CONNECTOR ONLY.)	item121	1	SET	INR			0.00			0.00		0.000	0.000	D INR Zero Only	
.37	OPEN/CLOSE CONTACTOR ASSEMBLY, TIMERS, KEY INTERLOCK, INTERLOCKINGCOILS, RELAYS, PUSH BUTTONS, INDICATING LAMPS, POWER CONTACTORS, RESISTORS, FUSES, MCBS & DRIVE CONTROL CARDS ETC. (AS APPLICABLE) ONEOF EACH TYPE FOR ONE COMPLETE MOM BOX FOR 400KV GIS DISCONNECTORSWITCH	item122	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only	
.38	OPEN/CLOSE CONTACTOR ASSEMBLY, TIMERS, KEY INTERLOCK, INTERLOCKINGCOILS, RELAYS, PUSH BUTTONS, INDICATING LAMPS, POWER CONTACTORS, RESISTORS, FUSES, MCBS & DRIVE CONTROL CARDS ETC. (AS APPLICABLE) ONEOF EACH TYPE FOR ONE COMPLETE MOM BOX FOR 400KV GIS MAINTENANCE EARTHSWITCH	item123	1	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only	
3.39	OPEN/CLOSE CONTACTOR ASSEMBLY, TIMERS, KEY INTERLOCK, INTERLOCKINGCOILS, RELAYS, PUSH BUTTONS, INDICATING LAMPS, POWER CONTACTORS, RESISTORS, FUSES, MCBS & DRIVE CONTROL CARDS ETC. (AS APPLICABLE) ONEOF EACH TYPE FOR ONE COMPLETE MOM BOX FOR 400KV GIS FAST EARTHINGSWITCH	item124	1	SET	INR			0.00			0.00		0.000	0.000	D INR Zero Only	
.3.40	LIMIT SWITCHES AND AUX. SWITCHES FOR ONE COMPLETE MOM BOX FORDISCONNECTOR-400KV GIS	item125	2	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only	
3.41	LIMIT SWITCHES AND AUX. SWITCHES FOR ONE COMPLETE MOM BOX FORMAINTENANCE EARTHING SWITCH-400KV GIS	item126	2	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only	
3.42	LIMIT SWITCHES AND AUX. SWITCHES FOR ONE COMPLETE MOM BOX FOR FASTEARTHING SWITCH (IF APPLICABLE)-400KV GIS	item127	2	SET	INR			0.00			0.00		0.000	0.000	INR Zero Only	

Price bid format (Un-priced)

Validate

Print

Item Wise BoQ

Tender Inviting Authority: BHEL TBG NOIDA

Name of Work: Powergrid's GIS pkg-II at KPS3

Enquiry/NIT No:

Name of the
Bidder/ Bidding
Firm / Company :

(This BOQ template must not be modified/replaced by the bidder and the same should	be uploaded after filling the relevent columns, else the bidder is liable to be reject	ed for this tender. Bidders are allowed to enter the Bidder Name and Values only)

				,							T T				
NUMBER #	TEXT #	TEXT #	NUMBER#	TEXT #	TEXT #	NUMBER #	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER#	NUMBER #	NUMBER#	TEXT#
SI. No.	Item Description	Item Code / Make	Quantity	Units	Quoted Currency in INR / Other Currency	Unit RATE In Figures To be entered by the Bidder in Rs. P	GST (in Percentage)	GST Amount (Unit Rate*Quantity* GST) Rs. P	Unit Freight & Insurance Charges in Rs. P	GST (in Percentage)	GST Amount on F&I (Unit Rate*Quantity*G ST) Rs. P	HSN / SAC Code	TOTAL Ex-Works + F & I AMOUNT excluding GST in Rs. P	TOTAL Ex-Works + F & I AMOUNT including GST in Rs. P	
1	2	3	4	5	12	13	14	15	16	20	21	51	53	54	55
3.3.43	DRIVE MECHANISM FOR 400KV GIS DISCONNECTOR SWITCH	item128	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
3.3.44	DRIVE MECHANISM FOR 400KV GIS MAINTENANCE EARTH SWITCH	item129	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
3.3.45	DRIVE MECHANISM FOR 400KV GIS FAST EARTHING SWITCH	item130	1	SET	INR			0.00			0.00		0.000	·	
3.3.46	MOTOR FOR DRIVE MECHANISM FOR 400KV GIS DISCONNECTOR SWITCH	item131	1	SET	INR			0.00			0.00		0.000	·	
3.3.47	MOTOR FOR DRIVE MECHANISM FOR 400KVGIS MAINTENANCE EARTH SWITCH	item132	1	SET	INR			0.00			0.00		0.000	· ·	
3.3.48	MOTOR FOR DRIVE MECHANISM FOR 400KV GIS FAST EARTHING SWITCH	item133	1	SET	INR			0.00			0.00		0.000	·	
3.3.49	400KV GIS- SINGLE PHASE OF CURRENT TRANSFORMER (3 CORES, TYPE-CTA)WITH ASSOCIATED ENCLOSURE AND PRIMARY CONDUCTOR COMPLETE IN ALLRESPECT	item134	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
3.3.50	400KV GIS- SINGLE PHASE OF CURRENT TRANSFORMER (2 CORES, TYPE-CTB)WITH ASSOCIATED ENCLOSURE AND PRIMARY CONDUCTOR COMPLETE IN ALLRESPECT	item135	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
3.3.51	GIS SPARES: 400KV GIS- SINGLE PHASE VT WITH ASSOCIATED ENCLOSURE COMPLETE IN ALL RESPECT	item136	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
3.3.52	GIS SPARES: 400KV GIS- SINGLE PHASE LA WITH ASSOCIATED ENCLOSURE COMPLETE IN ALL RESPECT	item137	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
4.01	SPARES- GIS: REFERENCE UNIT PRICE FOR ADDITION / DELETION OF SUPPLY ITEMS (Unit Prices of Individual Equipment included here or in manadatory spares are required for any Addition/Deletion of Equipment and replacement of damaged items. Bidder to ensure that the unit prices have a logical relationship with prices of assemblies in main items. Quoting for unit prices is mandatory and shall be considered for evaluation) (Item SI. No. 4.01-4.05): SPARES: 400KV GIS- GIS METALLIC ENCLOSURE	item138	50	KG	INR			0.00			0.00		0.000	0.000 INR Zero Only	
4.02	SPARES: 400KV GIS- EXPANSION BELLOWS/ JOINTS	item139	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
4.03	SPARES: 400KV GIS- TEE BEND	item140	1	SET	INR			0.00			0.00		0.000	0.000 INR Zero Only	
4.04	SPARES: 400KV GIS- L BEND	item141	1	SET	INR			0.00			0.00		0.000	·	
4.05	SPARES: Controlled Switching Device for 420 kV, 3- ph Circuit Breaker	item142	1	SET	INR			0.00			0.00		0.000	·	
5.01	400kV GIS AC station at KPS3 (HVDC) SERVICES- GIS: 400KV, 63KA FOR IS, GAS INSULATED SWITCHGEAR (GIS) AS PER TS (Item SI. No. 5.01-5.10): SERVICES- 400kV GIS: SUPERVISION OF ERECTION OF GIS	item143	18	Bays	INR			0.00			0.00		0.000	0.000 INR Zero Only	
5.02	SERVICES- 400kV GIS: SUPERVISION OF ERECTION OF GAS INSULATED BUS DUCT	item144	2500	MTR	INR			0.00			0.00		0.000	·	
5.03	SERVICES- 400kV GIS: SUPERVISION OF ERECTION OF SF6 TO AIR BUSHING	item145	30	SET	INR			0.00			0.00		0.000	·	
5.04	SERVICES- 400kV GIS: TESTING & COMMISSIONING OF GIS	item146	18	Bays	INR			0.00			0.00		0.000	0.000 INR Zero Only	

Price bid format (Un-priced)

Item Wise BoQ

Tender Inviting Authority: BHEL TBG NOIDA Name of Work: Powergrid's GIS pkg-II at KPS3

Enquiry/NIT No:

Name of the
Bidder/ Bidding
Firm / Company:

PRICE SCHEDULE

(This BOQ template must not be modified/replaced by the bidder and the same should be uploaded after filling the relevent columns, else the bidder is liable to be rejected for this tender. Bidders are allowed to enter the Bidder Name and Values only)

				(This BOQ t	emplate must not	t be modified/replaced by the bidder and the	same should be uplo	aded after filling th	e relevent columns, else the bidder is liabl	e to be rejected for th	is tender. Bidders ar	e allowed to enter the	Bidder Name and Values only)			
NUMBER #	TEXT#	TEXT #	NUMBER #	TEXT #	TEXT#	NUMBER#	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER#	NUMBER #	NUMBER #		TEXT #
SI. No.	Item Description	Item Code / Make	Quantity	Units	Quoted Currency in INR / Other Currency	Unit RATE In Figures To be entered by the Bidder in Rs. P	GST (in Percentage)	GST Amount (Unit Rate*Quantity* GST) Rs. P	Unit Freight & Insurance Charges in Rs. P	GST (in Percentage)	GST Amount on F&I (Unit Rate*Quantity*G ST) Rs. P	HSN / SAC Code	TOTAL Ex-Works + F & I AMOUNT excluding GST in Rs. P	TOTAL Ex-Works + F & I AMOUNT including GST in Rs. P	TOTAL AMOUNT In Words	
1	2	3	4	5	12	13	14	15	16	20	21	51	53	54		55
5.05	SERVICES- 400kV GIS : TESTING & COMMISSIONING OF GAS INSULATED BUS DUCT	item147	2500	MTR	INR			0.00			0.00		0.000	0.00	INR Zero Only	
5.06	SERVICES- 400kV GIS : TESTING & COMMISSIONING OF SF6 TO AIR BUSHING	item148	30	SET	INR			0.00			0.00		0.000		INR Zero Only	
5.07	SERVICES- 400kV GIS : FINAL SUCCESSFUL HV/ POWER FREQUENCY TESTING OF GIS INCLUDING ARRANGING OF HV TEST KIT ALONG WITH OPERATOR	item149	18	Bays	INR			0.00			0.00		0.000	0.00	00 INR Zero Only	
5.08	SERVICES- 400kV GIS : INSULATION CO- ORDINATION STUDIES FOR GIS SYSTEM	item150	1	LOT	INR			0.00			0.00		0.000		INR Zero Only	
5.09	SERVICES- 400kV GIS : TRAINING FOR GIS AT SITE	item151	2	DAY	INR			0.00			0.00		0.000	0.00	INR Zero Only	
5.10	SERVICES- 400kV GIS : TRAINING FOR GIS AT MANUFACTURER WORKS	item152	2	DAY	INR			0.00			0.00		0.000	0.00	INR Zero Only	
6.01	400kV GIS AC station at KPS-3 STATION (EXTN) SERVICES- GIS: 400kV, 63KA FOR IS, GAS INSULATED SWITCHGEAR (GIS) AS PER TS (Item SI. No. 6.01-6.10): SERVICES- 400kV GIS: SUPERVISION OF ERECTION OF GIS	item153	12	Bays	INR			0.00			0.00		0.000	0.00	10 INR Zero Only	
6.02	SERVICES- 400kV GIS: SUPERVISION OF ERECTION OF GAS INSULATED BUS DUCT	item154	3060	MTR	INR			0.00			0.00		0.000	0.00	INR Zero Only	
6.03	SERVICES- 400kV GIS: SUPERVISION OF ERECTION OF SF6 TO AIR BUSHING	item155	12	SET	INR			0.00			0.00		0.000	0.00	INR Zero Only	
6.04	SERVICES- 400kV GIS: TESTING & COMMISSIONING OF GIS	item156	12	Bays	INR			0.00			0.00		0.000	0.00	INR Zero Only	
6.05	SERVICES- 400kV GIS : TESTING & COMMISSIONING OF GAS INSULATED BUS DUCT	item157	3060	MTR	INR			0.00			0.00		0.000	0.00	INR Zero Only	
6.06	SERVICES- 400kV GIS : TESTING & COMMISSIONING OF SF6 TO AIR BUSHING	item158	12	SET	INR			0.00			0.00		0.000	0.00	INR Zero Only	
6.07	SERVICES- 400kV GIS : FINAL SUCCESSFUL HV/ POWER FREQUENCY TESTING OF GIS INCLUDING ARRANGING OF HV TEST KIT ALONG WITH OPERATOR	item159	12	Bays	INR			0.00			0.00		0.000	0.00	00 INR Zero Only	
6.08	SERVICES- 400kV GIS : INSULATION CO- ORDINATION STUDIES FOR GIS SYSTEM	item160	1	LOT	INR			0.00			0.00		0.000	0.00	100 INR Zero Only	
6.09	SERVICES- 400kV GIS : TRAINING FOR GIS AT SITE	item161	2	DAY	INR			0.00			0.00		0.000	0.00	00 INR Zero Only	
6.10	SERVICES- 400kV GIS : TRAINING FOR GIS AT MANUFACTURER WORKS	item162	2	DAY	INR			0.00			0.00		0.000	0.00	INR Zero Only	
7.01	400kV AC GIS Extension South Olpad SERVICES- GIS: 400KV, 63KA FOR IS, GAS INSULATED SWITCHGEAR (GIS) AS PER TS (Item sl. No. 7.01-7.10): SERVICES- 400kV GIS: SUPERVISION OF ERECTION OF GIS	item163	4	Bays	INR			0.00			0.00		0.000	0.00	00 INR Zero Only	
7.02	SERVICES- 400kV GIS: SUPERVISION OF ERECTION OF GAS INSULATED BUS DUCT	item164	600	MTR	INR			0.00			0.00		0.000	0.00	INR Zero Only	
7.03	SERVICES- 400kV GIS: SUPERVISION OF ERECTION OF SF6 TO AIR BUSHING	item165	6	SET	INR			0.00			0.00		0.000		INR Zero Only	
7.04	SERVICES- 400kV GIS: TESTING & COMMISSIONING OF GIS	item166	4	Bays	INR			0.00			0.00		0.000	0.00	INR Zero Only	

Item Wise BoQ

Tender Inviting Authority: BHEL TBG NOIDA

Name of Work: Powergrid's GIS pkg-II at KPS3

Enquiry/NIT No:

Name	of the
Bidder	/ Bidding
Firm /	Company:

IUMBER#	TEXT#	TEXT #	NUMBER#	TEXT#	TEXT #	NUMBER#	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER	NUMBER#	NUMBER#	NUMBER #		TEXT#
SI. No.	Item Description	Item Code / Make	Quantity	Units	Quoted Currency in INR / Other Currency	Unit RATE In Figures To be entered by the Bidder in Rs. P	GST (in Percentage)	GST Amount (Unit Rate*Quantity* GST) Rs. P	Unit Freight & Insurance Charges in Rs. P	GST (in Percentage)	GST Amount on F&I (Unit Rate*Quantity*G ST) Rs. P	HSN / SAC Code	TOTAL Ex-Works + F & I AMOUNT excluding GST in Rs. P	TOTAL Ex-Works + F & I AMOUNT including GST in Rs. P	TOTAL AMOUNT In Words	
1	2	3	4	5	12	13	14	15	16	20	21	51	53	54		55
7.05	SERVICES- 400kV GIS : TESTING & COMMISSIONING OF GAS INSULATED BUS DUCT	item167	600	MTR	INR			0.00			0.00		0.000	0.000	0 INR Zero Only	
7.06	SERVICES- 400kV GIS : TESTING & COMMISSIONING OF SF6 TO AIR BUSHING	item168	6	SET	INR			0.00			0.00		0.000	0.000	0 INR Zero Only	
7.07	SERVICES- 400kV GIS : FINAL SUCCESSFUL HV/ POWER FREQUENCY TESTING OF GIS INCLUDING ARRANGING OF HV TEST KIT ALONG WITH OPERATOR	item169	4	Bays	INR			0.00			0.00		0.000	0.000	0 INR Zero Only	
7.08	SERVICES- 400kV GIS: INSULATION CO- ORDINATION STUDIES FOR GIS SYSTEM	item170	1	LOT	INR			0.00			0.00		0.000	0.000	0 INR Zero Only	
7.09	SERVICES- 400kV GIS : TRAINING FOR GIS AT SITE	item171	2	DAY	INR			0.00			0.00		0.000	0.000	0 INR Zero Only	
7.10	SERVICES- 400kV GIS : TRAINING FOR GIS AT MANUFACTURER WORKS	item172	2	DAY	INR			0.00			0.00		0.000	0.000	0 INR Zero Only	
8.01	SERVICES- GIS: REFERENCE UNIT PRICE FOR ADDITION / DELETION OF SERVICES: (UNIT PRICES OF INDIVIDUAL SERVICES INCLUDED HERE ARE REQUIRED FOR ANY ADDITION/DELETION OF EQUIPMENT AND REPLACEMENT OF DAMAGED ITEMS. VENDOR TO ENSURE THAT THE UNIT PRICES HAVE A LOGICAL RELATIONSHIP WITH PRICES OF ASSEMBLIES IN MAIN ITEMS. QUOTING FOR UNIT PRICES IS MANDATORY AND SHALL BE CONSIDERED FOR EVALUATION) (Item sl. No. 8.01- 8.05): SERVICES- 400kV GIS: REF. UNIT PRICE OF GIS INDIVIDUAL ITEM/ EQUIPMENT - SERVICES FOR SUPERVISION OF ERECTION OF GIS	item173	10	MANDAY	INR			0.00			0.00		0.000	0.000	0 INR Zero Only	
8.02	SERVICES- 400kV GIS: REF. UNIT PRICE OF GIS INDIVIDUAL ITEM/ EQUIPMENT - SERVICES FOR TESTING & COMMISSIONING OF GIS	item174	10	MANDAY	INR			0.00			0.00		0.000	0.000	0 INR Zero Only	
	SERVICES- 400kV GIS: DEMOBILIZATION AND REMOBILIZATION CHARGES FOR GIS ERECTION SUPERVISION TEAM	item175	2	Set	INR			0.00			0.00		0.000	0.000	0 INR Zero Only	
	SERVICES- 400kV GIS: DEMOBILIZATION AND REMOBILIZATION CHARGES FOR GIS TESTING & COMMISSIONING TEAM	item176	2	Set	INR			0.00			0.00		0.000	0.000	0 INR Zero Only	
8.05	SERVICES- 400kV GIS: DEMOBILIZATION & REMOBILIZATION CHARGES OF HV TEST KIT ALONG WITH OPERATOR	item177	1	Lot	INR			0.00			0.00		0.000	0.000	0 INR Zero Only	
n Figures		0.000 0.000 Zero Only														

REV No: 0

DATE: 22.11.2024

SI. No.	Item Description	Unit	Qty.	Remarks
1. 400kV G	IS AC station at KPS3 (HVDC)			
1.1	SUPPLY- GIS: 400KV, 63KA FOR 1S, GAS INSULATED SWITCHGEAR (GIS) AS PER TS			
1.1.01	400KV, 3150A, 63KA, Single phase,SF6 Gas Insulated Bus Duct (GIB) outside GIS Hall alongwith associated	Mtr	2500	
1.1.02	support structure 420kV, 3150 A, 63 kA, SF6 GIS Converter feeder bay module as per Section-Project, Technical specification	SET	2	
1.1.03	420kV, 3150 A, 63 kA, SF6 GIS Tie bay module (of Converter Feeder) as per Section-Project, Technical	SET	2	
1.1.04	specification 420kV, 3150 A, 63 kA, SF6 GIS Line feeder bay module as per Section-Project, Technical specification	SET	4	
1.1.05	420kV, 3150 A, 63 kA, SF6 GIS Tie bay module as per Section-Project, Technical specification	SET	4	
1.1.06	420kV, 3150 A, 63 kA, SF6 GIS Reactor feeder bay module as per Section-Project, Technical specification	SET	2	
1.1.07	420kV, 3150 A, 63 kA, SF6 GIS Transformer feeder bay module as per Section-Project, Technical specification	SET	2	
1.1.08	420kV, 4000 A, 63 kA, SF6 GIS Bus sectionaliser module as per Section-Project, Technical specification	SET	2	
1.1.09	420kV, 4000 A, 63 kA, SF6 GIS Busbar module as per Section-Project, Technical specification	SET	4	
1.1.10	420kV GIS Interface Module for Future Extension of Bus Bar As per TS	SET	4	
1.1.11	420KV, 3150A, 63kA Single Phase SF6 to Air bushing connecting GIS to AIS alongwith support structure	EA	30	
1.1.12	Local Control Cubicle (LCC)	SET	18	INCLUDING POWER, CONTROL &
1.2	SUPPLY- GIS: SPECIAL TOOLS AND TESTING & MAINTENANCE INSTRUMENTS AS PER TS			INSTRUMENTATION CABLE AS APPLICABLE.
1.2.01	SF6 Gas Processing unit	Set	1	
1.2.02	Gas Analyzer [Dew Point Meter]	Set	1	
1.2.03	SF6 gas leak detector	Set	1	
1.3	SPARES- GIS: 400KV, 63KA FOR 1S, GAS INSULATED SWITCHGEAR (GIS) AS PER TS			
1.3.01	400KV GIS-SF6 GAS PRESSURE RELIEF DEVICE ASSEMBLY OF EACH TYPE with 'O' Rings	SET	1	1 SET= 1 Nos. of each type and rating
1.3.02	SF6 PRESSURE GAUGE CUM SWITCH /DENSITY MONITORS AND PRESSURESWITCH AS APPLICABLE, OF EACH TYPE-400KV GIS	SET	2	
1.3.03	COUPLING DEVICE FOR PRESSURE GAUGE CUM SWITCH FOR CONNECTINGGAS HANDLING PLANT OF EACH TYPE-400KV GIS	SET	2	
1.3.04	RUBBER GASKETS, 'O' RINGS AND SEALS FOR SF6 GAS FOR GISENCLOSURE OF EACH TYPE-400KV GIS	SET	3	
1.3.05	400KV GIS-MOLECULAR FILTER FOR SF6 GAS WITH FILTER BAGS (3 % OF TOTALWEIGHT)	SET	1	
1.3.06	CONTROL VALVES FOR SF6 GAS OF EACH TYPE-400KV GIS	SET	3	
1.3.07	400KV GIS-SF6 GAS (5 % OF TOTAL GAS QUANTITY)	LOT	1	1 LOT= 5 % OF TOTAL GAS QUANTITY
1.3.08	LOCKING DEVICE TO KEEP THE DIS-CONNECTORS (ISOLATORS)AND EARTHING/FAST EARTHING SWITCHES IN CLOSE OR OPEN POSITION IN CASEOF REMOVAL OF THE DRIVING MECHANISM-400KV GIS	SET	3	
1.3.09	UHF PD SENSORS OF EACH TYPE ALONG WITH BNC CONNECTOR FOR 420KV GIS	SET	5	1 SET= 1 Nos. of each type and rating
1.3.10	400KV GIS-SUPPORT INSULATORS (GAS THROUGH) OF EACH TYPE (COMPLETE WITHMETAL RING ETC.) ALONG WITH ASSOCIATED CONTACTS AND SHIELDS	SET	3	1 SET= 1 Nos. of each type and rating
1.3.11	400KV GIS-GAS BARRIERS OF EACH TYPE (COMPLETE WITH METAL RING ETC.)ALONG WITH ASSOCIATED CONTACTS AND SHIELDS	SET	3	1 SET= 1 Nos. of each type and rating
1.3.12	420KV, 3150A, 63kA Single phase SF6 to Air bushing of each type	SET	1	1 SET= 1 Nos. of each type and rating
1.3.13	LCC SPARES - AUX. RELAYS, CONTACTORS, PUSH BUTTONS, SWITCHES, LAMPS, ANNUNCIATION WINDOWS, MCB, FUSES, TIMERS, TERMINAL BLOCKS ETC. OF EACHTYPE & RATING-400kV GIS	SET	2	
1.3.14	400KV GIS-ONE POLE OF 3150A CIRCUIT BREAKER WITHOUT PIR WITHINTERRUPTER, MAIN CIRCUIT, ENCLOSURE AND OPERATING MECHANISM COMPLETEIN ALL RESPECT	SET	1	
1.3.15	400KV GIS-ONE POLE OF 4000A CIRCUIT BREAKER WITHOUT PIR WITHINTERRUPTER, MAIN CIRCUIT, ENCLOSURE AND OPERATING MECHANISM COMPLETEIN ALL RESPECT	SET	1	
1.3.16	Trip coil assembly with resistor for420kV GIS Circuit Breaker (asapplicable)	SET	3	
1.3.17	Closing coil assembly with resistor for420kV GIS Circuit Breaker (asapplicable)	SET	3	
1.3.18	Ferrules, Joints & Coupling of each type for CB	SET	1	

REV No: 0

DATE:

22.11.2024

SI. No.	Item Description	Unit	Qty.	Remarks
1.3.19	Window slope/ observing glass each type	SET	3	1 SET= 1 Nos. of each type and rating
1.3.20	RELAYS, POWER CONTACTORS, PUSH BUTTONS, TIMERS & MCBS ETC. (ASAPPLICABLE) OF EACH TYPE FOR 400KV GIS CIRCUIT BREAKER	SET	1	
1.3.21	Auxiliary switch assembly of each type for 420kV GIS Circuit Breaker	SET	3	
1.3.22	400KV GIS CIRCUIT BREAKER-OPERATION COUNTER Each Type	SET	3	
1.3.23	400KV GIS CIRCUIT BREAKER-HYDRAULIC OPERATING MECHANISM WITH DRIVEMOTOR (FOR HYDRAULIC OPERATED MECHANISM, IF APPLICABLE)	SET	1	
1.3.24	HYDRAULIC FILTER OF EACH TYPE (FOR HYDRAULIC OPERATED MECHANISM, IFPPLICABLE)-400KV GIS CIRCUIT BREKAER	SET	1	
1.3.25	400KV GIS CIRCUIT BREAKER- HOSE PIPE OF EACH TYPE (AS APPLICABLE) (FORHYDRAULIC OPERATED MECHANISM, IF APPLICABLE)	SET	1	
1.3.26	400KV GIS CIRCUIT BREAKER - N2 ACCUMULATOR (FOR HYDRAULIC OPERATEDMECHANISM, IF APPLICABLE)	SET	1	
1.3.27	VALVES OF EACH TYPE (FOR HYDRAULIC OPERATED MECHANISM, IFAPPLICABLE)-400KV GIS CIRCUIT BREKAER	SET	1	
1.3.28	PIPE LENGTH (COPPER & STEEL) OF EACH SIZE & TYPE (FOR HYDRAULICOPERATED MECHANISM, IF APPLICABLE)-400KV GIS CIRCUIT BREKAER	SET	1	
1.3.29	PRESSURE SWITCHES OF EACH TYPE (FOR HYDRAULIC OPERATED MECHANISM, IFAPPLICABLE)-400KV GIS CIRCUIT BREKAER	SET	1	
1.3.30	PRESSURE GAUGE WITH COUPLING DEVICE OF EACH TYPE (FOR HYDRAULICOPERATED MECHANISM, IF APPLICABLE)-400KV GIS CIRCUIT BREKAER	SET	1	
1.3.31	400KV GIS CIRCUIT BREAKER-HYDRAULIC OIL (5% OF TOTAL OIL QUANTITY)(FOR HYDRAULIC OPERATED MECHANISM, IF APPLICABLE)	SET	1	
1.3.32	PRESSURE RELIEF DEVICE OF EACH TYPE (FOR HYDRAULIC OPERATED MECHANISM,IF APPLICABLE)-400KV GIS CIRCUIT BREKAER	SET	1	
1.3.33	400KV GIS CIRCUIT BREAKER-COMPLETE SPRING OPERATING MECHANISMINCLUDING CHARGING MECHANISM ETC. (FOR SPRING OPERATED MECHANISM, IFAPPLICABLE) of each type	SET	1	
1.3.34	400kV GIS- Single phase of 3150Adisconnector switch including maincircuit, enclosure, driving mechanismand support insulator etc., complete inall respect (Note 1- The contractorshall supply spare for disconnectorswitch to ensure one to one replacementof all disconnector switch supplied asmain equipment without any requirementof modification in fittings at site tocover all different types ofdisconnector switch supplied. In case, quantity of supplied dis-connectorswitch types (for one to onereplacement) are more than the quantitymentioned in BPS for spare, thecontractor shall supply theseadditional types of disconnector switchwithout any additional priceimplication to POWERGRID and quantities of these additional type of disconnector switch are deem to beincluded in the quantities mentioned inBPS for spare disconnector. Note 2 - Incase, Dis-connector Switch (DS) & EarthSwitch (ES) is provided in a sameenclosure with common operatingmechanism, then the module comprisingof Disconnector & Earth switch insingle enclosure with common operatingmechanism is to be provided under thehead of spare Dis-connector Witch (DS) & Earth Switch (ES) is provided in asame enclosure with separate operatingmechanism, then the module comprisingof Dis-connector & Earth switch insingle enclosure with separateoperating mechanism is to be providedunder the head of spare Dis-connectoronly.)	SET	1	1 SET= 1 Nos. of each type and rating
1.3.35	400KV GIS- SINGLE PHASE MAINTENANCE EARTHING SWITCH INCLUDING MAINCIRCUIT, ENCLOSURE, DRIVING MECHANISM AND SUPPORT INSULATOR ETC., COMPLETE IN ALL RESPECT (NOTE 1 - IN CASE, DIS-CONNECTOR SWITCH (DS) & EARTH SWITCH (ES) IS PROVIDED IN A SAME ENCLOSURE WITH COMMONOPERATING MECHANISM, THEN THE MODULE COMPRISING OF DIS-CONNECTOR &EARTH SWITCH IN SINGLE ENCLOSURE WITH COMMON OPERATING MECHANISM IS TOBE PROVIDED UNDER THE HEAD OF SPARE DIS-CONNECTOR ONLY. NOTE 2 - INCASE, DIS-CONNECTOR SWITCH (DS) & EARTH SWITCH (ES) IS PROVIDED IN ASAME ENCLOSURE WITH SEPARATE OPERATING MECHANISM, THEN THE MODULECOMPRISING OF DIS-CONNECTOR & EARTH SWITCH IN SINGLE ENCLOSURE WITHSEPARATE OPERATING MECHANISM IS TO BE PROVIDED UNDER THE HEAD OF SPAREDIS-CONNECTOR ONLY.)	SET	1	1 SET= 1 Nos. of each type and rating
1.3.36	400KV GIS - SINGLE PHASE FAST EARTHING SWITCH INCLUDING MAIN CIRCUIT, ENCLOSURE, DRIVING MECHANISM AND SUPPORT INSULATOR ETC., COMPLETE INALL RESPECT (NOTE 1 - IN CASE, DISCONNECTOR SWITCH (DS) & EARTHSWITCH (ES) IS PROVIDED IN A SAME ENCLOSURE WITH COMMON OPERATINGMECHANISM, THEN THE MODULE COMPRISING OF DIS-CONNECTOR & EARTH SWITCHIN SINGLE ENCLOSURE WITH COMMON OPERATING MECHANISM IS TO BE PROVIDEDUNDER THE HEAD OF SPARE DIS-CONNECTOR ONLY, NOTE 2 - IN CASE, DIS-CONNECTOR SWITCH (DS) & EARTH SWITCH (ES) IS PROVIDED IN A SAMEENCLOSURE WITH SEPARATE OPERATING MECHANISM, THEN THE MODULECOMPRISING OF DIS-CONNECTOR & EARTH SWITCH IN SINGLE ENCLOSURE WITHSEPARATE OPERATING MECHANISM IS TO BE PROVIDED UNDER THE HEAD OF SPAREDIS-CONNECTOR ONLY.)	SET	1	1 SET= 1 Nos. of each type and rating
1.3.37	OPEN/CLOSE CONTACTOR ASSEMBLY, TIMERS, KEY INTERLOCK, INTERLOCKINGCOILS, RELAYS, PUSH BUTTONS, INDICATING LAMPS, POWER CONTACTORS, RESISTORS, FUSES, MCBS & DRIVE CONTROL CARDS ETC. (AS APPLICABLE) ONEOF EACH TYPE FOR ONE COMPLETE MOM BOX FOR 400KV GIS DISCONNECTORSWITCH	SET	1	
1.3.38	OPEN/CLOSE CONTACTOR ASSEMBLY, TIMERS, KEY INTERLOCK, INTERLOCKINGCOILS, RELAYS, PUSH BUTTONS, INDICATING LAMPS, POWER CONTACTORS, RESISTORS, FUSES, MCBS & DRIVE CONTROL CARDS ETC. (AS APPLICABLE) ONEOF EACH TYPE FOR ONE COMPLETE MOM BOX FOR 400KV GIS MAINTENANCE EARTHSWITCH	SET	1	

REV No: 0

DATE: 22.11.2024

SI. No.	Item Description	Unit	Qty.	Remarks
1.3.39	OPEN/CLOSE CONTACTOR ASSEMBLY, TIMERS, KEY INTERLOCK, INTERLOCKINGCOILS, RELAYS, PUSH BUTTONS, INDICATING LAMPS, POWER CONTACTORS, RESISTORS, FUSES, MCBS & DRIVE CONTROL CARDS ETC. (AS APPLICABLE) ONEOF EACH TYPE FOR ONE COMPLETE MOM BOX FOR 400KV GIS FAST EARTHINGSWITCH	1		
1.3.40	LIMIT SWITCHES AND AUX. SWITCHES FOR ONE COMPLETE MOM BOX FORDISCONNECTOR-400KV GIS	SET	2	
1.3.41	LIMIT SWITCHES AND AUX. SWITCHES FOR ONE COMPLETE MOM BOX FORMAINTENANCE EARTHING SWITCH-400KV GIS	SET	2	
1.3.42	LIMIT SWITCHES AND AUX. SWITCHES FOR ONE COMPLETE MOM BOX FOR FASTEARTHING SWITCH (IF APPLICABLE)-400KV GIS	SET	2	
1.3.43	DRIVE MECHANISM FOR 400KV GIS DISCONNECTOR SWITCH	SET	1	
1.3.44	DRIVE MECHANISM FOR 400KV GIS MAINTENANCE EARTH SWITCH	SET	1	
1.3.45	DRIVE MECHANISM FOR 400KV GIS FAST EARTHING SWITCH	SET	1	
1.3.46	MOTOR FOR DRIVE MECHANISM FOR 400KV GIS DISCONNECTOR SWITCH	SET	1	1 SET= 1 Nos. of each type and rating
1.3.47	MOTOR FOR DRIVE MECHANISM FOR 400KVGIS MAINTENANCE EARTH SWITCH	1	1 SET= 1 Nos. of each type and rating	
1.3.48	MOTOR FOR DRIVE MECHANISM FOR 400KV GIS FAST EARTHING SWITCH SET		1	1 SET= 1 Nos. of each type and rating
1.3.49	400KV GIS- SINGLE PHASE OF CURRENT TRANSFORMER (3 CORES, TYPE-CTA)WITH ASSOCIATED ENCLOSURE AND PRIMARY CONDUCTOR COMPLETE IN ALLRESPECT		1	1 SET= 1 Nos. of each type and rating
1.3.50	400KV GIS- SINGLE PHASE OF CURRENT TRANSFORMER (2 CORES, TYPE-CTB)WITH ASSOCIATED ENCLOSURE AND PRIMARY CONDUCTOR COMPLETE IN ALLRESPECT		1	1 SET= 1 Nos. of each type and rating
1.3.51	GIS SPARES: 400KV GIS- SINGLE PHASE VT WITH ASSOCIATED ENCLOSURE COMPLETE IN ALL RESPECT	SET	1	1 SET= 1 Nos. of each type and rating
1.3.52	GIS SPARES: 400KV GIS- SINGLE PHASE LA WITH ASSOCIATED ENCLOSURE COMPLETE IN ALL RESPECT	SET	1	1 SET= 1 Nos. of each type and rating
2. 400kV (GIS AC station at KPS-3 STATION (EXTN)			
2.1	SUPPLY- GIS: 400KV, 63KA FOR 1S, GAS INSULATED SWITCHGEAR (GIS) AS PER TS			
2.1.01	400KV, 3150A, 63KA, Single phase,SF6 Gas Insulated Bus Duct (GIB) outside GIS Hall alongwith associated support structure	Mtr	3000	
2.1.02	420kV, 3150 A, 63 kA, SF6 GIS Line feeder bay module as per Section-Project, Technical specification	SET	4	
2.1.03	420kV, 3150 A, 63 kA, SF6 GIS Tie bay module as per Section-Project, Technical specification	SET	4	
2.1.04	420kV, 4000 A, 63 kA, SF6 GIS Bus extension as per Section-Project, Technical specification		4	
2.1.05	400KV, 4000A, 63KA, Single phase,SF6 Gas Insulated Bus Duct (GIB) outside GIS Hall alongwith associated support structure	Mtr	60	
2.1.06	420kV GIS Interface Module for Future Extension of Bus Bar As per TS	SET	4	
2.1.07	420KV, 3150A, 63kA Single Phase SF6 to Air bushing connecting GIS to AIS alongwith support structure	SET	12	
2.1.08	Local Control Cubicle (LCC)	SET	8	INCLUDING POWER, CONTROL & INSTRUMENTATION CABLE AS APPLICABLE.

REV No: 0

DATE: 22.11.2024

SI. No.	Item Description	Unit	Qty.	Remarks		
3. 400kV A	C GIS Extension South Olpad					
3.1	SUPPLY- GIS: 400KV, 63KA FOR 1S, GAS INSULATED SWITCHGEAR (GIS) AS PER TS					
3.1.01	400KV, 3150A, 63KA, Single phase,SF6 Gas Insulated Bus Duct (GIB) outside GIS Hall alongwith associated	Mtr	600			
	support structure 420kV, 3150A, 63 kA, SF6 GIS Converter feeder bay module as per Section-Project, Technical specification					
3.1.02	420kV, 3150A, 63 kA, SF6 GIS Converter reeder bay module as per Section-Project, Technical specification 420kV, 3150A, 63 kA, SF6 GIS Tie bay module (of Converter Feeder) as per Section-Project, Technical	SET	2			
3.1.03	specification	SET	2			
3.1.04	420kV, 4000 A, 63 kA, SF6 GIS Bus extension as per Section-Project, Technical specification	SET	2			
3.1.05	420kV GIS Interface Module for Future Extension of Bus Bar As per TS	SET	2			
3.1.06	420KV, 3150A, 63kA Single Phase SF6 to Air bushing connecting GIS to AIS alongwith associated support structure	SET	6			
3.1.07	Local Control Cubicle (LCC)	SET	4	INCLUDING POWER, CONTROL & INSTRUMENTATION CABLE AS APPLICABLE.		
3.2	SUPPLY- GIS: SPECIAL TOOLS AND TESTING & MAINTENANCE INSTRUMENTS AS PER TS					
3.2.01	SF6 Gas Processing unit	Set	1			
3.2.02	Gas Analyzer [Dew Point Meter]	Set	1			
3.2.03	SF6 gas leak detector	Set	1			
3.3	SPARES- GIS: 400KV, 63KA FOR 1S, GAS INSULATED SWITCHGEAR (GIS) AS PER TS					
3.3.01	400KV GIS-SF6 GAS PRESSURE RELIEF DEVICE ASSEMBLY OF EACH TYPE with 'O' Rings	SET	1	1 SET= 1 Nos. of each type and rating		
3.3.02	SF6 PRESSURE GAUGE CUM SWITCH /DENSITY MONITORS AND PRESSURESWITCH AS	SET	2	TOET - TWOS. OF CAUTTYPE and Taking		
3.3.03	APPLICABLE, OF EACH TYPE-400KV GIS COUPLING DEVICE FOR PRESSURE GAUGE CUM SWITCH FOR CONNECTINGGAS HANDLING	SET	2			
3.3.00	PLANT OF EACH TYPE-400KV GIS	OL1				
3.3.04	RUBBER GASKETS, 'O' RINGS AND SEALS FOR SF6 GAS FOR GISENCLOSURE OF EACH TYPE-400KV GIS	SET	3			
3.3.05	400KV GIS-MOLECULAR FILTER FOR SF6 GAS WITH FILTER BAGS (3 % OF TOTALWEIGHT)	SET	1			
3.3.06	CONTROL VALVES FOR SF6 GAS OF EACH TYPE-400KV GIS	SET	3			
3.3.07	400KV GIS-SF6 GAS (5 % OF TOTAL GAS QUANTITY)	LOT	1	1 LOT= 5 % OF TOTAL GAS QUANTITY		
3.3.08	LOCKING DEVICE TO KEEP THE DIS-CONNECTORS (ISOLATORS)AND EARTHING/FAST EARTHING SWITCHES IN CLOSE OR OPEN POSITION IN CASEOF REMOVAL OF THE DRIVING MECHANISM-400KV GIS	SET	3			
3.3.09	UHF PD SENSORS OF EACH TYPE ALONG WITH BNC CONNECTOR FOR 420KV GIS	SET	5	1 SET= 1 Nos. of each type and rating		
3.3.10	400KV GIS-SUPPORT INSULATORS (GAS THROUGH) OF EACH TYPE (COMPLETE WITHMETAL RING ETC.) ALONG WITH ASSOCIATED CONTACTS AND SHIELDS	SET	3	1 SET= 1 Nos. of each type and rating		
3.3.11	400KV GIS-GAS BARRIERS OF EACH TYPE (COMPLETE WITH METAL RING ETC.)ALONG WITH ASSOCIATED CONTACTS AND SHIELDS	SET	3	1 SET= 1 Nos. of each type and rating		
3.3.12	420KV, 3150A, 63kA Single phase SF6 to Air bushing of each type	SET	1	1 SET= 1 Nos. of each type and rating		
3.3.13	LCC SPARES - AUX. RELAYS, CONTACTORS, PUSH BUTTONS, SWITCHES, LAMPS, ANNUNCIATION WINDOWS, MCB, FUSES, TIMERS, TERMINAL BLOCKS ETC. OF EACHTYPE & RATING-400kV GIS	SET	2			
3.3.14	400KV GIS-ONE POLE OF 3150A CIRCUIT BREAKER WITHOUT PIR WITHINTERRUPTER, MAIN CIRCUIT, ENCLOSURE AND OPERATING MECHANISM COMPLETEIN ALL RESPECT	SET	1			
3.3.15	400KV GIS-ONE POLE OF 4000A CIRCUIT BREAKER WITHOUT PIR WITHINTERRUPTER, MAIN CIRCUIT, ENCLOSURE AND OPERATING MECHANISM COMPLETEIN ALL RESPECT	SET	1			
3.3.16	Trip coil assembly with resistor for420kV GIS Circuit Breaker (asapplicable)	SET	3			
3.3.17	Closing coil assembly with resistor for420kV GIS Circuit Breaker (asapplicable)	SET	3			
3.3.18	Ferrules, Joints & Coupling of each type for CB	SET	1			
3.3.19	Window slope/ observing glass each type	SET	3	1 SET= 1 Nos. of each type and rating		
3.3.20	RELAYS, POWER CONTACTORS, PUSH BUTTONS, TIMERS & MCBS ETC. (ASAPPLICABLE) OF EACH TYPE FOR 400KV GIS CIRCUIT BREAKER	SET	1			
3.3.21	Auxiliary switch assembly of each type for 420kV GIS Circuit Breaker	SET	3			
3.3.22	400KV GIS CIRCUIT BREAKER-OPERATION COUNTER Each Type	SET	3			
3.3.23	400KV GIS CIRCUIT BREAKER-HYDRAULIC OPERATING MECHANISM WITH DRIVEMOTOR (FOR HYDRAULIC OPERATED MECHANISM, IF APPLICABLE)	SET	1			

REV No: 0

DATE:

22.11.2024

SI. No.	Item Description	Unit	Qty.	Remarks
3.3.24	HYDRAULIC FILTER OF EACH TYPE (FOR HYDRAULIC OPERATED MECHANISM, IFPPLICABLE)-400KV GIS CIRCUIT BREKAER	SET	1	
3.3.25	400KV GIS CIRCUIT BREAKER- HOSE PIPE OF EACH TYPE (AS APPLICABLE) (FORHYDRAULIC OPERATED MECHANISM, IF APPLICABLE)	SET	1	
3.3.26	400KV GIS CIRCUIT BREAKER - N2 ACCUMULATOR (FOR HYDRAULIC OPERATEDMECHANISM, IF APPLICABLE)	SET	1	
3.3.27	VALVES OF EACH TYPE (FOR HYDRAULIC OPERATED MECHANISM, IFAPPLICABLE)-400KV GIS CIRCUIT BREKAER	SET	1	
3.3.28	PIPE LENGTH (COPPER & STEEL) OF EACH SIZE & TYPE (FOR HYDRAULICOPERATED MECHANISM, IF APPLICABLE)-400KV GIS CIRCUIT BREKAER	SET	1	
3.3.29	PRESSURE SWITCHES OF EACH TYPE (FOR HYDRAULIC OPERATED MECHANISM, IFAPPLICABLE)-400KV GIS CIRCUIT BREKAER	SET	1	
3.3.30	PRESSURE GAUGE WITH COUPLING DEVICE OF EACH TYPE (FOR HYDRAULICOPERATED MECHANISM, IF APPLICABLE)-400KV GIS CIRCUIT BREKAER	SET	1	
3.3.31	400KV GIS CIRCUIT BREAKER-HYDRAULIC OIL (5% OF TOTAL OIL QUANTITY)(FOR HYDRAULIC OPERATED MECHANISM, IF APPLICABLE)	SET	1	
3.3.32	PRESSURE RELIEF DEVICE OF EACH TYPE (FOR HYDRAULIC OPERATED MECHANISM,IF APPLICABLE)-400KV GIS CIRCUIT BREKAER	SET	1	
3.3.33	400KV GIS CIRCUIT BREAKER-COMPLETE SPRING OPERATING MECHANISMINCLUDING CHARGING MECHANISM ETC. (FOR SPRING OPERATED MECHANISM, IFAPPLICABLE) of each type	SET	1	
3.3.34	400kV GIS- Single phase of 3150Adisconnector switch including maincircuit, enclosure, driving mechanismand support insulator etc., complete inall respect (Note 1- The contractorshall supply spare for disconnectorswitch to ensure one to one replacement of all disconnector switch supplied asmain equipment without any requirement of modification in fittings at site tocover all different types of disconnector switch supplied. In case, quantity of supplied dis-connectorswitch types (for one to onereplacement) are more than the quantitymentioned in BPS for spare, the contractor shall supply these additional types of disconnector switchwithout any additional priceimplication to POWERGRID and quantities of these additional type of disconnector switch are deem to beincluded in the quantities mentioned in BPS for spare disconnector. Note 2 - Incase, Dis-connector Switch (DS) & EarthSwitch (ES) is provided in a sameenclosure with common operatingmechanism, then the module comprising Disconnector & Earth switch insingle enclosure with common operatingmechanism is to be provided under thehead of spare Dis-connector only. Note3- In case, Dis-connector Switch (DS)&Earth Switch (ES) is provided in asame enclosure with separate operatingmechanism, then the module comprising Dis-connector & Earth switch insingle enclosure with separateoperating mechanism is to be providedunder the head of spare Dis-connectoronly.)	SET	1	1 SET= 1 Nos. of each type and rating
3.3.35	400KV GIS- SINGLE PHASE MAINTENANCE EARTHING SWITCH INCLUDING MAINCIRCUIT, ENCLOSURE, DRIVING MECHANISM AND SUPPORT INSULATOR ETC., COMPLETE IN ALL RESPECT (NOTE 1 - IN CASE, DIS-CONNECTOR SWITCH (DS) & EARTH SWITCH (ES) IS PROVIDED IN A SAME ENCLOSURE WITH COMMONOPERATING MECHANISM, THEN THE MODULE COMPRISING OF DIS-CONNECTOR &EARTH SWITCH IN SINGLE ENCLOSURE WITH COMMON OPERATING MECHANISM IS TOBE PROVIDED UNDER THE HEAD OF SPARE DIS-CONNECTOR ONLY. NOTE 2 - INCASE, DIS-CONNECTOR SWITCH (DS) & EARTH SWITCH (ES) IS PROVIDED IN ASAME ENCLOSURE WITH SEPARATE OPERATING MECHANISM, THEN THE MODULECOMPRISING OF DIS-CONNECTOR & EARTH SWITCH IN SINGLE ENCLOSURE WITHSEPARATE OPERATING MECHANISM IS TO BE PROVIDED UNDER THE HEAD OF SPAREDIS-CONNECTOR ONLY.)	SET	1	1 SET= 1 Nos. of each type and rating
3.3.36	400KV GIS - SINGLE PHASE FAST EARTHING SWITCH INCLUDING MAIN CIRCUIT, ENCLOSURE, DRIVING MECHANISM AND SUPPORT INSULATOR ETC., COMPLETE INALL RESPECT (NOTE 1 - IN CASE, DISCONNECTOR SWITCH (DS) & EARTHSWITCH (ES) IS PROVIDED IN A SAME ENCLOSURE WITH COMMON OPERATINGMECHANISM, THEN THE MODULE COMPRISING OF DIS-CONNECTOR & EARTH SWITCHIN SINGLE ENCLOSURE WITH COMMON OPERATING MECHANISM IS TO BE PROVIDEDUNDER THE HEAD OF SPARE DIS-CONNECTOR ONLY. NOTE 2 - IN CASE, DIS-CONNECTOR SWITCH (DS) & EARTH SWITCH (ES) IS PROVIDED IN A SAMEENCLOSURE WITH SEPARATE OPERATING MECHANISM, THEN THE MODULECOMPRISING OF DIS-CONNECTOR & EARTH SWITCH IN SINGLE ENCLOSURE WITHSEPARATE OPERATING MECHANISM IS TO BE PROVIDED UNDER THE HEAD OF SPAREDIS-CONNECTOR ONLY.)	SET	1	1 SET= 1 Nos. of each type and rating
3.3.37	OPEN/CLOSE CONTACTOR ASSEMBLY, TIMERS, KEY INTERLOCK, INTERLOCKINGCOILS, RELAYS, PUSH BUTTONS, INDICATING LAMPS, POWER CONTACTORS, RESISTORS, FUSES, MCBS & DRIVE CONTROL CARDS ETC. (AS APPLICABLE) ONEOF EACH TYPE FOR ONE COMPLETE MOM BOX FOR 400KV GIS DISCONNECTORSWITCH	SET	1	
3.3.38	OPEN/CLOSE CONTACTOR ASSEMBLY, TIMERS, KEY INTERLOCK, INTERLOCKINGCOILS, RELAYS, PUSH BUTTONS, INDICATING LAMPS, POWER CONTACTORS, RESISTORS, FUSES, MCBS & DRIVE CONTROL CARDS ETC. (AS APPLICABLE) ONEOF EACH TYPE FOR ONE COMPLETE MOM BOX FOR 400KV GIS MAINTENANCE EARTHSWITCH	SET	1	

REV No: 0

DATE: 22.11.2024

SI. No.	Item Description	Unit	Qty.	Remarks
3.3.39	OPEN/CLOSE CONTACTOR ASSEMBLY, TIMERS, KEY INTERLOCK, INTERLOCKINGCOILS, RELAYS, PUSH BUTTONS, INDICATING LAMPS, POWER CONTACTORS, RESISTORS, FUSES, MCBS & DRIVE CONTROL CARDS ETC. (AS APPLICABLE) ONEOF EACH TYPE FOR ONE COMPLETE MOM BOX FOR 400KV GIS FAST EARTHINGSWITCH		1	
3.3.40	LIMIT SWITCHES AND AUX. SWITCHES FOR ONE COMPLETE MOM BOX FORDISCONNECTOR-400KV GIS	SET	2	
3.3.41	LIMIT SWITCHES AND AUX. SWITCHES FOR ONE COMPLETE MOM BOX FORMAINTENANCE EARTHING SWITCH-400KV GIS	SET	2	
3.3.42	LIMIT SWITCHES AND AUX. SWITCHES FOR ONE COMPLETE MOM BOX FOR FASTEARTHING SWITCH (IF APPLICABLE)-400KV GIS	SET	2	
3.3.43	T)		1	
3.3.44	DRIVE MECHANISM FOR 400KV GIS MAINTENANCE EARTH SWITCH	SET	1	
3.3.45	DRIVE MECHANISM FOR 400KV GIS FAST EARTHING SWITCH	SET	1	
3.3.46	MOTOR FOR DRIVE MECHANISM FOR 400KV GIS DISCONNECTOR SWITCH		1	1 SET= 1 Nos. of each type and rating
3.3.47	MOTOR FOR DRIVE MECHANISM FOR 400KVGIS MAINTENANCE EARTH SWITCH	SET	1	1 SET= 1 Nos. of each type and rating
3.3.48	MOTOR FOR DRIVE MECHANISM FOR 400KV GIS FAST EARTHING SWITCH	SET	1	1 SET= 1 Nos. of each type and rating
3.3.49	400KV GIS- SINGLE PHASE OF CURRENT TRANSFORMER (3 CORES, TYPE-CTA)WITH ASSOCIATED ENCLOSURE AND PRIMARY CONDUCTOR COMPLETE IN ALLRESPECT	SET	1	1 SET= 1 Nos. of each type and rating
3.3.50	400KV GIS- SINGLE PHASE OF CURRENT TRANSFORMER (2 CORES, TYPE-CTB)WITH ASSOCIATED ENCLOSURE AND PRIMARY CONDUCTOR COMPLETE IN ALLRESPECT	SET	1	1 SET= 1 Nos. of each type and rating
3.3.51	GIS SPARES: 400KV GIS- SINGLE PHASE VT WITH ASSOCIATED ENCLOSURE COMPLETE IN ALL RESPECT	SET	1	1 SET= 1 Nos. of each type and rating
3.3.52	GIS SPARES: 400KV GIS- SINGLE PHASE LA WITH ASSOCIATED ENCLOSURE COMPLETE IN ALL RESPECT	SET	1	1 SET= 1 Nos. of each type and rating

4	SPARES- GIS: REFERENCE UNIT PRICE FOR ADDITION / DELETION OF SUPPLY ITEMS (Unit Prices of Individual Equipment included here or in manadatory spares are required for any Addition/Deletion of Equipment and replacement of damaged items. Bidder to ensure that the unit prices have a logical relationship with prices of assemblies in main items. Quoting for unit prices is mandatory and shall be considered for evaluation)			
4.01	SPARES: 400KV GIS- GIS METALLIC ENCLOSURE	KG	50	
4.02	SPARES: 400KV GIS- EXPANSION BELLOWS/ JOINTS	SET	1	1 SET= For Single Phase of any type and any rating.
4.03	SPARES: 400KV GIS- TEE BEND	SET	1	1 SET= For Single Phase of any type and any rating.
4.04	SPARES: 400KV GIS- L BEND	SET	1	1 SET= For Single Phase of any type and any rating.
4.05	SPARES: Controlled Switching Device for 420 kV, 3-ph Circuit Breaker	SET	1	1 SET= For Single Phase of any type and any rating.

SI. No.	Description	Unit	Quantity	Remarks
400kV	GIS AC station at KPS3 (HVDC)			
5	SERVICES- GIS: 400KV, 63KA FOR IS, GAS INSULATED			
	SWITCHGEAR (GIS) AS PER TS			
5.01	SERVICES- 400kV GIS: SUPERVISION OF ERECTION OF GIS	Bays	18	Supervision of erection of GIS with main bus, complete as per TS in all respect including LCC and its accessories. It also includes verification of materials for proper storage at site for final storage. Earthing, SF6 Gas Filling works, Internal Cabling from GIS to LCC, including Structure Works are covered under this item. GIS Bus Duct & SF6 to Air Bushing (SAB) are not covered in this BOQ item.
5.02	SERVICES- 400kV GIS: SUPERVISION OF ERECTION OF GAS INSULATED BUS DUCT	MTR	2500	Supervision of erection of GIB complete as per TS in all respect. GIB outside the GIS Hall wall shall be considered for mode of measurement. Earthing, SF6 Gas Fiiling works, Internal Cabling from GIS to LCC, including Structure Works are covered under this item. Inner side GIB / Aux Bus Module etc are to be considered as part of respective GIS Assembly and cost of the same shall be deemed inclusive.
5.03	SERVICES- 400kV GIS: SUPERVISION OF ERECTION OF SF6 TO AIR BUSHING	SET	30	Earthing, SF6 Gas Filling works, Internal Cabling from GIS to LCC, including Structure Works are covered under this item.
5.04	SERVICES- 400kV GIS: TESTING & COMMISSIONING OF GIS	Bays	18	Testing and commissioning of complete GIS system including main bus, LCC and associated system is to be executed by bidder. All the special testing instruments, kits, T&P etc. are to be arranged by bidder on returnable basis. Please refer relevant section of technical specification for details.
5.05	SERVICES- 400kV GIS : TESTING & COMMISSIONING OF GAS INSULATED BUS DUCT	MTR	2500	GIB outside the GIS Hall wall shall be considered for mode of measurement. Inner side GIB / Aux Bus Module e.t.c. are to be considered as part of respective GIS Assembly and cost of the same shall be deemed inclusive. All the special testing instruments, kits, T&P etc. are to be arranged by bidder on returnable basis. Please refer relevant section of technical specification for details.
5.06	SERVICES- 400kV GIS: TESTING & COMMISSIONING OF SF6 TO AIR BUSHING	SET	30	
5.07	SERVICES- 400kV GIS : FINAL SUCCESSFUL HV/ POWER FREQUENCY TESTING OF GIS INCLUDING ARRANGING OF HV TEST KIT ALONG WITH OPERATOR	Bays	18	Carrying out successful HV/ Power Frequency Testing of GIS as per IEC including Arrangement of HV Test kit with operator (on returnable basis) shall be in scope of bidder, which includes charges of HV test kit with operator, accessories & tools required for completion of HV testing. The quoted price shall include GIS bays including Main Bus, GIB & SAB and other common items as per TS complete in all respect.
5.08	SERVICES- 400kV GIS: INSULATION CO-ORDINATION STUDIES	LOT	1	In this BOQ item, mobilization and demobilization for HV test kit is considered for 1 Lot means Complete study report as per technical specification, Including VFTO
5.09 5.1	FOR GIS SYSTEM SERVICES- 400kV GIS : TRAINING FOR GIS AT SITE SERVICES- 400kV GIS : TRAINING FOR GIS AT MANUFACTURER	DAY DAY	2 2	report.
400kV	GIS AC station at KPS-3 STATION (EXTN	J)		
6	SERVICES- GIS : 400KV, 63KA FOR IS, GAS INSULATED SWITCHGEAR (GIS) AS PER TS	1)		
6.01	SERVICES- 400kV GIS: SUPERVISION OF ERECTION OF GIS	Bays	12	Supervision of erection of GIS with main bus, complete as per TS in all respect including LCC and its accessories. It also includes verification of materials for proper storage at site for final storage. Earthing, SF6 Gas Filling works, Internal Cabling from GIS to LCC, including Structure Works are covered under this item. GIS Bus Duct & SF6 to Air Bushing (SAB) are not covered in this BOQ item.
6.02	SERVICES- 400kV GIS: SUPERVISION OF ERECTION OF GAS INSULATED BUS DUCT	MTR	3060	Supervision of erection of GIB complete as per TS in all respect. GIB outside the GIS Hall wall shall be considered for mode of measurement. Earthing, SF6 Gas Filling works, Internal Cabling from GIS to LCC, including Structure Works are covered under this item. Inner side GIB / Aux Bus Module etc are to be considered as part of respective GIS Assembly and cost of the same shall be deemed inclusive.
6.03	SERVICES- 400kV GIS: SUPERVISION OF ERECTION OF SF6 TO AIR BUSHING	SET	12	Earthing, SF6 Gas Filling works, Internal Cabling from GIS to LCC, including Structure Works are covered under this item.
6.04	SERVICES- 400kV GIS: TESTING & COMMISSIONING OF GIS	Bays	12	Testing and commissioning of complete GIS system including main bus, LCC and associated system is to be executed by bidder. All the special testing instruments, kits, T&P etc. are to be arranged by bidder on returnable basis. Please refer relevant section of technical specification for details.
6.05	SERVICES- 400kV GIS : TESTING & COMMISSIONING OF GAS INSULATED BUS DUCT	MTR	3060	GIB outside the GIS Hall wall shall be considered for mode of measurement. Inner side GIB / Aux Bus Module e.t.c. are to be considered as part of respective GIS Assembly and cost of the same shall be deemed inclusive. All the special testing instruments, kits, T&P etc. are to be arranged by bidder on returnable basis. Please refer relevant section of technical specification for details.
6.06	SERVICES- 400kV GIS: TESTING & COMMISSIONING OF SF6 TO AIR BUSHING	SET	12	,
6.07	SERVICES- 400kV GIS: FINAL SUCCESSFUL HV/ POWER FREQUENCY TESTING OF GIS INCLUDING ARRANGING OF HV TEST KIT ALONG WITH OPERATOR	Bays	12	Carrying out successful HV/ Power Frequency Testing of GIS as per IEC including Arrangement of HV Test kit with operator (on returnable basis) shall be in scope of bidder, which includes charges of HV test kit with operator, accessories & tools required for completion of HV testing. The quoted price shall include GIS bays including Main Bus, GIB & SAB and other common items as per TS complete in all respect. In this BOQ item, mobilization and demobilization for HV test kit is considered for
6.08	SERVICES- 400kV GIS: INSULATION CO-ORDINATION STUDIES FOR GIS. SYSTEM	LOT	1	1 Lot means Complete study report as per technical specification, Including VFTO
6.09	SERVICES- 400kV GIS: TRAINING FOR GIS AT SITE	DAY DAY	2 2	renort
6.1	SERVICES- 400kV GIS : TRAINING FOR GIS AT MANUFACTURER WORKS	DAY		

SI. No.	Description	Unit	Quantity	Remarks
400kV	AC GIS Extension South Olpad			
7	SERVICES- GIS: 400KV, 63KA FOR IS, GAS INSULATED SWITCHGEAR (GIS) AS PER TS			
7.01	SERVICES- 400kV GIS: SUPERVISION OF ERECTION OF GIS	Bays	4	Supervision of erection of GIS with main bus, complete as per TS in all respect including LCC and its accessories. It also includes verification of materials for proper storage at site for final storage. Earthing, SF6 Gas Fiiling works, Internal Cabling from GIS to LCC, including Structure Works are covered under this item. GIS Bus Duct & SF6 to Air Bushing (SAB) are not covered in this BOQ item.
7.02	SERVICES- 400kV GIS: SUPERVISION OF ERECTION OF GAS INSULATED BUS DUCT	MTR	600	Supervision of erection of GIB complete as per TS in all respect. GIB outside the GIS Hall wall shall be considered for mode of measurement. Earthing, SF6 Gas Fiiling works, Internal Cabling from GIS to LCC, including Structure Works are covered under this item. Inner side GIB / Aux Bus Module etc are to be considered as part of respective GIS Assembly and cost of the same shall be deemed inclusive.
7.03	SERVICES- 400kV GIS: SUPERVISION OF ERECTION OF SF6 TO AIR BUSHING	SET	6	Earthing, SF6 Gas Fiiling works, Internal Cabling from GIS to LCC, including Structure Works are covered under this item.
7.04	SERVICES- 400kV GIS: TESTING & COMMISSIONING OF GIS	Bays	4	Testing and commissioning of complete GIS system including main bus, LCC and associated system is to be executed by bidder. All the special testing instruments, kits, T&P etc. are to be arranged by bidder on returnable basis. Please refer relevant section of technical specification for details.
7.05	SERVICES- 400kV GIS : TESTING & COMMISSIONING OF GAS INSULATED BUS DUCT	MTR	600	GIB outside the GIS Hall wall shall be considered for mode of measurement. Inner side GIB / Aux Bus Module e.t.c. are to be considered as part of respective GIS Assembly and cost of the same shall be deemed inclusive. All the special testing instruments, kits, T&P etc. are to be arranged by bidder on returnable basis. Please refer relevant section of technical specification for details.
7.06	SERVICES- 400kV GIS: TESTING & COMMISSIONING OF SF6 TO AIR BUSHING	SET	6	
7.07	SERVICES- 400kV GIS: FINAL SUCCESSFUL HV/ POWER FREQUENCY TESTING OF GIS INCLUDING ARRANGING OF HV TEST KIT ALONG WITH OPERATOR	Bays	4	Carrying out successful HV/ Power Frequency Testing of GIS as per IEC including Arrangement of HV Test kit with operator (on returnable basis) shall be in scope of bidder, which includes charges of HV test kit with operator, accessories & tools required for completion of HV testing. The quoted price shall include GIS bays including Main Bus, GIB & SAB and other common items as per TS complete in all respect. In this BOQ item, mobilization and demobilization for HV test kit is considered for
7.08	SERVICES- 400kV GIS: INSULATION CO-ORDINATION STUDIES FOR GIS SYSTEM	LOT	1	1 Lot means Complete study report as per technical specification, Including VFTO
7.09	SERVICES- 400kV GIS: TRAINING FOR GIS AT SITE	DAY	2	TECHNII.
7.1	SERVICES- 400kV GIS : TRAINING FOR GIS AT MANUFACTURER WORKS	DAY	2	
8	SERVICES- GIS: REFERENCE UNIT PRICE FOR ADDITION / DELETION OF SERVICES: (UNIT PRICES OF INDIVIDUAL SERVICES INCLUDED HERE ARE REQUIRED FOR ANY ADDITION/DELETION OF EQUIPMENT AND REPLACEMENT OF DAMAGED ITEMS. VENDOR TO ENSURE THAT THE UNIT PRICES HAVE A LOGICAL RELATIONSHIP WITH PRICES OF ASSEMBLIES IN MAIN ITEMS. QUOTING FOR UNIT PRICES IS MANDATORY AND SHALL BE CONSIDERED FOR EVALUATION)			
8.01	SERVICES- 400kV GIS: REF. UNIT PRICE OF GIS INDIVIDUAL ITEM/ EQUIPMENT - SERVICES FOR SUPERVISION OF ERECTION OF GIS	MANDAY	10	Charges for repetition of services - (if required due to reasons not attributed to the bidder) This item will be executed only if repetition of services is required by BHEL.
8.02	SERVICES- 400kV GIS: REF. UNIT PRICE OF GIS INDIVIDUAL ITEM/ EQUIPMENT - SERVICES FOR TESTING & COMMISSIONING OF GIS	MANDAY	10	Charges for repetition of services - (if required due to reasons not attributed to the bidder) This item will be executed only if repetition of services is required by BHEL.
0.22	DEMOBILIZATION AND REMOBILIZATION CHARGES	0 :	_	THE POOLITEM OLDER OF EVENUTED IT DESCRIPTION TO THE POOLITE OF TH
8.03	SERVICES- 400kV GIS: DEMOBILIZATION AND REMOBILIZATION CHARGES FOR GIS ERECTION SUPERVISION TEAM	Set	2	THIS BOQ ITEM SHALL BE EXECUTED IF REQUIRED FOR REASONS NOT ATTRIBUTABLE TO BIDDER.
8.04	SERVICES- 400kV GIS: DEMOBILIZATION AND REMOBILIZATION CHARGES FOR GIS TESTING & COMMISSIONING TEAM	Set	2	BOQ ITEM SHALL BE PAYABLE IF REQUIRED FOR REASONS NOT ATTRIBUTE TO BIDDER. HV TESTING IS NOT PART OF THIS ITEM.
8.05	SERVICES- 400kV GIS: DEMOBILIZATION & REMOBILIZATION CHARGES OF HV TEST KIT ALONG WITH OPERATOR	Lot	1	In this BOQ item, mobilization and demobilization chages for HV test kit is considered for second time or more, for reasons not attributable to bidder. HV testing charges shall be paid per bay basis as per main HV testing charge.

BHARAT HEAVY ELECTRICALS LTD. (TRANSMISSION BUSINESS GROUP)

GENERAL TERMS AND CONDITIONS FOR TENDER ENQUIRY / CONTRACT

This is to be submitted duly signed by bidder in original (NOT REQUIRED FOR ENQUIRY THROUGH E-PROCURMENT MODE). Clause-wise deviations and / or additional conditions / clarifications, if any, are to be brought out clearly in "Schedule of Commercial Deviation". Deviations and / or additional conditions / clarifications, if any, mentioned elsewhere in the bid / offer, shall not be considered.

Sr. No.							
1.	INST	RUCTION TO BIDDERS :					
	1.1	Sealed bids are invited for the items mentioned in the tender enquiry conforming to the NIT including Technical Specifications. Bids should be typed and free from overwriting and erasures. Corrections or additions / deletions, if any, must be clearly written and attested, otherwise offer may be rejected.					
	1.2	Bidder must ensure that their bid is submitted / dropped in the tender box on or before 14-00 Hrs. IST on the due date of opening, unless otherwise specified in the NIT, at the address as follows:-					
		Tender Box, Materials Management, Transmission Business Group, Bharat Heavy Electricals Limited, 5 th Floor, Tower-A, Advant Navis IT Business Park, Plot-7, Sector-142, Noida Expressway, Noida, Dist. G. B. Nagar, U. P. – 201305					
	1.3	In case tender enquiry is floated though the e-procurement system, offer / bid has to be submitted through the e-procurement system ONLY as per instructions given in the e-procurement portal (https://bhel.abcprocure.com/EPROC/).					
	1.4	The bids shall be opened at 14-30 Hrs. IST on the due date of opening, in the presence of participating bidders who may like to be present, unless otherwise specified in the NIT. Bids received late are liable for rejection. Bidders sending bids by courier or post will have to ensure that it is timely delivered at the above address.					
	1.5	Bids are to be submitted duly signed with seal in two parts :-					
		a) Techno-commercial Bid (Part-I) – To be submitted in 2 sets (original + copy). A copy of Price Bid (Part-II) clearly mentioning all the necessary information as per format without prices "Un-Priced Bid" is also to be enclosed in Part-I Bid.					
		b) Price Bid (Part-II) – To be submitted only in one set in a separate sealed envelope. This should not contain any Technical and / or Commercial Terms and Conditions. The rates should be quoted both in figures and words.					

Sr. No. The Part-I and Part-II Bids are to be sealed in separate envelopes and marked as "Techno-commercial Bid (Part-I)" and "Price Bid (Part-II)" respectively. Both the envelopes are to be kept in another common envelope and marked as "BID". Each envelope should be sealed and superscribed with tender enquiry no., item / package name, project name and due date of opening. Bidder's name and address shall also be mentioned on each envelope. For any technical clarification, please contact official mentioned in the tender enquiry / NIT. 1.8 For any commercial clarification please contact official issuing tender enquiry / NIT. Price bid (Part-II) should not contain any additional information / description other than given in "Un-Priced Bid" submitted with "Techno-commercial Bid (Part-I)" except prices, otherwise bid is liable for rejection. 1.10 Price Bid submitted along with the bid shall remain valid up to validity of offer. Any discount / revised offer submitted by the bidder on its own shall be accepted provided it is received before the due date and time of offer submission (i.e. Part-I Bid). The discount shall be applied on pro-rata basis to all items including optional items, if any, unless specified otherwise by the bidder. Discount offered shall be valid for full duration of validity of the offer including extension of validity, if any. Unsolicited Supplementary / Revised Price Bid submitted after the due date and time of offer submission (i.e. Part-I Bid), during validity period of offer, unless asked by BHEL, shall not be considered. Withdrawal of quotation by the bidder, at any stage after its opening, may entail suitable action against such bidder by BHEL. 1.11 The consultants / firm (and any of its affiliates) shall not be eligible to participate against tender enquiry for the related goods or works or services for the same project, if they were engaged by BHEL-TBG for the consultancy services. 1.12 In case any Foreign OEM / Foreign Principal insists on engaging the services of an agent, such agent shall not be allowed to represent more than one manufacturer / supplier in the same tender. Moreover, either the agent could bid on behalf of the manufacturer / supplier or the manufacturer / supplier could bid directly but not both. In case bids are received from the manufacturer / supplier and the agent, bid received from the agent shall be ignored. 1.13 Non-conformities / errors / discrepancies in quoted prices in price bids shall be dealt as follows :-If, in the price structure quoted for the required goods / services / works, there is discrepancy between the unit price and the total price (which is obtained by multiplying the unit price by the quantity), the unit price shall prevail and the total price corrected accordingly, unless in the opinion of BHEL there is an obvious misplacement of the decimal point in the unit price, in which case the total price as quoted shall govern and the unit price corrected accordingly. If there is an error in a total corresponding to the addition or subtraction

	1		
Sr. No.			
			of subtotals, the subtotals shall prevail and the total shall be corrected.
		c)	If there is a discrepancy between words and figures, the amount in words shall prevail, unless the amount expressed in words is related to an arithmetic error, in which case the amount in figures shall prevail subject to (a) and (b) above.
		d)	If there is such discrepancy in an offer as mentioned in (a), (b) & (c) above, the same shall be conveyed to the bidder with target date upto which the bidder has to send his acceptance on the above lines and if the bidder does not agree to the decision of the BHEL, the bid is liable to be ignored.
	1.14	enqu / ma Supp Portic ment Term Com appli Term Howe	ase the scope of the successful bidder / supplier against this tender hiry includes Erection, Testing and Commissioning (ETC) of the equipment terial at site in addition to Supply, Purchase Order shall be placed for by Portion and Contract shall be separately awarded for ETC at Site on. General Terms and Conditions for Tender Enquiry / Contract sioned herein shall be applicable for both Supply & ETC at Site. Additional has and Conditions for Tender Enquiry / Contract for Erection, Testing and missioning at Site "BHEL/TBG/GTC-ETC/2016 REV01" shall be cable for ETC at Site only which is to be read in conjunction with General has and Conditions for Tender Enquiry / Contract mentioned herein. Ever, any breach of either the Purchase Order or the Contract shall be need to be breach of the other.
	1.15	spec Price	es and Duties payable extra as per Clause No. 2.3 in NIT, if not ified/quoted clearly as extra shall be considered as included in Ex-works and therefore shall not be reimbursed. Taxes and duties not payable as per NIT shall be deemed to be included in Ex-works Price.
	1.16	servi of ter the	e rates for taxes and duties in respect of the quoted materials and / or ces assumed by the Supplier are less than the tariff prevailing at the time indering, Supplier will be responsible for such under quotations. However if rates assumed are higher than the correct rates prevailing at the time ering, the difference will be to the credit of BHEL.
	produ	esenta uce au	ative / official deputed by the bidder to witness tender opening must uthorization letter for the same.
2.	PRIC	ES:	
	е	nhand	specifically indicated in the NIT, all prices shall be FIRM. No cement of rate for whatsoever reasons unless and until asked by BHEL e allowed.
	2.2 U	nless	specifically indicated in the NIT, the prices shall be on INR basis.
			specifically indicated in the NIT, the prices are to be quoted on FOR (Site nation) basis excluding GST. The break-up of prices shall be as under :-
	a) E	x-wor	ks Price: Ex-works price including packing & forwarding charges.

Sr. No. b) Freight: Freight for door delivery up to destination / site / store are to be quoted separately. c) Insurance: Insurance for door delivery up to destination / site / store are to be quoted separately. d) Type Test Charges: If asked in the technical specification, it is to be quoted separately for each test. e) Charges for Supervision of Erection, Testing & Commissioning (ETC) at Site: To be quoted separately if specified in NIT/Price Schedule. f) Charges for Testing & Commissioning at Site: To be quoted separately if specified in NIT/Price Schedule. g) Charges for Erection, Testing & Commissioning at Site: To be quoted separately if specified in NIT/Price Schedule. h) Training Charges: To be quoted separately if specified in NIT/Price Schedule. 2.4 **GST rates** along with HSN/SAC code as applicable on Sr No (a) to (h) above is to be mentioned separately in percentage in both un-priced bid and price bid. i) Unless otherwise specified in the NIT, the purchase order shall be placed on Exworks basis for Indian bidders. ii) Prices quoted by Indian bidders shall be in Indian Rupees only. iii) In case Supervision of Erection, Testing & Commissioning (ETC) at Site or Testing & Commissioning at Site or Erection, Testing & Commissioning at Site is also in scope of the bidder along with supply, bidder has to ensure that prices quoted for such services also are in line with special terms & conditions of the NIT, if any. iv) Unless otherwise specified in the NIT, Unloading at Site / Destination shall not be in the scope of the supplier. v) Prices in respect of Sr No (a) to Sr No (h) of Clause 2.3 above are to be quoted inclusive of all taxes & Duties, charges. Levies, royalty etc. if any, excluding GST. 3. TERMS OF PAYMENT: 3.1 For Supply only in scope of the supplier 100% of payment within 60 days from the date of receipt of complete invoice along with documents in 3 sets (original + 2 copies) as follows: LR / GR duly endorsed by BHEL Site Official. Material Receipt Certificate issued by BHEL Site Official. **GST Compliant Tax Invoice** Packing List (Case-wise)

- · Copy of Transit Insurance Certificate from underwriters.
- Material Inspection Clearance Certificate (MICC) issued by BHEL Quality Management
- Guarantee Certificate
- Copy of Performance Bank Guarantee (PBG)
- · Certificate of acceptance of Type Test Reports issued by BHEL Engineering

Sr.	
No.	Management wherever specifically mentioned in the Purchase Order.
	3.2 For Supply where Supervision of Erection, Testing & Commissioning (ETC) at Site is in scope of the supplier or Supply where Testing & Commissioning at Site is in scope of the supplier
	 a) 95% of payment within 60 days from the date of receipt of complete invoice along with documents in 3 sets (original + 2 copies) as follows: LR / GR duly endorsed by BHEL Site Official. Material Receipt Certificate issued by BHEL Site Official. GST Compliant Tax Invoice Packing List (Case-wise) Copy of Transit Insurance Certificate from underwriters. Material Inspection Clearance Certificate (MICC) issued by BHEL Quality Management Guarantee Certificate Copy of Performance Bank Guarantee (PBG) Certificate of acceptance of Type Test Reports issued by BHEL Engineering
	Management wherever specifically mentioned in the Purchase Order.
	 b) 5% of payment within 60 days from the date of receipt of complete invoice along with documents in 3 sets (original + 2 copies) as follows: Certificate of successful completion of Supervision of Erection, Testing & Commissioning at Site if it is in the scope of the supplier or Certificate of successful completion of Testing & Commissioning at Site if it is in the scope of the supplier.
	 Certificate of completion of final documentation as per Purchase Order / Technical Specification issued by BHEL Engineering Management
	3.3 For Supply where Erection, Testing & Commissioning (ETC) at Site is in scope of the supplier
	a) 90% of payment within 60 days from the date of receipt of complete invoice along with documents in 3 sets (original + 2 copies) as follows:
	 LR / GR duly endorsed by BHEL Site Official. Material Receipt Certificate issued by BHEL Site Official. GST Compliant Tax Invoice Packing List (Case-wise) Copy of Transit Insurance Certificate from underwriters. Material Inspection Clearance Certificate (MICC) issued by BHEL Quality Management Guarantee Certificate
	 Copy of Performance Bank Guarantee (PBG) Certificate of acceptance of Type Test Reports issued by BHEL Engineering Management wherever specifically mentioned in the Purchase Order
	 b) 10% of payment within 60 days from the date of receipt of complete invoice along with documents in 3 sets (original + 2 copies) as follows: Certificate of successful completion of Erection, Testing & Commissioning at Site issued by BHEL Site Official / Construction Management Certificate of completion of final documentation as per Purchase Order /
	Technical Specification issued by BHEL Engineering Management
	3.4 For Type Test Charges

100% payment along with applicable GST within 60 days from the date of receipt of complete GST compliant Tax invoice along with copy of Certificate of acceptance of Type Test Reports issued by BHEL Engineering Management in 3 sets (original + 2 copies) on completion of delivery (at site, if F&I is in scope of supplier) of main supplies (excluding spares) for which Type Tests are applicable. List of main supplies (excluding spares) for which Type Tests are applicable shall be certified by BHEL Engineering Management.

3.5 For Charges for Supervision of Erection, Testing & Commissioning at Site

100% payment along with applicable GST within 60 days from the date of receipt of complete GST compliant Tax invoice along with certificate of successful completion of Supervision of Erection, Testing & Commissioning at Site issued by BHEL Site Official / Construction Management in 3 sets (Original + 2 copies).

3.6 For Charges for Testing & Commissioning at Site

100% payment along with applicable GST within 60 days from the date of receipt of complete GST compliant Tax invoice along with certificate of successful completion of Testing & Commissioning at Site issued by BHEL Site Official / Construction Management in 3 sets (Original + 2 copies).

3.7 For Training Charges

100% payment along with applicable GST within 60 days from the date of receipt of complete GST compliant Tax invoice along with certificate of completion of training issued by BHEL Engineering Management in 3 sets (original + 2 copies).

Note:

- i) Supplier has to submit invoice(s) as per PO or approved billing break-up of prices (if applicable as per NIT).
- ii) In case of supplies for overseas project, Material Receipt Certificate issued by BHEL Authorized Representative shall also be acceptable.
- iii) In case of Transit Insurance under Open Insurance Policy, Intimation / Declaration of Transit Insurance as per terms of the relevant Open Insurance Policy along with copy of Open Insurance Policy from underwriters shall also be acceptable.
- iv) Supplier has to ensure commencement of transit insurance from the date not later than LR / GR date.
- v) Supplier has to submit Tax Invoice(s). Supplier should ensure that Tax Invoice should comply all statutory requirements under GST Law to enable BHEL to avail input credit
- vi) MSMED Act, 2006 and the rules made thereunder as amended from time to time shall be applicable for release of payment to suppliers qualified & registered as Micro & Small Enterprises based on documents mentioned in the NIT for MSME.

Sr. No. vii) Supplier has to submit PBG (as per BHEL format) & Guarantee Certificate as per PO terms. viii) In case any shortages and / or damages in supplies, an amount calculated based on comments against Material Receipt Certificate issued by the BHEL Site Official shall be withheld from the supply payment against 3.1(a) or 3.2(a) above to be deemed fit by BHEL subject to a minimum of 10% of the total exworks value of the invoice corresponding to the LR / GR against which any shortages and / or damages are reported. The withheld amount shall be released after the shortages and / or damages in supplies are supplied / replenished against Certification by BHEL Site Official. ix) Payment of GST component shall be made only if vendor has deposited the Tax and credit for the same is reflected in GSTN (GST Network). In case credit of the same is not reflected in GSTN, vendor may alternatively furnish BG of GST Amount for a period valid for not less than 1 month .In case of disallowance of credit /non reflection of credit in GSTN, amount will be recovered from supplier along with applicable Interest, penalty etc from any of his dues. x) If GST is payable by BHEL on reverse Charge Mechanism basis, vendor should ensure the submission of GST compliant Tax invoice immediately on dispatch/ performance of service. In case of non-compliance any additional charges towards interest, penalty etc, will be to vendors account. xi) TDS under GST Act, if applicable, shall be deducted unless Exemption Certificate If applicable, from the appropriate authority is furnished to BHEL along with Invoice. 4. **INTEREST LIABILITY:** In case of any delay in payment due to any reason, BHEL shall not pay any interest on delayed payment. Also, no interest shall be payable by BHEL on the bank guarantee / deposit amount or balance payment or any other money which may become due owing to difference or misunderstanding or any dispute before any quasi judicial authority between BHEL and the Supplier / Contractor. 5. **GUARANTEE:** The equipment / material supplied and services rendered (if applicable) shall be guaranteed to be free from all defects and faults in design & engineering, material, workmanship & manufacture and in full conformity with the Purchase Order / Contract, Technical Specifications & approved drawings / data sheets, if any, for 18 months from the date of last delivery or 12 months from commissioning, whichever is earlier. Wherever Erection, Testing & Commissioning at Site are also in the scope of the Supplier, the guarantee period shall be 18 months from the date of last delivery or 12 months from the date of commissioning, whichever is later. The defective equipment / material / component shall be replaced free of cost at site. Freight & Insurance during transit shall also be in the scope of the supplier / contractor. Any expenditure for dismantling and re-erection of the replaced

equipment / material / component shall be to supplier's / contractor's account. All replacements during the guarantee period shall be delivered at site promptly and satisfactorily within a period not more than 45 days from the date of reporting the

defect / rejection etc.

In the event of the supplier / contractor failing to replace the defective equipment / material / component within the time period mentioned above, BHEL may proceed to undertake the replacement of such defective equipment / material / component at the risk and cost of the supplier / contractor without prejudice to any other rights under the contract and recover the same from PBG / other dues of this Purchase Order / Contract or any other Purchase Order / Contract executed by the supplier / contractor.

Note:

- i) In case of Illumination System, items viz. Lamps, Tubes, Ballast, Starters, Capacitors & Fuses will not be under Guarantee after commissioning.
- ii) In addition to the above guarantee period, Extended Guarantee / Warranty, if any, shall be as per NIT / Technical Specifications.
- iii) In case offer of agent of Foreign OEM / Foreign Principal is considered, as per Clause No. 1.12 above, Guarantee as mentioned above has to be provided by the Foreign OEM / Foreign Principal also.

6. LATENT DEFECT:

Liability for latent defects shall be for defects inherently lying within material or arising out of design deficiency which does not manifest itself during guarantee period but later and shall be limited to five years from the expiry of the guarantee period.

7. PERFORMANCE BANK GUARANTEE (PBG):

Supplier shall arrange to submit Performance BG / deposit on a non-judicial stamp paper of appropriate value along with first invoice or within 60 days from placement of Purchase Order (PO) whichever is earlier, in line with one of the applicable options as follows:-

Option "A"

A single rolling PBG for Rs. 50 Lakhs initially valid for 18 months with claim period of 3 months extra over and above 18 months for all the Purchase Orders being executed for Transmission Business Group, BHEL. However, validity of the PBG shall be extended till 18 months from the date of last delivery with 3 months claim period extra over and above 18 months.

Single Rolling PBG option shall not be applicable in case Ex-works value of the PO at the time of placement of PO exceeds Rs. One Crore.

Option "B"

PBG for 10% of the total Ex-works PO value, valid for 18 months from the date of last delivery with claim period of 3 months extra over and above 18 months. Ex-works PO value at the time of placement of PO shall be considered for calculation of the PBG amount.

Option "C"

In case the total Ex-works PO value at the time of placement of PO does not exceed Rs. Ten Lakhs, interest free Deposit of 10% of the total Ex-works PO value at the time of placement of PO in form of Demand Draft favouring "Bharat Heavy Electricals Limited" and payable at New Delhi / Delhi / Noida shall also be acceptable to BHEL in lieu of PBG, which shall be released after expiry of 21 months from the date of last delivery after deduction, if any, within 60 days from receipt of invoice in 3 sets (original + 2 copies) to be submitted by the supplier.

Note:

i) The Bank Guarantee shall be from any bank as per Annexure for List of Banks (32 Nos.). The original PBG should be sent by issuing Bank directly to AGM (Finance), TBG, BHEL, Noida.

- ii) Extension of validity of the PBG in original, as per above clause, should be sent by issuing Bank directly to AGM (Finance), TBG, BHEL, Noida at least 45 days before expiry of validity of the PBG.
- iii) Unless otherwise specified in the NIT, deviation taken for non-submission of PBG / Deposit, as applicable, shall not be accepted.
- iv) Supplier has to confirm one of the applicable options for submission of PBG / Deposit before placement of PO.
- v) In case of non–submission PBG / Deposit, as applicable, BHEL reserve the right for Risk Purchase as per terms of the NIT and impose Suspension of Business Dealings with the Supplier / Contractor.
- vi) BHEL reserve the right to encash the Bank Guarantee and forfeit the amount in the event of any default, failure or neglect on part of the Supplier in fulfilment of performance of the Purchase Order.
- vii) Value of the Bank Guarantee (at the time of submission) shall remain unchanged for any subsequent variations in Purchase Order value up to ± 20%. Beyond this variation of ± 20%, the Supplier shall arrange to enhance or may reduce the value of the Bank Guarantee accordingly for the total variation promptly.
- viii)Vendor to ensure submission of Certificate of Final Documentation /Confirmation regarding Non applicability of Final Documentation, as the case may be, as referred in clause No 9 regarding Final Documentation. BG shall be released only after submission of the same to BHEL TBMM.

8. SUBMISSION OF DRAWINGS / DOCUMENTS FOR APPROVAL :

Supplier shall submit the master document list within 7 days from date of Purchase Order / Contract, unless otherwise specified in the NIT, with planned dates for submission which shall be in line with activity schedule as per Purchase Order / Contract and shall be finalized with BHEL Engineering Management. Date of first submission of drawings / documents shall be certified by BHEL Engineering Management after the receipt of applicable drawings / documents (e.g. project specific cover sheet, GTP, OGA drawings, schemes, type test reports etc.) by BHEL. During detailed engineering stage, necessary hard copies of the engineering drawings / documents shall also be submitted by the supplier as per the Purchase Order / Contract requirement. The supplier shall also submit the packing drawings as per technical specifications.

In case item(s) offered require any interface details of other item (not in the scope of supplier & required for operating the equipment), the supplier has to submit interfaces schedule along with submission of engineering drawings / documents. It shall be responsibility of the supplier to get the details of the interfaced item from BHEL before manufacturing to avoid any mismatch at site.

9. FINAL DOCUMENTATION:

Final documentation as called in the Technical /contract specification is to be submitted within 3 months from the date of first delivery of respective equipment, item/material. After submission of Final Documentation, BHEL Engineering Management (TBEM) will issue a Certificate of Completion of Final Documentation. Wherever Final Documentation is not applicable, BHEL Engineering Management (TBEM) will issue confirmation regarding the same, Vendor to submit the Certificate of Final Documentation /Confirmation regarding Non applicability of Final Documentation, as the case may be, to BHEL TBMM. In case of Non Submission of Certificate of Final Documentation /Confirmation regarding Non applicability of Final Documentation, BG will be liable for encashment.

10. INSPECTION:

BHEL / customer / third party shall inspect equipment / material before despatch. Stage inspection during manufacturing may also be carried out. Material to be despatched only after getting Material Despatch Clearance Certificate (MDCC) / MICC issued by BHEL.

Supplier shall send inspection call on prescribed format / web site only, with an advance notice of 15 days.

Supplier to ensure submission of all routine / acceptance test reports, inspection reports and all other documents related to inspection, immediately to BHEL.

BHEL representative is authorised to carry out audits along with Third Party Inspection Agency at vendor's / supplier's works before clearing the items for despatch.

11. DESPATCH DOCUMENTS:

Despatch documents to be immediately sent to BHEL on despatch are as follows :-

- Copy of Invoice
- Copy of LR / GR in case of Indian suppliers or BL / AWB in case of foreign suppliers
- Copy of Packing List (Case-wise)
- Copy of Transit Insurance Certificate from underwriters
- Copy of Guarantee Certificate

12. DELIVERY PERIOD:

Delivery / Completion requirement shall be mentioned in the NIT. Bidder to specify best delivery / completion period possible in weeks from the date of LOI / PO as per activity schedule for consideration by BHEL. Time required for type test, if applicable, is to be separately indicated.

Note:

LR / GR date or invoice date (whichever is later) for indigenous supplies and BL / AWB date for FOB / CIF (if applicable) contracts shall be considered as delivery date.

13. LIQUIDATED DAMAGES FOR DELAYED DELIVERY:

In case of delay in execution of Purchase Order beyond the contractual delivery time, an amount of 0.5% of the total Purchase Order value for supply (excluding. taxes and duties as applicable) per week of delay or part thereof subject to a maximum of 10% of the total Purchase Order value for supply (excluding taxes and duties as applicable) shall be deducted as Liquidated Damages (LD).

However, in case of staggered (lot-wise) contractual delivery schedule, an amount of 0.5% of the total Purchase Order value for supply (excluding. taxes and duties as applicable) per week of delay or part thereof subject to a maximum of 10% of the total Purchase Order value for supply (excluding taxes and duties as applicable) shall be deducted as Liquidated Damages (LD).

Note

- i) In case of any amendment / revision in P.O./WO, the LD shall be linked to the amended / revised Purchase Order / Contract value and delivery / completion time / schedule, if applicable.
- ii) LR / GR date or invoice date (whichever is later) for indigenous supplies and BL / AWB date for FOB / CIF (if applicable) for imported supplies shall be treated as the date of dispatch for levying LD as above.
- iii) However, for indigenous supply, if time period between date of receipt of material at site / destination by Site Official & the date of LR / GR or invoice (whichever is later) is more than 30 days, where distance from place of despatch as per LR / GR is upto 1000 Kms or if time period between date of receipt of material at site / destination by Site Official & the date of LR / GR or invoice (whichever is later) is more than 45 days, where distance from place of despatch as per LR / GR is

Sr. No. more than 1000 Kms, such excess period shall also be considered for LD purpose. iv) If, as per supplier, delay is not attributable to the supplier, delay analysis with documentary evidence may be submitted by the supplier at the earliest but not later than six months from the end of the financial year in which the payment is withheld. Based on the above details / documents submitted by the supplier, BHEL shall take final decision and if considered appropriate by BHEL, withheld amount (full or part as the case may be) shall be released, otherwise, full or balance withheld amount shall be treated as deduction of Liquidated Damages (LD) towards delayed delivery. 14. **VALIDITY OF OFFER:** The offer shall be valid for 180 days from the due date of opening of tender (i.e. techno-commercial bid unless otherwise specified in the NIT). Prices of Spares, wherever they optional items, shall be valid till two years from the date of placement of PO. **ACCEPTANCE / REJECTION OF TENDER:** 15. BHEL reserve the right to reject in full or part, any or all tender without assigning any reason thereof. BHEL also reserve right to vary the quantities as mentioned in the NIT. Acceptance of offer is subject to vendor approval by customer before opening of price bid. BHEL shall not be bound by any power of attorney granted by tenderer or by changes in composition of the firm made subsequent to award of order / contract. BHEL may however recognize such power of attorney and changes after obtaining proper legal advice, cost of which will be chargeable to the seller / contractor concerned. If the tenderer deliberately gives wrong information, BHEL reserves the right to reject such an offer at any stage or cancel the order / contract, if awarded, and forfeit the security deposit and bank guarantee. 16. **DEVIATION:** The bids having deviation(s) w.r.t. tender are liable for rejection. However, BHEL, at its discretion, may load the prices for evaluation of offer with prior intimation to bidder. 17. TENDER EVALUATION: Comparative statement shall be prepared and evaluated on total cost basis at destination/site (as per terms of NIT) considering overall quantity indicated in NIT unless contrary to same is specifically mentioned in the tender enquiry / NIT. Total cost for this purpose shall include cost of scope of work as mentioned in NIT along with applicable taxes & duties, and other services etc. (if applicable). GST input credit available to BHEL shall be reduced from prices while determining L1 status. In case all bidders are foreign & Port of Import (destination port) is same for all the bidders, evaluation of offers shall be done on CIF (Port of Import) basis. Otherwise, evaluation of offers shall be done on the basis of delivered cost at site /destination to BHEL. Further, in case of foreign bidders, marine freight & insurance are to be quoted separately & the purchase order may be placed on FOB basis with an option for delivery on CIF / CFR basis, if required, later. In case of foreign bidders, Exchange Rate (TT selling rate of State Bank of India) as on date of tender opening (Part-I Bid in case of two part bid) shall be considered. If the relevant day happens to be a bank holiday, then the forex rate as on the previous bank (SBI) working day shall be taken for tender evaluation. 18. **LOADING CRITERIA:** List of permissible deviations & loading criteria thereof are as follows :a) Payment Terms Base rate of SBI (as applicable on the date of bid opening / techno-commercial

Sr. No. bid opening in case of two part bids) + 6% shall be considered for loading for the period of relaxation sought by bidder(s) against terms of payment in the NIT. b) Liquidated Damages (LD) for Delayed Delivery Loading on LD clause shall be to the extent to which it is not agreed to by the bidder (at offered value). c) In case of foreign bidders, if the quoted prices is on CIF basis only, it shall be loaded to arrive at total FOR (Site / Destination) price, as applicable, by factors as follows :i) Port handling / clearing charges: @ 1% of CIF value to arrive at Customs Assessable Value. ii) Custom Duty (including CVD & SAD) as per NIT prevailing on date of price bid opening. iii) Inland Freight & Transit Insurance: @ 5% of CIF value where distance between site / destination and Port of Discharge is upto 1000 Kms or @ 7% of CIF value where distance between site / destination and Port of Discharge is more than 1000 Kms. Note: Additional deviations (if considered acceptable by BHEL) & the loading criteria shall be communicated to all the qualified bidders before price bid opening. 19. **ARBITRATION:** In the event of any dispute emanating from and relating to this contract, the matter shall be referred to the sole arbitration of the person appointed by the competent authority of BHEL. Subject to aforesaid, the provisions of "The Arbitration and Conciliation Act, 1996" and the rules made thereunder as amended from time to time in India shall apply to the arbitration proceedings. The venue of arbitration shall be in New Delhi. Further there shall be no claim for any pre-reference or pendente-lite interest on the claims and any claim for such interest made shall be void. However, in case of contract with Public Sector Enterprise / Undertaking (PSE/PSU) or Govt. Dept., the extant guidelines of Govt. of India shall be followed. 20. **LEGAL SETTLEMENT:** Indian Courts at New Delhi / Delhi shall have exclusive jurisdiction to decide the dispute, if any, arising out of or in respect of the contract(s) to which these conditions are applicable. Contract, including all matters connected with contract, shall be governed by the Indian Law, both substantive and procedural, for the time being in force including modification thereto. 21. **SUB-CONTRACTING:** In case further subcontracting of BHEL Purchase Order / Contract or part thereof is envisaged by supplier, the same can be done after written permission is obtained from BHEL. However it shall not absolve the Supplier / Contractor of the responsibility of fulfilling BHEL Purchase Order / Contract requirements. In case of subcontracting of Purchase Order / Contract awarded by BHEL or part thereof without such permission, BHEL reserve the right to cancel the Purchase Order / Contract and source such material / component / equipment / system from any other agency at the risk and cost of the Supplier / Contractor.

If Supplier / Contractor is an individual or proprietary concern and the individual or the proprietor dies or the partnership is dissolved or substantially affected, then unless BHEL is satisfied that legal representative of individual Supplier / Contractor or proprietor of proprietary concern and surviving partners of partnership firm are capable of carrying out and completing the Purchase Order / Contract, BHEL shall be entitled to cancel the Purchase Order / Contract as to its incomplete portion and

without being in any way liable to payment of any compensation to legal representative of Supplier / Contractor and / or to surviving partners of Supplier's / Contractor's firm on account of cancellation of the Purchase Order / Contract. Decision of BHEL that legal representatives of deceased Supplier / Contractor or surviving partners of the Supplier's / Contractor's firm cannot carry out and complete the Purchase Order / Contract shall be final and binding on the parties hereto.

Terms and Conditions shall not get affected in case of de-merger / amalgamation / taking-over / re-constitution etc.

22. RISK PURCHASE:

In case the Supplier / Contractor fails to supply or fails to comply with terms & conditions of the Purchase Order / Contract or delivers equipment / material not of the contracted quality or fails to adhere to the contract specifications or fails to perform as per the activity schedule and there are sufficient reasons even before expiry of the delivery / completion period to justify that supplies shall be inordinately delayed beyond contractual delivery / completion period, BHEL reserve the right to cancel the Purchase Order / Contract either in whole or in part thereof without compensation to Supplier / Contractor and if BHEL so desires, may procure such equipment / material / items not delivered or others of similar description where equipment / material / items exactly complying with particulars are not readily procurable in the opinion of BHEL which is final and in such manner as deemed appropriate, at the risk and cost of the Supplier / Contractor and the Supplier / Contractor shall be liable to BHEL for any excess cost to BHEL. However, the Supplier / Contractor shall continue execution of the Purchase Order / Contract to the extent not cancelled under the provisions of this clause.

Recovery amount on account of purchases made by BHEL at the risk and cost of Supplier / Contractor shall be the difference of total value of new Purchase Order (PO) value and total value of old Purchase Order for applicable items, where the total value of new PO is more than total value of old PO for applicable items, plus additional 15% of the total ex-works value of new PO as overheads.

The Supplier / Contractor shall on no account be entitled to any gain on such risk & cost purchase. In case the purchase order (PO) value of the new PO is less than the PO value of the old PO, 15% of the total ex-works value of the new PO shall be recovered as overheads and the difference between the PO value of the old PO and the new PO shall not be considered for calculation of the recovery amount.

23. ADJUSTMENT OF RECOVERY:

Any amount payable by the Supplier / Contractor under any of the condition of this contract shall be liable to be adjusted against any amount payable to the Supplier / Contractor under any other Purchase Order / Contract awarded to him by any BHEL unit. This is without prejudice to any other action, as may be deemed fit, by BHEL.

24. FORCE MAJEURE CONDITION:

If by reason of war, civil commotion, act of god, Government restrictions, strike, lockout which are not in control of Supplier / Contractor the deliveries / services are delayed, Supplier / Contractor shall not be held responsible.

If at any time during the continuance of the Purchase Order / Contract, the performance in whole or in part by either party of any obligations under the Purchase Order / Contract is prevented or delayed by reason of any war hostilities, acts of the public enemy, restrictions by Govt. of India, civil commotion, sabotage, fires, floods, explosion, epidemics, quarantine restrictions, strike, lock-outs or acts of God (hereinafter referred to as "event"), which are not in control of Supplier / Contractor or BHEL, then provided notice of the happening of such event is given by either party to the other within fifteen (15) days from the date of occurrence thereof, neither

Sr. No. party shall by reason of such event be entitled to terminate the Purchase Order / Contract nor shall have any claim for damages against each other in respect of such non-performance and delay in performance. Performance under the Purchase Order / Contract shall be resumed immediately after such event has come to an end or ceased to exist and decision of BHEL as to whether the deliveries have to be resumed or not shall be final, conclusive and binding on the parties hereto. In the event of the parties hereto not able to agree that a force majeure event has occurred, the parties shall submit the disputes for resolution pursuant to the provisions hereunder, provided that the burden of proof as to whether a force majeure event has occurred shall be upon the party claiming such an event. Notwithstanding above provisions, BHEL shall reserve the right to cancel the Purchase Order / Contract, wholly or partly, in order to meet the overall project schedule and make alternative arrangements for completion of delivery and other 25. **MANUFACTURING QUALITY PLAN (MQP):** Supplier to submit approved MQP in line with requirement of BHEL/customer. SUPPLIER PERFORMANCE MONITORING AND RATING SYSTEM: 26. BHEL reserve the right for evaluation of Supplier Performance Rating as per Supplier Performance Monitoring and Rating System of BHEL for necessary action. Details are available at BHEL Website www.bhel.com for reference. 27. **DEALING WITH BANNED SUPPLIERS / CONTRACTORS IN BHEL:** Offers of the bidders, who are on the banned list, as also the offers of the bidders who engage the services of the banned firms, shall be rejected. The list of banned firms is available on BHEL website www.bhel.com for reference. 28. **ORDER OF PRECEDENCE:** The order of precedence shall be as follows: a) Special Terms & Conditions (STC) for Tender Enquiry / Contract, if any b) General Terms & Conditions (GTC) for Tender Enquiry / Contract & Additional General Terms & Conditions (GTC) for Tender Enquiry / Contract for Erection Testing & Commissioning (ETC) at Site, if applicable Provisions in (a) above shall prevail over (b). In case of conflict, between Technical Specifications and STC / GTC, bidder to seek necessary clarifications from BHEL concerned official as specified in NIT. 29. **PACKING:** Packing shall be in conformity with specifications and shall be such as to ensure prevention of damages, corrosion, deterioration, shortages, pilferage and loss in transit or storage. In case of shipment by sea or air, the packing shall be sea-worthy or air-worthy respectively and of international standards. Different types of spares i.e. start-up / commissioning spares and initial spares (mandatory spares and recommended O&M spares) are to be packed separately. Packing List shall be submitted as per standard format along with advance set of documents for claiming payment which shall also indicate :a) Case / Packing size (as applicable). b) Gross weight and net weight of each package. c) Detailed contents of the package with quantity of each item separately.

Project, Item / Package Description, BHEL's PO No. with date & Case / Packing Mark should also be clearly mentioned on the Case / Packing and Packing List for identification. Also, Packing List must be duly signed & should include respective Invoice No. & LR No.

Note:

Foreign suppliers to furnish details to arrange inland transportation by BHEL, if

Sr. No. applicable, as follows:i) No. of Packages ii) Size with Weight (Gross & Net) of each Package iii) No. of Containers with type & size required for inland transportation iv) Type of Cargo (Break Bulk / LCL / FCL) v) Customs Tariff No. 30. **COLOUR CODING:** Aluminium stickers are required to be attached to large components but plastic sheet tags should be tied with small components, giving details like purchase order, description of the component, quantity etc. Tags should be of the colour as follows:a) Main equipment: Yellow or White tag b) Start-up / Commissioning spares : Blue tag c) Mandatory spares: Pink or Red tag d) Recommended / O&M spares: Green tag 31. MICRO, SMALL & MEDIUM ENTERPRISES (MSME): MSMED Act 2006 as amended from time to time & extant regulations of Govt, of India for MSME will be applicable. Micro & Small Enterprises (MSE) can avail the intended benefits only if they submit along with the offer / bid, attested copies of either Acknowledgement of Entrepreneur Memorandum Part-II (EM-II certificate) having deemed validity (five years from the date of issue of acknowledgement in EM-II) or valid NSIC certificate or EM-II certificate along with attested copy of a CA certificate (As per BHEL format where deemed validity of EM-II certificate of five years have expired) applicable for the relevant financial year (latest audited). Date to be reckoned for determining the deemed validity will be the date of opening (for Techno-commercial Bid : Part-I in case of two part bid). Non-submission of such documents will lead to consideration of their bid at par with other bidders. No benefit shall be applicable for this enquiry if any deficiency in the above required documents are not submitted before price bid opening. If the tender is to be submitted through e-procurement portal, then the above required documents are to be uploaded on the portal. Documents should be notarized or arrested (in original) by a Gazetted officer. Copy of Udyog Aadhaar Memorandum with Acknowledgement of Ministry of Micro, Small & Medium Enterprises should also be furnished. BUSINESS ETHICS / SUSPENSION OF BUSINESS DEALINGS 32. **SUPPLIERS / CONTRACTORS:** If any bidder / supplier / contractor during pre-tendering / tendering / post tendering / award / execution / post-execution, indulges in malpractices cheating, bribery, fraud or other misconduct or formation of cartel so as to influence the bidding process or influences the price or fails to perform or is in default without any reasonable cause etc or performs any act considered objectionable as per extant guidelines, action may be taken against such bidders/supplier/contractor as per extant "Guidelines for Suspension of Business Dealings with Suppliers/Contractors". Abridged version of same is available at BHEL website (www.bhel.com) on "Supplier Registration" Page. 33. **REVERSE AUCTION:** BHEL reserve the right to go for Reverse Auction (RA) instead of opening the sealed envelope price bid, submitted by the bidder or price bid submitted by the bidder through e-procurement system. This will be decided after techno-commercial evaluation. All bidders to give their acceptance for participation in RA. Nonacceptance to participate in RA may result in non-consideration of their bids, in case BHEL decides to go for RA. In case BHEL decides to go for Reverse Auction, only those bidders who have given their unconditional acceptance to participate in RA will be allowed to participate in the Reverse Auction. Those bidders who have given their acceptance to participate in Reverse Auction will have to necessarily submit "online sealed bid□ in the

Sr. No. Reverse Auction. Non-submission of "online sealed bid by the bidder will be considered as tampering of the tender process and will invite action by BHEL as per extant guidelines in vogue. General Terms and Conditions of RA are available at Annexure. Business Rules for RA shall be sent to the bidders before conducting RA. Abridged Version of "Common Guidelines for Conducting Reverse Auction" may also be seen at BHEL website (www.bhel.com) on "Supplier Registration" Page & "Tender Notifications" Page. 34. **INTEGRITY PACT:** Bidders shall have to enter into Integrity Pact with BHEL, duly signed with seal in original, if specified in NIT / RFQ failing which bidder's offer shall be liable for rejection. 35. TERMINATION OF CONTRACT: BHEL shall have the right to cancel the Purchase Order / Contract without any financial implication to BHEL if vendor approval by end user / customer is withdrawn or in case of Suspension of Business Dealings with the Suppliers / Contractors by BHEL. BHEL shall have the right to cancel Purchase Order / Contract, wholly or in part, in case they are obliged to do so on account of any decline, diminution, curtailment or stoppage of their business and in that event, the Supplier's / Contractor' compensation claim shall be settled mutually. In case of cancellation of Purchase Order / Contract for main supply, all other associated Purchase Orders / Contracts like those for Mandatory Spares / Recommended Spares / Erection, Testing & Commissioning (ETC) / Supervision of ETC, if any, would also get cancelled. 36. SHELF LIFE Supplier has to inform the list of the items / sub-items which have limited shelf life like consumables or those required for the first fill and shall indicate the corresponding shelf life period in the offer. Such items / sub-items shall be manufactured / despatched only after getting formal clearance from BHEL. 37. **LIMITATION OF LIABILITY:** Notwithstanding any other provisions, except in cases of wilful misconduct and / or criminal negligence / acts, a) Neither the Supplier / Contractor nor BHEL shall be liable to the other, whether in Purchase Order / Contract, tort, or otherwise, for any consequential loss or damage, loss of use, loss of production or loss of profits or interest costs, provided however that this exclusion shall not apply to any obligation of the Supplier / Contractor to pay Liquidated Damages to the BHEL and b) Notwithstanding any other provisions incorporated elsewhere in the contract, the aggregate liability of the Contractor in respect of this contract, whether under the Contract, in tort or otherwise, shall not exceed total Contract Price, provided however that this limitation shall not apply to any obligation of the Vendor to indemnify BHEL with respect to Patent Infringement or Intellectual Property Rights. 38. **SHORTAGES / DAMAGES:** a) Against Supply only or Supply where Supervision of Erection, Testing & Commissioning (ETC) at Site or Supply where Testing & Commissioning at Site is in scope of the supplier: Any shortages and / or damages in supplies shall be supplied / replenished free of cost by the supplier as early as possible but not later than 30 days from the

date of intimation by BHEL to the supplier.

b) Against Supply where Erection, Testing & Commissioning (ETC) at Site is in scope of the supplier:

Any shortages and / or damages in supplies and during handling / storage, erection, testing and commissioning at site shall be supplied / replenished free of cost by the Supplier / Contractor, as early as possible, to meet the contractual completion time / schedule.

Note: There shall not be any extension in the contractual delivery time / schedule due to any shortages and / or damages in supplies.

39. VARIATION OF CONTRACT VALUE / QUANTITY VARIATION :

BHEL shall have the right to variation in quantities of items within ± 20% of the total Purchase Order / Contract value at the time of placement of PO or award of Contract on overall basis for all amendments together within two years from the date of original Purchase Order / Contract or completion of execution of the Purchase Order / Contract whichever is earlier but quantities of individual items may vary to any extent or may get deleted unless otherwise specified in the technical specifications. No compensation is payable due to variation in the quantities and the Supplier / Contractor shall be bound to accept the same the contracted prices / rates without any escalation. However, if the Purchase Order / Contract is on "Lumpsum" basis, no variation of Purchase Order / Contract value shall be admissible to the Supplier / Contractor within the scope of Purchase Order / Contract, as long as the inputs remain unchanged.

40. STATUTORY VARIATION:

GST rates prevailing at the time of dispatch of goods/ completion of services shall be payable by BHEL. All other taxes, duties, charges, royalty,cess,other levies shall be deemed to be included in the Ex Works Prices /Charges quoted by bidders and no variations shall be payable in respect thereof. No other variations such as on customs duty, exchange rate, minimum wages, prices of controlled commodities, any other input etc. shall be payable by the BHEL.

Notwithstanding anything above, where the actual completion of the supply / services occurs beyond the period stipulated in the Purchase Order / Contract or any extension thereof, variations referred to above, will be limited to the rates prevailing on the dates of such agreed completion periods only. For variations after the agreed completion periods, the Supplier / Contractor alone shall bear the impact for the upward revisions and for downward revisions BHEL shall be given the benefit of reduction in applicable taxes /GST. This will be without prejudice to the levy of liquidated damages for delay in delivery / completion.

If new tax is introduced by Central/ State Govt/ Municipality becomes directly applicable on items specified in Bill of Quantities/Purchase Order/Contract, full reimbursements shall be made provided it becomes applicable on items specified in Bill of Quantities.

However, any additional tax implication due to delay in delivery, beyond the Contractual Delivery, attributable to supplier shall be borne by supplier.

41. MODE OF PAYMENT:

Payment shall be made directly to the Supplier / Contractor by BHEL through NEFT / RTGS.

42. | CONFIDENTIALITY :

Supplier / Contractor shall, at all times, undertake to maintain complete confidentiality of all data, information, software, drawings & documents etc. belonging to BHEL and also of systems, procedures, reports, input documents, manuals, results and any other BHEL documents discussed and / or finalized during the course of execution of Purchase Order / Contract.

Sr. No. 43. **INDEMNIFICATION:** The Supplier / Contractor shall indemnify and keep indemnified and hold harmless BHEL and its employees and officers from and against any and all claims, suits, actions or administrative proceedings, demands, losses, damages, costs and expenses and any other claim of whatsoever nature in respect of the death or injury of any person or loss of or damage to any property arising during the course and out of the execution of the Purchase Order / Contract. 44. **TITLE OF GOODS:** a) Ownership of the equipment / material procured in India, shall be transferred to BHEL upon loading on to the mode of transport to be used for transportation of the said equipment / material from the works to the site / destination and upon endorsement of the dispatch documents in favour of BHEL. b) Ownership of the equipment / material to be imported into the country where the site is located, if not procured in India, shall be transferred to BHEL upon loading on the mode of transport to be used for transportation of the equipment / material from the country of origin to that country / destination and upon endorsement of despatch document in favour of BHEL. c) Notwithstanding the transfer of ownership of the equipment / material, the responsibility for care and safe custody thereof together with the risk of loss or damage thereto for whatsoever reason shall remain with the Supplier. 45. **COMPLIANCE OF STATUTORY REQUIREMENTS:** The vendor shall comply with all State and Central Laws / Acts, Statutory Rules, Regulations etc., as may be enacted by the Government during the tenure of the Purchase Order / Contract and having in force and applicable to the Purchase Order / Contract and nothing shall be done by the Supplier / Contractor in contravention of any Law / Act and / or Rules / Regulations, thereunder or any amendment thereof. The Supplier / Contractor shall pay all taxes, fees, licence charges / deposits, duties, tolls, royalty, commissions or other charges which may be levied on account of any of his operations connected with the Purchase Order / Contract. In case BHEL is constrained to make any of such payments, BHEL shall recover the same from the Supplier / Contractor either from moneys due to him or otherwise as deemed fit. 46. **ACCEPTANCE OF ORDER:** Supplier should acknowledge and accept the Letter of Award / Purchase Order issued by BHEL within 7 days of the issue of Letter of Award / Purchase Order. In case of any discrepancy / typographical error in issue of Purchase Order / Contract, the agreed terms & conditions, scope of work, rates / prices for placement of PO / award of contract shall be applicable and BHEL reserves the right to issue amendment(s) to PO / Contract for correction of discrepancies / typographical errors in the PO / Contract at a later date. 47. FRAUD PREVENTION POLICY: The Bidder along with its associate / collaborators / sub-contractors / sub-vendors / consultants / service providers shall strictly adhere to BHEL Fraud Prevention Policy displayed on BHEL website http://www.bhel.com and shall immediately bring to the notice of BHEL Management about any fraud or suspected fraud as soon as it comes to their notice.

Signature of Bidder (Authorized Signatory) with Date & Seal

BANK GUARANTEE FOR ADVANCE

Bank Guarantee No: Date:
То
NAME
& ADDRESSES OF THE BENEFICIARY
Dear Sirs,
In consideration of Bharat Heavy Electricals Limited¹ (hereinafter referred to as the 'Employer' which expression shall unless repugnant to the context or meaning thereof, include its successors and permitted assigns) incorporated under the Companies Act, 1956 and having its registered office at (Name of the Unit) having awarded to
AND WHEREAS the Employer has agreed to advance to the Vendor/Contractor/Supplier, a sum of Rs
We,, (hereinafter referred to as the Bank), having registered/Head office at
Any such demand made on the Bank shall be conclusive as regards the amount due and payable by the Bank under this guarantee. However, our liability under this guarantee shall be restricted to an amount not exceeding Rs.

We undertake to pay to the Employer any money so demanded notwithstanding any dispute or disputes raised by the Vendor/Contractor/Supplier in any suit or proceeding pending before any Court or Tribunal, Arbitrator or any other authority, our liability under this present being absolute and unequivocal.

The payment so made by us under this Guarantee shall be a valid discharge of our liability for payment hereunder and the Vendor/Contractor/supplier shall have no claim against us for making such payment.

We, theBank further agree that the guarantee herein contained shall remain in full force and effect during the period that would be taken for the performance of the said Contract and that it shall continue to be enforceable till all the dues of the Employer under or by virtue of the said Contract have been fully paid and its claims satisfied or discharged.

We>>>> Bank further agree that the Employer shall have the fullest liberty without our consent and without affecting in any manner our obligations hereunder to vary any of the terms and conditions of the said Contract or to extend time of performance by the said Vendor/Contractor/Supplier from time to time or to postpone for any time or from time to time any of the powers exercisable by the Employer against the said Vendor/Contractor/Supplier and to forbear or enforce any of the terms and conditions relating to the said Contract and we shall not be relieved from our liability by reason of any such variation, or extension being granted to the said Vendor/Contractor/Supplier or for any forbearance, act or omission on the part of the Employer or any indulgence by the Employer to the said Vendor/Contractor/Supplier or by any such matter or thing whatsoever which under the law relating to sureties would but for this provision have effect of so relieving us.

The Bank also agrees that the Employer at its option shall be entitled to enforce this Guarantee against the Bank as a principal debtor, in the first instance without proceeding against the Vendor/Contractor/Supplier and notwithstanding any security or other guarantee that the Employer may have in relation to the Vendor/Contractor/Supplier's liabilities.

We, BANK lastly undertake not to revoke this guarantee during its currency except with the previous
consent of the Employer in writing.
This Bank Guarantee shall be governed, construed and interpreted in accordance with the laws of India.
Courts at shall alone have exclusive jurisdiction over any matter arising out of or in connection with this Bank Guarantee
Notwithstanding anything to the contrary contained hereinabove:
The liability of the Bank under this Guarantee shall not exceed
This Guarantee shall be valid up to
Unless the Bank is served a written claim or demand on or before all rights under this
guarantee shall be forfeited and the Bank shall be relieved and discharged from all liabilities under this
guarantee irrespective of whether or not the original bank guarantee is returned to the Bank
We, Bank, have power to issue this Guarantee under law and the undersigned as a duly
authorized person has full powers to sign this Guarantee on behalf of the Bank.
For and on behalf of
(Name of the Bank)
Date Place of Issue
Flace of issue
¹ NAME AND ADDRESS OF THE EMPLOYER. i.e Bharat Heavy Electricals Limited
² NAME AND ADDRESS OF VENDOR /CONTRACTOR / SUPPLIER
³ DETAILS ABOUT THE NOTICE OF AWARD/CONTRACT REFERENCE
⁴ CONTRACT VALUE AND PROJECT/SUPPLY DETAILS
⁵ BG AMOUNT IN FIGURES AND WORDS
⁶ VALIDITY DATE
⁷ DATE OF EXPIRY OF CLAIM PERIOD

Note:

1. Units are advised that expiry of claim period may be kept 3-6 months after validity date. It may be ensured that the same is in line with the agreement/ contract entered with the Vendor.

Bank Guarantee No:

BANK GUARANTEE FOR PERFORMANCE SECURITY

Date:
То
NAME
& ADDRESSES OF THE BENEFICIARY
Door Sire
Dear Sirs,
In consideration of Bharat Heavy Electricals Limited (hereinafter referred to as the 'Employer' which expression
shall unless repugnant to the context or meaning thereof, include its successors and permitted assigns
incorporated under the Companies Act, 1956 and having its registered office at throug
its Unit at(name of the Unit) having awarded to (Name of the Vendor / Contractor / Supplier) wit
its registered office at hereinafter referred to as the ' <u>Vendor / Contractor / Supplier</u> ', which expression
shall unless repugnant to the context or meaning thereof, include its successors and permitted assigns), a contrac
Ref Nodatedvalued at Rs(Rupees)/FC(in words) fo
(hereinafter called the 'Contract') and the <u>Vendor / Contractor / Supplier</u> having agreed t
provide a Contract Performance Bank Guarantee, equivalent to% (Percent) of the said value of the Contrac
to the Employer for the faithful performance of the Contract,
we,(hereinafter referred to as the Bank), having registered/Head office atand inter alia a branc
at being the Guarantor under this Guarantee, hereby, irrevocably and unconditionally undertake t
forthwith and immediately pay to the Employer any sum or sums upto a maximum amount of Rs
Rupees) without any demur, immediately on first demand from the Employer and without an
reservation, protest, and recourse and without the Employer needing to prove or demonstrate reasons for it
such demand.
Any such demand made on the Bank shall be conclusive as regards the amount due and payable by the Ban
under this guarantee. However, our liability under this guarantee shall be restricted to an amount not exceedin Rs
We undertake to pay to the Employer any money so demanded notwithstanding any dispute or disputes raise

by the Vendor / Contractor / Supplier in any suit or proceeding pending before any Court or Tribunal, Arbitrator

or any other authority, our liability under this present being absolute and unequivocal.

The payment so made by us under this Guarantee shall be a valid discharge of our liability for payment thereunder and the Vendor / Contractor / Supplier shall have no claim against us for making such payment.

We thebank further agree that the guarantee herein contained shall remain in full force and effect during the period that would be taken for the performance of the said Contract/satisfactory completion of the performance guarantee period as per the terms of the Contract and that it shall continue to be enforceable till all the dues of the Employer under or by virtue of the said Contract have been fully paid and its claims satisfied or discharged.

WeBANK further agree with the Employer that the Employer shall have the fullest liberty without our consent and without affecting in any manner our obligations hereunder to vary any of the terms and conditions of the said Contract or to extend time of performance by the said Vendor / Contractor / Supplier from time to time or to postpone for any time or from time to time any of the powers exercisable by the Employer against the said Vendor / Contractor / Supplier and to forbear or enforce any of the terms and conditions relating to the said Contract and we shall not be relieved from our liability by reason of any such variation, or extension being granted to the said Vendor / Contractor / Supplier or for any forbearance, act or omission on the part of the Employer or any indulgence by the Employer to the said Vendor / Contractor / Supplier or by any such matter or thing whatsoever which under the law relating to sureties would but for this provision have effect of so relieving us.

The Bank also agrees that the Employer at its option shall be entitled to enforce this Guarantee against the Bank as a principal debtor, in the first instance without proceeding against the <u>Vendor / Contractor / Supplier</u> and notwithstanding any security or other guarantee that the Employer may have in relation to the <u>Vendor / Contractor / Supplier</u> 's liabilities.

This Guarantee shall remain in force upto and including...... and shall be extended from time to time for such period as may be desired by Employer.

This Guarantee shall not be determined or affected by liquidation or winding up, dissolution or change of constitution or insolvency of the <u>Vendor / Contractor / Supplier</u> but shall in all respects and for all purposes be binding and operative until payment of all money payable to the Employer in terms thereof.

Unless a demand or claim under this guarantee is made on us in writing on or before thewe shall be discharged from all liabilities under this guarantee thereafter.

This Bank Guarantee shall be governed, construed and interpreted in accordance with the laws of India.

Courts at shall alone have exclusive jurisdiction over any matter arising out of or in connection with this Bank Guarantee

We,	BANK lastly undertake not to revoke this guarantee during its currency except with the previou
conser	nt of the Employer in writing.
Notwit	hstanding anything to the contrary contained hereinabove:
a)	The liability of the Bank under this Guarantee shall not exceed
b)	This Guarantee shall be valid up to
c)	Unless the Bank is served a written claim or demand on or before all rights under thi
	guarantee shall be forfeited and the Bank shall be relieved and discharged from all liabilities under thi
	guarantee irrespective of whether or not the original bank guarantee is returned to the Bank.
	Bank, have power to issue this Guarantee under law and the undersigned as a dul ized person has full powers to sign this Guarantee on behalf of the Bank.
	For and on behalf of
	(Name of the Bank)
Dated.	
Place o	of Issue
¹ NAM	E AND ADDRESS OF EMPLOYER I.e Bharat Heavy Electricals Limited
² NAM	E AND ADDRESS OF THE VENDOR /CONTRACTOR / SUPPLIER.
³ DETA	AILS ABOUT THE NOTICE OF AWARD/CONTRACT REFERENCE
⁴ CON	TRACT VALUE
	ECT/SUPPLY DETAILS MOUNT IN FIGURES AND WORDS
⁷ VALI	DITY DATE
8 DATE	OF EXPIRY OF CLAIM PERIOD

Note:

- 1. Units are advised that expiry of claim period may be kept 3-6 months after validity date. It may be ensured that the same is in line with the agreement/ contract entered with the Vendor.
- 2. The BG should be on Non-Judicial Stamp paper/e-stamp paper of appropriate value as per Stamp Act prevailing in the State(s) where the BG is submitted or is to be acted upon or the rate prevailing in the State where the BG was executed, whichever is higher. The Stamp Paper/e-stamp paper shall be purchased in the name of Vendor/Contractor/Supplier/Bank issuing the guarantee.



BHARAT HEAVY ELECTRICALS LIMITED TRANSMISSION BUSINESSS GROUP MATERIAL RECEIPT CERTIFICATE

a) Sit	Site: BHEL C/O								
b										
C		oice no with date:								
	d) Vehicle No:e) Number of packages:									
f) Date of receipt of material at site:										
•										
9	g) Material details (as mentioned below):									
	SN	Item Description	Type of Packages	Qty as per Performa invoice	Qty as per packing list	Qty Received				
	1									
	2									
REMARKS: 1. Material received is subject to verification. Signature with date: Name & Designation:										



Transmission Business Group

HSE Department, HQ, Noida

HSE Policy

1. BHEL HSE Policy

HEALTH SIAFETY ENVIRONMENT POLICY In BHEL, Health, Safety and Environment (HSE) responsibilities are driven by our commitment to

In BHEL, Health, Safety and Environment (HSE) responsibilities are driven by our commitment to protect our employees and people we work with, community and environment. BHEL believes in zero tolerance for unsafe work/non-conformance to safety and in minimizing environmental footprint associated with all its business activities. We commit to continually improve our HSE performance by:

- Developing safety and sustainability culture through active leadership and by ensuring availability of required resources.
- Ensuring compliance with applicable legislation, regulations and BHEL systems.
- Taking up activities for conservation of resources and adopting sound waste management by following Reduce/Recycle/Reuse approach.
- Continually identifying, assessing and managing environmental impacts and Occupational Health & Safety risks of all activities, products and services adopting approach based on elimination/substitution/reduction/control.
- Incorporating appropriate Occupational Health, Safety and Environment criteria into business decisions, design of products & systems and for selection of plants, technologies and services.
- Imparting appropriate structured training to all persons at workplace and promoting awareness amongst customers, contractors and suppliers on HSE issues.
- Reviewing periodically this policy and HSE Management Systems to ensure its relevance, appropriateness and effectiveness.
- Communicating this policy within BHEL and making it available to interested parties.

Atul Sobti Chairman & Managing Director

June 5, 2018

Creating The of tomorrow

INSPECTION REQUEST

			INSPEC	TION KEQU	<u>LJI</u>				
1.	Name &	Address of Supplier		:					
2.	Project			:.					
3.	3. Purchase Order No. , Revision No. & Date :								
4.	4. Details of equipment / Material to be Inspected								
	SI.No.	Material offered for Inspection	P.O. Item No.	Total Quantity Ordered	Quantity offered for Inspection	Quantity Already Cleared	P.O. value of offered qty.		
	1.		1						
	2.		2						
5.	5. For structure, whether BOM & Proto Corrected : Yes / No. Drawings approved and available at place of inspection								
6.									
7.	7. Whether Quality Plan approved in Category – 1 available : Yes <u>/-No</u> . at place of inspection								
8.	3. Whether all type tests approved by Engineering			: Y	: Yes / No.				
(a) Place of Inspection & Address :				:	:				
9.	9. (b) Name & contact No. of supplier rep. for inspection			ection :	:				
10.	10. Sub – supplier contact person's name & contact no.			no. :	:				
11.	11. Weekly off day :			1	12. Working Hours :				
13. Date on which inspection requested (Inspection call to be raised at least 7 days prior to inspection):									
14.	No of roa	d permits required		:					
		ied that the above material cated above for inspection.							

Signature
Name :
Contact No. :
Date :

Distribution:

1. Material Management , BHEL, New Delhi

Note:

- 1. Unsigned inspection request & Inspection requests not given in this format are not accepted.
- Drawings, Quality Plan should be approved in category I by BHEL Transmission Business Engineering Management before the inspection date. In case inspection request is given without Category I approved documents, supplier should be obtain from BHEL Transmission Business Engineering Management in writing to this effect and attach to inspection request.