



PROJECT: 3X660 MW PRAYAGRAJ STPP AT BARA

**TECHNICAL SPECIFICATIONS FOR VIS
FOR TDBFP/MDBFP FOUNDATION**

SPECIFICATION NO. PE-TS-350-614-C001

VOLUME II B

SECTION A

REV.NO. 0 DATE 21-02-2011

Page 1 of 2

SECTION 'A'

SCOPE OF WORK



PROJECT: 3X660 MW PRAYAGRAJ STPP AT BARA

**TECHNICAL SPECIFICATIONS FOR VIS
FOR TDBFP/MDBFP FOUNDATION**

SPECIFICATION NO. PE-TS-350-614-C001

VOLUME II B

SECTION A

REV.NO. 0 DATE 21-02-2011

Page 2 of 2

Scope of work shall include the following:

1. Supply of the following

- a) Vibration Isolation System (VIS) as per Section-C
- b) Tools and facilities required for erection and commissioning including packing & transportation etc. complete.

2. Supervision of erection and commissioning of the VIS.

Vendor shall deploy experienced manpower for setting the VIS in position and final adjustments after machine installation. Vendor shall also confirm the readiness at site before deploying the manpower for supervision of erection.

3. Engineering for the vibration isolation system including civil drgs.(GA & RC details) is in vendor's scope