



PROJECT : 3X660 MW PRAYAGRAJ STPP AT BARA

**TECHNICAL SPECIFICATIONS FOR VIS  
FOR TDBFP/MDBFP FOUNDATION**

SPECIFICATION NO. PE-TS-350-614-C001

VOLUME II B

SECTION -C

REV.NO. 0 DATE 21-02-2011

Page 1 of 2

**SECTION 'C'**

**SPECIFIC TECHNICAL REQUIREMENTS**



PROJECT: 3X660 MW PRAYAGRAJ STPP AT BARA

**TECHNICAL SPECIFICATIONS FOR VIS  
FOR TDBFP/MDBFP FOUNDATION**

SPECIFICATION NO. PE-TS-350-614-C001

VOLUME II B

SECTION C

REV.NO. 0 DATE 21-02-2011

Page 2 of 2

**1.00.00 Vibration isolation system shall be selected by Vendor based on the following Input drawings.**

<u>SRL</u>	<u>TITLE</u>	<u>DRAWING NO.</u>
1	FOUNDATION ARRANGEMENT FOR BFP &DRIVE TURBINE	HY-TC-MPA1006-0111(R0)
2	FOUNDATION ARRANGEMENT FOR BFP &DRIVE TURBINE	HY-TC-MPA1006-0111(R0)
3	FOUNDATION ARRANGEMENT FOR BFP & DRIVE TURBINE	HY-TC-MPA1006-0111(R0)
4	FOUNDATION ARRANGEMENT OF MOTOR DRIVEN BFP UNIT	HY-DG-1-18000-57293(R0)

Vendor shall furnish General arrangement and reinforcement drawings complying with SECTION-D