

(LP PIPING WORKS FOR 2 X 250 MW, KORBA THERMAL POWER PLANT, CHHATISHGARH)

General points

1. It is clarified that supply portion of contract shall be on unit rate basis, based on supply portion of BOQ, Vol-III / Rev-03. Computation of tonnage as mentioned in Volume-IIB is for erection / services portion of contract only. Clause no. 2.03.00 (Supply conditions) shall be read accordingly.
 2. All black fittings below 250 NB shall be SA 234 WPB. Above this size it shall be as per cl. no. 2.02.03 of Sec-D of Vol-IIB.
- These clarifications (TCN-04) will form a part of the tender document and should be submitted (duly signed) along with bid as specified. Quoted price of bidders will be presumed on the basis of original tender (including TCN-01, TCN-02, TCN-03) & these clarifications (TCN-04). These clarifications (TCN-04) including all enclosures mentioned below will form a part of the tender document and should be submitted (duly signed) along with bid as specified. **Price shall be quoted in revised BOQ (vol-III), revision-3 only. Revision-03 of Vol-III (BOQ cum rate schedule, supply as well services portion) is issued alongwith TCN-03.**
 - Based on clarifications furnished above, all the bidders are requested to submit their offer without any deviation, within stipulated time i.e. by **02-05-2006 (Receipt date)**. No further queries/clarifications from bidders against this tender, shall be entertained.

All the clauses of original tender document (including TCN-01 dated 06/04/2006, TCN-02 dated 13/04/2006 & TCN-03 dated 24/04/2006) , which are not mentioned/covered in above clarifications (TCN-04), will remain unchanged. All other queries raised by bidders shall not be taken into consideration.

**(MANAGER/SCT)
BHEL/PSERHQ/KOLKATA**