

TECHNICAL PRE-QUALIFICATION CRITERIA

JOB	DESIGN, ENGINEERING, MANUFACTURING, SUPPLY/DELIVERY TO SITE OF CONTROL VALVES (Pneumatically Operated) WITH SMART POSITIONER & ACCESSORIES FOR 2 x 660MW RAGHUNATHPUR TPP.
------------	--

BIDDER SHALL NOTE & COMPLY WITH THE POINTS REFERRED BELOW.

SL NO	CRITERIA FOR BIDDERS NOT APPROVED WITH BHEL-PEM, NOIDA:
1.0	BIDDER SHOULD BE DESIGNER & ORIGINAL EQUIPMENT MANUFACTURER OF THE CONTROL VALVES WITH ACCESSORIES
2.0	BIDDER TO FURNISH LIST OF ORDERS EXECUTED IN LAST FIVE YEARS.
3.0	<p>a. SATISFACTORY PERFORMANCE FEEDBACK CERTIFICATES FROM END USER (IN ENGLISH) FOR THERMAL POWER PLANT OF RATING 500MW & ABOVE, INDICATING SALIENT FEATURES LIKE YEAR OF COMMISSIONING OF EQUIPMENT, DUTY PARAMETERS (SIZE ,FLOW), PROJECT NAME ETC., DATE OF ISSUE OF CERTIFICATE AND NAME/DESIGNATION OF THE CERTIFICATE ISSUER.</p> <p style="text-align: center;">OR</p> <p>THE SUPPLIER HAS BEEN AWARDED REPEAT CONTRACTS (MINIMUM 2 NOS.) BY SAME CUSTOMER FOR CONTROL VALVE AFTER 2 YEARS OF COMMISSIONING OR ON REGULAR BASIS FOR THERMAL POWER PLANT OF RATING 500MW & ABOVE.</p> <p>b. TWO SETS OF APPROVED DRGS, TECHNICAL DATA SHEETS OF WHICH THE BIDDER INTENDS TO FURNISH THE PERFORMANCE FEEDBACKS, FOR REFERENCE PURPOSE.</p>
4.0	<p>MANUFACTURER SHOULD COMPLY WITH BHEL QUALITY PLAN & SPECIFICATION FOR CONTROL VALVES.</p> <p>A CONFIRMATION FOR THE SAME SHALL BE SUBMITTED.</p>
5.0	<p>BIDDER SHALL HAVE THE REFERENCE OF SUPPLYING CONTROL VALVES WITH</p> <ol style="list-style-type: none">1. ANSI RATING UPTO CLASS-6002. VALVE SIZE UPTO 14 INCH3. SHUT OFF PRESSURES UPTO 90 KG/CM24. DESIGN TEMPERATURES UPTO 370 DEG C5. DIFFERENTIAL PRESSURES UPTO 85 KG/CM2 <p>RELEVANT DOCUMENT IN SUPPORT OF ABOVE SHALL BE SUBMITTED</p>
6.0	BIDDER TO FURNISH TECHNICAL CATALOGUE OF CONTROL VALVES.

NOTES

1.0	BIDDER(S) ALREADY REGISTERED WITH BHEL-PEM-NOIDA FOR SUBJECT PACKAGE, WITHOUT ANY TECHNICAL LIMIT, NEED NOT SUBMIT TECHNICAL PQ C/PQR. IN CASE OF LIMIT, THE REGISTERED BIDDER TO SUBMIT THE DOCUMENTS REQUIRED FOR REVIEW OF LIMIT ALONE, IF THE BIDDER WANTS RE-ASSESSMENT OF THE LIMIT.
2.0	AFTER SATISFACTORY FULFILLMENT OF ALL THE ABOVE CRITERIA/ REQUIREMENT, OFFER SHALL BE CONSIDERED FOR FURTHER EVALUATION AS PER NIT AND ALL OTHER TERMS OF THE TENDER.
3.0	CONSIDERATION OF OFFER WILL BE SUBJECT TO END USER'S APPROVAL OF BIDDER.

#

M. K. Wadhwa
26.07.13