

ANNEXURE-I: PRICE FORMAT FOR LT ~~22KV~~ FIRE SURVIVAL CABLE FOR 2X660 MW SURATGARH STPS STAGE-V

COPPER CONDUCTOR, EPR INSULATED, HOFR SHEATH ARMoured FIRE SURVIVAL CABLE

MAIN SUPPLY APPLICABLE TO TECHNICAL SPECIFICATION No. PE-TS-392-507-E005.

Sl. No.	Cable Sizes (no. of cores Cross section area (sqmm))	Order Quantity (meters)	Lot-I qty	Drum Length (meters)	UNIT EX-WORKS PRICE IN INR	TOTAL EX- WORKS PRICE	ED	CST/VAT@.....%	FREIGHT@.....% INCLUDING SERVICE TAX	TOTAL F.O.R. SITE PRICE
1	1C-300	4500	3500	500			NIL AGAINST PAC			
2	1C-150	3000	2500	500			NIL AGAINST PAC			
3	1C-70	4000	3000	500			NIL AGAINST PAC			
4	3CX1.5	6500	4500	500			NIL AGAINST PAC			
TOTAL (1 TO 4)										

MANDATORY SPARES APPLICABLE TO TECHNICAL SPECIFICATION No. PE-TS-392-507-E005.

Sl. No.	Cable Sizes (no. of cores Cross section area (sqmm))	Order Quantity (meters)	Lot-I qty	Drum Length (meters)	UNIT EX-WORKS PRICE IN INR	TOTAL EX- WORKS PRICE	ED	CST/VAT@.....%	FREIGHT@.....% INCLUDING SERVICE TAX	TOTAL F.O.R. SITE PRICE
5	1C-300	500		500			NIL AGAINST PAC			
6	1C-150	500		500			NIL AGAINST PAC			
7	1C-70	500		500			NIL AGAINST PAC			
8	3CX1.5	500		500			NIL AGAINST PAC			
TOTAL (5 TO 8)										
GRAND TOTAL (1 TO 8)										

Notes:

1	The variation in quantities of all sizes for Main items put together shall be limited to (-) 30% to (+) 30% of the total contract value derived on the basis of the Ordered quantities for this very project.
2	The bidder shall indicate the unit price of each type and size of cables listed as per the BOQ-Cum-Price Schedule enclosed with this specification. The unit prices shall apply for adjustment of variation in quantity as stipulated above.
3	Lot-1 Quantity indicated above shall be cleared for manufacturing along with LOI. However, manufacturing of the cables shall be taken up by the successful bidder only after approval of technical and quality documentation and shall be completed within four months from the date of approval of documentation. Subsequent lots shall be cleared for manufacture based on progress of engineering and site requirements. A lead-time of three months shall be given for completion of supply for each subsequent lot from the date of clearance of the quantities.
4	Delivery schedule of LOT-1 and subsequent lots shall be as per NIT.
5	Standard drum length shall be 500 metres. Tolerance on individual drum length shall be $\pm 5\%$.
6	Overall tolerance on total dispatched quantity of each size shall be (-) 2% and (+) 0%. Cables consumed for testing and inspection shall be to bidder's account.
7	For each individual cable size, one short length of not less than 200m may be accepted only in the final drum length to complete the supply. The overall tolerance limits stipulated above shall continue to apply (in case short lengths are accepted).
8	Bidder shall indicate unit price of cables inclusive of type test charges. No separate Type Test charges to be quoted by bidder.
9	In case the quantities cleared by BHEL for manufacturing (in a lot) are manufactured and offered for inspection by successful bidder in more than one batch, BHEL reserves the right to witness type testing on all batches.

Signature
08/10/13