



MINIMUM CLEARANCE TABLE (AS PER EC 71/72)	
PHASE TO PHASE (PP)	220KV 132KV
PHASE TO EARTH (PE)	2100 1300
SECTION CLEARANCE (SC)	5000 4000
GROUND CLEARANCE (AS PER IE RULE)	5500 4600
TO NEAREST PART NOT AT EARTH POTENTIAL OF AN INSULATOR SUPPORTING LIVE CONDUCTOR	2440 2440

1

132 K V SWITCHYARD AT TALCHER