



**भारत हेवी इलेक्ट्रिकल्स लिमिटेड**  
**Bharat Heavy Electricals Limited**  
(A Govt. of India Undertaking)  
Power Sector, Western Region,  
345, Kingsway, Nagpur - 440 001  
Phone : 0712-530641-45, Fax : 0712-530640



**FAX (PCC by Courier/Speed Post)**

Ref: BHE/PW/PUR/UKAI-BLR1/442/CLA-01

Date: 19/07/2006

To,  
All Bidders

Dear sir,

**SUB: CLARIFICATION-01 to Tender Specification No. BHE/PW/PUR/ UKAI-BLR1/442**

Job: Collection Of Materials From Stores/Storage Yard, Transportation To Site Of Work, Dismantling The Existing Components, Erection Of New Components, Packing And Loading Of Components To Be Transported To Units, Unloading Of Repaired Components Received From Units, Renovation And Modernization, Testing, Commissioning, Including Servicing/ Overhauling / Repair / Replacement, Returning / Disposal Of Dismantled Materials To Bhel/Client's Yard, And Handing Over Of 1x120 Mw Unit# 1 Boiler And Its Auxiliaries, ESP, Mills Etc. At UKAI TPS

Clarification on subject tender specification as asked by bidders are furnished below:

Q.1 Requirement of Huck Bolting Machine for ESP work

Ans 1-One Set of Huck Bolting machine shall be arranged by BHEL free of charges. This will be issued for limited duration for erection of two new ESP fields. BHEL will also issue spare parts of the H B M/c free of cost which are necessary for regular & smooth operation.

Q-2. Regarding necessarily of 90MT crane as mentioned in our tender specification (Appendix ).

Ans-2. The crane to be deployed by the contractor need not be essentially of 90MT capacity. Contractor shall depute suitable crane for handling the critical/heavy components as listed in tender specification. Contractor shall also depute suitable crane based on the sketches furnished now for ESP erection. (copy of sketches enclosed ) Contractor shall furnish details ( rated capacity and maximum boom length ) of such crane in the T&P deployment plan with the technical bid.

Above clarifications shall form a part of Tender Specification.

Please enclose one copy of this letter with enclosures duly counter-signed by your authorized signatory and stamped with your official seal as a token of your unqualified acceptance of this clarification along with your Technical Bid. In case the tender document already dispatched, you may please send copy of this letter separately duly signed and stamped as a token of acceptance of this clarification.

All other terms and conditions of the Tender Specification shall remain unaltered unless and otherwise expressly amended by BHEL.

Thanking you.

Yours faithfully  
FOR Bharat Heavy Electricals Ltd.

DGM (Purchase)

### SKETCH-I



