

TENDER SPECIFICATION

NO: BHE/PW/PUR/KLT-ELE/460

FOR

HANDLING AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, COMPLETE ERECTION, CHECKING OF CALIBRATION, TESTING, ASSISTANCE FOR COMMISSIONING AND HANDING OVER OF ELECTRICAL PACKAGES VIZ., ISOLATED PHASE BUS DUCT FOR SEGREGATED PHASE BUS DUCT, GENERATOR TRANSFORMER, UNIT AUXILIARY TRANSFORMER, ELECTROSTATIC PRECIPITATOR, GENERATOR CONTROL & PROTECTION PANELS, 6.6 KV HT SWITCHGEAR, LT 415 V SWITCHGEAR BOARDS MCC, SOOT BLOWER SYSTEM, EXCITATION SYSTEM, ELECTRICAL HOIST AND ASSOCIATED ITEMS FOR UNIT #4 (1X 75 MW)

AT

KUTCH LIGNITE TPS
VILLAGE-PANANDHRO
TALUKA-LAKHPAT
GUJARAT

PART –I

(TECHNICAL BID SPECIFICATION, NOTICE INVITING TENDER and GCC)



BHARAT HEAVY ELECTRICALS LIMITED
(A Govt. of India Undertaking)
POWER SECTOR - WESTERN REGION
345, KINGS WAY - NAGPUR 440 001

C o n t e n t s			
SN	Description	Section/ Appendix No.	No. of Pages
1.	Tender Specification issue details	--	1
2.	Project Information	--	1
3.	Procedure For Submission of Sealed Tender	--	2
4.	Check List	--	2
5.	Declaration Sheet	--	1
6.	Certificate of No-Deviation	--	1
7.	Notice Inviting Tender (includes Qualification Requirements etc.)	\$	3
8.	General Conditions of Contract	Sections -1 & 2 #	28
9.	Offer of Contractor	Section-3	1
Special Conditions of Contract			
10.	Scope of Work	Section-4	30
11.	Obligations Of The Contractor (Tools, Tackles, Consumables etc.)	Section-5	7
12.	Contractor's Obligations in Regard to Employment of Supervisory Staff and Workmen	Section-6	2
13.	Obligations of BHEL	Section-7	1
14.	Inspection/Quality Assurance/Quality Control/Statutory Inspection	Section-8	3
15.	Safety, Occupational Health and Environmental Management	Section-9	12
16.	Drawings And Documents	Section-10	1
17.	Time Schedule/Mobilization/ Progress Monitoring/ Overrun.	Section-11	3
18.	Terms of Payment	Section-12	6
19.	Extra Charges for Modification/ Rectification	Section-13	2
20.	Insurance	Section-14	2
21	Earnest Money Deposit and Security Deposit	Section-15	2
22	Technical Details, Bill of Quantities & List of Drawings enclosed with Tender Specs.	Section-16	5

C o n t e n t s			
SN	Description	Section/ Appendix No.	No. of Pages
Appendices			
23	List of T&P to be provided by BHEL	Appendix-I	1
24	List of Consumable to be Provided by BHEL	Appendix-II	1
25	Tentative List of Major T&P and MMD to be Deployed by the Contractor	Appendix-III	4
26	Month-wise Manpower Deployment Plan by Contractor	Appendix-IV	1
27	Analysis of Unit Rates Quoted	Appendix-V	1
28	T&P and MMD Deployment Plan by the Contractor	Appendix-VI	1
29	Details of Concurrent Commitment	Appendix-VII	1
30	Detail of work done during last seven years	Appendix-VIII	1
31	Price Bid:	Part-II	@

LEGEND:

- \$:** PLACED BEFORE 'GENERAL CONDITIONS OF CONTRACT' IN BOTH HARD AND SOFT COPY DOCUMENTS.
- #:** ATTACHED AT THE END OF HARD COPY OF TENDER SPECS. PART-I (TECHNICAL BID) AND AS A SEPARATE FILE TITLED 'WEB_NIT_GCC' AS SOFT COPY HOSTED IN WEB PAGE.
- @:** ISSUED AS SEPARATE BOOKLET IN HARD COPY AS PART-II (PRICE BID) AND AS SEPARATE FILE TITLED 'PRICE_BID' AS SOFT COPY HOSTED IN WEB PAGE.

TENDER SPECIFICATION

NO: BHE/PW/PUR/KLT-ELE/460

FOR

HANDLING AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, COMPLETE ERECTION, CHECKING OF CALIBRATION, TESTING, ASSISTANCE FOR COMMISSIONING AND HANDING OVER OF ELECTRICAL PACKAGES VIZ., ISOLATED PHASE BUS DUCT FOR SEGREGATED PHASE BUS DUCT, GENERATOR TRANSFORMER, UNIT AUXILIARY TRANSFORMER, ELECTROSTATIC PRECIPITATOR, GENERATOR CONTROL & PROTECTION PANELS, 6.6 KV HT SWITCHGEAR, LT 415 V SWITCHGEAR BOARDS MCC, SOOT BLOWER SYSTEM, EXCITATION SYSTEM, ELECTRICAL HOIST AND ASSOCIATED ITEMS FOR UNIT #4 (1X 75 MW)

AT

KUTCH LIGNITE TPS

EARNEST MONEY DEPOSIT: Please see Special Conditions of Contract.

LAST DATE FOR TENDER SUBMISSION: Please obtain updated information from web page www.bhel.com ® **Tender Notifications**
® **View Corrigendums.**

THESE TENDER SPECIFICATION DOCUMENTS CONTAINING **PART-I** TECHNICAL BID SPECIFICATION AND **PART-II** PRICE BID, ARE ISSUED TO:

M/s.

.....

PLEASE NOTE:

- 1) THESE TENDER SPECS DOCUMENTS ARE NOT TRANSFERABLE.
- 2) BIDDER SHALL NOTE THAT THEIR OFFER WILL BE CONSIDERED SUBJECT TO THE APPROVAL OF BHEL'S CUSTOMER.

For Bharat Heavy Electricals Limited

Dy. GEN MANAGER (Purchase)
PLACE: NAGPUR

DATE:

PROJECT INFORMATION

The proposed Unit no. IV will be located inside the boundary of the existing KLTPS near Panandhro Village of Lakhpat Taluka, Distt – Kutch, Gujarat. Nearest railway station and the airport is Bhuj which is about 140 Km South East of existing plant. The site is around 10 Km from state highway no. 45. Unit no. IV will be located by the side of existing Unit no. III. The site is approachable by road both from Dayapur village and Gadauli village.

Bharat Heavy Electricals Limited

Procedure for Submission of Sealed Tenders & Instructions to Bidders

The bidder must submit their tenders as required in two parts in separate sealed covers prominently super scribed as part-I technical bid and part-II price bid and also indicating on each of the covers the tender specification number and due date and time as mentioned in the tender notice.

Part-I (Technical Bid) cover-I:

Excepting rate schedule, all other schedules, data sheets and details called for in the specification shall be enclosed in part-I "Technical Bid" only.

EARNEST MONEY DEPOSIT (EMD)

EMD shall be included in the Technical Bid. **EMD shall be paid by bidders only in the form of account payee Demand Draft payable at Nagpur in favour of Bharat Heavy Electricals Limited.** No other mode of payment of EMD shall be acceptable. Provisions under clause no. 1.4 of the General Conditions of the Contract shall stand withdrawn for this tender.

Bidder may opt to deposit "One Time EMD" of Rs. 2 lacs with this office (BHEL:PSWR:Nagpur) which will enable them to participate in all the future tender enquiries in respect of Erection and Commissioning services issued from this office. Interested bidders may clearly sent their consent for converting the present EMD into an "One Time EMD" in their offer.

Bidders who have already submitted such "One Time EMD" will be exempted from submission of any EMD for this tender. However bidder shall furnish details of the "One Time EMD" in his offer including the Check List furnished herein.

Part-II (Price Bid) cover-II:

All indications of price shall be given in this part-II "Price Bid". **EMD shall not be included in this cover.**

These two separate covers-I and II (part-I and part-II) shall together be enclosed in a third envelope (cover-III) along with requisite EMD as indicated earlier and this sealed cover shall be super scribed and submitted to Dy. Gen Manager (Purchase) at the above-mentioned address on or before the due date as indicated.

The qualified bidder will be intimated separately about the status of their offer.

Bidder are requested to make specific note of the following conditions:

1. Contractor should have adequate resources including major T&P at his disposal for this job.

2. Contractor should have sound financial stability.
3. Bidder should meet quality requirement regarding workmanship, deployment of personnel, erection tools and necessary inspection, measurement & testing instruments.
4. All information as called for in various appendices and clauses of tender specification, should be furnished in completeness. Please refer the checklist.
5. Clarification on tender if any, shall be asked by bidders at least seven days before Due date as stipulated in the NIT.
6. Offers must be submitted without any deviation.
7. Offers received with any deviation or without relevant information as described above are liable to be rejected. Price bids received in the form other than specified in Part-II (Price Bid) are liable to be rejected.
8. **Bidder shall note that their offer will be considered subject to the approval of BHEL's customer.**

Check List			
(Vide Para 1.3 Of Section-I of General Conditions Of Contract)			
1	Name of the Bidder with Postal Address for Correspondence		
2	Name of Contact Person with Telephone & Fax No.	Mr./Ms Tel No. Fax No.	
3	Nature of the firm	PROPRIETARY / PARTNERSHIP / LIMITED CO.	
4	Details of EMD Please Indicate whether 1) One Time EMD or, 2) Only for this Tender	DD No. DD Date..... Name of Bank..... Amount: Rs.....	
5	Validity of Offer (BHEL's Requirement: 180 days from Due Date)	Validity _____ days	
6	Mobilization Time (Please refer Section-11 of SCC)	Mobilization Time _____	
7	Whether any conditions stipulated?	Yes (vide Document reference: 	No
		Bidder to note that tender with conditions unacceptable to BHEL shall be rejected.	
8	Bidder has visited the project site and acquainted with the site conditions	Yes	No
9	Details of concurrent jobs are furnished (Appendix-VII)	Yes	No
10	Headquarters organization is furnished	Yes	No
11	Proposed site organization is furnished	Yes	No
12	Names and particulars of directors/partners are furnished	Yes	No

Check List (Vide Para 1.3 Of Section-I of General Conditions Of Contract)			
13	Financial status of the firm (Annexure 'A' of GCC) is furnished	Yes	No
14	Copy of Audited Profit & Loss Account for preceding three years duly authenticated on each copy by bidders Chartered Accountants	Yes	No
15	Latest Certificate by Bidder's Banker for Overdraft & BG Limits is Furnished (Certificate shall not be older than six months from the Last Date for offer submission)	Yes	No
16	Latest copy of IT Return along with copy of PAN Card are Furnished	Yes	No
17	Month-wise Manpower Deployment Plan (Appendix –IV) is furnished	Yes	No
18	Analysis of Unit Rates quoted (Appendix -V) is furnished	Yes	No
19	Month-wise deployment plan for major T&P (Appendix -VI) is furnished	Yes	No
20	Whether all the pages of the Tender Specification documents are read, understood and signed	Yes	No
21	Power of Attorney enclosed in favour of person making offer	Yes	No
22	Bidder has familiarized himself with all Relevant Local Laws & Local Conditions	Yes	No
23	Safety Requirement of this work in a Running plant Premises has been understood.	Yes	No
24	Erection and Assistance for Commissioning programme furnished	Yes	No
25	List of Jobs completed in last seven years is furnished(Appendix-VIII)	Yes	No
26	Whether copies of detailed Work Orders (with BOQ) and Completion Certificates in support of above furnished	Yes	No
27	Whether contractor has left any job unfinished? If so, give reasons.	Yes	No
28	Whether any client has terminated the contractor's work before completion? If so, furnish reasons for the same	Yes	No

Note: strike off or tick '**yes**' or '**no**', as applicable

Date:

Signature of Bidder

Declaration by Bidder's Authorized Signatory

I, _____ hereby certify that all the information and data furnished by me with regard to the Tender Specification No. BHE/PW/PUR/KLT -ELE/460 are true and complete to the best of my knowledge. I have gone through the specifications, conditions and stipulations in detail and agree to comply with the requirements and intent of the specification. **I further certify that I am duly authorized representative of the under-mentioned bidder and a valid power of attorney to this effect is also enclosed with the tender.**

Authorized representative's signature with
Name and address

Date:

Bidder's Name and Address

Certificate of No-Deviation

Tender Specification No. BHE/PW/PUR/KLT-ELE/460

I/WE, M/s
HEREBY CERTIFY THAT NOTWITHSTANDING ANY CONTRARY INDICATIONS/
CONDITIONS ELSEWHERE IN OUR OFFER DOCUMENTS, I/WE HAVE NEITHER SET
ANY TERMS AND CONDITIONS NOR THERE IS ANY DEVIATION TAKEN FROM THE
CONDITIONS OF BHEL'S TENDER SPECIFICATIONS, EITHER TECHNICAL OR
COMMERCIAL, AND I/WE AGREE TO ALL THE TERMS AND CONDITIONS MENTIONED
IN BHEL'S TENDER SPECIFICATION WITH ASSOCIATED AMENDMENTS AND
CLARIFICATIONS.

Date:

Signature of the Bidder
and Official Seal

Section-3

Offer of the Contractor

To,
DGM (Purchase)
Bharat Heavy Electricals Limited
Power Sector - Western Region
Shreemohini Complex
345, Kingsway
Nagpur - 440 001

Dear Sir,

I/we hereby offer to carry out the work detailed in tender specification no. BHE/PW/PUR/KLT-ELE/460 issued by Bharat Heavy Electricals Limited, Power Sector-Western Region, Nagpur, in accordance with the terms and conditions thereof.

I/we have carefully perused the following listed documents connected with the above work and agree to abide by the same.

1. Instructions to bidders
2. General conditions of contract
3. Special conditions of contract
4. Other Sections, Appendices, Schedules and Drawings, whichever are applicable

I/WE HAVE DEPOSITED / FORWARDED HERewith THE REQUISITE EARNEST MONEY DEPOSIT (EMD) AND DETAILS OF EMD PAYMENT ARE FURNISHED IN THE CHECK LIST.

EMD shall be refunded should our offer not be accepted / EMD **need not be refunded and the amount may be treated as "one time EMD" for erection and commissioning tenders of BHEL-PSWR, Nagpur**. Should our offer be accepted, i/we further agree to deposit security deposit for the work as provided for in the tender specification within the stipulated time as may be indicated by BHEL, Power Sector-Western Region, Nagpur.

I/we further agree to execute all the works referred to in the said documents upon the terms and conditions contained or referred to therein and as detailed in the appendices annexed thereto.

Place:
Date :

Signature Of Bidder:
Address:

Witnesses With Their Address

Signature	Name	Address
1.		
2.		

SECTION-4

SPECIAL CONDITIONS OF CONTRACT

4.0 SCOPE OF WORK

The work under these specifications broadly covers the complete work of handling at storage yard/stores, transportation to work site, calibration, pre-assembly, erection, testing, pre-commissioning tests, checks, Assistance for commissioning and handing over of Electrical Equipment & Associated Auxiliaries of various systems as listed under.

1. GENERATOR TRANSFORMER, UNIT AUXILIARY TRANSFORMER
2. ISOLATED PHASE BUS DUCT, SEGREGATED PHASE BUS DUCT AND NON-SEGREGATED PHASE BUS DUCT.
3. SOOT BLOWER SYSTEM
4. 6.6KV, 415V AC, SWITCHGEAR BOARDS
5. STATIC EXCITATION SYSTEM
6. ELECTROSTATIC PRECIPITATOR
7. ELECTRICAL HOISTS AND ELEVATORS
8. CONTROL & RELAY PANELS
9. HT/LT MOTORS TESTING AND ASSISTANCE FOR COMMISSIONING
10. ANY OTHER ASSOCIATED SYSTEMS REQUIRED FOR COMPLETION OF THE BOILER-TURBINE-GENERATOR (BTG) PACKAGE.

Scope of work is further detailed in various clauses hereafter.

4.1 GENERAL REQUIREMENTS

- 4.1.1 The intent of specification is to provide services according to the most modern and proven techniques and codes. The omission of specific reference to any method, equipment or material necessary for proper and efficient execution of this work shall not relieve the contractor of the responsibility of providing such facilities to complete the work without any extra compensation.
- 4.1.2 The work to be carried out under the scope of this specification covers the complete work of loading, handling, transporting, unloading, preassembly, erection, calibration, testing, air flushing, pre-commissioning tests, commissioning of systems, trial run of various auxiliaries and equipments, achieving various milestones till handing over of the unit to BHEL's customer. The work shall conform to dimensions and tolerances specified in various drawings that will be provided during the erection. If any portion of the work is found to be defective in workmanship or not

conforming to drawings or other specifications, the contractor shall dismantle and re-do the work duly replacing the defective materials at his cost, failing which the work will be got done by engaging other agencies or departmentally and recoveries will be effected from contractor's bills towards expenditure incurred including 30% departmental charges.

- 4.1.3 The terminal points decided by BHEL should be final and binding on the contractor for deciding the scope of work and effecting payment for the work done.
- 4.1.4 The work shall be executed under the usual conditions affecting major power plant construction and in conjunction with numerous other operations at site. The contractor and his personnel shall cooperate with personnel of BHEL, BHEL's customer, customer's consultants and other contractors, coordinating his work with others and proceed in a manner that shall not delay or hinder the progress of work of the project as a whole.
- 4.1.5 The work covered under this specification is of highly sophisticated nature, requiring the best quality workmanship, supervision, engineering and construction management. The contractor should ensure proper planning and successful & timely completion of the work to meet the overall project schedule. The contractor must deploy adequate quantity of tools & plants, modern/latest construction aids etc. He must also deploy adequate trained, qualified and experienced supervisory staff and skilled personnel.
- 4.1.6 Contractor shall erect, align and commission all the equipments and auxiliaries as per the sequence & methodology prescribed by BHEL depending upon the technical requirements. Availability of materials and fronts will decide this. BHEL engineer's decision regarding correctness of the work and method of working shall be final and binding on the contractor. No claims for extra payment from the contractor will be entertained on the ground of deviation from the methods / sequences adopted in erection of similar sets elsewhere.
- 4.1.7 **All necessary certificates and licenses, permits & clearances required to carry out this work from the respective statutory authorities are to be arranged by the contractor expeditiously at his cost and in time to ensure smooth progress of work.**
- 4.1.8 The work shall conform to dimensions and tolerances specified in the various drawings / documents that will be provided during various stages of erection. If any portion of work is found to be defective in workmanship, not conforming to drawings or other stipulations due to contractor's fault, the contractor shall dismantle and re-do the work duly replacing the defective materials at his cost, failing which the work will be got done by BHEL and recoveries will be effected from the contractor's bills towards expenditure incurred including cost of materials and 30% departmental overheads of BHEL.
- 4.1.9 Contractor will be required to maintain in his site office at least one PC along with minimum accessories like printer, etc to enable him to carry out

site activities in a planned, well coordinated and smooth manner. ***(Also please refer to clause 4.7)***

- 4.1.10 The contractor shall execute the work in the most substantial and professional manner. The stores shall be handled with care and diligence.
- 4.1.11 BHEL reserves right to recover from the contractor any loss, which arises out of undue delay/discrepancy/shortage/damage, or any other causes due to contractor's lapse during any stage of work. Any loss to BHEL due to contractor's lapse shall have to be made good by the contractor.
- 4.1.12 All transport equipment, handling equipment, tools, tackles, fixtures, equipment, materials, manpower, supervisors/engineers, consumables etc., except otherwise specified as BHEL scope of free issue, required for this scope of work shall be provided by the contractor. All expenditure including taxes and incidentals in this connection will have to be borne by him unless otherwise specified in the relevant clauses. The contractor's quoted rates should be inclusive of all such contingencies.
- 4.1.13 During the course of erection, testing and assistance for commissioning certain rework/ modification / rectification / repair / fabrication etc. may become necessary on account of feedback / revision of drawing. This will also include modifications / re-works suggested by BHEL / customer / other inspection group. Contractor shall carry out such rework / modification / rectification / fabrication / repair etc., promptly and expeditiously. Daily log sheets signed by BHEL engineer and indicating the details of work carried out, man-hours etc. shall be maintained by the contractor for such reworks. Claim of contractor if any, for such works will be governed by clauses 13.1 to 13.8.
- 4.1.14 All works such as cleaning, levelling, aligning, trial assembly, dismantling of certain equipments / components for checking and cleaning, surface preparation, fabrication of sheets, tubes and pipes as per general engineering practice and as per BHEL engineer's instructions at site, cutting, gouging, weld depositing, grinding, straightening, chamfering, filing, chipping, drilling, reaming, scrapping, lapping, fitting up etc., as may be applicable in such erection works and which are treated incidental to the erection works and necessary to complete the work satisfactorily, shall be carried out by the contractor as part of the work within the quoted rates.
- 4.1.15 The contractor shall make all fixtures, temporary supports, steel structures required for jigs & fixtures, anchors for load and guide pulleys required for the work (excepting those specifically included in BHEL scope). However, necessary steel will be provided from the scrap / surplus materials available at site.
- 4.1.16 The contractor shall take delivery of the components, equipments, chemicals, lubricants etc from the BHEL stores/ storage area after getting the approval of BHEL engineer on standard indent forms of BHEL. Complete and detailed account of the materials and equipments after

usage shall be submitted to the BHEL and reconciled periodically. While taking delivery of items from store it may be necessary to handle (shift / relocate) other items (not necessarily those in the scope of the contractor). Separate payment will NOT be made if such situations arise.

- 4.1.17 Contractor shall plan and transport equipments, components from storage to erection site and erect them in such a manner and sequence that material accumulation at site does not lead to congestion at site of work. Materials shall be stacked neatly, preserved and stored in the contractor's shed and at work areas in an orderly manner. In case it is necessary to shift and re-stack the materials kept at work areas/ site to enable other agencies to carry out their work or for any other reason, contractor shall do it most expeditiously. No claim for extra payment for such work will be entertained.
- 4.1.18 Plant materials should not be used for any temporary supports / scaffolding / preparing pre-assembly bed etc.
- 4.1.19 **The services, tests and support to be provided by the agency for the work mentioned in various sections of this tender are indicative and not exhaustive, and not limited to these for completion of the work in all respects.**
- 4.1.20 All the work shall be carried out as per the instructions of BHEL engineer. BHEL engineer's decision regarding the correctness of the work and method of working shall be final and binding on the contractor.
- 4.1.21 **The weights & dimensions as mentioned against the individual items in Price Bid Part –II “Rate Schedule” are indicative approximate and there may be variation in dimension & weight in actual supply of equipment. No rate variation shall be considered on this account.**
- 4.1.22 The scope of work & description of system / equipment as given in the various clause of this tender specification and rate schedule are only for understanding the system requirement, contractor shall note this point and assess the volume of work prior to submitting the offer. No compensation shall be considered later on.
- 4.1.23 The contractor shall have total responsibility for all equipment and materials in his custody at contractor's stores, loose, semi-assembled, assembled or erected by him at site. He shall effectively protect the finished works from action of weather and from damages or defacement and shall also cover the finished parts immediately on completion of work as per BHEL engineer's instructions. The machine surfaces/finished surfaces should be greased and covered.
- 4.1.24 At all stages of work, equipments/materials in the custody of contractor, including those erected, will have to be preserved as per the instructions of BHEL.

- 4.1.25 The contractor shall make suitable security arrangements including employment of security personnel and ensure protection of all materials/equipment in their custody and installed equipments from theft/fire/pilferage and any other damages and losses.
- 4.1.26 Contractor shall collect all scrap materials periodically from various area of work site, deposit the same at one place earmarked at site or shift the same to a place earmarked in BHEL/ client's stores. In case of failure of contractor in compliance of this requirement, BHEL will make suitable arrangement at contractor's risk and cost.
- 4.1.27 The entire surplus, damaged, unused materials, packaging materials / containers, special transporting frames, gunny bags, etc., shall be returned to BHEL stores by the contractor.
- 4.1.28 The contractor shall not waste any materials issued to him. In case it is observed at any stage that the wastage/excess utilisation of materials is not within the permissible limits, recovery for the excess quantity used or wasted will be effected with departmental charges from the contractor. Decision of BHEL on this will be final and binding on the contractor.
- 4.1.29 For any class of work for which no specifications have been laid down in these specifications, work shall be executed as per the instructions of BHEL engineer.
- 4.1.30 House keeping in the erection and preassembly area is as important as well-planned and orderly work. The access to site for inspection, approaches by BHEL and customer engineers and leading of the material shall be made available by the contractor at all times. The shifting and re-shifting of erection materials, tools and plants and clearance of restrictions, filling of ditches, undulation near the pre-assembly and boiler area is the responsibility of the contractor. Contractor should visit the site and acquaint himself with all restrictions and difficulties that he may encounter during erection/commissioning stages.
- 4.1.31 The contractor shall take delivery of equipment, materials from the storage yard/ stores/sheds of BHEL/customer. He shall also make arrangements for verification of equipment, transportation up to site of work, safe custody, watch and ward of equipment after it has been handed over to him till these are fully erected, tested and commissioned and taken over by the customer. The contractor should note that the transport of equipments to erection site, assembly yards etc. should be done by the prescribed route without disturbing the other works and contractors and in the most professional manner. Special equipments such as measuring and control equipments, panels, console inserts, switches, cables, conduits etc. shall be stored when taken over by the contractor in appropriate manner as per BHEL's instructions.
- 4.1.32 The contractor shall handover all parts/materials remaining extra over the normal requirement with proper identification tags in a packed condition to

BHEL stores. In case of any misuse or use over actual design requirements, BHEL reserves the right to recover the cost of parts/materials used in excess or misused. Decision of BHEL engineer in this regard will be final and binding on the contractor.

- 4.1.33 The contractor should take all reasonable care to protect equipment and materials under his custody either in his stores or at site. Copper tubing, Copper bus bars, brass fittings, brass valves, contactors, etc., forming an integral part of equipment or system are liable to greater damages / pilferages /theft / losses. It will be responsibility of contractor to arrange for adequate security round the clock for protection from such damages/ pilferages/theft/losses .
- 4.1.34 The contractor shall ensure that all the packing materials and protection devices used for the various equipments during transit and storage are removed before these equipments are erected in position.
- 4.1.35 Overhauling, cleaning, revisioning, servicing of equipments during erection and commissioning stages will be arranged by the contractor. All equipments shall be preserved and protected before and after erection as per the advice of BHEL engineer.
- 4.1.36** Substantial portion of Cable laying & termination shall be done by other agencies for those equipment covered under this tender specification. The glands & lugs shall be supplied either loose or fitted with the equipments. Contractor shall take care of this aspect at the time of receipt of the equipment from BHEL stores. Contractor shall account for the quantities received with equipments and shall hand over the same to cabling agency under intimation to BHEL Engineer. Contractor shall extend all necessary help & co-ordinate with the cabling agency during the course of work.
- 4.1.37 Contractor shall prepare Marked-Up drawings incorporating modifications and deviations from original drawings or prepare fresh sketch for actual installation / connection details if need be, that can be converted to "As-built" drawing.

4.2 WELDING, NON-DESTRUCTIVE TESTING ETC.

- A) Installation of equipment involves good quality welding, NDE checks etc.
- B) Welder deployed for aluminium welding shall have experienced and approved by BHEL and MSEB after due qualification process/testing.
- C) Welding of all structural steel & aluminium shall be done only by the qualified and approved welders.
- D) All the welders shall be tested and approved by BHEL engineer before they are actually engaged on work though they may possess IBR/other certificate. BHEL reserves the right to reject any welder without assigning any reason.

- E) The welded surface shall be cleaned of slag and painted with primer paint to prevent corrosion. For this paint will be supplied by the contractor.
- F) Welding electrodes have to be stored in enclosures having temperature and humidity control arrangement. This enclosure shall meet BHEL specifications.
- G) Certain types of coated welding electrodes, prior to their use, call for baking for specified period and will have to be held at specified temperature for specified period. Also, during execution, the coated welding electrodes have to be carried in portable ovens.

4.3 TESTING, PRE-COMMISSIONING AND POST COMMISSIONING:

- 4.3.1 The contractor shall perform various activities during pre-commissioning, Integrated Testing, post-commissioning stages of equipment covered under this tender specification. It is responsibility of contractor to arranged tools & plants, test equipments, experienced engineers and technicians. Contractor shall earmark separate manpower for respective area of as specified in relevant clause and shall not be disturbed /diverted for other work. The contractor's commissioning group shall work as per the instruction of BHEL Engineer and they shall coordinate day-to-day activity with other agency and BHEL/ Customer. The testing activity may have to be repeated till satisfactory results are obtained and also to satisfy the requirement of Customer / statutory Authority.
- 4.3.2 The contractor shall simultaneously start testing & commissioning activities for equipments to match the mile stone activities of the project.
- 4.3.3 Mobilization of these commissioning groups shall be such that planned activities are taken up in time and also completed as per schedule and work undertaken round the clock if required. **It is responsibility of contractor to discuss on day to day / weekly / monthly basis the requirement of manpower, consumables, tools & tackles / testing equipments with BHEL Engineers and arrange for the same.** If at any time the requisite manpower, consumables etc are not arranged then BHEL shall make alternative arrangements and necessary recoveries with overhead cost will be made from the running bills.
- 4.3.4 Contractor shall cut/open work, if needed, as per BHEL engineer's instructions during commissioning for inspection, checking and make good the works after inspection is over.
- 4.3.5 It shall be specifically noted that the contractor may have to work round the clock and in shifts during the pre-commissioning and commissioning period along with or without BHEL engineers and hence considerable overtime payment is involved. The contractor's quoted rates shall be inclusive of all these factors.
- 4.3.6 In case any rework/ repair / rectification/ modification / fabrication etc is required because of contractor's faulty workmanship which are noticed during the commissioning of, at any stages, the same shall be rectified by the contractor at

his cost. If during the commissioning any improvement / repair / rework / rectification / fabrication / modification due to design improvement is required, the same shall be carried out by the contractor promptly and expeditiously. Claim if any, for such work from the contractor shall be governed by clause no. 13.1 to 13.8.

- 4.3.7 During the commissioning activities and carrying out various tests, if any of temporarily work such mounting of test equipments / cabling etc are required, the contractor shall carry out such work without on any extra cost. The same shall be removed after completion of the activity.
- 4.3.8 During this period, though BHEL/ client's staff will also be associated in the work, the contractor's responsibility will be to arrange for complete requirement of men and required Tools & Plants, Consumables, Scaffolding and approaches etc., till such time the commissioned unit is taken over for trial operations.
- 4.3.9 The contractor shall carry out any other tests as desired by BHEL engineer on erected equipment covered under the scope of this contract during testing, pre-commissioning and commissioning, to demonstrate the completion of any part or whole of work performed by the contractor.
- 4.3.10 The pre-commissioning activities will start in phased manner to meet the various milestones and shall continue till equipments are being commissioning fully with all connected drives/ equipment to HT/LT switchgear or handed over to customer for regular operation. In this duration other erection activities such as cabling or other work shall be carried out by other agency even though HT/LT switchgear board are charged. In order to co-ordinate the work such as issue of safety permit, normalization and compliance of other requirement, contractor shall keep team of one experience engineer / supervisor, technician and helper in each shift specially in 6.6 KV and 415 Volt switchgear rooms at each unit in three shift operation or as decided by BHEL Engineer. The team shall take instruction from BHEL Engineer for day-to-day work and shall not be diverted for other work. No extra payment shall be made for their services.

4.3.11 INTEGRATED ELECTRICAL TESTING/COMMISSIONING

The brief scope of work under is defined as below, but not limited to the following. Contractor shall discuss & finalize testing procedure with BHEL Engineer In-Charge for the test to be conducted on Generator Control & Relay Panel testing. Drawing & documents shall be provided by BHEL at the time of testing. BHEL decision in this regard shall be final and binding on the contractor.

The contractor shall prepare all erection / commissioning log sheets and protocols / test certificates as per field quality plan, get is signed by the concerned BHEL/Customer engineer and submit the same to BHEL engineer as per his instruction.

Contractor shall maintain the charged and commissioned equipment till the same is taken over by BHEL's end customer.

Contractor's quoted rates for all concerned items shall include Integrated Testing as defined hereinafter.

4.3.11.1 GENERATOR CONTROLS AND PROTECTIONS RELAY PANELS & ASSOCIATED EQUIPMENTS SUCH AS BUS DUCTS, GT, UNIT AUXILIARY TRANSFORMER etc.

1. Integrated Electrical testing/commissioning of Generator Control and Protection Relay Panels & associated equipment, etc. shall involve various activities like relay testing/setting, simulation checks, testing of energy meters, on/off line functional checks on integrated system.
2. Relay Testing in static condition for Generator, Transformers, and associated system by secondary current injection at different current and recording the time duration.
3. Testing and checking of control and protection interlock scheme in static condition and simulation of protection device contact from internal and external devices of all electrical panels.
4. Measurement of Insulations, Winding Resistance, Polarization Index of winding of Generator & associated equipment/ system.
5. Relay setting and checking the stability of protection relays in static and dynamic condition during the OCC (Open Circuit Characteristic) & SCC (Short Circuit Characteristic).
6. Functional checks / testing of synchronizing schemes, other electrical panels during the static and dynamic by simulation / back charging of generator transformer conditions.
7. Monitoring & recording the various parameters during open circuit and short circuit conditions test on generator & associated field equipment like generator transformer, unit auxiliary transformer. Recording and monitoring measurement.
8. Testing of protection current transformer for ratio test by primary injection, magnetization characteristic, polarity test, and IR measurement. Functional checks of relays of protection system by primary injection.
9. Testing of potential transformer for ratio test by voltage ratio, polarity test, insulation resistance measurement etc, testing of surge capacitors, PT isolator in PTPS cubicle etc.
10. Measurement of Insulation resistance of individual equipment and connected together.
11. Tan delta test on generator & other equipments as required.
12. Calibration of energy meters, tri-vector meters, voltmeters, ammeters, current & power transducers etc.

13. Providing temporary shorting link on bus duct or any other location while testing & normalisation after the test.

4.3.11.2 6.6 KV HT SWITCHGEAR, 415 VOLT LT SWITCHGEAR / MCC & DC DISTRIBUTION BOARD ETC

1. Checking of installation for correctness.
2. Mechanical functional checking/ adjustment of individual breaker.
3. Measurement of Insulation resistance of individual breaker, complete switchgear board and combined insulation resistance of individual breaker with cable connected to drives.
4. Testing of Protection Relay, Thermal over relay, Power transducers Energy/ Ammeters, Voltmeters, Power factor, frequency, tri-vector meters & metering etc. in static & dynamic condition relay
5. Conducting test such as Insulation Resistance measurement, Ratio, polarity, magnetisation characteristic, winding resistance on CT and PT.
6. Checking of electrical control & protection interlock of individual breaker and integration with other system.
7. Calibration of energy meters, tri-vector meters, voltmeters, ammeters, power current & voltage transducers etc.
8. Provide assistance for checking the electrical operation of individuals breakers from remote panels / MMI package.

4.3.11.2A

The following major works also shall be in the scope of the Contractor

1. Generator stator winding resistance and PI value measurement / check
2. Generator rotor winding resistance, impedance, IR value measurement / check
3. Generator Bushing HV test

Other than the above, minor testing / checks will also be involved in the generator area, which are also in the scope of the contractor. *Any instruments / tools etc required for carrying out the above shall be arranged by the contractor within the quoted rates.*

4.3.11.3 The scope of Testing and Assistance for Commissioning of electrically operated actuators for valves, dampers, gates, soot blowers etc., will include meggering, providing loop wire on actuator terminal block, adjustments of mechanical/ electrical or electronic position transmitters, setting of limit/torque switches, cable checking, internal wiring checking, local/remote operation from MCC & MMI package, replacement of limit/torque switches if required.

4.4.1 MEASUREMENTS & WASTAGE & CUTTING ALLOWANCES:

4.4.1 For all payment purposes, measurement shall be made on the basis of actual execution in line with drawings/documents/site requirements.

4.4.2 The measurement for cable, impulse pipes/tubes, GI pipe, conduits, flexible conduits, trays etc. shall be made on the basis of length actually laid.

4.4.3 All the surplus, scrap and serviceable materials, out of the quantity issued to the contractor shall be returned to BHEL in good condition and as directed by the engineer.

4.4.4 All materials returned to stores should carry an Aluminium tag indicating the size and type. More than 5 meters length shall be termed as serviceable and shall be returned size wise and category wise to the owner's stores/yard. Cable of serviceable length being returned to the stores in drums shall have their free ends sealed and the balance lengths on the drum(s) shall be noted and certified by the Engineer-in-charge. This shall be applicable only for the purpose of accounting the cables issued for installation.

4.4.5 While carrying out material appropriation with contractor, all the above points will be taken into account. All serviceable material returned by the contractor shall be deducted from the quantities issued for the respective sizes and categories and the balance quantity(ies) will be taken as the net quantity(ies) issued to the contractor. Material appropriation shall be done and allowable scrap quantity calculated as per wastage allowance percentage specified above. Any scrap/wastage generated by the contractor in excess of the allowable percentage shall be charged at the rates decided by the Engineer whose decision shall be final and binding on the contractor.

4.4.6 For all site-fabricated steel items such as supports, racks, frame, Canopy etc. physical measurement shall be made and then converted to tonnage. For steel material supplied to the contractor, all scrap shall be returned to BHEL stores with due accounting.

4.4.7 Every month the contractor shall submit an account for all the materials issued to him by BHEL in the standard Performa prescribed for this purpose by the site in charge.

4.4.8 The erection contractor shall make every effort to minimize wastage during erection work. Cutting and wastage allowance shall be computed on length/

weight of material actually used, measured and accepted. In any case, the wastage shall not exceed the following upper limits.

Sl No.	Item	% Wastage on issued Qty
01.	Each iron/steel section	2
02.	Each size of power cables	1
03.	Each size of control cables	2

4.4.9 If the actual wastage is more than the specified limits, cost of the excess portion will be recovered from the contractor's bill.

4.4.10 The cable take off from drums shall be planned strategically such that jointing in the run of cables and wastage are avoided. For this purpose the exact route length between various equipment/panels as per the cable schedule shall be measured and the route length recorded before laying of the cables. Depending upon the route length the type of cable required for various destinations, the cable drums should be suitably selected for cable laying. Any jointing shall be approved by the BHEL engineer. All the cut pieces/bits of cables, which are not used/unused, shall be returned to the purchaser for accounting towards wastage. The cables damaged by the contractor shall have to be replaced by the contractor at his own cost.

NOTES:

Salvageable scrap shall mean lengths of pipes, multi core cables, other cables etc., that can be used one time or other at a later date and normally they are recovered from the cut-pieces of pipes, multi core cables, other cables, etc.

Non - Salvageable scrap means the lengths of tubes, pipes, multi core cables, other cables etc., and they are from cut-pieces of tubes, pipes, multi core cables, other cables etc., that cannot be used at all one time or other.

4.5.0 For any items or class of work not specified herein but required for total completion of work, the same shall be carried out as per BHEL requirement. However, payment of these items/class of work shall be regulated on the basis of rate arrived at by either of the following methods:

- A) Based on rate of identical/similar items in the rate schedule.
- B) Based on the rate arrived from nearby items in the rate schedule.
- C) Wherever any item rate for similar type of work or nearby item rate does not exist in the rate schedule, rate will be worked out on the basis of work element or from fundamentals of estimation.

Contractor shall provide necessary resources for completion of such work within the stipulated time schedule. Value of such work shall be included while computing the total value of work finally executed for all contractual purposes, particularly for contract variation purpose.

4.6.0 The contractor's scope of work is further described in the clauses hereafter:

The work will comprise of, but not limited to the following:

4.6.1 INSTALLATION OF PANELS AND HT/LT SWITCHGEAR

1. Electrical control panels, electronic control panels, unit supervisory control desk, HT/LT switchgear, 415 volt LTMCC (if applicable), Analyser panels and transmitter racks/enclosure are normally supplied in suit of either one/two/three or loose shipping sections with integral base frame or loose base frame. These panels may have to be installed as stand alone or in groups consisting of number of panels in each row, depending upon the plant layout and foundation arrangement.
2. The panels shall be transported from stores to the place of installation in vertical position. Care shall be taken such that the switches, lamps, instruments etc. mounted on the panel do not get damaged during transit.
3. Installation of panel shall include fixing of base frame, levelling, alignment, fixing of anti-vibration pads, removal of side covers, fixing of cubicle interconnection hardware, interconnection of bus bar /bus bar jointing, wiring interconnection, welding and grouting of panels and base frames, mounting of panel canopy wherever supplied as part of panel, drilling of gland plates, sealing of panels/ cable entries. Where the base frame is not supplied as part of panel supply, the contractor shall fabricate the base frame from structural items at site. Payment for such fabrication will be effected on measured quantity at the rate applicable for structural steel fabrication and installation. Proper sealing of all the holes and cable entries (even if the cable has been laid by others) in the panel is in the contractor's scope.
4. Panels have to be shifted to their locations through floor openings, temporary openings like floor grills, door etc. which shall be a part of work and no claim whatsoever will be entertained with regard to non-availability of opening as per shortest route etc. Panels have to be erected at different locations and elevation in powerhouse building, LT & HT switchgear room, unit control room etc.
5. Panel and instruments once erected in position should be properly protected using necessary care to prevent ingress of dust/moisture. This will have to be periodically cleaned and surroundings have to be kept tidy.
6. Whenever the panels are to be mounted on cable trenches, channel supports have to be provided across the cable trench over which the base frame of panel shall be mounted. For such work, structural steel fabrication & installation rate shall be applicable.
7. Normally the panels shall be supplied with meters, relays, electronic modules, contactors, pushbuttons, etc., mounted and pre-wired. However, if such devices are supplied loose/separately for safety in transit, contractor shall mount the same, as part of panel installation work and no extra payment shall be made for this.

8. Supplier's instruction manuals, packing slips, door keys etc. received along with the panels will be handed over to BHEL's engineer on opening of the panels.
9. Regular cleaning of the panels as per the instruction of BHEL engineer till handing over of the set to customer is to be carried out by the contractor free of cost.
10. 24 / 48 Volt DC Interposing Relay along with mounting base shall be supplied separately for mounting in the various feeders of 6.6 KV HT switchgear boards and 415 Volt MCC Board / Switchgear Panel Boards for uni-directional / bi-directional drives, solenoid valves. 2 Nos. interposing relay may be required to be mounted in each feeder. Internal wiring for these relay shall be pre-wired in the feeders, wires to be terminated on relay terminals. Approximately quantity is 1500 Nos. Contractor shall mount the same and terminate the wire as part of panel installation work and no extra payment shall be made for this work.

4.6.2 STRUCTURAL STEEL FABRICATION AND INSTALLATION

A INSTRUMENT/ JUNCTION BOX FRAME/ CABLE TRAY & MISC STRUCTURES FABRICATION

1. Structural steel material like MS angles, channels, beams, flats, plates etc. shall be supplied in running meter and the same shall be used for fabrication of panel base frame, canopies for instruments/panels/ drives/JB/push buttons etc., instrument/junction box frames, impulse pipe/instrument air pipe supports and instruments etc.
2. This shall include cutting to size, contouring of ends for connections if required, welding, grinding of excess weld deposits/burrs, drilling of holes for mounting of device/instrument, installation at location, levelling, alignment, providing bracings and painting etc. No gas cut holes will be permitted. All paints, primers, etc are in the scope of the contractor.
3. All the fabricated supports/frames shall be painted as per painting specifications. Supply of all paints, primers etc shall be in contractor's scope.
4. Frame installation at site may involve mounting either on concrete floor by grouting/using anchor fasteners or on steel structure by welding etc. All consumables including anchor fasteners shall be arranged by the contractor. Where required, as part of work, concrete floors may have to be chipped out to reinforcement depth for anchoring the frames. Wherever grouting is required, contractor shall arrange all the required material including cement/grout mix, shuttering etc., necessary labour and meet all other requirements as part of work.
5. In case, structural cable trays, bends, tees, reducers etc., are required to be fabricated from structural steel and installed, unit rate applicable for fabrication and installation of structural steel shall be applicable in such instances.

6. In certain packages, members of frames/rack for mounting of junction boxes/instruments may be supplied readymade. These have to be assembled prior to installation. The installation rate as quoted shall include assembly of the frames.
7. **Gas cutting of tray/impulse pipe support and holes in frame is not permitted. Only hacksaw cutting/ drilled hole shall be permitted**

B CABLE TRAY SUPPORT

1. GI Structural material shall be supplied in standard length. The support member required for typical installation to be cut suit to site / lay out requirement from the straight length. Tray supporting members to be installed for typical installation as indicated in sectional arrangement of cable tray route plan. BHEL's customer shall provide projected dowels embedded in cable trenches for welding of supports. The support shall be either bolted or welded type as per drg. **No cutting by gas shall be permitted.**
2. Wherever supports needs to fixed on concrete slabs or ceiling with anchor fastener, and anchor fastener shall be arranged by contractor as part of work.
3. All galvanization damaged due to cutting / welding operation required to be carried out for the installation of cable support system shall be made good with application of cold galvanization paint (to be arranged by the contractor at his cost) immediately after completion of welding.

4.6.3 CABLE LAYING (POWER/CONTROL/INSTRUMENTATION SHIELDED CABLES/PLUG-IN CABLES/INTRA-PLANT BUS/DATA HIGHWAY, ARMoured/UN-ARMoured, SINGLE/MULTI-CORE, PVC/HR PVC/FRLS/TEFFLON/XLP INSULATION)

1. Cable laying includes cutting to the required length, laying in overhead / underground cable trench / through pipes / flexible conduits, dressing / clamping in tray (**all consumables for cable dressing, tagging, clamping etc., including aluminium trefoil and other clamps are in the scope of the contractor**), drilling of holes in gland plates in panels and junction box, glanding, splicing, dressing of spliced wire inside the panel and JBs, providing printed ferrules (**contractor to arrange ferrule printing machine(s) as required**), termination by using crimp type copper tinned/aluminium lugs, insulated/un-insulated, crimp and soldering termination, plug-in connections with insert type crimping, providing identification cable tags, PVC/aluminium at both the ends and at appropriate interval throughout the route length, continuity checking, insulation resistance checking, high voltage test on HT cables.
2. Entry to the panels, JB's may be at top, side or bottom. All cables are required to be supported and clamped near to the panel.
3. Wherever cable glanding is not possible, either due to the gland plate size limitations or more number of cable entries, pre-fab plug-in cables, for such cases, cables may have to be lifted inside the panel either making cut-out in gland plate and providing rubber profile for sharp edge protection or alternatively, provide 4/6"

PVC pipe coupling gland and these pipe coupling gland shall be supplied by contractor within the quoted rate of cable laying.

4. Supply of copper tinned lugs conforming to IS: 694 of various types (pin, ring, fork, snap-on) upto 4 sq.mm, PVC cable ties, printable ferrules, PVC button and tapes, cable identification tag of PVC/metal, clamping and dressing material with hardware, PVC sleeves etc. shall be supplied by contractor within the quoted rate for cable laying. The quality and make of cable lugs shall be got approved from BHEL engineer prior to their use on job.
5. All care should be taken to avoid abrasion, tension, twisting, kinking, stretching of cables during installation.
6. Cable shielding – all signal cables are supplied with bare shielded copper wire/with braided wire shield, general sealed wire is kept isolated at instrument/field device end and continuity is maintained through JBs and getting earth at panel end only. While terminated the sealed wire either in panel or JBs, PVC sleeves is to be used to avoid two-point earthing.
7. Wherever cable runs through the duct, conduit, valves, the entry and exit points shall be sealed using fire/weather proof compound. In addition to this, cable entry in panels, MCC/HT/LT breakers, instruments, electrical actuators etc. are also required to be similarly sealed. **The required material for doing so shall be included by contractor in the cable laying.**
8. Many of the cable trays and cables have to be laid in cable trenches. For this purpose, the cover of the trenches have to be opened for working in site and whenever the cables are to be laid in existing cable tray, all safety precautions have to be observed.
9. After completing the work, the trenches have to be cleaned and covers put back into position. Contractor shall also carry out de-watering from the trenches if required and arrange pumps etc. at his cost.
10. Looping wire at terminal block of panels and electrical actuator as shown in the inter-connection diagram is to be done by contractor at no extra cost.
11. **Contractor shall carefully plan the cutting schedule of each cable drum in consultation with BHEL site engineer such that wastages are minimised.** Recovery will be made in case the wastages are exceeding the wastage allowances fixed in this contract.

4.6.4 POWER TRANSFORMER

The scope of work under this head is defined as below.

1. Transportation of transformers tank and accessories from BHEL site stores/ Storage yard to the transformers foundation, erection, testing & commissioning.
2. The transformers shall be handled in such a manner so that no jerk is transferred to the core, winding and internals of the transformer.

3. Transformers are generally supplied in partly assembled condition either filled with oil upto the core end winding level or gas filled. Accessories, like radiators, conservator tank, pipes, fittings, hardwares, gaskets, buchholz relay, marshalling box, relief vent, valves, pumps, cooling fans, cables, bushings, radiator headers/fans, rollers, tap changer drive unit, cables of various sizes for interconnection from marshalling control box to field devices, bushing turrets and oil in 205/210 ltrs. barrels shall be supplied loose.
4. Contractor has to transport the transformer tanks & accessories of transformers from BHEL stores/ Storage yard to respective foundations. The approximate distance from BHEL Stores / Storage yard is 2.0 to 3.0 KM.
5. Generator Transformers etc., tank shall be made available to the contractor about **30 meters** away from the respective foundation, further transport and shifting to the foundation shall be in the scope of this work. The shifting operation may require dragging, fixing of wheels, rollers and turning of transformer to a suitable location en-route to suit the layout. The contractor shall arrange wooden sleepers, winches, jacks, rails and crane etc at his cost for this operation. However accessories shall have to be shifted from stores.
6. Placement on plinth, alignment with respect to the foundation and lay out drawings.
7. Internal inspection to verify the intactness of core and winding, tap changer leads, off-load switch, measurement of core and core bolt insulation.
8. In case of large capacity of transformers when supplied partly oil filled/gas filled, after internal inspection, the transformer shall be kept under vacuum for a period (to be decided by site engineer) and treated oil to be filled upto required level.
9. Each drums of oil to be tested for BDV and if BDV is less, then each drum should be filtered separately.
10. Contractor has to arrange storage tank of 10-kilolitre capacity with internally sand blasted and coated with one coat of oil resistance paint. Oil from drums to be transferred in storage tank and filtration to be carried out to achieve the required BDV/ withstand value. This treated oil to be filled in the transformers and auxiliaries. However, for low capacity of transformer, a separate storage tank for mass filtration may not be required.
11. All the accessories shall be assembled/mounted as per OGA drawings and these should be thoroughly cleaned prior to installation.
12. Drying out of transformer and filtration of oil in cooling bank, pipe line, diverter tank of tap changer etc. to be done with ultra vacuum filtering machine of adequate capacity and adequate numbers. Drying out process shall be carried out round-the-clock and contractor shall deploy trained

manpower for this purpose. If required, more than one filtration machine shall be used.

13. During dry out process, contractor has to plot the curve for insulation resistance value/time/oil temperature. Hourly reading to be recorded till completion of the dry out.
14. The criteria for deciding completion of drying out shall be breakdown value of oil, PPM value of contaminants in oil, resistivity of oil, insulation resistance value and polarisation index.
15. The filter machine(s) capacity if found to be inadequate, or in case of failure of existing machine(s), alternative arrangement is required to be done to meet the required result and time.
16. Due to unforeseen reasons if the commissioning of transformer is delayed after first drying out and if required, the contractor shall carry out the oil filtration of assembled transformer.
17. Contractor shall arrange required testing equipments for carrying out electrical test like voltage ratio, turn ratio, vector group, magnetic balance, winding resistance measurements, BDV value of oil, tan delta measurement of bushings & winding, insulation resistance, measurement of oil PPM, acidity, resistivity and tan delta test. The contractor shall arrange oil sample testing for PPM/resistivity or any other tests applicable for oil sample at approved testing laboratory at his own cost including all incidental expenses.
18. Contractor shall discuss and finalise installation and testing activity procedure with BHEL/customer prior to starting the work.
19. Contractor should have valid electrical contractor's licence to carry out installation of high voltage equipment.
20. Dry type transformer is supplied in sheet metal enclosure with natural/forced air-cooling. The contractor shall carry out all electrical tests as applicable for other transformer.

4.6.5 VARIABLE FREQUENCY DRIVE FOR I.D. FANS

VOID

4.6.6 ELECTROSTATIC PRECIPITATOR

1. ESP shall have four flue gas passes and each pass comprises of rectifier transformer (silicon oil filled), Auxiliary Control Panels, electronic controller, LT Main switch board and its bus duct, Drives for Rapping/Collecting/ Gas damper screen, heating element for hoppers/shaft and supporting insulator housing, ash level indicator and EP management system (software based) including computer interface and associated interlock and protection.
2. HV Rectifier Transformer shall be erected by other agencies engaged by BHEL. Scope of work covered under this contract is oil filtration of HV

Rectifier transformers and erection and testing of various devices as enlisted in rate schedule. Contractor shall provide silicon oil filter machine as a part of scope. Contractor has also to provide operator round-the-clock for oil filtration and other necessary testing equipments. Contractor shall utilise power supply for filter machine from the source, which is given for the construction purpose, and contractor shall arrange required cables.

4.6.7 ISOLATED PHASE BUS DUCT 11 KV, 6 KA CONTINUOUS AIR-COOLED.

1. GENERAL DESCRIPTION

Generator isolated bus duct is connected to low voltage side of Generator transformers 100 MVA and main bus duct shall have tee off connection for unit transformer, LAVT cubicles, excitation transformer and air pressurisation equipment. Bus duct consists of round / octagonal/ box hollow aluminium alloy conductor and supported inside aluminium enclosure with post insulator. Flexible connections and expansion joints are provided at terminals and intermediate point to alleviate stresses. Ring type protection current transformer will be mounted inside the bus duct.

Isolated phased bus duct shall have tap connection for potential transformer, surge protector etc. housed in a metal clad cubicle, UAT and NG cubicle/ resistor cubicle. Various electrical tests have to be performed before and after erection.

Bus duct enclosure /conductor is a continuous welded type. Conductor, enclosure, makeup pieces, shunts pieces etc have to be welded at site.

2. The scope of for Isolated Phase Bus Duct shall include Transportation of material from stores/ storage yard, preparatory work such as erection of supporting structure, placement of sub assemblies / equipments, alignment, edge preparation of conductor / enclosure, welding of conductor / enclosure, welding of shunt pieces & make up pieces, installation of seal of bushing & wall frame assemblies, shorting links, earthing, LAVT cubicle, copper flexible, copper rubber bellows, weldable / bolted flexible, installation of air pressurising unit and its associated piping work and cable etc, testing and commissioning.
3. Pre-fabricated G.I. supporting members shall be supplied loose and to be erected as per lay out drawing. Foundation pockets and embedded plate inserts shall be provided as per lay out drawing (on floor for bottom support and on bottom of concrete slabs). Contractor shall weld the supports on insert plate and shall carry out grouting including supply of grout materials after complete alignment/bolting of structural members. If any modifications are required in supporting structure due to site conditions, the same shall be carried out without any extra cost. All welded joints shall be applied cold galvanizing zinc paint (paint in the scope of the contractor).
4. Required aluminium welding of conductor, enclosures, shunt, make up pieces, aluminium flexible etc as detailed in drawings has to be carried out by contractor. MIG welding shall be applicable. Contractor shall arrange

necessary welding equipment/ accessory in sufficient number, filler wire, argon gas and other required consumables at his cost.

5. During erection of bus duct/enclosure, makeup pieces and shunts, if any modifications are needed to match the alignment, they shall be part of work and no extra payment shall be made.
6. All bolted joints and flanges shall be tightened with torque wrench to the approved torque. Wherever bolted joints, the same shall be cleaned and a layer of anti-oxidation paint shall be applied. Such paints etc will be arranged by the contractor within the quoted rates.
7. Top chamber/adaptor box for line and neutral side, hood assembly at UT, hood assembly at excitation transformer and at LAVT cubicle end shall have drilled hole in flange. If there is any mismatch of the hole in above with respect to the counter flange / welded studs provided on UAT, LAVT and excitation cubicle, the contractor shall drill new holes if required within the quoted rates.
8. Proper sequence shall be followed during erection to avoid any mismatch and alignment problem.
9. Prior to installation of bus duct assemblies in position, the various component like conductor, insulator shall be inspected and cleaned and insulation resistance to be measured and recorded. If any insulator found damaged, the same shall be replaced.
10. Electrical test on current transformers and potential transformers shall have to be carried out prior to installation & during pre-commissioning. The tests are insulation resistance measurement, winding resistance, magnetisation characteristic, ratio test, water ingress and air leak test on assembled bus-ducts.
11. Minor civil work such as chipping, levelling of foundation, providing pockets, drilling/enlargement of holes in structure, bus bar etc. which are incidental to the erection of bus duct shall not be treated as extra.
12. All miscellaneous items such as dis connecting links, flexible, shorting bars, hardware, conduit for wiring, marshalling box, CTs and PTs wiring through conduit, earthing materials, bus bar fish plates etc. are part of bus duct installation. Hence separate break-up quantity is not given in BOQ.
13. Round makeup pieces for main and tee off duct shall be supplied in two halves and it involves both circumferential and horizontal welding at parting plain.
14. Air tightness test have to be carried out on completion of bus duct installation. In case of any leakages, contractor has to rectify and bring to the required level of air tightness Without any extra cost.

15. High voltage test of bus duct is to be carried out as per the instruction of BHEL engineer. Contractor shall arrange necessary test equipment/ instrument for conducting various electrical tests at his own cost.
16. Contractor has to carry out final painting as per standard colour coat recommended by BHEL. Paints and consumables shall be in contractor's scope.
17. Shunt pieces shall be supplied in two halves and to be welded between two-phase bus ducts at transformer end. The shunt pieces to be welded on both the side on matching plane and bus duct circumference and horizontal plane
18. Contractor shall conduct 20 % radiography and 100% NDT test on welded joints.
19. Any enclosed drawings are for estimation and tendering purpose only. Contractor has to ascertain quantum of work involved. The BOQ as furnished in this tender specification for Isolated Phase Bus Duct & Segregated Phase Bus Duct are tentative / approximate. **Contractor has to ascertain the quantum of work involved and quote the lumpsum value, as called in the rate schedule, without any additional compensation for any variation in length or numbers of joints.**
20. One end of the enclosure to be earthed to the station earth at shunt location where all three-phase enclosures are shorted. Wherever shunts are not provided, each phase should be earthed separately.
21. In case of bolted bus-ducts, phase split covers, rubber bellows, clamping earth straps to be connected to maintain the electrical continuity and in turn enclosure gets earthed at one point.
22. All other equipment such as LAVT, NG transformer/ resistor cubicle, air pressurization, CT chambers, junction boxes, etc to be earthed at two points to the earth grid.

4.6.8 6.6 KV SEGREGATED PHASE BUS DUCT.

Each set of 6.6 KV Segregated phase bus duct shall be supplied complete with Aluminium alloy enclosure and conductor with epoxy bus support insulators arrangement, silica gel breathers, inspection windows, rubber bellows, flexible connector, bi-metallic strips etc. Galvanised iron earth bus shall be provided for enclosure continuity. All bolted joints shall have high tensile steel hardware cadmium plated. Each set of SP bus duct is meant for interconnection from low voltage side of Unit, Unit Auxiliary and Station Transformer to 6.6 KV switchgear board and bridging bus duct between the switchgear boards. The bus duct consists of rectangular conductor made of aluminium alloy supported on post insulator and housed in aluminium sheet metal rectangular enclosure. The bus bar enclosures are having bolted joints. The bus duct shall be supported either from bottom of the concrete slab with embedded insert plate/ TG building supporting structural members and pocket provided on foundations. The bus duct assemblies, supporting structures shall be pre-fabricated and to

be assembled as per lay out drawing. **Other erection and testing requirement shall be similar to the isolated phase bus duct, except the welding of bus bar and enclosures.**

Each set of bus duct shall be supported with supporting structure, which shall be fabricated from standard steel section and hot dip galvanised. All structure & bus duct assemble shall be erected as per drawings.

4.6.9 6.6 KV INDOOR SWITCHGEAR BOARDS

1. The scope of work includes transportation of material from stores / storage yard to erection site installation, testing and commissioning of switchgear . Contractor shall carry out works like fixing of base frame, fabrication of base frame if required, placement, levelling, alignment, fixing of anti-vibration pads if applicable, fixing of inter-connecting cubicle gasket, removal of side covers, fixing of cubicle inter-connecting hardware, bus bar jointing, wire inter-connection, fixing of safety barriers and shrouds, welding or grouting of panels with supply of grout material, drilling of holes in gland plates, ceiling of cable entry, chipping ,minor civil works etc. After completion of installation, various electrical tests to be conducted such as insulation resistance measurement, high voltage test, testing of CTs and PTs protection relays, meters, integrated electrical testing of control and protection system, mechanical checks of individual breaker etc. Contractor shall arrange all required testing equipments and consumables at his cost.
2. All the breakers are indoor type and shall be housed in 6.6 kV switchgear room. Panels have to be shifted to their location through floor opening, temporary opening like floor grills, doors, removing and re-fixing of grills for panel lifting shall be part of the work and no claim whatsoever will be entertained with regard to non-availability of opening as per the shortest route etc.
3. Normally breakers will be supplied complete with instrument, protection relays etc. mounted and pre-wired. However, if necessary, dismantling of existing component, making wiring modification to suit to operating condition, mounting and re-wiring of new component will be carried out without any extra cost if supplied loose for safety in transit to avoid damages .
4. Wherever breaker panels are to be mounted on cable trench, supports have to be provided across the cable trench over which the base frame of the panels shall be mounted.
5. The contractor has to do touch-up painting of switchgear panel wherever necessary. This includes supplies of paint.
6. Any drawings which are enclosed are for tendering purpose only. Contractor has to ascertain the quantum of work involved and quote lump- sum value as called in rate schedule.
7. After installation of switchgear board, for easy withdrawal of VCB truck, ISMC 75x500 mm to be grouted with suitable anchoring arrangement.

8. In addition to switchgear, which shall be installed as per layout and floor plan drawings, the following accessories shall be supplied which are required for testing and commissioning for maintenance purpose. Drawl of such material will be part of regular erection work. Contractor shall hand over to customer after completion of work as per the instruction of BHEL engineer without any extra cost.
 - 1) Set of accessories comprises of wedge type platform, spring charge handle, interlock and slow closing handle.
 - 2) Feeder earthing truck breaker type
 - 3) Bus bar earthing truck breaker type

4.6.10 SOOT BLOWER SYSTEM

Soot blower system comprises of motor control centre having various feeders of motor starters, micro-processor based PLC panel with mimic diagram and control station, push button boxes, junction boxes, wall blowers/LRSB with drive mechanism, integral control box with limit switch and internal wiring, inter connecting cables between field blowers and MCC, PLC panel etc. The scope of work for testing, commissioning covers the items/devices as per rate schedule and the testing, commissioning of blowers shall be carried out in close co-ordination with mechanical agencies who shall be erecting these blowers and contractor shall obtain clearance from BHEL engineer prior to start of work. The contractor shall carry out the following works under testing & commissioning:-

- 01 Pre-commissioning checks and tests on MCCs, blowers, PLC panels, energising of MCC and its feeders, wiring checks, insulation resistance measurements, testing of thermal over load relays etc.
- 02 Adjustment of limit switches, torque switches, internal wiring checks, minor wiring modification to suit to system requirements for HRSB /LRSB blowers.
- 03 Electric operation of each blower from local, MCC and PLC panels and from Unit control board.
- 04 Providing loop on terminal block of MCC individual feeders & blowers.
- 05 During pre-commissioning/post-commissioning of soot blower system, the component like TB's, limit switch, torque switch, over load relay, contactors etc. if found defective, contractor shall replace such components without any extra payment.

4.6.11 DIGITAL STATIC EXCITATION SYSTEM.

System comprises of regulation, field flushing, thyristor, field breaker panels, transformer trunking cubicle along with copper bus bar/flexible connectors/air duct and blowers/blower control box including internal wiring, and associated inter connecting cables.

4.6.12 ELECTRICAL HOIST

Electrically operated hoist of capacity varying from 3 MT to 35 MT are provided for maintenance purpose for ID/FD/PA fans, Mill area, Air Heater, ESP and other area in boiler. Mechanical erections of hoist components such as runway beams, hoist carriage, drive unit, etc. shall be done by other agency. The scope of work covered in this tender specification for erection & commissioning is installation of DSL system and associated accessories. The scope of work for the contract in this package is as under:

1. **TEE IRON TYPE DSL SYSTEM**:-It consists of tee iron guide for cable trolley and associated supporting structural members, trailing cable, cable guide trolley, dog chain, switch fuse unit, limit switch etc.
2. **TAUT WIRE TYPE DSL SYSTEM**:-It consists of end bracket, Galvanised wire rope, turn buckle/ straining bolt, real insulator,/cable guide trolley ,cable, switch fuse unit, rope clamps, leather bands, dog chain, limit switch etc.
3. DSL system shall have to be erected at higher elevation. Contractor shall take all safety measures while carrying out the work. **Erection of the above items is inclusive in the rate item for Electrical Hoist.**
4. Installation of tee iron & other structural steel member, unit rate for fabrication & installation shall be applicable and other items unit rate shall be paid, however cable dressing, fixing of leather bands, rope clamps and any incidental work such making approaches for executing the work, scaffolding etc. shall be part of work.
5. Commissioning & testing of electrical hoists shall includes panel wiring check, IR measurement, functional check, over load relay testing, trial run, providing assistance during load test, replacement of component if required etc. However, preparatory work for load test and arrangement of load etc. shall be done by other agency.

4.6.12A 415V MOTOR CONTROL CENTERS (MCC) & DC/AC DISTRIBUTION BOARDS

Motor control centres are double front draw –out/non-draw type consisting of circuit breakers units, contractor/starter, switch fuse units, MCC, Protection & metering relays/ instruments etc. arranged in multi tier construction. These PCC and MCC are mainly supplied to cater to the requirements of drives, valve actuators etc.

DC distribution Boards is single front non-draw out type consisting of circuit breakers, contactors, starters, fuse units, MCB etc arranged in multi-tier construction. Shall be located in LT switchgear room to cater the dc supply requirement.

The scope of work for the LT switch board and DCDB covers receipt of materials from stores, transportation to the respective location, erection, testing, commissioning and handing over.

Rubber mats shall be supplied by BHEL for HT/LT switchgear and the same shall be laid wherever required as part of work.

4.6.13 PAINTING

Colour Banding, Legend and Identification Marking, Direction marking etc. shall be in scope of the contractor for the work under scope of this contract.

4.6.13.1 TRANSFORMERS & BUS DUCTS

Exposed metal surfaces of Transformers and Bus Ducts erected by the contractor shall be painted with two coats of Finish Paint after thoroughly cleaning the surface from dust, rust, greases, oils, scales, etc, by wire brush, scrapping, machine buffing, water washing and any other appropriate method as specified in relevant erection documents. Bus Ducts shall first be coated with two coats of Primer before application of Finish Paint. Touch-up primer coat shall also be applied on Transformers as and where necessary. Supply of paints, etc for the above is in the scope of the contractor.

4.6.13.2 STRUCTURALS

Structural components may be supplied without any primer/paint coat from shop. The surface of such items shall be cleaned as per specifications and then coated with two coats of ROZC (IS:2074) Primer. Supply of Primer, etc is included in the scope of the contractor.

4.6.13.3 PANELS, JUNCTION BOXES

Panels and Junction Boxes shall be Touch-up painted as and where original shop paint is peeled off. Necessary surface cleaning and preparation shall be done by the contractor as per relevant painting codes followed by two coats of Primer and two coats of Finish Paint. All necessary paints, primers, etc are to be arranged by the contractor within the quoted rates.

4.7 PROVISION OF COMPUTER IN CONTRACTOR'S SITE OFFICE

The work under this scope being quite sophisticated and also quite extensive, for proper planning, monitoring, reporting, etc of ongoing works, the contractor shall establish his own computer(s) and printer(s) at his site office, along with suitable operator(s), consumables, etc . *Non-establishment of above equipment will attract penalty @ Rs 10,000 (Rs Ten thousand only) per month.*

BHEL uses its own software SOMS (Site Operation and Management System) for total project execution and billing. The contractor shall also provide adequate and suitable manpower within the quoted rates for updating / entries into SOMS in BHEL computers at site.

4.8 SHIFT OPERATION

During pre commissioning / commissioning stages when the plant will be under various stages of operation, it will be necessary to have continuous (day and night) presence of suitable manpower along with required tools to attend to any defects etc that may arise during such operation. The contractor will be required

to put such personnel in shifts in his area, within the quoted rates. The bidder must also take this aspect into consideration.

4.9

Equipments / instruments etc., under the above scope of erection and commissioning are generally despatched from BHEL's manufacturing units / vendor's works at site well before start of erection. Sometimes, such despatched materials may get stuck up with transporters/railways. The contractor shall provide suitable and experienced support / manpower for necessary chase up for removal of such bottlenecks in transportation. Also, for smaller items, it could be necessary to depute his person to personally carry certain items from works to site (or even from site to works in case of defective items being sent for repair). Requirement of above activities, which will be decided by BHEL engineer, shall be performed under authorization by BHEL. Approximately an average of 2 such visits in 3 months may be expected. The above services shall be provided within the quoted rates.

4.10 – INSTALLATION (ERECTION, TESTING AND COMMISSIONING) SUPERVISION SERVICES

The contractor shall extend various installation supervision services to BHEL site establishment as specified and explained in the following clauses. These installation supervision services are in addition to the scope of work specified in the clauses herein above in section-4 of special conditions of contract.

Separate item rate for these services are not envisaged. Bidder shall include the price of these services in rates being quoted for various items of work as per price bid.

4.10.1 **DETAILS OF MAJOR PRODUCT AREAS REQUIRING INSTALLATION (ERECTION, TESTING AND COMMISSIONING) SUPERVISION SERVICES**

The contractor shall provide to BHEL installation supervision services for the installation of various equipments/components/assemblies/sub-assemblies/parts etc. **This service shall be available to BHEL irrespective of terminal points of erection testing and commissioning work covered under this tender.** BHEL may use these services at its discretion. The service categories are:

1. HT and LT Transformers: One service point
2. HT switchgears : One service point
3. LT switchgears : One service point
4. Busducts : One service point
5. ESP: One service point
6. Electrical Valves and dampers: One Service point

4.10.2 **SCOPE OF INSTALLATION (ERECTION, TESTING AND COMMISSIONING) SUPERVISION SERVICES**

4.10.2.A

The contractor under this contract shall provide services towards installation (erection, testing and commissioning) supervision as per instructions of BHEL engineer for the relevant product system assigned as above for the time being and shall broadly include the following responsibilities:

- Studying the relevant drawings, documents etc. of concerned product/ system
- Draw out periodical plans with the engineers/supervisors of the contractor deployed for direct on the job supervision.
- Check with the stores the receipt of required materials for the current plan and for the period ahead as may be directed.
- Check the materials for correctness and soundness and ensure proper stacking, storage, preservation of materials brought to site for erection, refer and implement concerned documents in this regard.
- Ensure proper handling of materials during all site activities.
- Assist contractor in tracing of materials wherever required and as instructed
- Study, understand and implement the erection, testing & commissioning procedures/manuals requirements as applicable. Seek guidance of BHEL engineer wherever required.
- Study the relevant field quality plans and understand requirements of quality checks especially with regard to customer check points.
- Carry out all erection, testing and commissioning activities as planned/ instructed.
- Carry out all field checks along with contractor.
- Ensure implementation of safety instructions.
- Verify daily/ periodical reports and maintain progress registers
- Ensure filling of all protocols/ log sheets/ check lists etc
- Ensure material re-conciliation with contractor regularly.

4.10.2.B EXPECTED MINIMUM QUALITY OF SERVICE

Contractor shall render the installation (erection, testing and commissioning) supervisory services by ensuring deployment of requisite personnel with adequate educational qualification in engineering and possessing valid and current certificates wherever applicable, having thorough field experience to enable understanding the intricacies of and special requirements involved in erection, testing and commissioning of projects, taking care of inconsistencies and uncertainties associated with flow of project activities. These personnel would be required to work beyond normal working hours, on holidays and irregular working hours. Contractor shall ensure prompt and timely availability of such services as and when required by BHEL. The CV of such personnel shall be submitted to concerned BHEL engineer for approval at site before them being deployed.

4.10.3 PARAMETERS AND QUANTIFICATION OF INSTALLATION (ERECTION, TESTING AND COMMISSIONING) SUPERVISION SERVICES, PERIODIC MONITORING

For the purpose of delivery of the aforesaid installation (erection, testing and commissioning) supervision services & progressive monthly billing by the contractor and release of payment thereof by BHEL, there shall be an action plan jointly agreed by BHEL and contractor. This action plan shall be drawn at the beginning of each quarter/each month/any convenient number of months as per actual project need. The plan shall detail the following aspects.

- Plan period (number of months planned).
- List of activities/targets to be carried out/achieved by the contractor under the scope of these installation (erection, testing and commissioning) supervision services in the defined plan period.
- Identification of necessary resources to be deployed by the contractor for delivery of the planned activities/targets in the defined plan period.
- Deciding on the break up of the assigned amount towards installation (erection, testing and commissioning) supervision services in the plan period for the purpose of monthly billing by contractor and payment by bhel.

4.10.4 PRICE AND STAGE PAYMENT

Contractor shall include the price for rendering complete installation (erection, testing and commissioning) supervision services in the various item rates as appearing in the rate schedule of price bid. Contractor shall not quote any separate item rate/price for installation (erection, testing and commissioning) supervision services in the rate schedule.

4.10.5 DEFICIENT/UNSATISFACTORY INSTALLATION SUPERVISION SERVICES & NOT RENDERING INSTALLATION SUPERVISION SERVICES

4.10.5.1

Contractor shall render the installation (erection, testing and commissioning) supervision services as per the jointly agreed plan and parameters thereof as described in “parameters and quantification of installation (erection, testing and commissioning) supervision services”. In case the contractor fails in delivering/ rendering these services partly or totally, either qualitatively or quantitatively in the concerned plan period, bhel will take the following recourse.

- **Deficient/unsatisfactory services:**

In case the level/quality of installation supervision services is found not in compliance with the plan (either in terms of deficiency in quality or quantity or both, with regard to the mutually agreed/identified resources), bhel will communicate the same to the contractor on record. Contractor shall immediately take corrective action to eradicate the complaint. BHEL will not make any payments for such period / number of days when services are found deficient/ unsatisfactory. Payment will be made for the period /number of days of satisfactory services on pro-rata basis as per the following formula.

$P = P_a \times D_s / D_m$, where

P = amount payable for rendering the installation supervision service satisfactorily in a billing month.

P_a = amount assigned towards the installation supervision service for the concerned month as per agreed plan (10% of RA Bill value).

D_s = number of equivalent days including Sundays and BHEL holidays of satisfactory services rendered in the particular billing month.

D_m = total number of days including Sundays and BHEL holidays in the particular billing month.

In addition to no payment for the unsatisfactory/deficient services period, a penalty @ 5% applied on the pro-rata amount of the deficient period i.e. 5% of ($P_a - P$) will be levied on the contractor. This penalty will be recovered from the running account bill of the same month.

4.10.5.2 NOT RENDERING THE SERVICES AT ALL

In the event, the contractor fails to render a particular service during the month (either part of the month or full) BHEL will not make any payment towards that service for such period. Additionally, a penalty @ 15% will be levied as under.

For no service in the entire month:	15% of the total monthly assigned amount.
-------------------------------------	---

For no services during part of the month:	15% of the pro-rata amount for the defaulting period as per formula given earlier here.
---	---

4.10.6 IRREVOCABLE PENALTY AND DISALLOWED AMOUNT

It shall be specifically noted that the payment disallowed for deficient or nil service in a particular month and/or penalties levied on similar ground, shall not be considered for release in any subsequent month even if the contractor takes corrective action in the later stage.

4.11 EXCLUSIONS

The following are specific exclusions from this work.

1. Erection of dampers, valves, electrical actuators, pneumatic actuators.
2. Erection of ESP rectifier transformer, electrical heaters, rapping motors, mechanical interlocks.
3. Erection of HT/LT motors (**Commissioning included in scope**)
4. Erection, testing and commissioning of elevators and DG sets.

Note:

The aforesaid exclusions should not be construed as exhaustive. They are meant for general guideline. BHEL reserves the right to include or exclude any item, which is required for completing the job as per rates, indicated in rate schedule. Contractor should carry out all such jobs as per the instructions of BHEL engineer.

Section-5

Special Conditions of Contract

5.0 Obligations of the Contractor (Tools, Tackles, Consumables etc.)

5.1 Labour Colony

BHEL'S customer will provide the open land with single point for drinking water and electricity. Contractor shall make further arrangements for constructing the labour colony and including lighting, water distribution and suitable provisions of drainage/sanitation.

5.2 Tools & Plants and MMD

5.2.1

The contractor shall provide all required Tools and Plants, inspection, Measuring and Monitoring Devices (MMD), Handling & Transportation Equipments for the scope of work covered under these specifications in addition to the T&P indicated to be provided by BHEL in **Appendix-I**. An indicative list of major T&P and MMD to be deployed by the Contractor is given in the **Appendix-III**. It may be noted that this list does not intend to exhaustively cover the contractor's responsibility with regard to T&P to be deployed by him. BHEL will provide the services of their T & P listed in Appendix-I, free of charge, on sharing basis. Refer section-7 for further details with regard to BHEL's T&P.

5.2.2

All tools and tackles to be deployed by the contractor for the work shall have the prior approval of BHEL engineer with regard to brand, quality and specification.

5.2.3

Timely deployment of adequate quantity of T&P is the responsibility of the contractor. The contractor shall be prepared to augment the T&P at short notice to match the planned targets and to achieve the milestones.

5.2.4

Contractor shall maintain and operate his tools and plants in such a way that major breakdowns are avoided. In the event of major breakdown, contractor shall make alternate arrangements expeditiously so that the progress of work is not hampered.

5.2.5

In the event of contractor failing to arrange the required tools, plants, machinery, equipment, material or non-availability of the same owing to breakdown, BHEL will make the alternate arrangement at the risk and cost of the contractor.

5.2.6

The T&P to be arranged by the contractor shall be in proper working condition. The operation shall not lead to unsafe condition. The movements of cranes, and other equipment should be such that no damage/breaking occur to foundation, equipment,

material and men. All arrangements for the movement of his T&P etc, shall be the contractor's responsibility.

5.2.7

Normally, for welding only the use of welding generators/rectifiers will be permitted. The use of welding transformers will be subject to the approval of BHEL engineer.

5.2.8

The contractor at his cost shall carry out periodical testing of his construction equipments and calibration of measuring instruments (MMD) and tests. Test/ calibration certificates shall be furnished to BHEL. MMD shall be calibrated only at accredited laboratory as per the list available with BHEL or any other laboratory approved by BHEL.

The contractor shall provide all the necessary steel scaffolding materials, temporary structures and necessary safety devices etc. during preassembly, calibration, erection, testing and commissioning of the equipment.

Contractor shall maintain and operate his tools, plants, calibrating instruments etc. in such a way that major breakdowns are avoided. In the event of major breakdown, the contractor shall make alternate arrangements expeditiously so that the progress of the work is not hampered.

5.3 Consumables

5.3.1

The contractor shall provide all consumables required for carrying out the work covered under these specifications excepting those, which are specifically indicated as BHEL scope.

5.3.2

All consumables to be used for the work shall have prior approval of BHEL engineer with regard to brand and quality specifications. Test reports/ certificates in respect of these consumables, wherever applicable, shall be submitted to BHEL engineer.

5.3.3 Primers, Paints etc.

The contractor shall provide Primer (ROZC as per IS:2074), Synthetic Enamel Paint (IS:2932) and Aluminum Paint – as necessary for respective painting area for the scope of painting work indicated in Section-4 as well as for protection of site weld joints and gas cut locations. Contractor shall also arrange to provide the required thinner and other consumables, T&P and implements etc. required for application of Primer and Paints. All primers, paints and thinners shall be sourced by contractor only from BHEL approved manufacturers. Some of them are as listed under.

- 1) M/s Asian Paints
- 2) M/s Berger paints
- 3) M/s Jenson & Nicholson
- 4) M/s Shalimar Paints
- 5) Any other BHEL approved manufacturer.

5.4 Welding Electrodes, Filler Wires for MIG/TIG Welding and Gases

5.4.1

Contractor at his cost shall arrange all the required welding electrodes as approved by BHEL. It shall be the responsibility of the contractor to obtain prior approval of BHEL, regarding manufacturer, type and brand name of welding electrodes etc. On receipt of the electrodes at site, it shall be subject to inspection and approval by BHEL regarding type of electrodes, batch number, date of expiry etc. Batch test certificates shall be made available to BHEL for verification & records.

BHEL reserves the right to reject the use of any electrodes, if found non-acceptable because of bad quality, deterioration in quality due to improper storage, shelf-life expiry, unapproved type/brand etc

5.4.2

All the required gases for welding and gas cutting like Oxygen, Acetylene, Argon (welding quality), Nitrogen etc. shall be arranged by the contractor at his cost.

5.4.3

If at any time during the execution of work, it is noticed that the work is suffering on account of non-availability of consumables from the contractor's side BHEL will make alternate arrangements at the risk and cost of contractor. The expenditure incurred with overheads will be recovered from the contractor.

5.4.4 TEST PIECES FOR WELDERS QUALIFICATION TEST.

Materials for Test Pieces for qualification of structural welders shall be supplied by the Contractor. Contractor shall also prepare the test coupons from such materials. All expenses in respect of welders' qualification test shall be to the contractors account.

5.5 Field Office

5.5.1

The contractor shall make his own arrangements for field office and stores for accommodating necessary equipments, tools room for execution of the work. Only open space will be provided by BHEL's customer free of charges within the project premises as per the availability of space.

5.5.2

On completion of work, all the temporary buildings, structures, pipelines, cables, etc shall be dismantled and leveled and debris shall be removed as per instruction of BHEL by the contractor at his cost. In the event of his failure to do so, the same will be arranged to be removed and expenditure thereof will be recovered from the contractor. The decision of BHEL engineer in this regard shall be final. However, the scope of dismantling and leveling the area is limited only to the contractor's site office, yard and other spaces occupied by the contractor.

5.6 Area Lighting

Contractor shall arrange adequate floodlights, hand lamps and area lighting. Provision of distribution lines for lighting from the single point to the required place with proper

distribution boards, observing the safety rules laid down by the electrical authorities of the state shall be done by the contractor including all the materials like cables, fuses, switch boards etc

5.7 Construction Power & Water

5.7.1

Construction power (415 V / 440 V, 200 AMPS, 4 WIRE) will be provided at a single point near the site on chargeable basis. All Taxes, duties, Levies, Charges etc as applicable shall be borne by the contractor. Additional source at the discretion of BHEL may also be provided if need arises. The contractor shall provide all necessary cables, fuses, switches, switchboards, MCCB, energy meters etc, and any other installation as specified by statutory authority in this regard for further drawl of power. Obtaining approvals / clearance of such installations, prior to their being put to use or as may be specified, shall be the responsibility of the contractor.

5.7.2

It shall be the responsibility of the contractor to provide, maintain the complete installation on the load side of the supply with due regard to the safety requirements at site. All cabling and installations shall comply in all respects with the appropriate statutory requirements.

5.7.3

The Customer will provide water for Construction purpose a single point on chargeable basis. All Taxes, duties, Levies, Charges etc as applicable shall be borne by the contractor. All arrangements for further distribution beyond this point shall be made by the contractor. The contractor shall make his own arrangement for drinking water by drilling suitable bore wells or any other arrangement at his cost.

5.7.4

In case of non-availability of customer supplied power, it is the responsibility of the contractor to make alternate arrangements. Contractor shall be adequately equipped to arrange standby diesel welding generators in the event of construction power failure. Essential welding jobs shall not be stopped on account of main construction power failure.

5.7.5

BHEL is not responsible for any loss or damage to the contractor's equipment as a result of variations in voltage or frequency or interruptions in power supply.

5.8 Contract Labour

5.8.1

The contractor in the event of his engaging 10 or more workmen will obtain independent license under the Contract Labour (regulations and abolition) Act 1970 from the concerned authorities based on the certificate (form –V) issued by the principal employer/customer.

5.8.2 Provident Fund

Contractor will deduct the necessary amount from his employees towards provident fund and contribute equal amount as per government of India labour laws. Contractor regularly to the provident fund commissioner and get the account code will deposit this amount. Contractor shall submit the account code duly certified by pf commissioner to BHEL project in-charge.

5.8.3

Contractor shall also comply with the provisions of ESIS act in vogue and submit evidence thereof to BHEL site in-charge. All other expenses such as employees' benefits to be borne by the contractor as per the labour laws. Contractor shall produce necessary certificates towards their compliance with such statutes and payment of all statutory dues.

5.8.4

Contractor shall also comply with the requirements of local authorities/ project authorities calling for police verification of antecedents of the workmen, staff etc

5.8.5

Where applicable, provisions of workman compensation act shall be adhered to.

5.8.6

BHEL/customer may insist upon witnessing the regular payment to the labour. They may also like to verify the relevant records for compliance with statutory requirements. Contractor shall enable such facilities to BHEL/ Customer.

TAXES, DUTIES, LEVIES

5.9

Refer to Clause 2.8.4 of General Conditions of Contract. Notwithstanding anything contained therein, the following provisions shall be applicable for this contract.

5.9.1

The contractor shall pay all (save the specific exclusions as enumerated in this contract) taxes, fees, license charges, deposits, duties, tools, royalty, commissions or other charges which may be levied on the input goods & services consumed and output goods & services delivered in course of his operations in executing the contract. In case BHEL is forced to pay any of such taxes, BHEL shall have the right to recover the same from his bills or otherwise as deemed fit.

However, provisions regarding Service Tax and Value Added Tax (VAT) on output services and goods shall be as per following clauses.

5.9.2 Service Tax & Cess on Service Tax

Service Tax and Cess on Service Tax as applicable on output Services are excluded from contractor's scope; therefore contractor's price/rates shall be **exclusive** of Service Tax and Cess on Output Services. In case, it becomes mandatory for the contractor under provisions of relevant act/law to collect the Service Tax & Cess from BHEL and deposit the same with the concerned tax authorities, such applicable

amount will be paid by BHEL. Contractor shall submit to BHEL documentary evidence of Service Tax registration and remittance record of such tax immediately after depositing the tax with concerned authorities. Contractor shall obtain prior written consent from BHEL before billing the amount towards such taxes.

With introduction of Cenvat Credit Rules 2004, which came into force w.e.f. 10.09.2004, Excise Duty paid on Input Goods including Capital Goods and Service Tax paid on Input Services that are used for providing the output services can be taken credit of against the Service Tax payable on output services. However BHEL may opt for availing the abatement provision in which case cenvat credit may not be available on input duty.

5.9.3 VAT (Sales Tax /WCT)

As regards Value Added Tax (VAT) on transfer of property in goods involved in Works Contract (previously known as Works Contract Tax) applicable as per local laws, the price quoted by the contractor shall be **exclusive** of the same. Where such taxes are required to be paid by the contractor, this will be reimbursed on production of proof of payment made to the authorities by the Contractor. In any case the Contractor shall register himself with the respective Sales Tax authorities of the state and submit proof of such registration to BHEL along with the first RA bill. The contractor has to take all necessary steps to **minimize tax on input goods** by purchasing the materials from any registered dealer of the concerned state only. In case contractor opts for composition, it will be with the prior express consent of BHEL. Deduction of tax at source shall be made as per the provisions of law unless otherwise found exempted. In case tax is deducted at source as per the provisions of law, this is to be construed as an advance tax paid by the contractor and no reimbursement thereof will be made unless specifically agreed to.

5.9.4 Modalities of Tax Incidence on BHEL

Wherever the relevant tax laws permit more than one option or methodology for discharging the liability of tax/levy/duty, BHEL will have the right to adopt the appropriate one considering the amount of tax liability on BHEL/Client as well as procedural simplicity with regard to assessment of the liability. The option chosen by BHEL shall be binding on the Contractor for discharging the obligation of BHEL in respect of the tax liability to the Contractor.

5.9.5 New Taxes/Levies

In case the Government imposes any new levy/tax on the output service/ goods/work after award of the contract, the same shall be reimbursed by BHEL at actual.

In case any new tax/levy/duty etc. becomes applicable after the date of Bidder's offer, the Bidder/Contractor must convey its impact on his price duly substantiated by documentary evidence in support of the same **before opening of Price Bid**. Claim for any such impact after opening the Price Bid will not be considered by BHEL for reimbursement of tax or reassessment of offer.

No reimbursement/recovery on account of increase/reduction in the rate of taxes, levies, duties etc. on input goods/services/work shall be made. Such impact shall be taken care of by the Price Variation/Adjustment Clause (PVC) if any. In case PVC is

not applicable for the contract, Bidder has to make his own assessment of the impact of future variation if any, in rates of taxes/duties/ levies etc. in his price bid.

5.10 Submission of Periodical Reports

Contractor shall submit periodical reports in respect of following aspects of operation:

- 1) Consumption of welding electrodes and gases
- 2) Consumption of construction power
- 3) Manpower reports
- 4) Progress reports – periodically
- 5) Field calibration reports

BHEL at site will inform formats for these reports.

5.11

It is the responsibility of the contractor to arrange gate pass for all his employees, T&P etc. Necessary coordination with customer officials is the responsibility of the contractor. Contractor to follow all the procedures laid-down by the customer for making gate passes. Where permitted, by customer/ BHEL, to work beyond normal working hours, the contractor shall arrange necessary work permit for working beyond normal working hours.

5.12 ELECTRICAL INSPECTORATE'S APPROVAL /STATUTORY INSPECTION

5.12.1 Contractor shall have/obtain valid Electrical Contractors License to carry out the Erection, Testing & Commissioning work on High/Low Voltage Electrical Equipments from the appropriate statutory authority of the concerned state or Central Electricity Authority, as the case may be. All fees and expenses in this regard shall be in the contractor's account.

5.12.2 Contractor shall arrange inspection of concerned Statutory Authority for the installation, testing & commissioning of High / Low voltage equipments covered under the scope of work in this tender specification and obtain their approval in appropriate format prior to charging of the equipments.

5.12.3 Contractor shall be responsible for all necessary liaisoning work with Statutory Authority towards the certification of installation / works. BHEL will pay Statutory Fees in respect of inspection of installations as per demand note/challan issued by the statutory authority. All other expenses shall be borne by the Contractor. BHEL/ BHEL's Customer shall be providing technical assistance, drawing & document for submission to Statutory Authority. Contractor shall provide all logistics services in this regard.

Section-6

Special Conditions of Contract

6.1 Contractor's Obligation with Regard to Employment of Supervisory Staff and Workmen

The contractor shall deploy all the skilled/semiskilled/ unskilled labour including highly skilled workmen like high-pressure welders etc. These workmen should have previous experience on similar job. They shall hold valid certificates wherever necessary. BHEL reserves the right to insist on removal of any employee of the contractor at any time if he is found to be unsuitable and the contractor shall forthwith remove him. Contractor should furnish a tentative deployment plan of his manpower as required vide appendix-IV. Also the actual deployment will be so as to satisfy the erection and commissioning targets set by BHEL.

6.2

It is the responsibility of the contractor to engage his workmen in shifts and or on overtime basis for achieving the targets set by BHEL. This target may be set to suit BHEL's commitments to its customer or to advance date of completion of events or due to other reasons. The decision of BHEL in regard to setting the erection and commissioning targets will be final and binding on the contractor.

6.3

Contractor shall deploy only qualified and experienced engineers/ supervisors. They shall have professional approach in executing the work.

6.4

The contractor's supervisory staff shall execute the work in the most professional manner in the stipulated time. Accuracy of work and aesthetic finish are essential part of this contract. They shall be responsible to ensure that the assembly and workmanship conform to dimensions and tolerances given in the drawings/instructions given by BHEL engineer from time to time.

6.5

The supervisory staff employed by the contractor shall ensure proper outturn of work and discipline on the part of the labour put on the job by the contractor. Also in general they should see that the works are carried out in a safe and proper manner and in coordination with other labour and staff employed directly by BHEL or other contractors of BHEL /customer.

6.6 WATCH AND WARD

Contractor has to arrange and provide watch and ward round the clock. Any theft or damage of component due to negligence of the contractor will have to be replaced/ repaired by the contractor. The areas are unit control/ESP control room and field.

6.7 Industrial Relations and Labour Laws

An industrial relations supervisor shall coordinate for the implementation of local labour laws, maintenance of records as required by contract labour (regulation and abolition) act and also coordinate with the local labour authorities and any other such authorities under whom this work falls.

6.8

If at any time, it is found that the contractor is not in a position to deploy the required engineers/supervisors/workmen due to any reason, BHEL shall have the option to make alternate arrangements at the contractor's risk and cost.

6.9 Site Organization.

Contractor shall employ only qualified and experienced engineers/supervisors for this job. They shall have professional approach in executing the work having adequate knowledge and experience in the fields of erection, erection methodology, calibration, testing and commissioning, quality control and quality assurance procedures, planning, safety etc., required to undertake the type of work as per this tender.

The contractor's supervisory staff shall execute the work in the most substantial and workmanlike manner in the stipulated time. Accuracy of work and aesthetic finish are essential part of this contract. They shall be responsible to ensure that the assembly and workmanship conform to dimensions and tolerances given in the drawings/ instructions given by bhel engineer from time to time.

The supervisory staff employed by the contractor shall ensure proper outturn of work and discipline on the part of the labour put on the job by the contractor and in general, see that the works are carried out in a safe and proper manner in coordination with other labour and staff employed directly by BHEL or other contractors of BHEL or BHEL's client.

Contractor should provide a team of engineers with proven experience of erection, testing/ commissioning of electrical equipments as specified in tender specification. They shall be in a position to undertake specific assignments during the start up/ post start up/stabilization.

The contractor shall deploy adequate labourers and supervisory staff in the following areas.

- A) Overall planning, monitoring & control
- B) Equipments Erection
- C) Welding & NDT & Stress Relieving operators, induction.
- D) Testing & Commissioning
- E) Quality Control and Quality Assurance
- F) Materials Management
- G) Safety, Fire & Security
- H) Industrial Relations and Fulfillment of Labour Laws and Other Statutory Obligations.

Contractor shall furnish an organization chart indicating the staffing pattern for the above functions. Contractor shall provide the names and details of engineer/ supervisors at the time of mobilization to BHEL as per the proposed organization chart.

Section-7

Special Conditions

7.0 Obligations Of BHEL

7.1 Facilities Provided By BHEL

7.2 Space For Field Office

Refer section-5 in this regard.

7.3 Construction Water

Refer section-5 in this regard.

7.4 Construction Power

Refer section-5 in this regard.

7.5 Other Materials and Consumables:

BHEL will supply consumables free of charges as listed in **Appendix-II**.

7.6 Test Blanks (Plates & Pipes)

Test pieces for qualification of structural welders shall be supplied by the Contractor.

7.7 Filler Wire and Welding Electrodes

All the welding consumables shall be arranged by contractor.

7.8 Tools & Plants

BHEL will provide the Tools & Plants listed in **Appendix—I** free of charges on sharing basis.

BHEL will also provide any special tools that are supplied by BHEL manufacturing units/vendors/suppliers as special installation tools under regular DU/DESS numbers in various product groups free to contractor. Contractor shall return these tools after the completion of the specific task for which such tools are intended, in good working order after proper servicing/overhauling.

Section-8

Special Conditions of Contract

8.0 Inspection/Quality Assurance/Quality Control/ Statutory Inspection

- 8.1 Various inspection/quality control/quality assurance procedures/methods at various stages of erection and commissioning will be as per BHEL/customer quality control procedure/codes and other statutory provisions and as per BHEL engineer's instructions.
- 8.2 Preparation of quality assurance log sheets and protocols with customer/consultants/statutory authority, welding logs, NDE records, testing & calibration records and other quality control and quality assurance documentation as per BHEL engineer's instructions, is within the scope of work/specification. These records shall be submitted to BHEL/customer for approval from time to time.
- 8.3 A daily logbook of all measurements and testing/calibration should be maintained by contractor on the job for detailing inspection details of various equipments.
- 8.4 The performance of welders will be reviewed from time to time as per the BHEL standards. Welders' performance record shall be furnished periodically. Corrective action as informed by BHEL shall be taken in respect of those welders not conforming to these standards. This may include removal/ discontinuance of concerned welder(s). Contractor shall arrange for the alternate welders immediately.
- 8.5 All the welders shall carry identity cards as per the proforma prescribed by BHEL only welders duly authorized by BHEL/customer/consultant shall be engaged on the work.
- 8.6 Contractor shall provide all the measuring monitoring devices (MMDs) required for completion of the work satisfactorily. These MMDs shall conform to job requirement in respect of measurement range, accuracy level & any other specification. The indicative list of MMDs required for this work and to be made available by the contractor is given in appendix-III. The list will be reviewed by BHEL and the contractor shall meet any augmentation needed.
- 8.7 The MMDs deployed by the contractor shall, at all stages of work, have valid and current calibration. BHEL shall be done the calibration of these MMDs from the agencies accredited/ approved. Copy of calibration certificates in respect of these MMDs has to be submitted to BHEL. Periodical status report regarding validity of calibration has to be submitted to BHEL. Re-calibration/ re-validation shall be done periodically as per BHEL specifications. Contractor shall conform to the specifications of BHEL regarding storage of the MMDs.
- 8.8 Re-work necessitated on account of use of invalid MMDs shall be entirely to the contractor's account. He shall be responsible to take all corrective actions, including resource augmentation if any, as specified by BHEL to make-up for the loss of time.

8.9 In the course of work BHEL may counter/ finally check the measurements with their own MMDs. Contractor shall render all assistance in conduct of such counter/final measurements.

8.10 Total quality is the watchword of the work and contractor shall strive to achieve the quality standards, procedures laid down by BHEL. He shall follow all the instructions as per BHEL drawings and quality standards. Contractor shall provide for the services of quality assurance engineer.

8.11 Stage Inspection By FES/QA Engineers

Apart from day-to-day inspection by BHEL engineers stationed at site and also by customer's engineers, stage inspection of equipments under erection and commissioning at various stages of erection and commissioning by teams of engineers from field engineering services of BHEL's manufacturing units and quality assurance teams from field quality assurance factory quality assurance and commissioning engineers from technical services of BHEL will also be conducted. Contractor shall arrange all labour, tools and tackles etc, for such stage inspections as part of work.

8.12 Void

8.13 Statutory Inspection of Work

8.13.1

The work to be executed under these specifications has to be offered for inspection, at appropriate stages of work completion, to various statutory authorities for compliance with applicable regulations.

8.13.2

The work related statutory inspections, though not limited to, are as under:

- 1) Inspectorate of the Chief Electrical Inspector of Maharashtra OR Central Electricity Authority as per statute.
- 2) Any other authority connected to this work.

The scope includes getting the approval of the installations from the statutory authorities, which includes arranging for inspection visits of statutory authority periodically as per BHEL engineer's instructions, submitting documents, radiographs etc. and following up the matter with them. Contractor shall also make all arrangements for offering the products/systems for inspection, as applicable, to the concerned authority.

8.13.3

It shall be contractor's responsibility to obtain approval of statutory authorities, whenever applicable, for conducting any work which comes under the purview of these authorities.

8.13.4

BHEL will pay fees for visits, inspection fees etc. of these statutory authorities. Please refer Section-5 for working arrangement for payment of fees in this regard. All other expenses shall be borne by the contractor. In case these inspections have to be repeated due to reasons attributable to the contractor and fees have to be paid again, the contractor has to pay such additional charges.

8.13.5

It shall be the responsibility of contractor to obtain license from chief electrical inspector, **Gujrat** for carrying out high voltage work. Contractor shall also comply with the provisions of the latest Electricity Act, including the amendments thereof.

8.13.6

The contractors shall pay all fees connected with testing of his welders/workers and testing, inspection & calibration of his MMD and T&P.

8.14.0

The quality management system of BHEL, Power Sector – Western Region (PSWR) has already been certified and accredited under ISO 9002 standards in this regard. The basic philosophy of the quality management system is to define the organizational responsibility, work as per documented procedures, verify the output with respect to acceptance norms, identify the non-conforming product/ procedure and take corrective action for removal of non-conformance specifying the steps for avoiding recurrence of such non-conformities, & maintain the relevant quality records. The non-conformities are to be identified through the conduct of periodical audit of implementation of quality systems at various locations/stages of work. Suppliers/vendors of various products/services contributing in the work are also considered as part of the quality management system. As such the contractor is expected not only to conform to the quality management system of BHEL but also it is desirable that they themselves are accredited under any quality management system standard.

8.15.0 Field Quality Assurance

Contractor shall carry out all activities conforming to the approved Field Quality Plan (FQP) as revised from time to time. Total quality shall be the watchword of the work and contractor shall strive to achieve the quality standards, procedures laid down by BHEL. He shall follow all the instructions as per BHEL drawings and quality standards. Contractor shall provide the services of quality assurance engineer as per the relevant clauses.

Section-9

Special Conditions of Contract

Safety, Occupational Health and Environmental Management

Introduction:-

BHEL PSWR has been certified for Environmental Management under ISO 14001:1996 standard and Occupational Health & Safety under OHSAS 18001 by DNV. In order to comply with the above standards, it shall be the endeavour of BHEL and all its subcontractors to meet and implement the requirements by following the guidelines issued under Environmental, Occupational Health and Safety Management (EHS) manual a copy of which will be available with the BHEL site-in-charge.

Contractor shall also enter into a "Memorandum of Understanding" as given in clause 9.9 in case of award of contract.

9.0 Responsibility Of The Contractor In Respect Of Safety Of Men, Equipment, Material And Environment.

9.1 The Contractor Shall

9.1.1 Abide by the Safety Regulations applicable for the Site/Project and in particular as mentioned in the booklet "Safe Work Practices" issued by BHEL. Contractors are also to ensure that their employees and workmen use safety equipments as stipulated in the Factories Act (Latest Revision) during the execution of the work. Failure to use safety equipment as required by BHEL Engineer will be a sufficient reason for issuance of memo, which shall become part of Safety evaluation of the contractor at the end of the Project. Also all site work may be suspended if it is found that the workmen are employing unsafe working practice and all the costs/losses incurred due to suspension of work shall be borne by contractor. A comprehensive list of National Standards from which the contractor can draw references for complying with various requirements under this section is given under 9.10

9.1.2 Hold BHEL harmless and indemnified from and against all claims, cost and charges under Workmen's Compensation Act 1923 and 1933 and any amendment thereof and the contractor shall be solely responsible for the same.

9.1.3 Abide by the Procedure governing entry/exit of the contractor's personnel within the Customer/Client premises. All the contractors' employees shall be permitted to enter only on displaying of authorized Photo passes or any other documents as authorised by the Customer/Client

9.1.4 Be fully responsible for the identity, conduct and integrity of the personnel/workers engaged by them for carrying out the contract work and ensure that none of them are ever engaged in any anti national activity

9.1.5 prepare a sign board giving the following information and display it near the work site:

Name of Contractor

Name of Contractor Site-in-charge & Telephone number

Job Description in short

Date of start of job

Date of expected completion

Name of BHEL Site-in-charge.

9.1.6 Abide by the rules and regulations existing during the contract period as applicable for the contractors at the Project premises.

9.1.7 Observe the timings of work as advised by BHEL Engineer-in-charge for carrying out the contract work.

9.2 SPECIAL CONDITIONS

9.2.1 Safety

9.2.1.1 Safety Plan

Before commencing the work, contractor shall submit a "safety plan" to the authorised BHEL official. The safety plan shall indicate in detail the measures that would be taken by the contractor to ensure safety to men, equipment, material and environment during execution of the work. The plan shall take care to satisfy all requirements specified hereunder.

The contractor shall submit "safety plan" before start of work. During negotiations, before placing of work order and during execution of the contract, BHEL shall have right to review and suggest modifications in the safety plan. Contractor shall abide by BHEL's decision in this respect.

9.2.1.1 The contractor shall take all necessary safety precautions and arrange for appropriate appliances and/or as per direction of BHEL or its authorised person to prevent loss of human lives, injuries to men engaged and damage to property and environment.

9.2.1.2 The contractor shall provide to his work force and also ensure the use of Personnel Protection Equipment (PPE) as found necessary and/or as directed and advised by BHEL officials without which permission is liable to be denied.

- Safety helmets conforming to IS 2925/1984 (1990)
- Safety belts conforming to IS 3521/1989
- Safety shoes conforming to IS 1989 part-II /1986(1992)
- Eye and face protection devices conforming to IS 2573/1986(1991), IS 6994 (1973), part-I (1991), IS 8807/1978 (1991), IS 8519/1977(1991).
- Other job specific PPE of standard ISI make as may be prescribed

9.2.1.3 All tools, tackles, lifting appliances, material handling equipment, scaffolds, cradles, cages, safety nets, ladders, equipment, etc used by the contractor shall be of safe design and construction. These shall be tested and certificate of fitness obtained before putting them to use and from time to time as instructed by authorised BHEL official who shall have the right to ban the use of any item found to be unsafe

9.2.1.4 All electrical equipment, connections and wiring for construction power, its distribution and use shall conform to the requirements of Indian Electricity Act and Rules. Only electricians licensed by the appropriate statutory authority shall be employed by the contractor to carryout all types of electrical works. All electrical appliances including portable electric tools used by the contractor shall have safe plugging system to source of power and be appropriately earthed.

9.2.1.5 The contractor shall not use any hand lamp energised by electric power with supply voltage of more than 24 volts. For work in confined spaces, lighting shall be arranged with power source of not more than 24 volts.

9.2.1.6 The contractor shall adopt all fire safety measures as per relevant Indian Standards

9.2.1.7 Where it becomes necessary to provide and/or store petroleum products, explosives, chemicals and liquid or gaseous fuel or any other substance that may cause fire or explosion, the contractor shall be responsible for carrying out such provisions and/or storage in accordance with the rules and regulations laid down by the relevant government acts, such as petroleum act, explosives act, petroleum and carbides of calcium manual of the chief controller of explosives, Government of India etc.

The contractor in all such matters shall also take prior approval of the authorised BHEL official at the site.

9.2.1.8 Proper means of access must be used e.g. ladders, scaffolds, platforms etc. No makeshift access such as oil drums or pallets shall be used. Design of these will be in accordance with relevant standards and certified by competent persons before use.

9.2.1.9 Temporary arrangements made at Site for lifting, platforms, approach, access etc should be properly designed and approved before being put to use.

9.2.1.10 All excavations and openings must be securely and adequately fenced/barricaded and warning signs erected when considered necessary as per relevant code of practice.

9.2.1.11 No persons shall remove guardrails, covers or protective devices unless authorised by a responsible supervisor and alternative precautions have been taken.

9.2.1.12 Access ways, means of escape and fire exits shall be clearly marked, kept clear and unobstructed at all times

9.2.1.13 Only authorised persons holding relevant license will drive and operate site plant and equipments eg cranes, dumpers, excavators, transport vehicles etc.

9.2.1.14 Only authorised personnel are allowed to repair, commission electrical equipments.

9.2.1.15 Gas cylinders shall be handled and stored as per Gas Cylinder Rules and relevant safe working practices

9.2.1.16 All wastes generated at Site shall be segregated and collected in a designated place so as to prevent spillage/contamination/scattering at Site, until the waste is lifted for disposal to designated disposal area as advised by BHEL official.

9.2.1.17 The contractor shall arrange at his cost (wherever not specified) appropriate illumination at all work spots for safe working when natural day light is not adequate for clear visibility.

9.2.1.18 The contractor shall train adequate number of workers/supervisors for administering "FIRST AID". List of competent first aid administrators should be prominently displayed.

9.2.1.19 The contractor shall display at strategic places and in adequate numbers the following in fluorescent markings

- Emergency telephone numbers
- Exit, Walkways
- Safe working load charts for wire ropes, slings, D shackles etc
- Warning signs

9.2.1.20 The contractor shall be held responsible for any violation of statutory regulations (local, state or central) and BHEL instructions that may endanger safety of men, equipment, material and environment in his scope of work or other contractors or agencies. Cost of damage, if any, to life and property arising out of such violation of statutory regulations and BHEL instructions shall be borne by the contractor.

9.2.1.21 In case of a fatal or disabling injury/accident to any person at construction sites due to lapses by the contractor, the victim and/or his/her dependents shall be compensated by the contractor as per statutory requirements. However, if considered necessary, BHEL shall have the right to impose appropriate financial penalty on the contractor and recover the same from payments due to the contractor for suitably compensating the victim and/or his/her dependents. Before imposing any such

penalty, appropriate enquiry shall be held by BHEL giving opportunity to the contractor to present his case.

9.2.1.22 In case of any damage to property due to lapses by the contractor, BHEL shall have the right to recover cost of such damages from payments due to the contractor after holding an appropriate enquiry.

9.2.1.23 In case of any delay in the completion of a job due to mishaps attributable to lapses by the contractor, BHEL shall have the right to recover cost of such delay from payments due to the contractor after notifying the contractor suitably and giving him opportunity to present his case.

9.2.1.24 If the contractor fails to improve the standards of safety in its operation to the satisfaction of BHEL after being given a reasonable opportunity to do so, and/or if the contractor fails to take appropriate safety precautions or to provide necessary safety devices and equipment or to carry out instructions regarding safety issued by the authorised BHEL official, BHEL shall have the right to take corrective steps at the risk and cost of the contractor after giving a notice of not less than seven days indicating the steps that would be taken by BHEL.

9.2.1.25 **Emergency Response**

9.2.1.15.1 BHEL will have an Emergency Response Plan for each Project Site in consultation with the Owner as the case may be, detailing the procedure for mobilization of personnel and equipment, and defining the responsibilities of the personnel indicated, in order to prepare for any emergency that may arise in order to ensure the priorities of

- Safeguard of life
- Protect assets under construction or neighbouring
- Protect environment
- Resumption of normal operations as soon as the emergency condition is called off

All Contractors shall also be part of the Emergency response Plan and the personnel so nominated shall be aware of their duties and responsibilities in an emergency response situation.

9.2.1.15.2 At least 5% Contractors supervisors and workmen shall undergo training in administering 'First Aid'. The trained persons should represent for all categories of work and for all areas of work. Adequate number of trained persons should be available for each shift. These first aid personnel shall be included in the emergency response team. Contractor employees and workmen are encouraged to participate in first aid training programmes whenever organised by BHEL.

9.2.2 **OCCUPATIONAL HEALTH**

9.2.2.1 Specific occupational health hazards will be identified through the hazard evaluation processes in consultation with BHEL engineers and the necessary prevention/reduction/elimination methods implemented.

9.2.2.2 All personnel working in an activity with a potential risk to health shall be made aware of all those risks and the actions they must take to reduce/control/eliminate the risk

9.2.2.3 Safety coordinator shall conduct periodic checks to ensure that every group of workers engaged in similar activities are aware of potential risks to health and the actions required to be taken to mitigate the risk

9.2.2.4 In order to protect personnel from associated health hazards, the following main areas will be focussed

- Issue of approved Personnel Protective Equipment
- Verification that the PPEs are adequate/maintained and worn by all staff involved in operations that are potentially hazardous to their health
- Ensure that the personnel deployed are physically fit for the operation/work concerned
- Provide hygienic and sanitary working conditions

9.2.2.5 Contractor workers employees engaged in noise risk areas shall be issued with hearing protection aids and the use of the same will be enforced. Further, these workers will be educated on the hazards of noise

9.2.2.6 Contractor workers engaged in dust environment shall be issued with necessary dust protection aids and the use of the same shall be enforced

9.2.2.7 Workers engaged in exposure to bright light/rays as in welding or radiation shall be issued with eye protection devices and the use of the same shall be enforced

9.2.2.8 Adequate arrangements shall be made to provide safe drinking water

9.2.2.9 Health monitoring records on at least sample basis for contractor employees & workmen shall be maintained for persons engaged in specified categories of work. These shall include

- Noise induced hearing loss
- Lung Function test
- Ergonomic Test
- Eye Test for Welders, Grinders, Drivers etc

9.2.3.0 HYGIENE and HOUSEKEEPING

9.2.3.1 Good house keeping and proper hygiene is one of the key requirements of Occupational Health Safety and Environment management. Towards this the contractor shall encourage his workers and supervisors to maintain cleanliness in their area of work.

9.2.3.2 The Contractor shall arrange to place waste bins/chutes at convenient locations for the collection of scrap and other wastes. The bins shall be clearly marked and segregated for metal, non-metal, hazardous and non hazardous wastes.

9.2.3.3 BHEL may take up appropriate remedial measures at the cost of the contractors if the contractors fails in good house keeping and if there is an imminent risk of pollution

9.2.4 ENVIRONMENT MANAGEMENT

9.2.4.1 BHEL has a sound environmental management system, which is to be maintained and implemented by all the contractors. The system allows for project specific objectives to be set and developed sensitive to client requirements, applicable environmental legislation and BHEL's own objectives and policy. BHEL engineers will assess and monitor the environmental impact of their work and lay out objectives for their minimisation. The contractors shall implement the objectives for continual improvement of environmental performance. BHEL shall regularly audit environmental impacts and their improvements.

9.2.4.2 WASTE MANAGEMENT

9.2.4.3.1 The objective of waste management is to ensure the safe and responsible disposal of waste, ensuring that it is correctly disposed of and being able to audit the process to ensure compliance.

9.2.4.3.2 Chemical wastes if any shall be collected separately and disposed of to BHEL designated refuse yard as per BHEL advise

9.2.4.3.3 No dangerous chemicals, noxious waste products or materials will be disposed off on or off site without approval obtained through BHEL.

9.2.4.3.4 All disposal of wastes generated during construction shall be in accordance with all relevant legislation.

9.2.4.3.5 Acid and alkali cleaning wastes shall be neutralized to acceptable norms before disposal to the designated area.

9.2.4.3.6 All necessary measures shall be taken to ensure safe collection and disposal of waste oils. In particular to ensure the prevention of their discharge into surface waters, ground waters, coastal waters or drainages

9.3 SUPERVISION

9.3.1 Contractor must provide at least one full time on site safety coordinator when the manpower engaged is in excess of 50 for the contract activities in the premises. If the manpower is less than 50, the on site safety coordination responsibilities shall be assumed by any one of the contractor's other supervisory staff; however in both the cases, the contractor must specify in writing the name of such persons to the BHEL Engineer in Charge.

9.3.2 Contractor's safety coordinator or his supervisor responsible for safety as the case may be shall conduct at his work site, and document formal safety inspection and audits at least once in a week. Such documents are to be submitted to BHEL Engineer in Charge for his review and record

9.3.3 Contractor, supervisor must attend all schedule safety meetings as would be intimated to him by the BHEL Engineer in Charge.

9.3.4 Before starting work under any contract, the contractor must ensure that a job specific safety procedures/field practices as required over and above the safety permit conditions are prepared and followed .He should also ensure that all supervisors and workers involved understand and follow this procedures /field practices.

9.3.5 Contractor must ensure that in his work site appropriate display boards are put displaying signs for site safety, potential hazards and precautions required

9.4.0 TRAINING & AWARENESS

9.4.1 Contractor shall deploy experienced supervisors and other manpower that are well conversant with the safety and environment regulations of the Project. The electricians to be deployed on the job should have wireman license.

9.4.2 All Supervisors & Workmen of the Contractor shall undergo Fire safety training/demonstration whenever arranged by BHEL with the help of either Customer's Fire and Safety department or outside faculty so as to acquire knowledge of fire prevention and also to be able to make use of appropriate fire extinguishers.

9.4.3 Contractor must familiarize himself from BHEL Engineer in Charge about all known potential fire, explosion or toxic release hazards related to the contract. He in turn will ensure that same information has been passed to the supervisors and workmen

9.4.4 Contractor must ensure that all his supervisors are properly trained and each employee has received and understood from his supervisor necessary training and briefing about the safety requirement. Necessary document as a means to verify that employees have understood the training is to be maintained.

9.4.5 The contractor supervisors shall also give a small safety briefing to all the workmen under his charge before undertaking any new work and specially understand the safety requirements that are mandatory

9.5.0 REPORTING

9.5.1 The contractor shall submit report of all accidents, fires and property damage, dangerous occurrences to the authorized BHEL official immediately after such occurrence but in any case not later than twelve hours of the occurrence. Such report shall be furnished in the manner prescribed by BHEL and also to meet statutory requirement.

9.5.2 Any injury sustained by any of the contractor's employees within the Project premises must be reported to BHEL supervisor and FIRST AID should be immediately administered. The Contractor shall be responsible for keeping and maintaining proper records of Accidents to his personnel.

9.5.3 Contractor must arrange to immediately investigate, properly document and report any injury, accident or near miss involving any of his employees and take appropriate follow up action. He must furnish within 12 hours of the incident a written report to BHEL Engineer in charge and the Safety Section.

9.5.4 According to the Factory Act and the Employees state Insurance Act & regulation, any person sustaining any injury within the project premises and absenting himself from work for more than 46 hours, his accident report has to be sent to the respective Government Authorities. Therefore contractor shall inform the owner's representative such matter immediately for their needful action.

9.5.5 In addition, contractor shall submit periodic reports on safety to the authorised BHEL official from time to time as prescribed.

9.5.6 Before commencing the work, the contractor shall appoint/nominate a responsible officer to supervise implementation of all safety measures and liaison with his counterpart of BHEL.

9.6 AUDIT REVIEW AND INSPECTION

9.6.1 BHEL shall conduct audit on the contractor performance and compliance with the project specific requirements of the Environment and Occupational Health & Safety Management systems. The programme of audit shall cover all activities under the contract but will focus particularly on high-risk activities. The Construction Manager shall decide the schedule of audit. The audit findings shall be communicated to the contractors and necessary remedial action as advised by BHEL Engineers shall be under taken within the stipulated time.

9.6.2 Inspections shall be carried out regularly by the contractors and by BHEL engineers on activities, facilities, equipment and documentation to cover the following aspects.

- Compliance with procedures and systems
- Availability, condition and use of PPE
- Condition of maintenance tools, equipments, facilities
- Availability of fire fighting equipments and its condition
- Use of fire fighting equipments and first aid kit
- Awareness of occupational health hazard
- Awareness of safe working practices
- Presence of quality supervision
- Housekeeping

The Safety Co-coordinator shall visit and inspect work sites daily. All unsafe acts, unsafe conditions that have imminent potential for causing harm/injury/damage will be immediately corrected. He shall maintain a daily logbook giving details of unsafe acts or conditions observed and the corrective action taken and recommendations for preventing recurrence. Adequacy of corrective actions will be verified

The contractor shall take remedial measures as per the findings of each inspection. Besides the above, the contractor shall be required to carry out the following inspections.

SN	Equipment	Scope of inspection	Inspection by	Schedule
1	Hand tools	To identify unsafe/defective tool	User	Daily
2	Power tools	To identify unsafe/defective tool	User	Daily
3	Fire Extinguishers	To check pressure and any defect	User	Daily
4	Lifting equipment/tackles	To check for defects and efficacy of brakes	Safety Coordinator User Third party	Every month Daily Every Year
5	PPE	To check for defects	User	Daily

9.7 **NON COMPLIANCE:-**

9.7.1 NONCONFORMITY OF SAFETY RULES AND SAFETY APPLIANCES WILL BE VIEWED SERIOUSLY AND THE BHEL HAS RIGHT TO IMPOSE FINES ON THE CONTRACTOR AS UNDER **for every instance of violation noticed:**

Sl. No.	Violation of Safety Norm	Fine (in Rs)
01.	Not Wearing Safety Helmet	50/-
02.	Not wearing Safety Belt	100/-
03.	Grinding Without Goggles	50/-
04.	Not using 24 V Supply For Internal Work	500/-
05.	Electrical Plugs Not used for hand Machine	100/-
06.	Not Slings property	200/-
07.	Using Damaged Sling	200/-
08.	Lifting Cylinders Without Cage	500/-
09.	Not Using Proper Welding Cable With Lot of Joints And Not Insulated Property.	200/-
10.	Not Removing Small Scrap From Platforms	200/-
11.	Gas Cutting Without Taking Proper Precaution or Not Using Sheet Below Gas Cutting	200/-
12.	Not Maintaining Electric Winches Which are Operated Dangerously	500/-
13.	Improper Earthing Of Electrical T&P	500/-
14.	Accident Resulting in Partial Loss in Earning Capacity	25,000/- per victim
15.	Fatal Accident/Accidents Resulting in total loss in Earning Capacity	1,00,000/- per victim

Any other non-conformity noticed not listed above will also be fined as deemed fit by BHEL. The decision of BHEL engineer is final on the above. The amount will be deducted from running bills of the contractor. The amount collected above will be utilised for giving award to the employees who could avoid accident by following safety rules. Also the amount will be spent for purchasing the safety appliances and supporting the safety activity at site.

9.8 CITATION:- If safety record of the contractor in execution of the awarded job is to the satisfaction of safety department of BHEL, issue of an appropriate certificate to recognise the safety performance of the contractor may be considered by BHEL after completion of the job

9.9 Memorandum of Understanding

After Award Of Work, Contractors Are Required To Enter Into A Memorandum Of Understanding As Given Below:

Memorandum of Understanding

BHEL, PSWR is committed to Health, Safety and Environment Policy (EHS Policy) as given in the booklet titled “ Safe Working Practices” issued to all contractors.

M/s _____ do hereby also commit to the same EHS Policy while executing the Contract Number _____

M/s _____ shall ensure that safe work practices not limited to the above booklet are followed by all construction workers and supervisors. Spirit and content therein shall be reached to all workers and supervisors for compliance.

BHEL will be carrying out EHS audits twice a year and M/s _____ shall ensure to close any non-conformity observed/reported within fifteen days.

Signed by authorised representative of M/s-----

Name :

Place & Date:

9.10.1 Comprehensive list of National Standards for reference and use wherever applicable in the execution of Civil, Erection and Commissioning Contracts

IS No.	YEAR	Amd. upto	Description
IS 10204	1982		PORTABLE FIRE EXTINGUISHERS MECHANICAL FOAM TYPE
IS 10245	1994		SPECIFICATION FOR BREATHING APPARATUS
IS 10291	1982		SAFETY CODE FOR DRESS DRIVERS IN CIVIL ENGINEERING WORKS
IS 10658	1983		HIGHER CAPACITY DRY POWDER FIRE EXTINGUISHERS (TROLLEY MOUNTED)
IS 10662	1992		COLOUR TELEVISION
IS 10667	1983		GUIDE FOR SELECTION OF INDUSTRIAL SAFETY EQUIPMENT FOR PROTECTION OF FOOT AND LEG
IS 11037	1984		ELECTRONIC FAN REGULATORS
IS 11057	1984		INDUSTRIAL SAFETY NETS
IS 11451	1998		RECOMMENDATION FOR SAFETY AND HEALTH REQUIREMENT RELATING TO OCCUPATION EXPOSURE TO ASBESTOS
IS 1169	1967		PEDESTAL FANS
IS 1179	1967		SPECIFICATION FOR EQUIPMENT FOR EYE AND FACE PROTECTION DURING WELDING
IS 11833	1986		DRY POWDER FIRE EXTINGUISHERS FOR METAL FIRES
IS 11972	1987		CODE OF PRACTICE FOR SAFETY PRECAUTION TO BE TAKEN WHEN ENTERING A SEWAGE SYSTEM
IS 1287	1986		ELECTRIC TOASTER
IS 13063	1991		STRUCTURAL SAFETY OF BUILDINGS ON SHALLOW FOUNDATIONS ON ROCKS
IS 13385	1992		SPECIFICATIONS FOR FIRE EXTINGUISHERS 50 LITRE

IS No.	YEAR	Amd. upto	Description
			WHEEL MOUNTED WATER TYPE (GAS CARTRIDGES)
IS 13386	1992		SPECIFICATIONS FOR FIRE EXTINGUISHERS 50 LITRE MECHANICAL FOAM TYPE
IS 13415	1992		CODE OF SAFETY FOR PROTECTIVE BARRIERS IN AND AROUND BUILDINGS
IS 13416	1992		RECOMMENDATIONS FOR PREVENTIV E MEASURES AGAINST HAZARDS AT WORKING PLACE PART 1 TO PART 5
IS 13430	1992		CODE OF PRACTICE FOR SAFETY DURING ADDITIONAL CONSTRUCTION AND ALTERATION TO EXISTING BUILDINGS
IS 13849	1993		PORTABLE FIRE EXTINGUISHERS DRY POWDER TYPE (CONSTANT PRESSURE)
IS 1446	1985		CLASSIFICATION OF DANGEROUS GOODS (FIRST REVISION)
IS 1476	1979		REFRIGERATORS
IS 1641	1988		CODE OF PRACTICE FOR FIRE SAFETY OF BUILDINGS (GENERAL): GENERAL PRINCIPLES OF FIRE GRADING AND CLASSIFICATION
IS 1642	1989		CODE OF PRACTICE FOR FIRE SAFETY OF BUILDINGS- DETAILS OF CONSTRUCTION
IS 1643	1988		CODE OF PRACTICE FOR FIRE SAFETY OF BUILDINGS (GENERAL): EXPOSURE HAZARD
IS 1646	1997		CODE OF PRACTICE FOR FIRE SAFETY OF BUILDINGS (GENERAL): ELECTRICAL INSTALLATIONS
IS 1904	1986		CODE OF PRACTICE FOR DESIGN AND CONSTRUCTION OF FOUNDATIONS IN SOIL
IS 1905	1987		STRUCTURAL SAFETY OF BUILDINGS MASONARY WALLS
IS 2082	1985		ELECTRICAL GEYSERS
IS 2171	1985		PORTABLE FIRE EXTINGUISHERS DRY POWDER TYPE (CARTRIDGE)
IS 2309	1989		PRACTICE FOR THE PROTECTION OF BUILDINGS AND ALLIED BUILDINGS AGAINST LIGHTENING
IS 2312	1967		EXHAUST FANS
IS 2361	1994		SPECIFICATION FOR BUILDING GRIPS - FIRST REVISION
IS 2418	1977		TUBULAR FLUORSCENT LAMPS IS 2418 (FT-1)
IS 2750	1964		STEEL SCAFFOLDINGS
IS 27 62	1964		SAFE WORKING LOADS IN KGS FOR WIRE ROPE SLINGS
IS 2878	1986		FIRE EXTINGUISHERS CARBON DIOXIDE TYPE (PORTABLE AND TROLLEY MOUNTED)
IS 2925	1984		SPECIFICATION FOR INDUSTRIAL SAFETY HELMETS
IS 3016	1982		CODE OF PRACTICE FOR FIRE PRECAUTIONS IN WELDING AND CUTTING OPERATIONS- FIRST REVISION
IS 3315	1974		DESERT COOLERS
IS 3521	1989		INDUSTRIAL SAFETY BELTS AND HARNESS
IS 368	1983		IMMERSION WATER HEATERS
IS 3696	1991		SAFETY CODE OF SCAFFOLDS AND LADDERS PART 1 TO 2
IS 3737	1996		LEATHER SAFETY BOOTS FOR WORKERS IN HEAVY METAL INDUSTRIES

IS No.	YEAR	Amd. upto	Description
IS 374	1979		CEILING FANS INCLUDING REGULATORS
IS 3764	1992		EXCAVATION WORK - CODE OF SAFETY
IS 3786	1983		METHOD FOR COMPUTATION OF FREQUENCY AND SEVERITY RATES FOR INDUSTRIAL INJURIES AND CLASSIFICATION OF INDUSTRIAL ACCIDENTS
IS 3935	1966		CODE OF PRACTICE FOR COMPOSITE CONSTRUCTION
IS 4014	1967		CODE OF PRACTICE FOR STEEL TUBULAR SCAFFOLDING
IS 4081	1986		SAFETY CODE FOR BLASTING AND RELATED DRILLING OPERATIONS
IS 4082	1977	1996	STACKING AND STORAGE OF CONSTRUCTION MATERIALS AND COMPONENTS AT SITE
IS 4130	1991		DEMOLITION OF BUILDINGS - CODE OF SAFETY PART 1 TO 2
IS 4138	1977		SAFETY CODE FOR WORKING IN COMPRESSED AIR (FIRST REVISION)
IS 4155	1966		GLOSSARY OF TERMS RELATING TO CHEMICAL AND RADIATION HAZARDS AND HAZARDOUS CHEMICALS
IS 4209	1967		CODE OF SAFETY FOR CHEMICAL LABORATORY
IS 4250	1980		FOOD MIXERS
IS 4262	1967		CODE OF SAFETY FOR SULFURIC ACID
IS 4756	1978		SAFETY CODE FOR TUNNELING WORK
IS 4912	1978		SAFETY REQUIREMENTS FOR FLOOR AND WALL OPENINGS, RAILINGS AND TOE BOARDS
IS 5121	1969		SAFETY CODE FOR PILING AND OTHER DEEP FOUNDATIONS
IS 5182	1969	1982	METHODS FOR MEASUREMENT OF AIR POLLUTION
IS 5184	1969		CODE OF SAFETY FOR HYDROFLUORIC ACID
IS 5216	1982	2000	RECOMMENDATIONS ON SAFETY PROCEDURES AND PRACTICE IN ELECTRICAL WORK PART I AND II
IS 555	1979		TABLE FANS
IS 5557	1995		INDUSTRIAL AND SAFETY LINED RUBBER BOOTS (SECOND REVISION)
IS 5916	1970		SAFETY CODE FOR CONSTRUCTION INVOLVING USE OF HOT BITUMINOUS MATERIALS
IS 5983	1980		SPECIFICATION FOR EYE PROTECTORS - FIRST REVISION
IS 6234	1986		PORTABLE FIRE EXTINGUISHERS WATER TYPE (STORED PRESSURE)
IS 692	1994		CRITERIA FOR SAFETY AND DESIGN OF STRUCTURES SUBJECTED TO UNDERGROUND BLASTS
IS 6994	1973		SPECIFICATION FOR SAFETY GLOVES
IS 7155	1986		CODE OF RECOMMENDED PRACTICE FOR CONVEYOR SAFETY (PART 1 TO 8)
IS 7205	1974		SAFETY CODE FOR ERECTION OF STRUCTURAL STEEL WORK
IS 7293	1974		SAFETY CODE FOR WORKING WITH CONSTRUCTION MACHINERY
IS 7323	1994		GUIDELINES FOR OPERATIONS OF RESERVOIRS
IS 7812	1975		CODE OF SAFETY FOR MERCURY
IS 7969	1975		SAFETY CODE FOR HANDLING AND STORAGE OF BUILDING MATERIALS

IS No.	YEAR	Amd. upto	Description
IS 8089	1976		CODE OF SAFE PRACTICE FOR LAYOUT OF OUTSIDE FACILITIES IN AN INDUSTRIAL PLANT
IS 8091	1976		CODE OF PRACTICE FOR INDUSTRIAL PLANT LAYOUT
IS 8095	1976		ACCIDENTS PREVENTION TAGS
IS 818	1968	1997	CODE OF PRACTICE FOR SAFETY AND HEALTH REQUIREMENTS IN ELECTRIC AND GAS WELDING, AND CUTTING OPERATIONS
IS 8448	1989		AUTOMATIC LINE VOLTAGE CORRECTOR (STABILISER)
IS 8519	1977		GUIDE FOR SELECTION OF INDUSTRIAL SAFETY EQUIPMENT FOR BODY PROTECTION
IS 8520	1977		GUIDE FOR SELECTION OF INDUSTRIAL SAFETY EQUIPMENT FOR EYE, FACE AND EAR PROTECTION
IS 875	1987		STRUCTURAL SAFETY OF BUILDING: LOADING STANDARD PART 1 TO 5
IS 8807	1978		GUIDE FOR SELECTION OF INDUSTRIAL SAFETY EQUIPMENT FOR PROTECTION OF ARMS AND HANDS
IS 8978	1985		INSTANTANEOUS WATER HEATERS
IS 8989	1978		SAFETY CODE FOR ERECTION OF CONCRETE FRAMED STRUCTURES
IS 940	1989		PORTABLE FIRE EXTINGUISHERS WATER TYPE (GAS CARTRIDGE)
IS 9457	1980		SAFETY COLOURS AND SIGNS
IS 9679	1980		CODE OF SAFETY FOR WORK ENVIRONMENTAL MONITORING
IS 9706	1997		CODE OF PRACTICE FOR THE CONSTRUCTION OF AERIAL RPEWAYS FOR THE TRANSPORTATION OF MATERIAL
IS 9759	1981		GUIDELINES FOR DEWATERING DURING CONSTRUCTION
IS 9815	1989		SERVO MOTOR OPERATED LINE VOLTAGE CORRECTOR (SERVO STABILISER)
IS 9944	1992		RECOMMENDATIONS ON SAFE WORKING LOAD FOR NATURAL AND MAN-MADE FIBRE ROPE SLINGS
IS 996	1979		SINGLE PHASE ELECTRIC MOTORS
ISO 3873	1977		SAFETY HELMET

SECTION-10

SPECIAL CONDITIONS OF CONTRACT

10.0 DRAWINGS AND DOCUMENTS

- 10.1 The detailed drawings, specifications available with BHEL engineers will also form part of this tender specification. Revision of drawings/documents may take place due to various considerations as is normal in such large project. Work will have to be carried out as per revised drawings/ documents. These documents will be made available to the contractor during execution of work at site.
- 10.2 One set of necessary drawings/documents to carry out the erection work will be furnished to the contractor by BHEL on loan that shall be returned to BHEL after completion of the work. Contractor's personnel shall take care of these documents given to them.
- 10.3 The data furnished in various sections and appendices and the drawings enclosed with this tender specification describe the equipment to be installed, tested and commissioned under this specification, briefly. However, the changes in the design and in the quantity may be expected to occur as is usual in any such large scale of works.
- 10.4 If any error or ambiguity is discovered in the specification/information contained in the documents/drawings and tender, the contractor shall forthwith bring the same to the notice of BHEL before submission of offer.
- 10.5 In case an ambiguity is detected after award of work, the same must be brought to the notice of BHEL before commencement of the work/activity. BHEL's interpretation in such cases will be final and binding on the contractor.
- 10.6 In case of any conflict between General Instructions to Bidders, General Conditions of Contract contained in Sections 1 & 2 respectively and Special Conditions of Contract contained in Sections 4 to 15 and Appendices, provisions contained in Special Conditions of Contract in Sections 4 to 15 and Appendices shall prevail.
- 10.7 In case of discrepancy between quoted item rate and corresponding amount in the rate schedule, the **quoted item rates shall be reckoned as correct and amount recalculated**. Quoted item rates shall also prevail for arriving at the total price quoted for offer evaluation and Work Order placement. Order will be placed by BHEL for all the items under the scope of this contract to one bidder without splitting.
- 10.8 Bank Guarantees to be furnished by the contractor towards Security Deposit and Performance Guarantee (last 5% payment against workmanship warranty/defect liability) shall have a claim period of six months over and above the validity period required for the respective cases. BG for advance payment shall be kept valid for a period of two more months beyond the recovery period of the advance with interest thereof.

SECTION-11 SPECIAL CONDITIONS OF CONTRACT

TIME SCHEDULE – CONTRACT VARIATION – PROGRESS AND MONITORING-COMPLETION, OVERRUN, and PRICE VARIATION etc.

11.1 TIME SCHEDULE & MOBILIZATION

11.1.1 INITIAL MOBILIZATION AND TENTATIVE SCHEDULE

CONTRACTOR SHALL REACH SITE, MAKE HIS SITE ESTABLISHMENT AND BE READY TO COMMENCE THE WORK WITHIN TWO WEEKS FROM THE DATE OF FAX LETTER OF INTENT OR AS PER DIRECTIONS OF CONSTRUCTION MANAGER OF BHEL.

THE CONTRACTOR HAS TO SUBSEQUENTLY AUGMENT HIS RESOURCES IN SUCH A MANNER THAT THE ENTIRE WORK IS COMPLETED TO ACHIEVE THE FOLLOWING TENTATIVE SCHEDULE:

S N	Activity / Milestone	Tentative Date of Completion
1	Start of Erection	Nov, 06
2	Boiler light up and ABO	Mar, 07
3	Turbine box-up	Dec, 06
4	Steam blowing of boiler and piping completion	Apr, 07
5	Oil flushing of turbine & integral system	Feb, 07
6	Synchronization and Coal Firing	Jun, 07
7	Trial Operation	Aug, 07
8	PG test	Sep, 07
9	Completion of work	Oct, 07

IN ORDER TO MEET ABOVE SCHEDULE IN GENERAL, AND ANY OTHER INTERMEDIATE TARGETS SET, TO MEET CUSTOMER REQUIREMENTS, CONTRACTOR SHALL ARRANGE ALL NECESSARY RESOURCES IN CONSULTATION WITH BHEL.

11.1.2 CONTRACT PERIOD

THE CONTRACT PERIOD FOR COMPLETION OF ENTIRE WORK UNDER SCOPE SHALL BE **10 (TEN MONTHS)** FROM THE START OF CONTRACT PERIOD.

PERMANENT ERECTION OF THE FIRST COLUMN SEGMENT OR MAJOR SUB-ASSEMBLY/MAIN ASSEMBLY OF ANY OTHER EQUIPMENT ON ITS DESIGNATED FOUNDATION FOLLOWING DUE PROCESS OF PRE-ASSEMBLY AND QUALITY CHECKS AS PER APPROVED FIELD QUALITY PLAN (FQP) SHALL BE CONSIDERED AS THE **START OF CONTRACT PERIOD** FOR THIS CONTRACT. PLACEMENT OF PACKER PLATES ETC SHALL NOT BE CONSIDERED AS START OF ERECTION.

11.1.3 GRACE PERIOD

GRACE PERIOD OF **2 (TWO) MONTHS** BEYOND THE CONTRACT PERIOD (12 MONTHS) MAY BE PROVIDED FOR THIS CONTRACT AT THE DISCRETION OF BHEL.

BHEL, OWING TO ITS COMMITMENT TO THEIR CUSTOMER, MAY ASK CONTRACTOR TO COMPRESS THE TOTAL COMPLETION SCHEDULE BY UPTO 15%. THIS WILL RESULT IN PREPONEMENT OF VARIOUS MILESTONES. CONTRACTOR SHALL PLAN HIS ACTIVITIES AND MOBILISE ADDITIONAL RESOURCES ACCORDINGLY TO THE SATISFACTION OF BHEL ENGINEER WITHIN THE QUOTED RATES.

11.1.4 CONSEQUENCE OF DELAY

IT MAY BE NOTED THAT IN THE EVENT DELAY IN COMPLETION IS ATTRIBUTABLE TO THE CONTRACTOR THAT LEADS TO IMPOSITION OF LIQUIDATED DAMAGES BY BHEL'S CLIENT, BHEL WILL IMPOSE LD ON THE CONTRACTOR AS PER GCC.

11.2 PROGRESS MONITORING, CONTRACT EXTENSION AND OVERRUN

11.2.1 PROGRESS MONITORING

PROGRESS WILL BE REVIEWED PERIODICALLY (DAILY/WEEKLY/MONTHLY) INCLUDING MONTH END REVIEW VIS-A-VIS THE PLANS DRAWN AS ABOVE. THE CONTRACTOR SHALL SUBMIT PERIODICAL PROGRESS REPORTS AND OTHER REPORTS/INFORMATION INCLUDING MANPOWER, CONSUMABLES ETC AS DESIRED BY BHEL.

11.2.2 ASCERTAINING AND ESTABLISHING THE REASONS FOR SHORTFALL

THE ONUS PROBANDI THAT THE CAUSES LEADING TO EXTENSION OF THE CONTRACT PERIOD IS NOT DUE TO ANY REASONS ATTRIBUTABLE TO THE CONTRACTOR IS ON HIM (THE CONTRACTOR). REVIEW OF THE PERFORMANCE AS STATED VIDE CL. 11.2.1 ABOVE WILL BE MADE CONSIDERING THE AVAILABILITY OF COMPONENTS TO BE ERECTED AND OTHER INPUTS / CONSTRAINTS OVER WHICH THE CONTRACTOR HAS NO CONTROL. THE PROGRAMME WILL BE REVIEWED AREA-WISE AND THE FOLLOWING FACTS WILL BE RECORDED IN CASE OF SHORTFALL AT THE END OF EVERY MONTH:

- A) ERECTION / COMMISSIONING PROGRAMME NOT ACHIEVED OWING TO NONAVAILABILITY OF FRONTS.
- B) ERECTION / COMMISSIONING PROGRAMME NOT ACHIEVED OWING TO NONAVAILABILITY OF MATERIALS.
- C) ERECTION/COMMISSIONING PROGRAMME NOT ACHIEVED OWING TO NON-AVAILABILITY OF TOOLS AND PLANTS, MANPOWER AND CONSUMABLES BY THE CONTRACTOR OR ANY OTHER REASON ATTRIBUTABLE TO THE CONTRACTOR.
- D) ERECTION / COMMISSIONING PROGRAMME NOT ACHIEVED DUE TO ANY OTHER REASONS NOT ATTRIBUTABLE TO THE CONTRACTOR.

11.2.3 CONTRACT EXTENSION

IF THE COMPLETION OF WORK AS DETAILED IN THESE SPECIFICATION GETS DELAYED BEYOND THE END OF CONTRACT PERIOD AND GRACE PERIOD THEN DEPENDING ON THE BALANCE WORK LEFT OUT, BHEL AT ITS DISCRETION MAY EXTEND THE CONTRACT.

11.2.4

A JOINT PROGRAMME SHALL BE DRAWN FOR THE WORK TO BE COMPLETED DURING THE EXTENDED CONTRACT PERIOD. REVIEW OF THE PROGRAM AND RECORD OF SHORTFALL AS DESCRIBED VIDE CLAUSE NO. 11.2.2 SHALL BE DONE DURING THE EXTENDED PERIOD. THE OVER RUN CHARGES WILL BE PAID IN PROPORTION TO THE ACHIEVEMENT OF THE RESPECTIVE MONTH VIS-À-VIS THE PLAN FOR THE MONTH (FOR ASSESSING THE PERFORMANCE, THE AGREED PLAN SHALL BE REDUCED BY SHORTFALL ATTRIBUTABLE TO THE BHEL). BHEL MAY DISALLOW CONTRACTOR'S CLAIM FOR OVER RUN CHARGES IF THE MONTHLY PROGRAMME AS MENTIONED IN THESE SPECIFICATIONS ARE NOT MADE BY HIM.

11.2.5

THE PART OF EXTENSION ATTRIBUTABLE TO THE CONTRACTOR, IF ANY, IN TOTAL CONTRACT EXTENSION SHALL BE EXHAUSTED FIRST i.e., IMMEDIATELY AFTER END OF GRACE PERIOD. THIS SHALL BE FOLLOWED BY THE EXTENSION ON ACCOUNT OF FORCE MAJEURE CONDITIONS, IF ANY, AND LASTLY ON ACCOUNT OF BHEL.

11.2.6 OVERRUN COMPENSATION

IF THE CONTRACT IS EXTENDED BEYOND THE CONTRACT AND GRACE PERIOD FOR ANY REASON OTHER THAN THOSE ATTRIBUTABLE TO THE CONTRACTOR OR FORCE MAJEURE CONDITIONS, THE CONTRACTOR WILL BE COMPENSATED BY PAYMENT OF OVERRUN CHARGES AT THE RATE OF **Rs.50,000/-** (RUPEES FIFTY THOUSAND ONLY) PER MONTH. OVERRUN COMPENSATION WILL BE PAID FOR THE EXTENSION ATTRIBUTABLE TO BHEL ONLY. NO OVERRUN COMPENSATION WILL BE PAYABLE FOR THE EXTENSION ON ACCOUNT OF REASONS ATTRIBUTABLE TO CONTRACTOR AND/OR FORCE MAJEURE CONDITIONS. OVERRUN COMPENSATION FOR ELIGIBLE PERIOD SHALL BE IN PROPORTION TO THE PROGRESS ACHIEVED AGAINST THE PLAN FOR RESPECTIVE PERIOD.

11.3 PRICE VARIATION

AGREED RATES SHALL REMAIN FIRM THROUGHOUT THE CONTRACT PERIOD AND EXTENSIONS THEREOF. NO PRICE VARIATION/ADJUSTMENT SHALL BE APPLICABLE FOR THIS CONTRACT.

11.4 CONTRACT VARIATIONS

11.4.1 VARIATION IN WEIGHT/QUANTITIES

WEIGHTS OF VARIOUS EQUIPMENTS, QUANTITIES OF VARIOUS ITEMS OF WORK COVERED UNDER THESE SPECIFICATIONS & INDICATED IN RELEVANT APPENDICES ARE LIKELY TO VARY BY ABOUT +/- 25% IN GENERAL AND +/- 40% IN CASE OF CABLES. FOR ANY UPWARD OR DOWNWARD VARIATION IN THE QUANTITIES, THE RATES ACCEPTED SHALL BE APPLICABLE WITHOUT ANY VARIATION. PAYMENT WILL BE MADE BY BHEL FOR THE ACTUAL EXECUTED QUANTITIES.

11.4.2 ADDITIONAL ITEMS

EQUIPMENTS /INSTRUMENTS REQUIRED TO BE ERECTED FOR THIS WORK, THOUGH NOT LIMITED TO BUT ARE GENERALLY AS PER RATE SCHEDULE. FOR ANY ITEMS OR CLASS OF WORK NOT SPECIFIED HEREIN BUT REQUIRED FOR TOTAL COMPLETION OF WORK, THE SAME SHALL BE CARRIED OUT AS PER BHEL REQUIREMENT. HOWEVER THE PAYMENT OF THESE ITEMS/CLASS OF WORK SHALL BE REGULATED ON THE BASIS OF MUTUALLY AGREED RATE ARRIVED AT BY EITHER OF THE FOLLOWING METHODS, WHICH SHOULD BE DONE PRIOR TO UNDERTAKING THE WORK:

- A. BASED ON RATE OF IDENTICAL/SIMILAR ITEMS IN THE RATE SCHEDULE
- B. BASED ON THE RATE ARRIVED FROM NEARBY ITEMS IN THE RATE SCHEDULE

WHEREVER ANY ITEM RATE FOR SIMILAR TYPE OF WORK OR NEARBY ITEM RATE IS NOT EXISTING IN THE RATE SCHEDULE, RATE WILL BE WORKED OUT ON THE BASIS OF WORK ELEMENT OR FROM FUNDAMENTALS OF ESTIMATION OR EXISTING RATES IN OTHER JOB.

11.5 INTEREST BEARING RECOVERABLE ADVANCE

INTEREST BEARING (@ 12% PER ANNUM INTEREST ON MONTHLY REDUCING BALANCE BASIS) RECOVERABLE ADVANCE LIMITED TO 5% OF THE CONTRACT VALUE MAY BE PAID BY BHEL AT ITS DISCRETION DEPENDING ON THE MERIT OF THE CASE AGAINST RECEIPT & ACCEPTANCE OF BANK GUARANTEE FROM THE CONTRACTOR FOR THE AMOUNT SOUGHT. THIS BANK GUARANTEE (BG) SHALL BE VALID AT LEAST FOR ONE YEAR OR THE RECOVERY DURATION. IN CASE RECOVERY OF DUES DOES NOT GET COMPLETED WITHIN THE AFORESAID BG VALIDITY PERIOD, THE CONTRACTOR MUST RENEW THE VALIDITY OF BG OR SUBMIT FRESH BG FOR THE OUTSTANDING AMOUNT AND REMAINING RECOVERY PERIOD. BHEL IS ENTITLED TO MAKE RECOVERY OF THE ENTIRE OUTSTANDING AMOUNT IN CASE THE CONTRACTOR FAILS TO COMPLY WITH THE BG REQUIREMENT AS ABOVE.

RECOVERY OF DUES WILL BE MADE MINIMUM @ 10% OF THE ADMITTED GROSS RUNNING BILL AMOUNT FROM THE FIRST APPLICABLE RUNNING BILL ONWARDS TILL ENTIRE DUE (PRINCIPAL PLUS INTEREST) IS RECOVERED. IN THE EVENT SUFFICIENT TIME DURATION IS NOT LEFT FOR RECOVERY @10%, THE RATE OF RECOVERY SHALL BE SUITABLY ENHANCED SO THAT ENTIRE DUE IS RECOVERED WITHIN THE CONTRACT PERIOD (INCLUDING EXTENSIONS GRANTED OR FORECLOSURE IF ANY).

11.6 DEFINITION OF WORK COMPLETION

THE CONTRACTOR'S SCOPE OF WORK UNDER THESE SPECIFICATIONS WILL BE DEEMED TO HAVE BEEN COMPLETED IN ALL RESPECT, ONLY WHEN ALL THE ACTIVITIES ARE COMPLETED SATISFACTORILY AND SO CERTIFIED BY BHEL SITE IN CHARGE. THE DECISION OF BHEL IN THIS REGARD SHALL BE FINAL AND BINDING ON THE CONTRACTOR.

11.7 FORECLOSURE OF CONTRACT

BHEL, AT ITS DISCRETION MAY FORECLOSE THE CONTRACT AT ANY DURING THE CONTRACT PERIOD FROM THE DATE OF STARTING OF WORK AT SITE.

SPECIAL CONDITIONS OF CONTRACT

SECTION-12

12.0 TERMS OF PAYMENT

12.0.1

THE CONTRACTOR SHALL SUBMIT HIS MONTHLY ON ACCOUNT BILLS WITH ALL THE DETAILS REQUIRED BY BHEL ON SPECIFIED DATE EVERY MONTH COVERING PROGRESS OF WORK IN ALL RESPECTS AND AREAS FROM THE 25TH OF PREVIOUS CALENDAR MONTH TO 24TH OF THE CURRENT MONTH.

12.0.2

CLAUSE 2.6 OF GENERAL CONDITIONS OF CONTRACT SHALL BE REFERRED TO AS REGARDS MODE OF PAYMENT, AND MEASUREMENT OF THE WORK COMPLETED.

12.0.3

RELEASE OF PAYMENT IN EACH RUNNING BILL WILL BE RESTRICTED TO 95% OF THE VALUE OF WORK ADMITTED, AS PER THE PERCENTAGE BREAK-UP FOR THE STAGE OF WORK COMPLETION STIPULATED VIDE CLAUSES HEREINAFTER.

THE 5% THUS REMAINING SHALL BE ON ACCOUNT OF WORKMANSHIP GUARANTEE OF WORK EXECUTED. THE SAME WILL BE RELEASED AFTER COMPLETION OF THE GUARANTEE PERIOD OF 12 MONTHS FROM THE DATE OF COMPLETION OF ENTIRE WORK AS CERTIFIED BY BHEL ENGINEER. HOWEVER, THIS AMOUNT MAY BE RELEASED EARLIER ON RECEIPT AND ACCEPTANCE OF BANK GUARANTEE OF EQUAL AMOUNT IN PRESCRIBED FORMAT AND THE BG SHALL BE KEPT VALID TILL COMPLETION OF SUCH GUARANTEE PERIOD AND AN ADDITIONAL SIX MONTHS CLAIM PERIOD.

12.0.4

THE PAYMENT FOR RUNNING BILLS WILL NORMALLY BE RELEASED WITHIN AROUND 30 DAYS OF SUBMISSION OF RUNNING BILL WITH MEASUREMNT SHEETS. CONTRACTOR SHALL MAKE HIS OWN ARRANGEMENT FOR MAKING PAYMENT OF IMPENDING LABOUR WAGES AND OTHER DUES IN THE MEANWHILE.

12.1 STAGES OF PROGRESSIVE PRO-RATA PAYMENTS

12.1.1

The agreed rates for each item shall be paid on pro-rata basis progressively as per the break up given hereunder (aggregating 100%), based on the progress of work in each month. The contractor shall submit his running bills with the details of measurement required by BHEL engineer on or before 26th of every month covering progress of work in all respect in the area upto 24th day of the same month.

TRANSFORMERS (GT, UAT, ST): Item nos A.1, A.2 and A.3 of Rate Schedule		
SN	DESCRIPTION OF ACTIVITY	PERCENTAGE
01	COLLECTION OF MATERIALS, TRANSPORTATION POSITIONING ON FOUNDATION AND ALIGNMENT AS PER LAYOUT DRAWING	15%
02	INTERNAL INSPECTION OF CORE AND WINDING TAPS SWITCH OFF-LOAD/ON-LOAD, H.V./L.V. BUSHING TURRET ASSEMBLY, VACUUM PULLING, OIL FILTERATION AND FITTING OF OIL UPTO CORE AND WINDING LEVEL	15%
03	ASSEMBLY OF ALL ACCESSORIES, PIPES AND FITTINGS, CONSERVATOR TANK, COOLER BANK/RADIATOR BANK, BUSHINGS, MARSHALLING BOX, CABLING FROM MARSHALLING BOX TO FIELD DEVICES, FANS AND PUMPS ETC.	20%

TRANSFORMERS (GT, UAT, ST): Item nos A.1, A.2 and A.3 of Rate Schedule		
04	OIL FILLING IN COMPLETE ASSEMBLED TRANSFORMERS, COMPLETION OF DRY OUT AND FILTERATION OF OIL OF COOLING BANK, ACCEPTANCE OF DRY OUT.	15%
05	PRE-COMMISSIONING CHECKS, ELECTRICAL TESTS, CALIBRATION AND PROTECTION AND INTER LOCK CHECKS	15%
06	INTEGRATED ELECTRICAL TESTING/ COMMISSIONING WITH ASSOCIATED CONNECTED EQUIPMENT , BACK CHARGING/FORWARD CHARGING	12%
07	FINISH PAINTING	05%
08	TRIAL RUN AND FULL LOADING	02%
09	COMPLETION OF ALL FACILITIES AND HANDING OVER	01%

6.6 KV / 415V / DCDB SWITCHGEAR BOARDS, GENERATOR CONTROL/ PROTECTION PANEL & ACCESSORIES : Item nos. D.1 to D.9 of Rate Schedule		
SN	DESCRIPTION OF ACTIVITY	PERCENTAGE
01	COLLECTION OF MATERIAL AND TRANSPORTATION FROM BHEL STORES TO SITE	10%
02	PLACEMENT ON FOUNDATION, ASSEMBLIES ETC.	20%
03	ADJUSTMENT, ALIGNMENT, GROUTING, ELECTRICAL INTER-CONNECTIONS, INTER PANEL WIRING AND BUS BAR, INSTALLATION OF LOOSE ACCESSORIES ETC.	35%
04	PRE-COMMISSIONING AND ELECTRICAL TEST, MECHANICAL/ ELECTRICAL CHECKS INCLUDING PROTECTION, INTERLOCK TESTING AND MAKING THE SYSTEM READY BY ENERGIZATION	13%
05	INTEGRATED ELECTRICAL TESTING/ COMMISSIONING WITH ASSOCIATED CONNECTED EQUIPMENT	08%
05	ENERGIZATION OF SWITCH BOARD AND TRIAL OF INDIVIDUAL FEEDERS ON LOAD	10%
06	COMPLETION OF TRIAL RUN OF MAIN TG SET/FULL LOADING	02%
07	COMPLETION OF ALL FACILITIES AND HANDING OVER	02%

EXCITATION SYSTEMS & ACCESSORIES, DAVR, GENERATOR, GT & UT PROTECTION & METERING PANELS: Item nos. F.1, G.1 to G.2 of Rate Schedule		
SN	DESCRIPTION OF ACTIVITY	PERCENTAGE
01	COLLECTION OF MATERIAL, TRANSPORTATION FROM BHEL STORE TO SITE	10%
02	PLACEMENT, ALIGNMENT, GROUTING, INTER CONNECTION OF BUS BAR AND WIRING, FIXING OF LOOSE COMPONENTS AND AIR EXHAUST OUTLET DUCT FOR REGULATION, FIELD FLUSHING AND THYRISTOR PANELS	60%
04	PRE-COMMISSIONING TESTS	13%
05	UNIT SYNCHRONIZATION AND STABILIZATION, INTEGRATED ELECTRICAL TESTING/ COMMISSIONING WITH ASSOCIATED CONNECTED EQUIPMENT	13%
06	TRIAL RUN AND FULL LOADING	02%
07	COMPLETION OF ALL FACILITIES AND HANDING OVER	02%

ISOLATED PHASE BUS DUCT: Item no. B.1 of Rate Schedule		
SN	DESCRIPTION OF ACTIVITY	PERCENTAGE
01	COLLECTION OF MATERIAL, TRANSPORTATION FROM BHEL STORES TO SITE	10%
02	ERECTION AND ALIGNMENT OF SUPPORTING STRUCTURE	10%
03	PLACEMENT OF BUS DUCT, SUB-ASSEMBLIES, LAVT CUBICLE, NG TRANSFORMER AND RESISTANCE CUBICLE, AIR PRESSURIZATION UNIT AND ITS PIPING AND ACCESSORIES, EXCITATION TRANSFORMER AND ITS TRUNKING CUBICLE, WALL FRAME ASSEMBLY, SEAL AIR BUSHINGS	20%
04	ALIGNMENT OF BUS DUCT ASSEMBLIES, WELDING OF CONDUCTORS, MAKEUP PIECES, SHUNTS, FLEXIBLES, CURRENT TRANSFORMERS AND VOLTAGE TRANSFORMER, SURGE PROTECTOR ETC. INSTALLATION, LINE, NEUTRAL TEE OFF DUCT CTs, WIRING UPTO MARSHALLING BOX, DPD TEST ON CONDUCTOR WELD JOINTS ETC.	25%
05	PRE-COMMISSIONING TESTS, HIGH VOLTAGE TEST	10%
06	COMPLETION OF AIR LEAKAGE TEST	03%
07	FINAL BOX-UP AND END TERMINATION AND MAKING READY FOR ENERGIZATION	04%
08	COMPLETION OF SHORT CIRCUIT/OPEN CIRCUIT TEST WHICH INCLUDES FIXING AND REMOVING OF CERTAIN LINK AND NORMALISATION AND SYNCHRONIZATION OF THE UNIT, INTEGRATED ELECTRICAL TESTING/ COMMISSIONING WITH ASSOCIATED CONNECTED EQUIPMENT	10%
09	FINISH PAINTING	05%
10	TRIAL RUN AND FULL LOADING	02%
11	COMPLETION OF ALL FACILITIES AND HANDING OVER	01%

SEGREGATED PHASE BUS DUCT: Item no. C.1 to C.9 of Rate Schedule		
SN	DESCRIPTION OF ACTIVITY	PERCENTAGE
01	COLLECTION OF MATERIAL, TRANSPORTATION FROM BHEL STORES TO SITE	05%
02	ERECTION, ALIGNMENT, GROUTING SUPPORTING STRUCTURE	15%
03	PLACEMENT, ALIGNMENT, BOLTING OF CONDUCTOR, ENCLOSURE, COPPER FLEXIBLE, WALL FRAME ASSEMBLIES, SEAL OFF BUSHINGS, CONDUIT AND WIRING FOR ANTI-CONTAMINATION HEATERS, EARTHING INTER CONNECTING BRIDGING BUS DUCT BETWEEN THE SWITCH BOARD ETC.	45%
04	PRE-COMMISSIONING AND COMPLETION OF AIR LEAK TEST	10%
05	COMPLETION OF AIR PRESSURIZATION TEST	05%
06	ENERGIZATION OF INDIVIDUAL BUS DUCT AND SWITCH BOARD, INTEGRATED ELECTRICAL TESTING/ COMMISSIONING WITH ASSOCIATED CONNECTED EQUIPMENT	12%
07	FINISH PAINTING	05%
08	TRIAL RUN AND FULL LOADIN G	02%
09	COMPLETION OF ALL FACILITIES AND HANDING OVER	01%

12.1.2 OTHERS: Item nos. H.1 to H.4, J.1 to J.12, K.1 to K.7, L.1, M.1 and M.2 of Rate Schedule)

Unit rate payment shall be made for other systems (ESP, Soot Blower, Electrical Hoist, DCDB, & Misc. Items) as per the rate schedule and percentage breakup for erection, testing, commissioning shall be as per detailed breakup given below: -

1. 80% of the agreed unit rates on completion of erection, testing and commissioning.
2. 12% after completion of the individual system commissioning.
3. 5% after trial operation or unit handing over whichever is earlier.
4. 3% on completion of facilities and handing over.

12.1.3 Testing of Commissioning of Equipment erected by other agencies: Item nos. N.1 to N.5 of Rate Schedule

1. 80% of the agreed unit rates on completion of testing and off-load commissioning.
2. 10% after on-load commissioning of each item.
3. 5% after completion of trial operation of unit.
4. 5% on completion of facilities and handing over.

12.1.4 Cables (Item nos. P.1 to P.4 and Q.1 to Q.4 of Rate Schedule)

1. 70% after laying of cable.
2. 10% after termination.
3. 10% after testing of cables.
4. 05% after dressing of cables
5. 05% after completion of facilities and handing over.

12.1.4.1 Cable Tray (Item nos. R.1 to R.3 and S.1 of Rate Schedule)

1. 80% after erection of trays in position
2. 15% after completion of welding/bolting.
3. 05% after completion of facilities and handing over.

12.2 PAYMENT FOR THE WORK COMPLETED

12.2.1

For the items where the payment is to be made against unit of weight, the actual weight of items erected by contractor will be paid after assessing the weight on the basis of shipping list or standard engineering practice. BHEL engineer's decision will be final and binding on contractor in this regard.

12.2.2 STAGE-WISE BREAK UP FOR PRO-RATA PROGRESSIVE PAYMENT FOR VARIOUS INSTALLATION (ERECTION, TESTING & COMMISSIONING) SUPERVISION SERVICES

For the purpose of payments to the contractor, 10% of the contract value shall be assigned as the amount payable towards installation (erection, testing & commissioning) supervision services.

For the purpose of release of progressive payments, month-wise break up for each of the above services will be jointly worked out by BHEL and the contractor at site at the time of start of work. This will be dynamically and regularly reviewed every month/quarter or mutually agreed periodicity and shall be re-calculated based on expected requirement of services keeping in view relevant aspects. On all the issues as above, BHEL engineer's decision shall be final & binding.

These services are to be rendered even during extended period (the contract extension may be due to any reason) without any additional payment/ compensation. The periodical review of monthly billing/payment break up shall take this aspect in consideration. Progressive payment for the service rendered will be made on certification of BHEL accordingly.

12.2.3

The bidder shall quote separate unit rates for each item of work listed in the rate schedule.

12.3 Measurement for Payment

12.3.1

In rate schedule, unit rates called for erection, testing and commissioning for various devices and equipment and payment shall be made accordingly.

12.3.2

For all payment purpose, measurement shall be made on the basis of physical measurement. Contractor shall make physical measurement in presence of BHEL engineer. Contractor shall maintain records for utilization of material system-wise.

12.3.3

All the surplus, scrap and serviceable materials shall be returned by the contractor to BHEL's stores as per the instruction of engineer

12.3.4

Wherever additional instrumentation work has to be carried out for performance guarantee test, the same has to be executed by the contractor as per the applicable rates already provided in the rate schedule.

Section –13

Special Conditions of Contract

13.0 Extra Charges For Rectification And Modification

13.1

If extra works (requiring less than **40 man-hours**) for modification, rework, revamping, in brief, any work done to change the state existing to a stage desired and also fabrication, all or any, are needed due to any change in or deviation from the drawings and design of equipment, operation/ maintenance requirements, mismatching, transit damages and other allied works which are not very specifically indicated in the drawings, but are found essential for satisfactory completion of the work, are done, no extra charges will be paid. The tenderers are requested to take this aspect into account and the quoted rate should include all such contingencies.

13.2

It may also be noted that if any such said extra works arise on account of the contractor's fault it will have to be carried out by the contractor free of cost. Under such circumstances, any material and consumable required for this purpose will also have to be arranged by the contractor at his cost.

13.3

However, BHEL may consider for payment as extra, for such of those works detailed in clause 13.1 which require more than **40 man-hours** and such payment will be regulated by the terms, conditions and stipulations contained in the clauses 13.4 to 13.8 and/or 14.2.1 to 14.2.10 as the case may be. It may be specifically noted that the decision of BHEL as to whether such payment is due shall be final and binding on the contractor. It may also be noted that only those works, which are identified as major and warrant extra payment and certified as such by the site engineer and accepted by the designers and/or competent authority of BHEL, will be considered for extra payment.

13.4

For extra works arising out of transit, storage and erection damages, payment, if found due, will be regulated by clauses 14.2.1 to 14.2.10.

13.5

All the extra work should be carried out by a separately identifiable gang, without affecting routine activities. Daily log sheets in the pro-forma prescribed by BHEL should be maintained and shall be signed by the contractor's representative and BHEL engineer. No claim for extra work will be considered/entertained in the absence of the said supporting documents ie. Daily log sheets. It may, however be noted that signing of log sheets by BHEL engineer does not mean the acceptance of such works as extra works. All admissible claims shall be submitted to BHEL.

13.6

BHEL retains the right to award or not to award any of the major repair/rework/modification/rectification/fabrication works under clauses 13.1 to 13.6 to the contractor, at their discretion without assigning any reason for the same.

13.7

Extra works that arise on account of contractor's fault will have to be carried out by the contractor free of cost including the supply of material and consumables

13.8

After eligibility of extra works is established and finally accepted by BHEL engineer/designer, payment will be released on competent authority's approval at the following rate.

Man-day rate for eligible extra works:

Single average man-day rate, including overtime if any, and other site expenses and incidentals, including consumables, tools and tackles, for carrying out rework / repairs / rectification / modification / fabrication for a man-day of 8 hours as may arise during the course of erection will be **Rs. 240/- (Rupees Two hundred and forty only)**

As mentioned above, no payment will be made if an item of work lasts less than 40 man-hours.

SECTION-14

SPECIAL CONDITIONS OF CONTRACT

14.0 Insurance

14.1 Marine, Storage cum Erection (MCE) Insurance and Repairing Damages

14.1.1

BHEL/client has an MCE insurance cover, inter-alia, for all the permanent project equipments/components supplied by BHEL under scope of this work by way of a transit and storage cum erection policy covering liability against damages/ losses etc.

14.2 Reporting Damages and Carrying out Repairs

14.2.1

Checking all components/equipments at siding/site and reporting to transporter and /or insurance authorities of any damages/losses will be done by BHEL.

14.2.2

Contractor shall render all help to BHEL in inspection including handling, re-stacking etc, assessing and preparing estimates for repairs of components damaged during transit, storage and erection, commissioning and preparing estimates for fabrication of materials lost/damaged during transit, storage and erection. Contractor shall help BHEL to furnish all the data required by railways, insurance company or their surveyors.

14.2.3

Contractor shall report to BHEL in writing any damages to equipments/ components on receipt, storing, and during drawl of the materials from stores, in transit to site and unloading at place of work and during erection and commissioning. The above report shall be as prescribed by BHEL site management. Any consequential loss arising out of non-compliance of this stipulation will be borne by contractor.

14.2.4

Contractor shall carry out fabrication of any material lost/damaged as per instructions from BHEL engineer.

14.2.5

BHEL, however, retains the right to award or not to award to the contractor any of the rectification/rework/repairs of damages and also fabrication of components.

14.2.6

All the repairs/rectification/rework of damages and fabrication of materials lost, if any, shall be carried out by a separately identifiable gang for certification of man-hours. Daily log sheets should be maintained for each work separately and should be signed by contractor's representative and BHEL engineer. Signing of log sheets does not necessarily mean the acceptance of these as extra works.

14.2.7

All rectification, repairs, rework and fabrication of components lost, which are minor and incidental to erection work (consuming not more than 100 man-hours on each occasion) shall be treated as part of work without any extra cost.

14.2.8

Insurance cover under this policy will generally be as per clauses 2.10.1 to 2.10.4 of General Conditions of Contract unless and otherwise specified differently in the Special Conditions.

14.2.9

In case the loss/damage is not attributable to the contractor, Payments of all extra works on account of repair / rectification / reworks of damages and fabrication of materials lost will be as per provisions of Section-13 of SCC.

14.2.10

In case the repairs/rectification/rework and fabrication of materials lost, the work has been done by more than one agency including the contractor, the payment towards extra charges will be on pro-rata basis and the decision of BHEL in this regard is final and binding on the contractor.

14.2.11

In case of theft / damage / loss of materials due to **repeated/continued instances of negligence/failure** attributable to the contractor, the expenses incurred on account of repair/ replacement of such components including BHEL's overhead expenses as applicable (presently @ 30%) in excess of the amount realized from the underwriters, if any, shall be recovered from the contractor. Recovery will be limited to Normal Deductible Franchise (DF)/Excess as per applicable Insurance (TAC) tariff guidelines for every incidence of loss/damage.

14.2.12

In case any insurance claim does not become tenable due to **willful** negligence/ damage/loss attributable to the contractor, the total cost of repair/replacement including BHEL overhead expenses shall be recovered from the contractor.

14.3 Insurance by the Contractor and Indemnification of BHEL

14.3.1

BHEL has taken third party liability insurance, indicating in the proposal for such insurance that sub-contractors will be taking part in the erection work detailed in this tender specification. However, the bidder has to bear any expenses/consequences over and above the amount that may be reimbursed to BHEL by such coverage of third party liability insurance taken by BHEL.

Such additional liability will be to cover and indemnify BHEL and its customer of all liabilities which may come up and cause harm/damage to other contractors/customer/BHEL properties/ personnel or all or anybody rendering service to BHEL/ customer or is connected with BHEL/ customer's work in any manner whatsoever. The bidders' specific attention is also invited to clause 2.10 of General Conditions of Contract.

14.3.2

Contractor shall obtain suitable statutory as well as non-statutory insurance policies for all the properties belonging to him and also for his personnel deployed at project for execution of the contract work.

SECTION-15

Special Condition of Contract

15.0 Earnest Money Deposit & Security Deposit

15.1 EARNEST MONEY DEPOSIT:

EARNEST MONEY DEPOSIT FOR THIS TENDER WILL BE Rs. 2,00,000/- (RUPEES TWO LACS ONLY).

ONE TIME EMD WILL ALSO BE Rs. 2 LACS.

EMD SHALL BE DEPOSITED IN CASH (AS PERMISSIBLE UNDER INCOME TAX ACT), PAY ORDER OR DEMAND DRAFT (PAYABLE AT NAGPUR IN FAVOUR OF 'BHARAT HEAVY ELECTRICALS LIMITED') ONLY. **NO OTHER FORM OF EMD REMITTANCE SHALL BE ACCEPTABLE TO BHEL.**

15.1.1 EMD BY THE TENDERER WILL BE FORFEITED AS PER TENDER DOCUMENTS IF

- I) AFTER OPENING THE TENDER, THE TENDERER REVOKES HIS TENDER WITHIN THE VALIDITY PERIOD OR INCREASES HIS EARLIER QUOTED RATES.
- II) THE TENDERER DOES NOT COMMENCE THE WORK WITHIN THE PERIOD AS PER LOI / CONTRACT. IN CASE THE LOI / CONTRACT IS SILENT IN THIS REGARD THEN WITHIN 15 DAYS AFTER AWARD OF CONTRACT.

15.1.2 EMD SHALL NOT CARRY ANY INTEREST.

15.2 SECURITY DEPOSIT

15.2.1 SECURITY DEPOSIT SHOULD BE COLLECTED FROM THE SUCCESSFUL TENDERER. THE RATE OF SECURITY DEPOSIT WILL BE AS BELOW:

SN	Contract Value	Security Deposit Amount
1	Up to Rs. 10 lakhs	10% of Contract Value
2	Above Rs. 10 lakhs upto Rs.50 lakhs	1 lakh + 7.5% of the Contract Value exceeding Rs. 10 lakhs.
3	Above Rs. 50 lakhs	Rs 4 lakhs + 5% of the Contract Value exceeding Rs. 50 lakhs.

THE SECURITY DEPOSIT SHALL BE REMITTED BEFORE START OF THE WORK BY THE CONTRACTOR IN THE MANNER SPECIFIED AS FOLLOWS.

15.2.2 SECURITY DEPOSIT MAY BE FURNISHED IN ANY ONE OF THE FOLLOWING FORMS

- I) CASH (AS PERMISSIBLE UNDER THE INCOME TAX ACT)
- II) PAY ORDER, DEMAND DRAFT IN FAVOUR OF BHEL.
- III) LOCAL CHEQUES OF SCHEDULED BANKS, SUBJECT TO REALIZATION.
- IV) SECURITIES AVAILABLE FROM POST OFFICES SUCH AS NATIONAL SAVINGS CERTIFICATES, KISAN VIKAS PATRAS ETC.

(CERTIFICATES SHOULD BE HELD IN THE NAME OF CONTRACTOR FURNISHING THE SECURITY AND DULY PLEDGED IN FAVOUR OF BHEL AND DISCHARGED ON THE BACK).

- V) BANK GUARANTEE FROM SCHEDULED BANKS / PUBLIC FINANCIAL INSTITUTIONS AS DEFINED IN THE COMPANIES ACT SUBJECT TO A **MAXIMUM OF 50%** OF THE TOTAL SECURITY DEPOSIT VALUE. THE BALANCE 50% HAS TO BE REMITTED EITHER BY CASH OR IN THE OTHER FORM OF SECURITY. THE BANK GUARANTEE FORMAT SHOULD HAVE THE APPROVAL OF BHEL.
- VI) FIXED DEPOSIT RECEIPT ISSUED BY SCHEDULED BANKS / PUBLIC FINANCIAL INSTITUTIONS AS DEFINED IN THE COMPANIES ACT. THE FDR SHOULD BE IN THE NAME OF THE CONTRACTOR, A/C BHEL, DULY DISCHARGED ON THE BACK.
- VII) SECURITY DEPOSIT CAN ALSO BE RECOVERED AT THE RATE OF 10% FROM THE RUNNING BILLS. HOWEVER IN SUCH CASES AT LEAST 50% OF THE SECURITY DEPOSIT SHOULD BE REMITTED (EITHER BY CASH/DD OR **BG FOR MAXIMUM 50%** OF TOTAL SD) BEFORE START OF THE WORK AND THE BALANCE 50% MAY BE RECOVERED FROM THE RUNNING BILLS.
- VIII) EMD OF THE SUCCESSFUL TENDERER, EXCEPTING THOSE WHO HAVE REMITTED ONE TIME EMD, SHALL BE CONVERTED AND ADJUSTED AGAINST THE SECURITY DEPOSIT OR SPECIFIC REQUEST BY THE CONTRACTOR.
- IX) THE SECURITY DEPOSIT SHALL NOT CARRY ANY INTEREST.

NOTE: ACCEPTANCE OF SECURITY DEPOSIT AGAINST SL. NO. (IV) AND (VI) ABOVE WILL BE SUBJECT TO HYPOTHECATION OR ENDORSEMENT ON THE DOCUMENTS IN FAVOUR OF BHEL. HOWEVER, BHEL WILL NOT BE LIABLE OR RESPONSIBLE IN ANY MANNER FOR THE COLLECTION OF INTEREST OR RENEWAL OF THE DOCUMENTS OR IN ANY OTHER MATTER CONNECTED THEREWITH.

- 15.2.3 SECURITY DEPOSIT SHALL NOT BE REFUNDED TO THE CONTRACTOR EXCEPT IN ACCORDANCE WITH THE TERMS OF THE CONTRACT.

SECTION –16

TECHNICAL DETAILS, BILL OF QUANTITIES & LIST OF DRAWINGS

16.1 GENERATOR TRANSFORMER

Quantity – 1 No.

SN	DESCRIPTION	GENERAL INFORMATION
1	Rating	100 MVA, 11/230 KV, Cooling OFAF, Three Phase, Vector group Ynd11, with OFF Load tap switch
2	Weight of core &winding	MT
3	Total weight of assembled transformer including oil	120MT (APPROX)
4	Transportation / shipping weight (gas filled)	MT
5	Weight of tank &fitting, marshalling kiosk &wiring, cooler bank, conservator & pipe work, supports, rollers HV/LV turrets, pumps, bushings HT/LT, OFAF Coolers, Fans, Marshalling box, Cabling from marshalling box to field devices and other accessories & fittings	MT
6	Oil quantity	
	Oil in transformer tank	LITRES
	Oil in cooler, conservator, &pipe work	LITERS
	Total oil quantity	LITRE
7	Weight of heaviest packages	MT
8	Dimensions of assembled transformer	METERS (Approx)

16.2 UNIT TRANSFORMER

Quantity – 2 Nos.

SL. NO	DESCRIPTION	UNIT TRANSFORMER
1	Rating	20 MVA, 3-PHASE 11 /7.7/7.7 KV; On load Tap changer on HV side
2	Type of cooling	ONAN/ONAF
3	Winding connection	Dyn1
4	WEIGHT OF ACCESSORIES	
	Weight of core & winding	KGS
	Tank & fitting including HV/LV bushings turrets, rollers	KGS
	Bushings	KGS
	Radiator bank, fans & valves, pipe & fitting, Cabling between marshalling box to field devices, On load tap Chamber, etc.	KGS
	Total weight of transformer including oil	30000 KGS (APPROX)
	Shipping weight of transformer (gas filled)	KGS
	Untanking weight	KGS
7	Oil Quantity	
	Oil in transformer tank including On Load Tap Changer, turrets	LITRES
	Oil in radiator bank, conservator & pipe work	LITRES
	Total oil quantity	LITRES

16.4 GENERATOR BUS DUCT ISOLATED PHASE BUS DUCT

BUS DUCT –1 SET

General data of 11 KV 6000 Amp IPBD

1. Cross section of Main Bus duct
 - a. Enclosure 1070mm OD, 8 mm thick
 - b. Conductor 530mm OD, 16 mm thick
 - c. Phase to Phase 1300mm
2. Cross section of Tap off bus duct
 - a. Enclosure 780mm OD, 4.78 mm thick
 - b. Conductor 203mm box section
 - c. Phase to Phase 1000mm
3. Main section
 - a. Nos of main sections 32 Nos (6000 X 900 X 900 MM)OF 750 KGS EACH
 - b. Enclosure welding joints nos
 - c. Conductor weld joints nos
 - d. Bolted joints nos
4. Tap off section
 - a. Nos of sections 16 Nos (4000 X 800 X 800 MM OF 350 KGS EACH)
 - b. Enclosure welding joints nos
 - c. Conductor weld joints nos
 - d. Bolted joints Nos
5. Length of Bus duct per phase meters
6. Length of tap off BD per phase meters
7. ONE sets of air pressurization units : 3500 X 2000 X 3500 MM OF 2.5 MT
8. LAVT, VT and NGR (3 cubicles, 1.5 MT, 1.5MT, 2.5MT respectively)
 - a. Enclosure welding joints nos
 - b. Conductor weld joints nos
 - c. Bolted joints nos
9. Structural steel 12 MT

GENERAL INFORMATION

1.CONTACT PRESSURE

FOLLOWING TORQUE ARE NORMALLY RECOMMENDED FOR VARIOUS BOLTS.

BOLT SIZE	RECOMMENDED TORQUE	TORQUE SPANNER CAPTY.
M10	0.85 TO 1.3 NM (17-30 Ft- lb)	0.85 TO 1.3 NM
M12	1.3 TO 1.7 NM (30-40 FT-lb)	0.85 TO 4.3NM
M16	1.7 TO 2.1NM(40 –50 FT-lb)	0.85 TO 4.3 NM

M20	2.1 TO 2.5 NM (50 –60 FT-lb)	0.85 TO 4.3 NM
-----	------------------------------	----------------

Alternatively tightening the nut till Belleville washer becomes flats. Then unscrew the nut by 1/8th turn. Exact method and extent of tightening shall be done as per instructions of BHEL site engineer / as per equipment supplier's recommendation.

RECOMMENDATION FOR WELDED JOINTS (FOR ENCLOSURE, TUBULAR CONDUCTOR, MAKE UP PIECES, SHUNT AND FLEXIBLE JOINT ETC)

TYPE OF WELDING

FILLER WIRE

ANGLE

CLEANING

CURRENT SETTING

GAS SUPPLY/ PURITY

SHIELD

MIG WELDING

1.6 mm DIA. (NG 21 WITH 5% SILICON)

10 TO 15 DEG. FOREHEADS

DEGREASE AND SCRATCH BRUSH

DEPENDENT ON THICKNESS

50 Cu. FT/ HRS ARGON /99.98% WELDING

QUALITY

5/8" dia.

16.5 6.6 KV SEGREGATED PHASE BUS DUCTS

SN	Connection		Bus duct cross section (mm)	No of sections	Length in Meters (Approximate)
	From	To			
SPBD	UAT	6.6 KV SWGR	450X1350	35	30 MT
			STRUCTURE		07 MT
			MISC ITEMS		12 MT

Note: - Considering the layout of the bus ducts as mentioned above for interconnection between the transformer and 6.6KV switchgear boards and bridging bus duct in between the switchgear boards, it is not possible to segregate the quantity of structural support materials for individual area, hence the quantity mentioned above is common for all.

One set of portable hot air blower is also supplied, common for all.

Flexible joints, seal off bushings, rubber bellows, space heaters and their wiring, conduits/GI pipes breather tapping etc, etc are accessories and form a part of the system.

No separate payments are envisaged for the above.

16.7 DIGITAL VOLTAGE REGULATOR PANELS

SN	DESCRIPTION	Quantity
1.	Digital Voltage Regulator panels consist of Regulation Cubicle, Thyristor Cubicle and Field suppression cubicle, Excitation Transformer. Associated plug in / loose supplied cables / modules etc. DVR console assembled or loose components are to be mounted on Unit Control Desk.	1 No

16.8 GENERATOR, GT & UT PROTECTION AND METERING PANELS

SN	DESCRIPTION	Quantity per Unit
I	Generator, Generator Transformer, Unit Transformers, “Control / Protection & Metering Panels” , Over all dimension of each panels 1000 x 1000 x 2330 mm, Panel are to be erected in row, fixing of inter panel fasteners/ gasket, inter panel wiring, jointing of bus bar etc. Following items along with each unit panels shall be supplied loose for mounting in the panels / Unit Control Board 1. PC –2 Nos. 2. Replay S/W on CD –1 No. 3. Colored Inkjet printer – 2 Nos. 4. Antenna with 6 mtr cable 5. Cables for antenna- 60 m 6. UPS for PC– 2 Nos. 7. Hub between PCs & DR– 1 No. 8. Cable DR to Hub – 2 Nos 9. Cable from Hub to PC – 2 Nos. 10. Disturbance Recorder (DR) – 2 Nos. 11. Energy Meter along with power pack unit & chargers – 1 No.	8 Nos.

APPENDIX-I

List of T&P to be provided by BHEL Free of Hire Charges on Sharing Basis

1. EOT Crane in TG Hall

1 no.

NOTES:

1. THE ABOVE EQUIPMENT WILL BE PROVIDED ON SHARING BASIS FOR SPECIFIC ERECTION / COMMISSIONING ACTIVITIES INSIDE THE TG HALL ACCORDING TO NECESSITY AND AVAILABILITY.
2. EOT CRANE WILL BE OPERATED BY TURBINE ERECTION AGENCY OF BHEL. CONTRACTOR SHALL PAY THE OPERATING CHARGES DIRECTLY TO THAT AGENCY AT THE MUTUALLY AGREED RATE IN PROPORTION TO USAGE. IN CASE, OPERATING CREW OF THE OTHER AGENCY IS NOT AVAILABLE, CONTRACTOR SHALL MAKE HIS OWN ARRANGEMENT.

APPENDIX-II

CONSUMABLES/ITEMS TO BE PROVIDED BY BHEL FREE OF CHARGE

01) CABLE GLANDS

02) LUGS BEYOND 4 sq. mm. SIZE.

APPENDIX-III

Tentative List of Major T&P and MMD to be Deployed by the Contractor

A. T&P FOR ELECTRICAL WORKS

SN	DESCRIPTION	MINIMUM QUANTITY
01	TRANSFORMER OIL PURIFICATION PLANT WITH VACUUM PUMP FOR EVACUATION OF TRANSFORMER ALONGWITH ACCESSORIES & HOSES. A) C APACITY 5000/6000 LTR PER HOUR B) C APACITY 2000/2500 LTR.PER HOUR C) C APACITY 750/1000 LTR. PER HOUR	 1 NO. 1 NO. 1 NO.
02	SILICON OIL FILTERING MACHINE FOR ESP RECTIFIER TRANSFORMERS	1 NO.
03	TRANSFORMER OIL TRANSFER/STORAGE TANK WITHSTANDING FULL VACUUM CAP. 10 KILOLITRES	2 NOS
04	PRIMARY INJECTION KIT UPTO 10000 AMPS	1 NO.
05	SECONDARY INJECTION KIT WITH INTEGRAL TIMER FOR RELAY TESTING	1 NO.
06	3 PHASE VARIAC	1 NO.
07	SINGLE PHASE VARIAC 28 AMPS	1 NO.
08	TRANSFORMER TURNS RATIO TEST KIT	1 NO.
09	HV TEST KIT AC, 0-50 KV &DC, 0- 100 KV PREFERSBLY WITH DRY TYPE TRANSFORMER	1 NO. EACH
10	TRANSFORMER OIL BDV TEST KIT 0-100 KV WITH 2.5MM AIR GAP.	1 NO.
11	PORTABLE AIR COMPRESSOR WITH DRIER AND REGULATOR MAKE "TOSHNIWAL"/"KHOSLA" RATED FOR 7/10 KG/CM2	1 NO.
12	SOLDERING IRON "SOLDRON" MAKE 25 WATT	2 NOS.
13	VACUUM PUMP	1 NO.
14	MULTIMETRES	
	W) DIGITAL 3 1/2 DIGIT OF REPUTED MAKE	4 NOS.
	b> ANALOG MOTWANE MAKE	3 NOS.
	c> DIGITAL 4 1/2 DIGIT OF REPUTED MAKE	1NO.
16	STANDARD MILLI AMPS/MILLIVOLTS SOURCE MAKE RANGE 0 TO 60 mA AND 0 TO 100 mV	1 NO.
17	INSULATION TESTER HAND OPERATED 250V/500V/1000 V RATED MAINS/BATTERY OPERATED	1 NO. EACH
18	INSULATION TESTER MAINS OPERATED 2500/5000V	1 NO.

SN	DESCRIPTION	MINIMUM QUANTITY
19	DC POWER SUPPLY 0 TO 250 V DC, 5 A MAKE "APLAB" OR EQUIVALENT (VARIABLE SOURCE)	1 NO
20	PHASE SEQUENCE INDICATOR	1 NO.
21	FREQUENCY SOURCE 45 TO 55 HZ WITH 110V	1 NO.
22	TONG TESTER AC 5/10, 25/60/300 AMP RANGE REPUTED MAKE	1 NO. EACH
23	TONG TESTER DC 30/60/300 AMP	1 NO.
24	STOP WATCH	1 NO.
25	CONTAINER FOR TRANSFORMER OIL SAMPLING	10 NOS.
26	TARPOLIN FIRE PROOF	As required
27	DC SHUNT 400 AMP 75 MV	1 NO.
28	3 PHASE SHIFTER	1 NO.
29	INDUSTRIAL TYPE VACUUM CLEANER	1 NO.
30	MICRO OHM METER	1 NO.
31	DECADE RESISTANCE BOX	2 NOS.
32	TELETALK 2 WIRE SYSTEM	6 SETS
33	PORTABLE BLOWER WITH HEATING ARRANGEMENT	1 NO.
34	TORQUE WRENCH (12-60Nm, 50-225 Nm)	1 NO EACH
35	WATTMETER AC/DC 0-125-250V, 0-5-10A	1 NO
36	OSCILLOSCOPE	1 NO
37	TACHOMETER	1 NO
38	TAN DELTA TEST KIT	1 NO
39	OIL SPECIFIC GRAVITY AND PPM MEASURING INSTRUMENT	1 NO
40	RHEOSTAT	3 NOS
41	POLARITY TEST KIT	1 NO
42	NON – CONTACT TYPE DIGITAL THERMOMETER	1 NO
43	RELAY TESTING KIT	1 NO
44	FERRULE PRINTING MACHINE	1 NO

B. T&P FOR MECHANICAL WORK

SN	DESCRIPTION	MINIMUM QUANTITY
	HANDLING EQUIPMENTS	
1	TURN BUCKLES	AS PER REQMT
2	'D' SHACKLES	AS PER REQMT
3	STEEL WIRE ROPES	AS PER REQMT
4	MANILA ROPES	AS PER REQMT
5	CHAIN PULLEY BLOCK/TIRFUR	AS PER REQMT
	MAJOR T&P	
1	PIPE BENDING MACHINE – 2" SIZE	2 NOS
2	GRINDING MACHINE	2 NOS
3	DRILLING MACHINES 1/4", 1/2", 3/4" & 1"	1 NO. EACH
4	COPPER TUBE BENDER AND CUTTER SIZES 6MM, 8MM, 1/2", 1/4"	1 NO. EACH
5	DYE SETS FOR THREADING UPTO 2" PIPE.	2 NOS
6	SPIRIT LEVEL	2 NOS.
7	TAP SETS FOR BOTH BSP AND MPT THREADS UPTO 1" EACH	1 SET EACH
8	MEASURING INSTRUMENTS LIKE MICROMETRES AND CALIPERS	1 SET EACH
9	WELDING GENERATORS	1 NO.
10	WELDING TRANSFORMER	1 NO.
11	TIG WELDING SET	1 NO.
12	MECHANICAL TOOL KIT FOR FITTERS	4 NOS.
13	ELECTRICIAN TOOL KIT	4 NOS.
14	CRIMPING TOOL UPTO 2.5 SQ.MM CABLE	4 NOS.
15	FLOOD LIGHT FITTINGS	2 NOS.
16	FIRE EXTINGUISHERS	3 NOS.
17	DISTRIBUTION BOARDS WITH POWER CABLE COMPLETE AS REQUIRED	1 SET
18	PAINTING BRUSH	AS PER REQMT.
19	FIRE PROOF TARPAULIN	AS PER REQMT.
20	SAFETY BELTS AND SAFETY HELMETS	AS PER REQMT
21	24V A/C TRANSFORMER & HAND LAMPS	4 NOS.
22	MIG WELDING MACHINE WITH ACCESSORIES AIR COOL TYPE	2 NOS.
23	CRIMPING TOOL HYDRAULIC UPTO 600 SQ.MM	1 NO.
24	TORQUE WRENCH SET	1 SET
25	HYDRAULIC JACKS 250T CAPACITY/100T	4 NOS.EACH
26	TUFFER CAP ACITY 15T	2 NOS.
27	CHAIN PULLEY BLOCKS 5/10T	1 NO.EACH
28	MOBILE PICKUP / CARRY CRANE (SUITABLE CAPACITY)	AS PER REQMT.
29	TRUCK / TRAILER	AS PER REQMT.

OTHER THAN THE ABOVE, ONE COMPUTER, PRINTER AND OTHER NECESSARY PERIPHERALS WILL HAVE TO BE MAINTAINED BY THE CONTRACTOR IN HIS SITE OFFICE.

NOTE:

THE LIST OF INSTRUMENTS / EQUIPMENTS TO BE BROUGHT BY THE CONTRACTOR AS SHOWN ABOVE SECTIONS A AND B **ARE ONLY INDICATIVE** ANY OTHER INSTRUMENTS / EQUIPMENTS REQUIRED FOR THE EXECUTION OF THE WORK IS TO BE NECESSARILY ARRANGED BY THE CONTRACTOR WITHIN THE QUOTED RATES.

THE TESTING/CALIBRATION INSTRUMENTS WHICH ARE USED TO BE DULY CALIBRATED IN THE INTERVAL PRESCRIBED BY BHEL ENGINEERS FROM THE REPUTED AGENCIES DECIDED BY BHEL AND TEST CERTIFICATE TO BE FURNISHED.

APPENDIX -IV

MONTHWISE MANPOWER DEPLOYMENT (NUMBER TO BE INDICATED CATEGORY-WISE IN EACH MONTH) BY THE CONTRACTOR.

SL. NO.	CATEGORY	MONTHS																	
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	so on
01.	RESIDENT MGR																		
02.	ENGINEERS																		
03.	SUPERVISORS																		
04.	RIGGERS																		
05.	FITTERS																		
06.	HP WELDERS																		
07.	STRUCT. WELDERS																		
08.	TIG WELDERS																		
09.	MIG WELDERS																		
10.	ELECTRICIANS																		
11.	INSTRUMENT TECHNICIANS																		
12.	STORE KEEPER																		
13.	SEMISKILLED & UNSKILLED WORKERS																		
14.	WATCHMEN/SECURITY																		

NOTE:

01. MONTHWISE MINIMUM NUMBER OF PERSONS TO BE INDICATED.
02. ABOVE DEPLOYMENT PLAN WILL BE DISCUSSED PRIOR TO START OF WORK AND NECESSARY CHANGES SHALL HAVE TO BE MADE BY CONTRACTOR AS REQUIRED. ANY ADDITIONAL DEPLOYMENT REQUIRED DURING EXECUTION OF WORK SHALL HAVE TO BE MADE BY CONTRACTOR FOR MEETING VARIOUS SCHEDULES/TARGETS SET BY BHEL WITHOUT ANY ADDITIONAL COMPENSATION.

SIGNATURE OF TENDERER WITH SEAL

APPENDIX-V

ANALYSIS OF UNIT RATE QUOTED

Sl. No.	DESCRIPTION	Percentage of Unit Rate Quoted	Remarks If Any
01	SITE FACILITIES VIZ., ELECTRICITY, WATER, WORKSHOP AND OTHER INFRASTRUCTURE.		
02	SALARY & WAGES		
03	CONSUMABLES		
04	DEPRECIATION & MAINTENANCE FOR T&P/INSTRUMENTS AND OTHER ITEMS		
05	ESTABLISHMENT & ADMINISTRATION EXPENSES OF SITE		
06	RETRENCHMENT BENEFIT		
07	EXTRA WORK INCIDENTAL TO ERECTION		
08	OVERHEADS		
09	PROFIT		

SIGNATURE OF THE TENDERER WITH SEAL

APPENDIX–VI

Contractor's T&P/MMD Deployment Plan

SN	DESCRIPTION & CAPACITY OF T&P	MONTHS													
		1	2	3	4	5	6	7	8	9	10	11	12	13	14 and so on*
01															
02															
03															
04															
05															
06															
07															
08															
09															
10															

SIGNATURE OF THE BIDDER

DATE:

* Please use additional sheet if needed.

**APPENDIX-VII
CONCURRENT COMMITMENTS**

SN	FULL POSTAL ADRESS OF CLIENT AND NAME OF OFFICER IN- CHARGE	DESCRIPTION OF THE WORK	VALUE OF THE CONTRACT	COMMENC- EMENT DATE	SCHEDU- LED COMPLE- TION	% COMPL- TD. AS ON DATE	ANTICIPA- TED COMPLN. DATE	REMARKS

SIGNATURE OF THE BIDDER
DATE:

APPENDIX–VIII

DETAILS OF SIMILAR WORK DONE DURING THE LAST SEVEN YEARS

SN	FULL POSTAL ADDRESS OF CLIENT & NAME OF OFFICER IN CHARGE	DESCRIPTION OF WORK	VALUE OF CONTRACT (Rs.)	DATE OF AWARD OF WORK	DATE OF COMMENCEMENT OF WORK	TIME SCHEDULE (MONTHS)	DATE OF ACTUAL COMPLETION OF WORK	REMARKS

SIGNATURE OF BIDDER WITH SEAL

- PLEASE USE ADDITIONAL SHEET IF NEEDED BUT **IN THE SAME FORMAT.**
- **PLEASE ENCLOSE COPIES OF WORK ORDERS INCLUDING DETAILED BILL OF QUANTITIES, COMPLETION CERTIFICATES IN SUPPORT OF THIS STATEMENT.**