

CORRIGENDUM-IV

Tender No. BHEL:PSNR(SCT):KOSTI:CIVIL(3):375

Following amendments are hereby incorporated in specifications for the above mentioned tender:

AA : FOR 2 NOS 120 MTR TWIN STEEL FLUE CHIMNEY (CHANGE W.R.T REVISION IN QTY, UOM & CLARIFICATIONS.)				
SL.NO	UNIT	QTY. as per tender	Revised QTY.	ANY OTHER CHANGE/ CLARIFICATION
1-a)	CUM	4000	5500	
2-i-a	CUM	1200	1000	
2-i-b	CUM	800	500	
2-ii-a	CUM	400	0	
2-ii-b	CUM	2000	100	
7	CU.M	120	60	
8 i- a	CU.M	2000	1800	
8 ii- b	CU.M	6400	4600	
8 ii- c	CU.M	200	100	
9-i-a	MT	200	180	
9-ii-a	MT	10	5	
9-ii-b	MT	600	380	
10-i	SQ.M	500	400	
10-ii-a	SQ.M	24000	21000	
13	SQ.M	150	15	
15	MT	6	4	
17	MT	200	125	STEEL SHALL BE SUPPLIED FREE OF COST AGAINST THIS ITEM AS PER CL 39.1 of NIT
20	MT	34	30	
21-a	MT	4	0.5	
22	SQ.M.	70 (for 12 nos)	44 (for 8 nos)	
23	SQ.M.	12	11	
29-a	MT	4	1	
29-b	MT	16	6	
31-a	RM	100	50	
31-b	RM	600	400	
52-a	RM	1000	500	
52-b	RM	2600	1200	
52-c	RM	2200	1000	
53-a	RM	3200	1500	
53b	RM	10000	5000	
54	RM	6600	3000	

SL.NO	UNIT	QTY. as per tender	Revised QTY.	ANY OTHER CHANGE/ CLARIFICATION
56	RM			UNIT OF MEASUREMENT AGAINST THIS ITEM SHALL BE IN 'MT' INSTEAD OF 'RM'
59	NOS	200	16	
60	NOS	200	16	
BB : FOR 4 NOS INDUCED DRAFT COOLING TOWERS (CHANGE IN DESCRIPTION)				
1507-A	The description against this item is hereby changed as follows; "Providing and fixing corrugated 18 gauge GI sheet as cladding/ roofing as per IS 277 and min grade of galvanization shall be 450 gms/Sqm including all fixing accessories, labour, material, scaffolding etc. all complete as per spec. drawing and instruction of engineer incharge"			
All other terms and conditions against this shall remain unchanged.				
This corrigendum shall form a part of the tender and is to be submitted, duly signed and stamped, along with the Technical bid (Part-I).				
AGM/SCP				