



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TENDER CHANGE NOTE 01 (TCN – 01) DT: 05-04-2007

WITH REFERENCE TO THE NIT, PUBLISHED IN THE WEB SITES FOR THE WORK OF LIFTING OF GENERATOR STATOR BY STRAND JACK METHOD FOR 2 (TWO) UNITS OF 2 X 45 MW HMPCL-HALDIA PROJECT, WEST BENGAL AGAINST **TENDER DOCUMENT NO PSER:SCT:MET-M741:07**, FOLLOWING CHANGES MAY PLEASE BE NOTED AND COMPLIED.

SL. NO.	BIDDER'S Queries	BHEL's clarification
1	From the Tender document we understand that BHEL will not provide us with any crane at site. As you are aware normally BHEL provides the Carnage facility at site. Kindly Clarify	IT IS CONFIRMED THAT CRANE FACILITY SHALL NOT BE PROVIDED BY BHEL AS NO BHEL CRANE IS BEING DEPLOYED AT SITE. THE SAME HAS TO BE ARRANGED BY THE VENDOR AT HIS COST.
2	Please advice us if BHEL will give us the service of EOT (Electric Over Head Cranes). If yes, please give us the lifting capacity of this EOT.	NO EOT CRANE SERVICE SHALL BE PROVIDED.
3	Please clarify if the Generator will arrive at the site before we mobilize our equipment to the site. As you will appreciate, in this case, the Generator will have to be dragged by us. Otherwise if the Generator arrives at site after our lifting equipment is assembled then we can lift the Generator directly from the Trailer.	IT MAY PLEASE BE NOTED THAT IN THIS CASE FIRST GENERATOR SHALL REACH SITE BEFORE MOBILISATION OF STRAND JACK LIFTING CONTRACTOR. UNLOADING OF GENERATOR, PLACEMENT, FURTHER DRAGGING AND PLACEMENT OF THE SAME IN BETWEEN THE TOWER FOUNDATION AT 0.0M IS NOT COVERED UNDER THE SCOPE OF THIS TENDER.
4	In the Tender, removal of Carrier Beam is in Contractor's scope. Usually very heavy Generator are transported using railway wagons & carrier beams. We understand that a small Generator (like in this case) weighing only 70MT can be transported on normal/ hydraulic Trailer, in which case the carrier beam is not required. Kindly confirm.	AGREED. HERE THE GENERATOR SHALL BE TRANSPORTED THROUGH HYDRAULIC TRAILER.HENCE REMOVAL OF CARRIER BEAM DOES NOT COME INTO PICTIURE.

This document shall form part of tender document. All other terms & conditions shall remain unchanged.

Yours faithfully,
for BHARAT HYEAVY ELECTRICALS LTD

Sr Manager (SCT)

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION DJ 9/2 , SALT LAKE CITY, KOLKATA – 700 091

फैक्स/Fax : (033) 2321-1960 फोन/Phone : बोर्ड/EPABX : 2321 – 1691 / 1684