



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

(भारत सरकार का उपक्रम)

BHARAT HEAVY ELECTRICALS LIMITED

(A Govt. of India Undertaking)

TCN - 05

Ref: PSER:SCT:MJA-C752:TCN-05

Date: 29-06-2007

Sub	Tender change notice (TCN) 05.	
Job	Civil, structural etc work of Power Block 2 covering power house including mill bay, aux buildings, along with CW pump house and CW duct, misc civil works etc of unit # 2 for 2x500 MW at Mejia-B TPS, West Bengal.	
Ref	1.0	Tender no PSER:SCT:MJA-C752:07.
	2.0	BHEL's NIT, vide reference no PSER:SCT:MJA-C752:0901, dated 18-05-07.
	3.0	BHEL's TCN-01, vide reference no PSER:SCT:MJA-C752:TCN-01, dated 25-05-07
	4.0	BHEL's TCN-02, vide reference no PSER:SCT:MJA-C752:TCN-02, dated 01-06-07.
	5.0	BHEL's TCN-03, vide reference no PSER:SCT:MJA-C752:TCN-03, dated 11-06-07.
	6.0	BHEL's TCN-04, vide reference no PSER:SCT:MJA-C752:TCN-04, dated 21-06-07

With reference to above, following points, relevant to tender, may please be noted and complied with while submitting offer.

- 1.0 Bidder shall note the clarification/ modifications as per enclosed Annexure-A while submitting offer.
- 2.0 No deviation certificate has been revised as per enclosed Annexure-2. Bidder shall submit 'No deviation certificate' as per attached format only.
- 3.0 All other terms & conditions shall remain unchanged.

Thanking you,

Yours faithfully,
for BHARAT HEAVY ELECTRICALS LTD

DGM (SCT)

Encl

- 1.0 Annexure-A.
- 2.0 Annexure-2 - Revised format of 'No deviation certificate'.

पावर सेक्टर पूर्वी क्षेत्र (मुख्यालय)

POWER SECTOR EASTERN REGION, DJ-9/1, SALT LAKE CITY, KOLKATA - 700 091

फैक्स/Fax : (033) 23211960 फोन/Phone : बोर्ड/EPABX : 23211691

FORMAT FOR NO DEVIATION CERTIFICATE
(To be submitted in the bidder's letter head)

BHARAT HEAVY ELECTRICALS LIMITED,
Power Sector - Eastern Region,
Plot no 9/1, DJ Block, Sector – II, Salt Lake City,
Kolkata – 700 091

Sub	No Deviation Certificate.	
Job	Civil, structural etc work of Power Block 2 covering power house including mill bay, aux buildings, along with CW pump house and CW duct, misc civil works etc of unit # 2 for 2x500 MW at Mejia-B TPS, West Bengal.	
Ref	01	BHEL's NIT vide reference no PSER:SCT:MJA-C752:0901, dated 18-05-2007.
	02	Tender no PSER:SCT:MJA-C752:07.
	03	BHEL's TCN-01 vide reference no PSER:SCT:MJA-C752:TCN-01, dated 25-05-07.
	04	BHEL's TCN-02 vide reference no PSER:SCT:MJA-C752:TCN-02, dated 01-06-07.
	05	BHEL's TCN-03 vide reference no PSER:SCT:MJA-C752:TCN-03, dated 11-06-07.
	06	BHEL's TCN-04 vide reference no PSER:SCT:MJA-C752:TCN-04, dated 21-06-07.
	07	BHEL's TCN-05 vide reference no PSER:SCT:MJA-C752:TCN-05, dated 29-06-07.
	08	Other references (if any).

Dear Sirs,

With reference to above, this is to confirm that as per tender conditions, we have visited site before submission of our offer and noted the job content & site conditions etc. We also confirm that we have not changed/ modified the tender documents as appeared in the website and in case of observance at any stage, it shall be treated as null and void.

We hereby confirm that we have not taken any deviation from tender clauses together with other references as enumerated in the above referred NIT and confirm our acceptance to reverse auctioning process and we hereby convey our unqualified acceptance to all terms and conditions as stipulated in the tender and NIT.

In the event of observance of any deviation in any part of our offer at a later date whether implicit or explicit, the deviations shall stand null & void.

We confirm to have submitted offer strictly in accordance with tender instructions.

Thanking you,

Yours faithfully,

(Signature, date & seal of authorized
representative of the bidder)

Sl no	Tender no/ / Volume no/ clause no	Clarification/ modification.
1.0	PSER:SCT:MJA-C751:07/ PSER:SCT:MJA-C752:07/ PSER:SCT:MJA-C753:07 Volume-IIIA & IIIB, Rev-1/ ST NO 212B	The unit shall be `SQM' instead of `SQMM'.
2.0	PSER:SCT:MJA-C751:07/ PSER:SCT:MJA-C752:07/ PSER:SCT:MJA-C753:07 Volume-IIIA & IIIB, Rev-1/ ST NO 502(i)	The description of item stands corrected as under. `75 mm thick'.
3.0	PSER:SCT:MJA-C751:07/ PSER:SCT:MJA-C752:07/ Volume-IIIA & IIIB, Rev-1/ ST NO 502(ii)	The description of item stands corrected as under. `100 mm thick'.
4.0	PSER:SCT:MJA-C751:07/ PSER:SCT:MJA-C752:07/ PSER:SCT:MJA-C753:07 Volume-IIIA & IIIB, Rev-1/ ST NO 503	The description of item stands corrected as under. Providing & laying pressed pre-cast concrete tiles over water proofing of minimum size 600mmx600mm and min thickness 20 mm conforming to IS 13801 including 15mm thick cement mortar (1:4) bedding inclusive of provision for thermal expansion for each roofing tile filled with polysulfide joint sealant (water proofing paid else where).