
		BHARAT HEAVY ELECTRICALS LTD., RAMACHANDRAPURAM HYDERABAD - 500 032. ANDHRA PRADESH - INDIA.		PH: 040 - 23184380 & 040-23182208 FAX.NO:040-23021910&23021954		ENQUIRY PURCHASE DEPARTMENT		SHEETOF			
SUPPLIER CODE:				ENQUIRY		AMENDMENT		NO. OF ITEMS.			
M/s. Sreelakshmi Traders, M/s. Citadel Architectural Solutions.				No. M3/07/MA-013/PS1		Date: 1/8/2007		No. Date.			
				DUE DATE OF QUOTATION. 16/08/2007		THIS IS ONLY A REQUEST FOR QUOTATION AND NOT AN ORDER.					
				Kindly note that visiting hours are only after 14.30 hrs. unless with a prior appointment.							
				Please specify on all your Correspondence/Envelopes/Telexes addressee's name, designation department and our reference for our prompt action.							
ENQ Sl.No.	INDENT (MPR)No.	INDT. Sl.No.	MATERIAL CODE/ DRAWING.NO	DESCRIPTION SPECIFICATION.		UNIT	QTY	DELIVERY SCHEDULE			
								DATE	QTY		
1	MA-013	1	NIC	Supply, installation and Erection of 24" Wind Driven Spherical Turbo Ventilator with FRP base plate suitable to existing profile of asbestos sheet. (Detailed technical specifications and Terms & Conditions as per enclosure)		Nos.	156	Sep, 2007	156 Nos		
REMARKS SPECIAL ATTENTION: DEAR SIR, Please submit your lowest quotation in sealed cover superscribed with enquiry.No & date subject to our terms and conditions attached for the above materials so as to reach us on or before due date by 2 p.m. and the Tenders will be opened at 3.00 P.M. If our enquiry.no. tender due date are not superscribed on the tender cover, your offer shall be summarily rejected. Also quote enquiry.No. date and enquiry SL.NO. in all correspondence for prompt action.						TEST CERTIFICATE* REQD <input type="checkbox"/> NOT REQD <input type="checkbox"/>		* TICK THE APPLICABLE BOX for AND ON BEHALF OF BHARAT HEAVY ELECTRICALS LTD.,  (P. SURYA CHANDRA RAJU) Manager/Purchase (M&S) E Mail: surya@bhelhyd.co.in			
						GUARANTEE REQD <input type="checkbox"/> NOT REQD <input type="checkbox"/>					
						SAMPLE REQD <input type="checkbox"/> NOT REQD <input type="checkbox"/>					

SPECIFICATION FOR TURBO VENTILATOR

1. Description : Supply, Installation and Erection of 24" Wind Driven Spherical Turbo Ventilator with FRP base plate suitable to existing profile of asbestos sheet in 06 Shop
2. Size of the Ventilator : 24"
3. Throat Size : 24"
4. Discharge Capacity : To be specified at min 56 feet & max 64 feet height
5. Construction material : All Aluminum alloy construction
6. Base : FRP Base plate with profile to suit to existing roof
7. Protection : From rain and dust in to the shop
8. Bearings : High Precision Sealed Ball Bearings
9. Noise Level : To be specified
10. Customer Reference List : To be supplied along with offer
11. Weight of Ventilator : To be specified
12. Dynamic Balance : Required level to be indicated
13. Guarantee : 12 Months from the date of Commissioning OR 18 Months from the date of Supply which ever is earlier.
14. Dimensions of the Ventilator : To be specified
15. Up to what velocity of wind, ventilator will withstand : To be specified

Manoj
30/07/2007