

TENDER SPECIFICATION

No. BHE/PW/PUR/TRT-ELE/516

FOR

HANDLING AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, COMPLETE ERECTION, CHECKING OF CALIBRATION, TESTING, COMMISSIONING AND HANDING OVER OF ELECTRICAL PACKAGES VIZ., POWER TRANSFORMERS, ISOLATED PHASE BUS DUCT FOR GENERATOR TRANSFORMER, STATION TRANSFORMER / UNIT AUX. TRANSFORMER, ELECTROSTATIC PRECIPITATOR, GENERATOR CONTROL & PROTECTION PANELS, STATION TRANSFORMER, CONTROL & RELAY PANELS, 6.6kV / 0.415 kV SWITCHGEAR BOARDS MCC, LV 0.415 KV BUSDUCTS, SOOT BLOWER SYSTEM, DIGITAL STATIC EXCITATION SYSTEM, VARIABLE FREQUENCY DRIVE, 220 VOLT BATTERY SYSTEM, ELECTRICAL HOIST & ASSOCIATED ITEMS AND CABLING PACKAGE FOR UNIT #8 of 250 MW

AT

TROMBAY THERMAL POWER GENERATING STATION

TATA POWER COMPANY LTD.

TROMBAY, MUMBAI

MAHARASHTRA

PART: I

TECHNICAL BID SPECIFICATION

&

REVERSE AUCTION PROCEDURE, NOTICE INVITING TENDER, GCC



BHARAT HEAVY ELECTRICALS LIMITED
(A Govt. of India Undertaking)
POWER SECTOR - WESTERN REGION
345, KINGS WAY - NAGPUR 440 001

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

C o n t e n t s			
SN	Description	Section/ Appendix No.	No. of Pages
1	Tender Specification issue details	–	1
2	Procedure For Submission of Sealed Tender	–	1
3	Project Information	–	1
4	Check List	–	2
5	Declaration by Bidder's Authorized Representative	–	1
6	Certificate of No-Deviation	--	1
7	Notice Inviting Tender (includes Qualification Requirements etc.)	\$	3
8	Reverse Auction Procedure	\$	11
9	General Conditions of Contract #	Sections-1 & 2 \$	29
10	Offer of Bidder	Section-3	1
Special Conditions of Contract			
11	Scope of Work	Section-4 & 16	66
12	Obligations of the contractor (TOOLS, TACKLES & CONSUMABLES)	Section-5	8
13	Contractor's Obligations in Regard to Employment of Supervisory Staff and Workmen	Section-6	2
14	Obligations of BHEL	Section-7	1
15	Inspection/Quality Assurance/Quality Control/Statutory Inspection	Section-8	3
16	Safety, Occupational Health and Environmental Management	Section-9	14
17	Drawings And Documents	Section -10	1
18	Time Schedule/Mobilization/ Progress Monitoring/ Overrun.	Section -11	4
19	Terms of Payment	Section -12	6
20	Extra Charges for Modification/ Rectification	Section -13	2
21	Insurance	Section -14	2
22	Earnest Money Deposit and Security Deposit	Section -15	2
Appendices			
23	General information for transformers, HVR, Battery Charger, Bus Duct, DVR, GRP	Appendix-I	9
24	List of T&P to be provided by BHEL free of charges	Appendix-IIA	1
25	List of Consumable to be Provided by BHEL free of cost	Appendix-IIB	1

C o n t e n t s			
SN	Description	Section/ Appendix No.	No. of Pages
26	Tentative List of T&P and MMD to be Deployed by the Contractor	Appendix-III	4
27	Tentative List of Consumable to be Provided by the Contractor		
28	Month -wise Manpower Deployment Plan by Contractor for E&C work	Appendix-IVA	1
29	Month -wise Deployment Plan of major T&P and MMD by the Contractor	Appendix-IVB	1
30	Analysis of Unit Rates Quoted	Appendix-V	1
31	Detail of work done during last seven years	Appendix-VI	1
32	Details of Concurrent Commitment	Appendix-VII	1
33	Part-II (Price Bid)	Part-II	@

LEGEND:

\$: Attached at the end of hard copy of Tender Specifications Part-I. Hosted in BHEL web page (www.bhel.com) as file titled “**NIT+RA+GCC-516**”.

@: Issued as separate hard copy booklet ‘Tender Specifications Part-II (Price Bid)’. Hosted in BHEL web page (www.bhel.com) as files titled “**PRICE BID-516**” & “**PRICE BID-516 Cover Pages**”

Note:

Rest of the tender documents are included in Tender Specifications Part-I. Hosted in BHEL web page (www.bhel.com) as file titled “**TECH BID-516**”

BHARAT HEAVY ELECTRICALS LIMITED

(A GOVERNMENT OF INDIA UNDERTAKING)

POWER SECTOR - WESTERN REGION

SHREEMOHINI COMPLEX

345-KINGSWAY, **NAGPUR** 440 001

HANDLING AT SITE STORES/STORAGE YARD, TRANSPORTATION TO SITE OF WORK, COMPLETE ERECTION, CHECKING OF CALIBRATION, TESTING, COMMISSIONING AND HANDING OVER OF ELECTRICAL PACKAGES VIZ., POWER TRANSFORMERS, ISOLATED PHASE BUS DUCT FOR GENERATOR TRANSFORMER, STATION TRANSFORMER / UNIT AUX. TRANSFORMER, ELECTROSTATIC PRECIPITATOR, GENERATOR CONTROL & PROTECTION PANELS, STATION TRANSFORMER, CONTROL & RELAY PANELS, 6.6kV / 0.415 kV SWITCHGEAR BOARDS MCC, LV 0.415 KV BUSDUCTS, SOOT BLOWER SYSTEM, DIGITAL STATIC EXCITATION SYSTEM, VARIABLE FREQUENCY DRIVE, 220 VOLT BATTERY SYSTEM, ELECTRICAL HOIST & ASSOCIATED ITEMS AND CABLING PACKAGE FOR UNIT #8 of 250

AT

TROMBAY THERMAL POWER GENERATING STATION

TATA POWER COMPANY LTD.

TROMBAY, MUMBAI

MAHARASHTRA

EARNEST MONEY DEPOSIT : Please see Special Conditions of Contract.

LAST DATE FOR TENDER SUBMISSION: Please obtain updated information from web page "<http://www.bhel.com>" → Tender Notifications → View Corrigendums.

THESE TENDER SPECIFICATION DOCUMENTS CONTAINING PART-I (TECHNICAL BID SPECIFICATION) AND PART- II (PRICE BID), ARE ISSUED TO:

M/s.

.....

PLEASE NOTE:

THESE TENDER SPECS DOCUMENTS ARE NOT TRANSFERABLE.

BIDDER SHALL NOTE THAT THEIR OFFER WILL BE CONSIDERED SUBJECT TO THE APPROVAL OF BHEL'S CUSTOMER.

For Bharat Heavy Electricals Limited

Dy. General Manager (Purchase)

Place: Nagpur

Date:

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

Bharat Heavy Electricals Limited

(A Government of India Undertaking)
Power Sector - Western Region
345-Kingsway, Nagpur - 440 001

Procedure for Submission of Sealed Tenders & Instructions to Bidders

The bidder must submit their tenders as required in two parts in separate sealed covers prominently super scribed as part-I technical bid and part-II price bid and also indicating on each of the covers the tender specification number and due date and time as mentioned in the tender notice.

Part-I (Technical Bid) cover-I:

Excepting rate schedule, all other schedules, data sheets and details called for in the specification shall be enclosed in part-I "Technical Bid" only.

Part-II (Price Bid) cover-II:

All indications of price shall be given in this part-II "Price Bid". EMD shall not be included in this cover.

These two separate covers-I and II (part-I and part-II) shall together be enclosed in a third envelope (cover-III) along with requisite EMD as indicated earlier and this sealed cover shall be super scribed and submitted to Dy. Gen Manager (Purchase) at the above -mentioned address on or before the due date as indicated.

The qualified bidder will be intimated separately about the status of their offer.

Bidders are requested to make specific note of the following conditions:

1. Contractor should have adequate resources including major T&P at his disposal for this job.
2. Contractor should have sound financial stability.
3. Bidder should meet quality requirement regarding workmanship, deployment of personnel, erection tools and necessary inspection, measurement & testing instruments.
4. All information as called for in various appendices and clauses of Tender Specification should be furnished in completeness. Please refer the checklist.
5. Clarification on tender if any shall be asked by bidders at least seven days before Due date as stipulated in the NIT.
6. Offers must be submitted without any deviation.
7. Offers received with any deviation or without relevant information as described above are liable to be rejected. Price bids received in the form other than specified in Part-II (Price Bid) are liable to be rejected.
8. Bidder shall note that their offer will be considered subject to the approval of BHEL's customer.

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

PROJECT INFORMATION

1.00.00 BACKGROUND

TATA Power Company Limited as part of expansion plan is installing the 1x250 MW Unit#8 Trombay Thermal Power Generating Station within the existing premises of their Trombay Thermal Generating Station at Trombay, Mumbai (Maharashtra).

1.01.00 Location and Approach

The site is located at Trombay, Mumbai and is connected by Rail to Kurla Marshaling Yard. Trombay is accessible by Road & Rail.

1.02.00 Climatic conditions:

- (a) Maximum dry bulb temperature – 36.7 Degree Centigrade
- (b) Minimum dry bulb temperature – 18.3 Degree Centigrade

1.03.00 Relative humidity:

- (a) Maximum during monsoon – 100 %
- (b) Minimum during December to January – 22 %

1.04.00 Rainfall : Annual average rainfall is about 2099 mm (Most of which occurs during the monsoon season from June to September)

1.05.00 Wind Data : Basic wind speed-44 M/sec (in accordance with IS 875-1987 (Parts-3))

1.06.00 Seismic conditions : The proposed site is located in seismic ZONE III as per the Indian Standard IS 1893 and importance factor of 1.5

1.07.00 Air Quality: Atmosphere polluted with industrial gases and wastes because of proximity to petroleum refineries and fertilizer complex.

Contractor is advised to visit the site and appraise himself about the conditions of site, Layout and infrastructure available in the area for fulfilling their commitments under the contract.

Check List			
(Vide Para 1.3 Of Section-I of General Conditions Of Contract)			
1	Name of the Bidder with Postal Address for Correspondence		
2	Name of Contact Person with Telephone & Fax No.	Mr./Ms Tel No. Fax No.	
3	Nature of the firm	PROPRIETARY / PARTNERSHIP / LIMITED CO.	
4	Details of EMD Please Indicate whether 1) One Time EMD or, 2) Only for this Tender	DD No. DD Date..... Name of Bank..... Amount: Rs.....	
5	Validity of Offer (BHEL's Requirement: 180 days from Due Date)	Validity _____ days	
6	Mobilization Time (Please refer Section-11 of SCC)	Mobilization Time _____	
7	Whether any conditions stipulated?	Yes (vide Document reference:	No
		Bidder to note that tender with conditions unacceptable to BHEL shall be rejected.	
8	Bidder has visited the project site and acquainted with the site conditions	Yes	No
9	Details of concurrent jobs are furnished (Appendix-VII)	Yes	No
10	Headquarters organization is furnished	Yes	No
11	Proposed site organization is furnished	Yes	No
12	Names and particulars of directors/partners are furnished	Yes	No
13	Financial status of the firm (Annexure 'A' of GCC) is furnished	Yes	No
14	Copy of Audited Profit & Loss Account for preceding three years duly authenticated on each copy by bidders Chartered Accountants	Yes	No

Check List			
(Vide Para 1.3 Of Section-I of General Conditions Of Contract)			
15	Latest Certificate by Bidder's Banker for Overdraft & BG Limits is Furnished (Certificate shall not be older than six months from the Last Date for offer submission)	Yes	No
16	Latest copy of IT Return along with copy of PAN Card are Furnished	Yes	No
17	Month-wise Manpower Deployment Plan (Appendix – IVA) is furnished	Yes	No
18	Analysis of Unit Rates quoted (Appendix-V) is furnished	Yes	No
19	Month-wise deployment plan for major T&P (Appendix-IVB) is furnished	Yes	No
20	Whether all the pages of the Tender Specification documents are read, understood and signed	Yes	No
21	Power of Attorney enclosed in favour of person making offer	Yes	No
22	Bidder has familiarized himself with all Relevant Local Laws & Local Conditions	Yes	No
23	Safety Requirement of this work in a Running plant Premises has been understood.	Yes	No
24	Erection and Commissioning programme furnished	Yes	No
25	List of Jobs completed in last seven years is furnished (Appendix-VI)	Yes	No
26	Whether copies of detailed Work Orders (with BOQ) and Completion Certificates in support of above furnished	Yes	No
27	Whether contractor has left any job unfinished? If so, give reasons.	Yes	No
28	Whether any client has terminated the contractor's work before completion? If so, furnish reasons for the same	Yes	No

Note: strike off or tick '**yes**' or '**no**', as applicable

Date:

Signature of Bidder

Declaration by Bidder's Authorized Signatory

I.....hereby certify that all the information and data furnished by me with regard to this tender specification No. **BHE/PW/PUR/TRT-ELE/516** is true and complete to the best of my knowledge. I have gone through the specification, conditions and stipulations in detail and agree to comply with the requirements and intent of the specification. I further certify that I am duly authorized representative of the under mentioned bidder and a **valid power of attorney to this effect is also enclosed with the offer.**

Bidder's name and address

Authorised representative's signature with
Name and Address

Date:

CERTIFICATE OF NO-DEVIATION

TENDER SPECIFICATION No. BHE/PW/PUR/TRT - ELE/516

I/WE, M/s.....

HEREBY CERTIFY THAT NOTWITHSTANDING ANY CONTRARY INDICATIONS/ CONDITIONS ELSEWHERE IN OUR OFFER DOCUMENTS, I/WE HAVE NEITHER SET ANY TERMS AND CONDITIONS NOR THERE IS ANY DEVIATION TAKEN FROM THE CONDITIONS OF BHEL'S TENDER SPECIFICATIONS, EITHER TECHNICAL OR COMMERCIAL, AND I/WE AGREE TO ALL THE TERMS AND CONDITIONS MENTIONED IN BHEL'S TENDER SPECIFICATION WITH ASSOCIATED AMENDMENTS AND CLARIFICATIONS.

Date:

Signature of the Bidder

SECTION-3 OFFER OF THE BIDDER

To
DGM (PURCHASE)
BHARAT HEAVY ELECTRICALS LIMITED
POWER SECTOR - WESTERN REGION
SHREEMOHINI COMPLEX
345-KINGSWAY
NAGPUR 440 001

DEAR SIR,

I/WE HEREBY OFFER TO CARRY OUT THE WORK DETAILED IN TENDER SPECIFICATION NO. BHE/PW/PUR/TRT-ELE/516 ISSUED BY BHARAT HEAVY ELECTRICALS LIMITED, POWER SECTOR-WESTERN REGION, NAGPUR, IN ACCORDANCE WITH THE TERMS AND CONDITIONS THEREOF.

I/WE HAVE CAREFULLY PERUSED THE FOLLOWING DOCUMENTS CONNECTED WITH THE ABOVE WORK AND AGREE TO ABIDE BY THE SAME.

1. INSTRUCTIONS TO TENDERERS
2. GENERAL CONDITIONS OF CONTRACT
3. SPECIAL CONDITIONS OF CONTRACT
4. OTHER SECTIONS, APPENDICES, SCHEDULES AND DRAWINGS.

I/WE HAVE DEPOSITED / FORWARDED HERewith THE EARNEST MONEY DEPOSIT AND DETAILS OF EMD PAYMENT ARE FURNISHED IN THE CHECK LIST.

EMD SHALL BE REFUNDED SHOULD OUR OFFER NOT BE ACCEPTED /EMD NEED NOT BE REFUNDED AND THE AMOUNT MAY BE TREATED AS "ONE TIME EMD" FOR ERECTION AND COMMISSIONING TENDERS OF BHEL –PSWR NAGPUR SHOULD OUR OFFER BE ACCEPTED, I/WE FURTHER AGREE TO DEPOSIT SECURITY DEPOSIT FOR THE WORK AS PROVIDED FOR IN THE TENDER SPECIFICATION WITHIN THE STIPULATED TIME AS MAY BE INDICATED BY BHEL, POWER SECTOR –WESTERN REGION, NAGPUR.

I/WE FURTHER AGREE TO EXECUTE ALL THE WORKS REFERRED TO IN THE SAID DOCUMENTS UPON THE TERMS AND CONDITIONS CONTAINED OR REFERRED TO THEREIN AND AS DETAILED IN THE APPENDICES ANNEXED THERETO.

PLACE:
DATE :

SIGNATURE OF BIDDER:
ADDRESS:

WITNESSES WITH THEIR ADDRESS

SIGNATURE	NAME	ADDRESS
-----------	------	---------

1.

2.

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

SECTION-4

SPECIAL CONDITIONS OF CONTRACT

THE SCOPE OF WORK UNDER THIS CONTRACT IS BROADLY CLASSIFIED INTO TWO GROUPS.

GROUP ONE IS FOR ELECTRICAL EQUIPMENTS AND ASSOCIATED AUXILIARIES SUCH AS TRANSFORMERS,BUS DUCT, SOOT BLOWER, SWITCHGEARS, ESP, VFD, MOTORS ETC. THE SCOPE OF WORK FOR THIS GROUP HAS BEEN DETAILED IN SECTION-4 AND GENERAL INFORMATION IS GIVEN IN APPENDIX -1

GROUP TWO IS FOR CABLING, TRAY AND ASSOCIATED WORKS. THE SCOPE OF WORK FOR THIS GROUP HAS BEEN DETAILED IN SECTION-16 OF THIS TENDER SPECIFICATION.

4.0 SCOPE OF WORK

The work under these specifications broadly covers the complete work of handling at storage yard/stores, transportation to work site, calibration, pre-assembly, erection, testing, pre-commissioning tests and checks and handing over of Electrical Equipment & Associated Auxiliaries of various systems as listed under.

1. GENERATOR TRANSFORMER, STATION TRANSFORMER, UNIT TRANSFORMER AND OTHER TRANSFORMERS OF VARIOUS CAPACITIES
2. ISOLATED PHASE BUS DUCT, SEGREGATED PHASE BUS DUCT AND NON-SEGREGATED PHASE BUS DUCT.
3. SOOT BLOWER SYSTEM
4. 6.6KV, 415V AC, 220V DC, 24 VOLT, & UPS SWITCHGEAR BOARDS
5. 415 VOLTS LV BUS DUCTS
6. DIGITAL STATIC EXCITATION SYSTEM
7. ELECTROSTATIC PRECIPITATOR
8. ELECTRICAL HOISTS AND ELEVATORS
9. CONTROL & RELAY PANELS
10. VARIABLE FREQUENCY DRIVE
11. HT/LT MOTORS TESTING AND COMMISSIONING
12. TRAY WORK , CABLING SYSTEM
13. EARTHING & LIGHTENING PROTECTION SYSTEM.
14. ANY OTHER ASSOCITED SYSTEMS REQUIRED FOR COMPLETION OF THE BOILER-TURBINE-GENERATOR (BTG) PACKAGE.

For proper planning, monitoring and smooth execution of job at site, the contractor will be required to maintain his own computer, printer along with operator at his site office.

BHEL uses its own software SOMS (Site Operation and Management System) for total project execution and billing. The contractor shall also provide adequate and suitable manpower for updating/entries into SOMS in BHEL computers at site.

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

Scope of work is further detailed in various clauses hereafter.

4.1 GENERAL REQUIREMENTS

- 4.1.1 The intent of specification is to provide services according to the most modern and proven techniques and codes. The omission of specific reference to any method, equipment or material necessary for proper and efficient execution of this work shall not relieve the contractor of the responsibility of providing such facilities to complete the work without any extra compensation.
- 4.1.2 The work to be carried out under the scope of this specification covers the complete work of loading, handling, transporting, unloading, preassembly, erection, calibration, testing, air flushing, pre-commissioning tests, commissioning of systems, trial run of various auxiliaries and equipments, achieving various milestones till handing over of the unit to BHEL's customer. The work shall conform to dimensions and tolerances specified in various drawings that will be provided during the erection. If any portion of the work is found to be defective in workmanship or not conforming to drawings or other specifications, the contractor shall dismantle and re-do the work duly replacing the defective materials at his cost, failing which the work will be got done by engaging other agencies or departmentally and recoveries will be effected from contractor's bills towards expenditure incurred including 30% departmental charges.
- 4.1.3 The terminal points decided by BHEL should be final and binding on the contractor for deciding the scope of work and effecting payment for the work done.
- 4.1.4 The work shall be executed under the usual conditions affecting major power plant construction and in conjunction with numerous other operations at site. The contractor and his personnel shall cooperate with personnel of BHEL, BHEL's customer, customer's consultants and other contractors, coordinating his work with others and proceed in a manner that shall not delay or hinder the progress of work of the project as a whole.
- 4.1.5 The work covered under this specification is of highly sophisticated nature, requiring the best quality workmanship, supervision, engineering and construction management. The contractor should ensure proper planning and successful & timely completion of the work to meet the overall project schedule. The contractor must deploy adequate quantity of tools & plants, modern/latest construction aids etc. He must also deploy adequate trained, qualified and experienced supervisory staff and skilled personnel.
- 4.1.6 Contractor shall erect, align and commission all the equipments and auxiliaries as per the sequence & methodology prescribed by BHEL depending upon the technical requirements. Availability of materials and fronts will decide this. BHEL engineer's decision regarding correctness of the work and method of working shall be final and binding on the

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

contractor. No claims for extra payment from the contractor will be entertained on the ground of deviation from the methods / sequences adopted in erection of similar sets elsewhere.

- 4.1.7 All necessary certificates and licenses, permits & clearances required to carry out this work from the respective statutory authorities are to be arranged by the contractor expeditiously at his cost and in time to ensure smooth progress of work.
- 4.1.8 The work shall conform to dimensions and tolerances specified in the various drawings / documents that will be provided during various stages of erection. If any portion of work is found to be defective in workmanship, not conforming to drawings or other stipulations due to contractor's fault, the contractor shall dismantle and re-do the work duly replacing the defective materials at his cost, failing which the work will be got done by BHEL and recoveries will be effected from the contractor's bills towards expenditure incurred including cost of materials and 30% departmental overheads of BHEL.
- 4.1.9 Contractor will be required to maintain in his site office at least one PC along with minimum accessories like printer, etc to enable him to carry out site activities in a planned, well coordinated and smooth manner.
- 4.1.10 The contractor shall execute the work in the most substantial and workmanlike manner. The stores shall be handled with care and diligence.
- 4.1.11 BHEL reserves right to recover from the contractor any loss, which arises out of undue delay/discrepancy/shortage/damage, or any other causes due to contractor's lapse during any stage of work. Any loss to BHEL due to contractor's lapse shall have to be made good by the contractor.
- 4.1.12 All transport equipment, handling equipment, tools, tackles, fixtures, equipment, materials, manpower, supervisors/engineers, consumables etc., except otherwise specified as BHEL scope of free issue, required for this scope of work shall be provided by the contractor. All expenditure including taxes and incidentals in this connection will have to be borne by him unless otherwise specified in the relevant clauses. The contractor's quoted rates should be inclusive of all such contingencies.
- 4.1.13 During the course of erection, testing and commissioning certain rework/ modification / rectification / repair / fabrication etc. may become necessary on account of feedback / revision of drawing. This will also include modifications / re-works suggested by BHEL / customer / other inspection group. Contractor shall carry out such rework / modification / rectification / fabrication / repair etc., promptly and expeditiously. Daily log sheets signed by BHEL engineer and indicating the details of work carried out, man-hours etc. shall be maintained by the contractor for such reworks. Claim of contractor if any, for such works will be governed by clauses 13.1 to 13.8.

- 4.1.14 All works such as cleaning, levelling, aligning, trial assembly, dismantling of certain equipments / components for checking and cleaning, surface preparation, fabrication of sheets, tubes and pipes as per general engineering practice and as per BHEL engineer's instructions at site, cutting, gouging, weld depositing, grinding, straightening, chamfering, filing, chipping, drilling, reaming, scrapping, lapping, fitting up etc., as may be applicable in such erection works and which are treated incidental to the erection works and necessary to complete the work satisfactorily, shall be carried out by the contractor as part of the work within the quoted rates.
- 4.1.15 The contractor shall make all fixtures, temporary supports, steel structures required for jigs & fixtures, anchors for load and guide pulleys required for the work (excepting those specifically included in BHEL scope). However, necessary steel will be provided from the scrap / surplus materials available at site.
- 4.1.16 The contractor shall take delivery of the components, equipments, chemicals, lubricants etc from the BHEL stores/ storage area after getting the approval of BHEL engineer on standard indent forms of BHEL. Complete and detailed account of the materials and equipments after usage shall be submitted to the BHEL and reconciled periodically. While taking delivery of items from store it may be necessary to handle (shift / relocate) other items (not necessarily those in the scope of the contractor). Separate payment will NOT be made if such situations arise.
- 4.1.17 Contractor shall plan and transport equipments, components from storage to erection site and erect them in such a manner and sequence that material accumulation at site does not lead to congestion at site of work. Materials shall be stacked neatly, preserved and stored in the contractor's shed and at work areas in an orderly manner. In case it is necessary to shift and re-stack the materials kept at work areas/ site to enable other agencies to carry out their work or for any other reason, contractor shall do it most expeditiously. No claim for extra payment for such work will be entertained.
- 4.1.18 Plant materials should not be used for any temporary supports / scaffolding / preparing pre-assembly bed etc.
- 4.1.19 The services, tests and support to be provided by the agency for the work mentioned in various sections of this tender are indicative and not exhaustive, but not limited to these for completion of the work in all respects.**
- 4.1.20 All the work shall be carried out as per the instructions of BHEL engineer. BHEL engineer's decision regarding the correctness of the work and method of working shall be final and binding on the contractor.
- 4.1.21 The weights & dimensions as mentioned against the individual items in Price Bid Part –II "Rate Schedule" are indicative approximate and there may be variation in dimension & weight in actual supply of equipment. No rate variation shall be considered on this account.**

- 4.1.22 The scope of work & description of system / equipment as given in the various clause of this tender specification and rate schedule are only for understanding the system requirement, contractor shall note this point and assess the volume of work prior to submit the offer. No compensation shall be considered later on.
- 4.1.23 The contractor shall have total responsibility for all equipment and materials in his custody at contractor's stores, loose, semi-assembled, assembled or erected by him at site. He shall effectively protect the finished works from action of weather and from damages or defacement and shall also cover the finished parts immediately on completion of work as per BHEL engineer's instructions. The machine surfaces/finished surfaces should be greased and covered.
- 4.1.24 At all stages of work, equipments/materials in the custody of contractor, including those erected, will have to be preserved as per the instructions of BHEL.
- 4.1.25 The contractor shall make suitable security arrangements including employment of security personnel and ensure protection of all materials/equipment in their custody and installed equipments from theft/fire/pilferage and any other damages and losses.
- 4.1.26 Contractor shall collect all scrap materials periodically from various area of work site, deposit the same at one place earmarked at site or shift the same to a place earmarked in BHEL/ client's stores. In case of failure of contractor in compliance of this requirement, BHEL will make suitable arrangement at contractor's risk and cost.
- 4.1.27 The entire surplus, damaged, unused materials, packaging materials / containers, special transporting frames, gunny bags, etc., shall be returned to BHEL stores by the contractor.
- 4.1.28 The contractor shall not waste any materials issued to him. In case it is observed at any stage that the wastage/excess utilisation of materials is not within the permissible limits, recovery for the excess quantity used or wasted will be effected with departmental charges from the contractor. Decision of BHEL on this will be final and binding on the contractor.
- 4.1.29 For any class of work for which no specifications have been laid down in these specifications, work shall be executed as per the instructions of BHEL engineer.
- 4.1.30 House keeping in the erection and preassembly area is as important as the well-planned and orderly work. The access to site for inspection, approaches by BHEL and customer engineers and leading of the material shall be made available by the contractor at all times. The shifting and resifting of erection materials, tools and plants and clearance of restrictions, filling of ditches, undulation near the pre-assembly and boiler area is the responsibility of the contractor. Contractor should visit the site

and acquaint himself with all restrictions and difficulties that he may encounter during erection/commissioning stages.

- 4.1.31 The contractor shall take delivery of equipment, materials from the storage yard/ stores/sheds of BHEL/customer he shall also make arrangements for verification of equipment, transportation up to site of work, safe custody, watch and ward of equipment after it has been handed over to him till these are fully erected, tested and commissioned and taken over by the customer. The contractor should note that the transport of equipments to erection site, assembly yards etc. should be done by the prescribed route without disturbing the other works and contractors and in the most professional manner. Special equipments such as measuring and control equipments, panels, console inserts, switches, cables, conduits etc. shall be stored when taken over by the contractor in appropriate manner as per BHEL's instructions.
- 4.1.32 The contractor shall handover all parts/materials remaining extra over the normal requirement with proper identification tags in a packed condition to BHEL stores. In case of any misuse or use over actual design requirements, BHEL reserves the right to recover the cost of parts/materials used in excess or misused. Decision of BHEL engineer in this regard will be final and binding on the contractor.
- 4.1.33 The contractor should take all reasonable care to protect equipment and materials under his custody either in his stores or at site. Copper tubing, Copper bus bars, brass fittings, brass valves, contactors, etc., forming an integral part of equipment or system are liable to greater damages / pilferages /theft / losses. It will be responsibility of contractor to arrange for adequate security round the clock for protection from such damages/pilferages/theft/losses .
- 4.1.34 The contractor shall ensure that all the packing materials and protection devices used for the various equipments during transit and storage are removed before these equipments are erected in position.
- 4.1.35 Overhauling, cleaning, revisioning, servicing of equipments during erection and commissioning stages will be arranged by the contractor. All equipments shall be preserved and protected before and after erection as per the advice of BHEL engineer.
- 4.1.36 Substantial portion of Cable laying & termination shall be done by other agencies for those equipment covered under this tender specification. The glands & lugs shall be supplied either loose or fitted with the equipments. Contractor shall take care of this aspect at the time of receipt of the equipment from BHEL stores. Contractor shall account for the quantities received with equipments and shall hand over the same to cabling agency under intimation to BHEL Engineer. Contractor shall extend all necessary help & co-ordinate with the cabling agency during the course of work.
- 4.1.37 Contractor shall prepare Marked-Up drawings incorporating modifications and deviations from original drawings or prepare fresh sketch for actual

installation / connection details if need be, that can be converted to "As-built" drawing.

4.2 WELDING, NON-DESTRUCTIVE TESTING ETC.

- A) Installation of equipment involves good quality welding, NDE checks etc .
- B) Welder deployed for aluminium welding shall have experienced and approved by BHEL and MSEB after due qualification process/testing.
- C) Welding of all structural steel & aluminium shall be done only by the qualified and approved welders.
- D) All the welders shall be tested and approved by BHEL engineer before they are actually engaged on work though they may possess the IBR/other certificate. BHEL reserves the right to reject any welder without assigning any reason.
- E) The welded surface shall be cleaned of slag and painted with primer paint to prevent corrosion. For this paint will be supplied by the contractor.
- F) Welding electrodes have to be stored in enclosures having temperature and humidity control arrangement. This enclosure shall meet BHEL specifications.
- G) Certain types of coated welding electrodes, prior to their use, call for baking for specified period and will have to be held at specified temperature for specified period. Also, during execution, the coated welding electrodes have to be carried in portable ovens.

4.3 TESTING, PRE-COMMISSIONING, AND POST COMMISSIONING:

- 4.3.1 The contractor shall perform various activities during pre-commissioning, Integrated Testing, post-commissioning stages of equipment covered under this tender specification. It is responsibility of contractor to arranged tools & plants, test equipments, experienced engineers and technicians. Contractor shall earmark separate manpower for respective area of as specified in relevant clause and shall not be disturbed /diverted for other work. The contractor's commissioning group shall work as per the instruction of BHEL Engineer and they shall coordinate day-to-day activity with other agency and BHEL/ Customer. The testing activity may have to be repeated till satisfactory results are obtained and also to satisfy the requirement of Customer / statutory Authority.
- 4.3.2 The contractor shall simultaneously start testing & commissioning activities for equipments to match the mile stone activities of the project.
- 4.3.3 The mobilization of these commissioning groups shall be such that planned activities are taken up in time and also completed as per schedule and work undertaken round the clock if required. It is responsibility of contractor to discuss on day to day / weekly / monthly basis the requirement of manpower, consumables, tools & tackles / testing equipments with BHEL Engineers and arrange for the same. If at any time the requisite manpower, consumables etc

are not arranged then BHEL shall make alternative arrangements and necessary recoveries with overhead cost will be made from the running bills.

- 4.3.4 Contractor shall cut/open work, if needed, as per BHEL engineer's instructions during commissioning for inspection, checking and make good the works after inspection is over.
- 4.3.5 It shall be specifically noted that the contractor may have to work round the clock and in shifts during the pre-commissioning and commissioning period along with or without BHEL engineers and hence considerable overtime payment is involved. The contractor's quoted rates shall be inclusive of all these factors.
- 4.3.6 In case any rework/ repair / rectification/ modification / fabrication etc is required because of contractor's faulty workmanship which are noticed during the commissioning of, at any stages, the same shall be rectified by the contractor at his cost. If during the commissioning any improvement / repair / rework / rectification / fabrication / modification due to design improvement is required, the same shall be carried out by the contractor promptly and expeditiously. Claim if any, for such work from the contractor shall be governed by clause no. 13.1 to 13.8.
- 4.3.7 During the commissioning activities and carrying out various tests, if any of temporarily work such mounting of test equipments / cabling etc are required, the contractor shall carry out such work without on any extra cost. The same shall be removed after completion of the activity.
- 4.3.8 During this period, though BHEL/ client's staff will also be associated in the work, the contractor's responsibility will be to arrange for complete requirement of men and required Tools & Plants, Consumables, Scaffolding and approaches etc., till such time the commissioned unit is taken over for trial operations.
- 4.3.9 The contractor shall carry out any other tests as desired by BHEL engineer on erected equipment covered under the scope of this contract during testing, pre-commissioning and commissioning, to demonstrate the completion of any part or whole of work performed by the contractor.
- 4.3.10 The pre-commissioning activities will start in phased manner to meet the various milestones and shall continue till equipments are being commissioning fully with all connected drives/ equipment to HT/LT switchgear or handed over to customer for regular operation. In this duration other erection activities such as cabling or other work shall be carried out by other agency even though HT/LT switchgear board are charged. In order to co-ordinate the work such as issue of safety permit, normalization and compliance of other requirement, contractor shall keep team of one experience engineer / supervisor, technician and helper in each shift specially in 6.6 KV and 415 Volt switchgear rooms at each unit in three shift operation or as decided by BHEL Engineer. The team shall take instruction from BHEL Engineer for day-to-day work and shall not be diverted for other work. No extra payment shall be made for their services.

4.3.11 INTEGRATED ELECTRICAL TESTING/COMMISSIONING

The brief scope of work under is defined as below, but not limited to the following. Contractor shall discuss & finalize testing procedure with BHEL Engineer In-Charge for the test to be conducted on Generator Control & Relay Panel testing. Drawing & documents shall be provided by BHEL at the time of testing. BHEL decision in this regard shall be final and binding on the contractor.

The contractor shall prepare all erection / commissioning log sheets and protocols / test certificates as per field quality plan, get it signed by the concerned BHEL/Customer engineer and submit the same to BHEL engineer as per his instruction.

Contractor shall maintain the charged and commissioned equipment till the same is taken over by BHEL's end customer.

Contractor's quoted rates for all concerned items shall include Integrated Testing as defined hereinafter.

4.3.11.1 GENERATOR CONTROLS AND PROTECTIONS RELAY PANELS & ASSOCIATED EQUIPMENTS SUCH AS BUS DUCTS, GT, UNIT & STATION TRANSFORMER, GENERATOR BREAKER etc.

1. Integrated Electrical testing/commissioning of Generator Control and Protection Relay Panels & associated equipment, etc. shall involve various activities like relay testing/setting, simulation checks, testing of energy meters, on/off line functional checks on integrated system.
2. Relay Testing in static condition for Generator, Transformers, and associated system by secondary current injection at different current and recording the time duration.
3. Testing and checking of control and protection interlock scheme in static condition and simulation of protection device contact from internal and external devices of all electrical panels.
4. Measurement of Insulations, Winding Resistance, Polarization Index of winding of Generator & associated equipment/ system.
5. Relay setting and checking the stability of protection relays in static and dynamic condition during the OCC (Open Circuit Characteristic) & SCC (Short Circuit Characteristic).
6. Functional checks / testing of synchronizing schemes, other electrical panels during the static and dynamic by simulation / back charging of generator transformer conditions.
7. Monitoring & recording the various parameters during open circuit and short circuit conditions test on generator & associated field equipment like generator transformer, unit auxiliary transformer. Recording and monitoring measurement.
8. Testing of protection current transformer for ratio test by primary injection, magnetization characteristic, polarity test, and IR measurement. Functional checks of relays of protection system by primary injection.

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

9. Testing of potential transformer for ratio test by voltage ratio, polarity test, insulation resistance measurement etc, testing of surge capacitors, PT isolator in PTPS cubicle etc.
10. Measurement of Insulation resistance of individual equipment and connected together.
11. Tan delta test on generator & other equipments as required.
12. Calibration of energy meters, tri-vector meters, voltmeters, ammeters, current & power transducers etc.
13. Providing temporary shorting link on bus duct or any other location while testing & normalisation after the test.

4.3.11.2 6.6 KV HT SWITCHGEAR, 415 VOLT LT SWITCHGEAR / MCC & DC DISTRIBUTION BOARD ETC

1. Checking of installation for correctness.
2. Mechanical functional checking/ adjustment of individual breaker.
3. Measurement of Insulation resistance of individual breaker, complete switchgear board and combined insulation resistance of individual breaker with cable connected to drives.
4. Testing of Protection Relay, Thermal over relay, Power transducers Energy/ Ammeters, Voltmeters, Power factor, frequency, tri-vector meters & metering etc. in static & dynamic condition relay
5. Conducting test such as Insulation Resistance measurement, Ratio, polarity, magnetisation characteristic, winding resistance on CT and PT.
6. Checking of electrical control & protection interlock of individual breaker and integration with other system.
7. Calibration of energy meters, tri-vector meters, voltmeters, ammeters, power current & voltage transducers etc.
8. Provide assistance for checking the electrical operation of individuals breakers from remote panels / MMI package.

4.3.11.3 The scope of testing & commissioning of electrically operated actuators for valves, dampers, gates, soot blowers etc., will include meggering, providing loop wire on actuator terminal block, adjustments of mechanical/ electrical or electronic position transmitters, setting of limit/torque switches, cable checking, internal wiring checking, local/remote operation from MCC & MMI package, replacement of limit/torque switches if required.

4.4 MEASUREMENTS & WASTAGE & CUTTING ALLOWANCES:

- 4.4.1 For all payment purposes, measurement shall be made on the basis of actual execution in line with drawings/documents/site requirements.
- 4.4.2 The measurement for cable, impulse pipes/tubes, GI pipe, conduits, flexible conduits, trays etc. shall be made on the basis of length actually laid.

- 4.4.3 All the surplus, scrap and serviceable materials, out of the quantity issued to the contractor shall be returned to BHEL in good condition and as directed by the engineer.
- 4.4.4 All materials returned to stores should carry an Aluminium tag indicating the size and type. More than 5 metres length shall be termed as serviceable and shall be returned size wise and category wise to the owner's stores/yard. Cable of serviceable length being returned to the stores in drums shall have their free ends sealed and the balance lengths on the drum(s) shall be noted and certified by the Engineer-in-charge. This shall be applicable only for the purpose of accounting the cables issued for installation.
- 4.4.5 While carrying out material appropriation with contractor, all the above points will be taken into account. All serviceable material returned by the contractor shall be deducted from the quantities issued for the respective sizes and categories and the balance quantity(ies) will be taken as the net quantity(ies) issued to the contractor. Material appropriation shall be done and allowable scrap quantity calculated as per wastage allowance percentage specified above. Any scrap/wastage generated by the contractor in excess of the allowable percentage shall be charged at the rates decided by the Engineer whose decision shall be final and binding on the contractor.
- 4.4.6 For all site-fabricated steel items such as supports, racks , frame , Canopy etc. physical measurement shall be made and then converted to tonnage . For steel material supplied to the contractor, all scrap shall be returned to BHEL stores with due accounting.
- 4.4.7 Every month the contractor shall submit an account for all the materials issued to him by BHEL in the standard Performa prescribed for this purpose by the site in charge.
- 4.4.8 The erection contractor shall make every effort to minimize wastage during erection work. Cutting and wastage allowance shall be computed on length/ weight of material actually used, measured and accepted. In any case, the wastage shall not exceed the following upper limits.
- | Sl No. | Item | % Wastage on issued Qty |
|--------|-----------------------------|-------------------------|
| 01. | Each iron/steel section | 2 |
| 02. | Each size of power cables | 1 |
| 03. | Each size of control cables | 2 |
- 4.4.9 If the actual wastage is more than the specified limits, cost of the excess portion will be recovered from the contractor's bill.
- 4.4.10 The cable take off from drums shall be planned strategically such that jointing in the run of cables and wastage are avoided. For this purpose the exact route length between various equipment/panels as per the cable schedule shall be measured and the route length recorded before laying of the cables. Depending upon the route length the type of cable required for various destinations, the cable drums should be suitably selected for cable laying. Any jointing shall be approved by the BHEL engineer. All the cut pieces/bits of cables, which are not used/unused, shall be returned to the purchaser for accounting towards

wastage. The cables damaged by the contractor shall have to be replaced by the contractor at his own cost.

NOTES:

Salvageable scrap shall mean lengths of pipes, multi core cables, other cables etc., that can be used one time or other at a later date and normally they are recovered from the cut-pieces of pipes, multi core cables cables, etc.

Non - Salvageable scrap means the lengths of tubes, pipes, multi core cables, other cables etc., and they are from cut-pieces of tubes, pipes, multi core cables, other cables etc., that cannot be used at all one time or other.

4.4.11 The rates of laying for LT Power, control & Signal cables is inclusive of glanding and termination at both ends. Glands & Lugs above 4 sq mm shall be supplied by BHEL. Lugs up to 4 sq mm shall be in vendor's scope.

The Unit rates for HT cable termination are exclusive of Unit rates for laying of HT Cables. Glands & Termination Kits for HT Cables (3.3 KV & above) shall be supplied by BHEL.

4.5.0 For any items or class of work not specified herein but required for total completion of work, the same shall be carried out as per BHEL requirement. However, payment of these items/class of work shall be regulated on the basis of rate arrived at by either of the following methods:

- A) Based on rate of identical/similar items in the rate schedule.
- B) Based on the rate arrived from nearby items in the rate schedule.
- C) Wherever any item rate for similar type of work or nearby item rate does not exist in the rate schedule, rate will be worked out on the basis of work element or from fundamentals of estimation.

Contractor shall provide necessary resources for completion of such work within the stipulated time schedule. Value of such work shall be included while computing the total value of work finally executed for all contractual purposes, particularly for contract variation purpose.

4.6.0 The contractor's scope of work is further described in the clauses hereafter:

The work will comprise of, but not limited to the following:

4.6.1 INSTALLATION OF PANELS AND HT/LT SWITCHGEAR

1. Electrical control panels, electronic control panels, unit supervisory control desk, HT/LT switchgear, 415 volt LTMCC (if applicable), Analyser panels and transmitter racks/enclosure are normally supplied in suit of either one/two/three or loose shipping sections with integral base frame or loose base frame. These panels may have to be installed as stand alone or in groups consisting of number of panels in each row, depending upon the plant layout and foundation arrangement.

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

2. The panels shall be transported from stores to the place of installation in vertical position. Care shall be taken such that the switches, lamps, instruments etc. mounted on the panel do not get damaged during transit.
3. Installation of panel shall include fixing of base frame, levelling, alignment, fixing of anti-vibration pads, removal of side covers, fixing of cubical interconnection hardware, interconnection of bus bar /bus bar jointing, wiring interconnection, welding and grouting of panels and base frames, mounting of panel canopy wherever supplied as part of panel, drilling of gland plates, sealing of panels/ cable entries. Where the base frame is not supplied as part of panel supply, the contractor shall fabricate the base frame from structural items at site. Payment for such fabrication will be effected on measured quantity at the rate applicable for structural steel fabrication and installation. Proper sealing of all the holes and cable entries (even if the cable has been laid by others) in the panel is in the contractor's scope.
4. Panels have to be shifted to their locations through floor openings, temporary openings like floor grills, door etc. which shall be a part of work and no claim whatsoever will be entertained with regard to non-availability of opening as per shortest route etc. Panels have to be erected at different locations and elevation in powerhouse building, LT & HT switchgear room, unit control room etc.
5. Panel and instruments once erected in position should be properly protected using necessary care to prevent ingress of dust/moisture. This will have to be periodically cleaned and surroundings have to be kept tidy.
6. Whenever the panels to be mounted on cable trenches, channel supports have to be provided across the cable trench over which the base frame of panel shall be mounted. For such work, structural steel fabrication & installation rate shall be applicable.
7. Normally the panels shall be supplied with meters, relays, electronic modules, contactors, pushbuttons, etc., mounted and pre-wired. However, if such devices are supplied loose/separately for safety in transit, contractor shall mount the same as part of panel installation work and no extra payment shall be made for this.
8. Supplier's instruction manuals, packing slips, door keys etc. received along with the panels will be handed over to BHEL's engineer on opening of the panels.
9. Regular cleaning of the panels as per the instruction of BHEL engineer till handing over of the set to customer is to be carried out by the contractor free of cost.
10. 24 / 48 Volt DC Interposing Relay along with mounting base shall be supplied separately for mounting in the various feeders of 6.6 KV HT switchgear boards and 415 Volt MCC Board / Switchgear Panel Boards for uni-directional / bi-directional drives, solenoid valves. 2 Nos. interposing relay may be required to be mounted in each feeder. Internal wiring for these relay shall be pre-wired in the feeders, wires to be terminated on relay terminals. Approximately quantity

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

is 3500 Nos. Contractor shall mount the same and terminate the wire as part of panel installation work and no extra payment shall be made for this work.

4.6.2 STRUCTURAL STEEL FABRICATION AND INSTALLATION

A INSTRUMENT/ JUNCTION BOX FRAME/ CABLE TRAY & MISC STRUCTURES FABRICATION

1. Structural steel material like MS angles, channels, beams, flats, plates etc. shall be supplied in running meter and the same shall be used for fabrication of panel base frame, canopies for instruments/panels/ drives/JB/push buttons etc., instrument/junction box frames, impulse pipe/instrument air pipe supports and instruments etc.
2. This shall include cutting to size, contouring of ends for connections if required, welding, grinding of excess weld deposits/burrs, drilling of holes for mounting of device/instrument, installation at location, levelling, alignment, providing bracings and painting etc. No gas cut holes will be permitted. All paints, primers, etc are in the scope of the contractor.
3. All the fabricated supports/frames shall be painted as per painting specifications.
4. Frame installation at site may involve mounting either on concrete floor by grouting/using anchor fasteners or on steel structure by welding etc. All consumables including anchor fasteners shall be arranged by the contractor. Where required, as part of work, concrete floors may have to be chipped out to reinforcement depth for anchoring the frames. Wherever grouting is required, contractor shall arrange all the required material including cement/grout mix, shuttering etc., necessary labour and meet all other requirements as part of work.
5. In case, structural cable trays, bends, tees, reducers etc., are required to be fabricated from structural steel and installed, unit rate applicable for fabrication and installation of structural steel shall be applicable in such instances.
6. In certain packages, members of frames/rack for mounting of junction boxes/ instruments may be supplied readymade. These have to be assembled prior to installation. The installation rate as quoted shall include assembly of the frames.
7. Gas cutting of tray/impulse pipe support and holes in frame is not permitted. Only hacksaw cutting/ drilled hole shall be permitted

B CABLE TRAY SUPPORT

1. GI Structural material shall be supplied in standard length. The support member required for typical installation to be cut suit to site / lay out requirement from the straight length. Tray supporting members to be installed for typical installation as indicated in sectional arrangement of cable tray route plan. BHEL's customer shall provide projected dowels embedded in cable

trenches for welding of supports. The support shall be either bolted or welded type as per drg. No cutting by gas shall be permitted.

2. Wherever supports needs to fixed on concrete slabs or ceiling with anchor fastener, and anchor fastener shall be arranged by contractor as part of work.
3. All galvanization damaged due to cutting / welding operation required to be carried out for the installation of cable support system shall be made good with application of cold galvanization paint (to be arranged by the contractor at his cost) immediately after completion of welding.

4.6.3 CABLE LAYING (POWER/CONTROL/INSTRUMENTATION SHIELDED CABLES/PLUG-IN CABLES/INTRA-PLANT BUS/DATA HIGHWAY, ARMOURED/UN-ARMOURED, SINGLE/MULTI-CORE, PVC/HR PVC/FRLS/TEFFLON/XLP INSULATION)

1. Cable lengths include cutting to the required length, laying in overhead/underground cable trench/through pipes/flexible conduits, dressing/clamping in tray, drilling of holes in gland plates in panels and junction box, glanding, splicing, dressing of spliced wire inside the panel and JBs, providing printed ferrules (**contractor to arrange ferrule printing machine(s) as required**), termination by using crimp type copper tinned/aluminium lugs, insulated/un-insulated, crimp and soldering termination, plug-in connections with insert type crimping, providing identification cable tags, PVC/aluminium at both the ends and at appropriate interval throughout the route length, continuity checking, insulation resistance checking, high voltage test on HT cables.
2. Entry to the panels, JB's may be at top, side or bottom. All cables are required to be supported and clamped near to the panel.
3. Wherever cable glanding is not possible, either due to the gland plate size limitations or more number of cable entries, pre-fab plug-in cables, for such cases, cables may have to be lifted inside the panel either making cut-out in gland plate and providing rubber profile for sharp edge protection or alternatively, provide 4/6" PVC pipe coupling gland and these pipe coupling gland shall be supplied by contractor within the quoted rate of cable laying.
4. Supply of copper tinned lugs conforming to IS: 694 of various types (pin, ring, fork, snap-on) upto 4 sq.mm, PVC cable ties, printable ferrules, PVC button and tapes, cable identification tag of PVC/metal, clamping and dressing material with hardware, PVC sleeves etc. shall be supplied by contractor within the quoted rate for cable laying. The quality and make of cable lugs shall be got approved from BHEL engineer prior to their use on job.
5. All care should be taken to avoid abrasion, tension, twisting, kinking, stretching of cables during installation.
6. Cable shielding – all signal cables are supplied with bare shielded copper wire/with braided wire shield, general sealed wire is kept isolated at instrument/field device end and continuity is maintained through JBs and getting earth at panel end only. While terminated the sealed wire either in panel or JBs, PVC sleeves is to be used to avoid two-point earthing.
7. Wherever cable runs through the duct, conduit, valves, the entry and exit points shall be sealed using fire/weather proof compound. In addition to this, cable entry

in panels, MCC/HT/LT breakers, instruments, electrical actuators etc. are also required to be similarly sealed. **The required material for doing so shall be included by contractor in the cable laying.**

8. Many of the cable trays and cables have to be laid in cable trenches. For this purpose, the cover of the trenches have to be opened for working in site and whenever the cables are to be laid in existing cable tray, all safety precautions have to be observed.
9. After completing the work, the trenches have to be cleaned and covers put back into position. Contractor shall also carry out de-watering from the trenches if required and arrange pumps etc. at his cost.
10. Looping wire at terminal block of panels and electrical actuator as shown in the inter-connection diagram is to be done by contractor at no extra cost.
11. Contractor shall carefully plan the cutting schedule of each cable drum in consultation with BHEL site engineer such that wastages are minimised. Recovery will be made in case the wastages are exceeding the wastage allowances fixed in this contract.

4.6.4 POWER TRANSFORMER

The scope of work under this head is defined as below.

1. Transportation of transformer tanks and accessories from BHEL site stores/ Storage yard to the transformer foundations, erection, testing & commissioning.
2. The transformers shall be handled in such a manner so that no jerk is transferred to the core, winding and internals of the transformer.
3. Transformers are generally supplied in partly assembled condition either filled with oil upto the core end winding level or gas filled. Accessories, like radiators, conservator tank, pipes, fittings, hardwares, gaskets, buchholz relay, marshalling box, relief vent, valves, pumps, cooling fans, cables, bushings, radiator headers/fans, rollers, tap changer drive unit, cables of various sizes for interconnection from marshalling control box to field devices, bushing turrets and oil in 205/210 ltrs. barrels shall be supplied loose.
4. Generator Transformer tanks shall be made available to the contractor 50 to 70 meters away from the respective foundation; further transport and shifting to the foundation shall be in the scope of this work. The shifting operation may require dragging, fixing of wheels, rollers and turning of transformer to a suitable location enroute to suit the layout. The contractor shall arrange wooden sleepers, winches, jacks, rails, crane etc at his cost for this operation. However accessories shall have to be shifted from stores.
5. For transformers other than Generator Transformer, contractors have to transport the transformer tanks & accessories of transformers from BHEL stores/ Storage yard to respective foundations. The approximate distance from BHEL Stores / Storage yard is 2.0 to 3.0 KM.

6. Placement on plinth, alignment with respect to the foundation and lay out drawings.
7. Internal inspection to verify the intactness of core and winding, tap changer leads, off-load switch, measurement of core and core bolt insulation.
8. In case of large capacity of transformers when supplied partly oil filled/gas filled, after internal inspection, the transformer shall be kept under vacuum for a period (to be decided by site engineer) and treated oil to be filled upto required level.
9. Each drum of oil to be tested for BDV and if BDV is less, then each drum should be filtered separately.
10. Contractor has to arrange storage tank of 10 kilo litre capacity with internally sand blasted and coated with one coat of oil resistance paint. Oil from drums to be transferred in storage tank and filtration to be carried out to achieve the required BDV/ withstand value. This treated oil to be filled in the transformers and auxiliaries. However, for low capacity of transformer, a separate storage tank for mass filtration may not be required.
11. All the accessories shall be assembled/mounted as per OGA drawings and these should be thoroughly cleaned prior to installation.
12. Drying out of transformer and filtration of oil in cooling bank, pipe line, diverter tank of tap changer etc. to be done with ultra vacuum filtering machine of adequate capacity and adequate numbers. Drying out process shall be carried out round-the-clock and contractor shall deploy trained manpower for this purpose. If required, more than one filtration machine shall be used.
13. During dry out process, contractor has to plot the curve for insulation resistance value/time/oil temperature. Hourly reading to be recorded till completion of the dry out.
14. The criteria for deciding completion of drying out shall be breakdown value of oil, PPM value of contaminants in oil, resistivity of oil, insulation resistance value and polarisation index.
15. The filter machine(s) capacity if found to be inadequate, or in case of failure of existing machine(s), alternative arrangement is required to be done to meet the required result and time.
16. Due to unforeseen reasons the commissioning of transformer is delayed after first drying out and if required, the contractor shall carry out the oil filtration of assembled transformer.
17. Contractor shall arrange required testing equipments for carrying out electrical test like voltage ratio, turn ratio, vector group, magnetic balance, winding resistance measurements, BDV value of oil, tan delta measurement of bushings & winding, insulation resistance, measurement of oil PPM, acidity, resistivity and tan delta test. The contractor shall arrange oil sample testing for PPM/resistivity or any other tests applicable for oil sample at approved testing laboratory at his own cost including all incidental expenses.
18. Contractor shall discuss and finalise installation and testing activity procedure with BHEL/customer prior to starting the work.

Bharat Heavy Electricals limited, PSWR, Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

19. Contractor should have valid electrical contractor ship licence to carry out installation of high voltage equipment.
20. Dry type transformer is supplied in sheet metal enclosure with natural/forced air-cooling. The contractor shall carry out all electrical tests as applicable for other transformer.

4.6.5 VARIABLE FREQUENCY DRIVE FOR I.D. FANS

VFD system comprise for each ID of Power Transformers 6.6/3 KV ONAN cooled (2 Nos.), Vacuum Circuit Breaker type VM-12(2 Nos.), D.C. Series Reactor(2Nos.), Control panels(1NO.), Load Converter / Inverter panels(2Nos.) and associated accessories. For detail work scope refer other relevant clause for transformer, switchgear & panels.

4.6.6 ELECTROSTATIC PRECIPITATOR

1. ESP shall have four flue gas passes and each pass comprises of rectifier transformer (silicon oil filled), Auxiliary Control Panels, electronic controller, LT Main switch board and its bus duct, Drives for Rapping/Collecting/ Gas damper screen, heating element for hoppers/shaft and supporting insulator housing, ash level indicator and EP management system (software based) including computer interface and associated interlock and protection.
2. Transformer shall be erected by other agencies engaged by BHEL. Scope of work covered under this contract is oil filtration of transformers and erection and testing of various devices as enlisted in rate schedule. Contractor shall provide silicon oil filter machine as a part of scope. Contractor has also to provide operator round-the-clock for oil filtration and other necessary testing equipments. Contractor shall utilise power supply for filter machine from the source, which is given for the construction purpose, and contractor shall arrange required cables.
3. Ash level indicators are supplied loose in various components such as probe, electronic unit, **connecting wires and flexible conduit etc. The rate is inclusive of all these**. No separate rate for Flexible conduit for ash level indicator / probe etc is permissible.
4. Panel type hopper heaters shall be mounted by Mechanical agency. However **Electrical wire lead coming out of heater to be brought upto Junction box through flexible conduit by clamping it on hopper body . The rate is inclusive of heater testing & commissioning. No separate rate for Wiring & Conduit / clamp fixing shall be permissible.**

4.6.7 ISOLATED PHASE BUS DUCT 16.5 KV, 12KA CONTINUOUS AIR-COOLED.

1. GENERAL DESCRIPTION

Generator isolated bus duct is connected to low voltage side of Generator transformers 315 MVA and main bus duct shall have tee off connection for unit transformer, LAVT cubicles, excitation transformer and air pressurisation equipment. Bus duct consist of round / octagonal/ box hollow aluminium alloy conductor and supported inside aluminium enclosure with post insulator. Flexible connections and expansion joints are provided at

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

terminals and intermediate point to alleviate stresses. Ring type protection current transformer will be mounted inside the bus duct.

Isolated phased bus duct shall have tap connection for potential transformer, surge protector etc. housed in a metal clad cubicle, UAT and NG cubicle/ resistor cubicle. Various electrical tests have to be performed before and after erection.

Bus duct enclosure /conductor is a continuous welded type. Conductor, enclosure, makeup pieces, shunts pieces etc have to be welded at site.

2. The scope of for Isolated Phase Bus Duct shall includes Transportation of material from stores/ storage yard, preparatory work such as erection of supporting structure, placement of sub assemblies / equipments, alignment, edge preparation of conductor / enclosure, welding of conductor / enclosure, welding of shunt pieces & make up pieces, installation of seal of bushing & wall frame assemblies, shorting links, earthing, LAVT cubicle, copper flexibles, copper rubber bellows, weldable/ bolted flexibles, installation of air pressurising unit and its associated piping work and cable etc, testing and commissioning.
3. Pre-fabricated G.I. supporting members shall be supplied in loose and to be erected as per lay out drawing. Foundation pockets and embedded plate inserts shall be provided as per lay out drawing (on floor for bottom support and on bottom of concrete slabs). Contractor shall weld the supports on insert plate and shall carry out grouting(including supply of grout materials) / encasing of foundation plate etc after complete alignment/bolting of structural members. If any modification required in supporting structure due to site conditions, the same shall be carried out without any extra cost. All welded joints shall be applied cold galvanizing zinc paint (paint in the scope of the contractor).
4. Required aluminium welding of conductor, enclosures, shunt, make up pieces, aluminium flexible etc as detailed in drawings has to be carried out by contractor. MIG welding shall be applicable. Contractor shall arrange necessary welding equipment/ accessory in sufficient number, filler wire, argon gas and other required consumables at his cost. The technical specification of MIG welding machine, filler wires, etc are given in relevant sections in these specifications. Or BHEL APPROVED MAKE.
5. During erection of bus duct/enclosure, makeup pieces and shunts, if any modifications needed to match the alignment shall be part of work and no extra payment shall be made.
6. All bolted joints and flanges shall be tightened with torque wrench to the approved torque. Wherever bolted joints, the same shall be cleaned and a layer of anti-oxidation paints shall be applied. Such paints etc will be arranged by the contractor within the quoted rates.
7. Top chamber/adopter box for line and neutral side, hood assembly at UT, hood assembly at excitation transformer and at LAVT cubicle end shall have drilled hole in flange. If any mismatch of the hole in above with respect to the counter flange/welded studs provided on UAT, LAVT and excitation cubicle, the contractor shall drill new holes if required within the quoted rates.

8. Proper sequence shall be followed during erection to avoid any mismatch and alignment problem.
9. Prior to installation of bus duct assemblies in position, the various component like conductor, insulator shall be inspected and cleaned and insulation resistance to be measured and recorded. If any insulator found damaged, the same shall be replaced.
10. Electrical test on current transformers and potential transformers shall have to be carried out prior to installation & during pre-commissioning. The tests are insulation resistance measurement, winding resistance, magnetisation characteristic, ratio test, water ingress and air leak test on assembled bus-ducts.
11. Minor civil work such as chipping, levelling of foundation, providing pockets, drilling/enlargement of holes in structure, bus bar etc. which are incidental to the erection of bus duct shall not be treated as extra.
12. All miscellaneous items such as disconnecting links, flexibles, shorting bars, hardwares, conduit for wiring, marshalling box, CTs and Pts wiring through conduit, earthing materials, bus bar fish plates etc. are part of bus duct installation. Hence separate break-up quantity is not given in BOQ.
13. Round makeup pieces for main and tee off duct shall be supplied in two halves and it involves but circumferential and horizontal welding at parting plain.
14. Air tightness and water tightness test have to be carried out on completion of bus duct installation. In case of any leakages, contractor has to rectify and bring to the required level of air tightness/water tightness without any extra cost.
15. High voltage test of bus duct is to be carried out as per the instruction of BHEL engineer. Contractor shall arrange necessary test equipment/instrument for conducting various electrical tests at his own cost.
16. Contractor has to carry out final painting as per standard colour coat recommended by BHEL. Paints and consumables shall be in contractor's scope.
17. Shunt pieces shall be supplied in two halves and to be welded between two-phase bus duct at transformer end. The shunt pieces to be welded on both the side on matching plain and bus duct circumference and horizontal plain
18. Contractor shall conduct 20 % radiography and 100% NDT test on welded joints.
19. Enclosed drawings are for estimation and tendering purpose only. Contractor has to ascertain quantum of work involved. The BOQ as furnished in this tender specification for Isolated Phase Bus Duct & Segregated Phase Bus Duct are tentative / approximate. The enclosed drawings are for tender purpose only. Contractor has to ascertain the quantum of work involved and quote the lump-sum value, as called in the rate schedule, without any additional compensation for any variation in length or numbers of joints.

20. One end of the enclosure to be earthed to the station earth at shunt location where all three-phase enclosure is shorted. Wherever shunts are not provided, each phase should be earthed separately.
21. In case of bolted bus-ducts, phase split covers, rubber bellows, clamping earth straps to be connected to maintain the electrical continuity and in turn enclosure gets earthed at one point.
22. All other equipment such as LAVT, NG transformer/ resistor cubicle, air pressurization, CT chambers, junction boxes, etc to be earthed at two points to the earth grid.

4.6.8 6.6 KV SEGREGATED PHASE BUS DUCT.

Each set of 6.6 KV Segregated phase bus duct shall be supplied complete with Aluminium alloy enclosure and conductor with epoxy bus support insulators arrangement, silica gel breathers, inspection windows, rubber bellows, flexible connector, bi-metallic strips etc. Galvanised iron earth bus shall be provided for enclosure continuity. All bolted joints shall have high tensile steel hardware cadmium plated.

Each set of SP bus duct is meant for interconnection from low voltage side of Unit, Unit Auxiliary and Station Transformer to 6.6 KV switchgear board and bridging bus duct between the switchgear boards. The bus duct consists of rectangular conductor made of aluminium alloy supported on post insulator and housed in aluminium sheet metal rectangular enclosure. The bus bar enclosures are having bolted joints.

The bus duct shall be supported either from bottom of the concrete slab with embedded insert plate/ TG building supporting structural members and pocket provided on foundations. The bus duct assemblies, supporting structures shall be pre-fabricated and to be assembled as per lay out drawing. **Other erection and testing requirement shall be similar to the isolated phase bus duct, except the welding of bus bar and enclosures.**

Each set of bus duct shall be supported with supporting structure, which shall be fabricated from standard steel section and hot dip galvanised. All structure & bus duct assemble shall be erected as per drawings.

4.6.9 6.6 KV INDOOR SWITCHGEAR BOARDS

1. The scope of work includes transportation of material from stores / storage yard to erection site installation, testing and commissioning of switchgear. Contractor shall carry out works like fixing of base frame, fabrication of base frame if required, placement, levelling, alignment, fixing of anti-vibration pads if applicable, fixing of inter-connecting cubicle gasket, removal of side covers, fixing of cubicle inter-connecting hardwares, bus bar jointing, wire inter-connection, fixing of safety barriers and shrouds, welding or grouting of panels with supply of grout material, drilling of holes in gland plates, ceiling of cable entry, chipping, minor civil works etc. After completion of installation, various electrical tests to be conducted such as insulation resistance measurement, high voltage test, testing of CTs and PTs protection relays, meters, integrated electrical testing of control and protection system, mechanical checks of individual breaker etc. Contractor shall arrange all required testing equipments and consumables at his cost.

2. All the breakers are indoor type and shall be housed in 6.6 kV switchgear room. Panels have to be shifted to their location through floor opening, temporary opening like floor grills, doors, removing and re-fixing of grills for panel lifting shall be part of the work and no claim whatsoever will be entertained with regard to non-availability of opening as per the shortest route etc.
3. Normally breakers will be supplied complete with instrument, protection relays etc. mounted and pre-wired. However, if necessary, dismantling of existing component, making wiring modification to suit to operating condition, mounting and re-wiring of new component will be carried out without any extra cost if supplied loose for safety in transit to avoid damages.
4. Wherever breakers panel to be mounted on cable trench, supports have to be provided across the cable trench over which the base frame of the panels shall be mounted.
5. The contractor has to do touch-up painting of switchgear panel wherever necessary. This includes supplies of paint.
6. The relevant erection drawing is enclosed for tendering purpose. Contractor has to ascertain the quantum of work involved and quoted lumpsum value as called in rate schedule.
7. After installation of switchgear board, for easy withdrawal of VCB truck, ISMC 75x500 mm to be grouted with suitable anchoring arrangement.
8. In addition to switchgear, which shall be installed as per layout and floor plant drawings, the following accessories shall be supplied which are required for testing and commissioning for maintenance purpose. Drawl of such material will be part of regular erection work. Contractor shall hand over to customer after completion of work as per the instruction of BHEL engineer without any extra cost.
 - 1) Set of accessories comprises of wedge type platform, spring charge handle, interlock and slow closing handle.
 - 2) Feeder earthing truck breaker type
 - 3) Bus bar earthing truck breaker type

4.6.10 SOOT BLOWER SYSTEM

Soot blower system comprises of Local Starter Boxes, Local Power distribution boxes / MCC, Micro-processor based plc panel with mimic diagram and control station, push button boxes, junction boxes, wall blowers/LRSB with drive mechanism, integral control box with limit switch and internal wiring, inter connecting cables between field blowers, Local starter boxes , Local Power distribution Boxes /MCC and PLC panel etc. The scope of work for testing, commissioning covers the items/devices as per rate schedule and the testing, commissioning of blowers shall be carried out in close co-ordination with mechanical agencies who shall be erecting these blowers and contractor shall obtain clearance from BHEL engineer prior to start of work. The contractor shall carry out the following works under testing & commissioning:-

- 01 Pre-commissioning checks and tests on local Starter Boxes, Local Power Distribution Boxes/ MCC, blowers, PLC panels, energisation of MCC and its feeders, wiring checks, insulation resistance measurements, testing of thermal over load relays etc.

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

- 02 Adjustment of limit switches, torque switches, internal wiring checks, minor wiring modification to suit to system requirements for wall/LRSB blowers.
- 03 Electric operation of each blower from local, / local starter / PDB / MCC and PLC panels and from Unit control board.
- 04 Providing loop on terminal block of MCC individual feeders & blowers.
- 05 During pre-commissioning/post-commissioning of soot blower system, the component like TB's, limit switch, torque switch, over load relay, contactors etc. if found defective, contractor shall replace such components without any extra payment.

4.6.11 DIGITAL STATIC EXCITATION SYSTEM.

System comprises of regulation, field flashing, thyristor, field breaker panels, Excitation Transformer trunking cubicle along with copper bus bar/flexible connectors/air duct and blowers/blower control box including internal wiring, and associated inter connecting cables.

4.6.12 ELECTRICAL HOIST

Electrically operated hoist of capacity varying from 3 MT to 35 MT are provided for maintenance purpose for ID/FD/PA fans, Mill area, Air Heater, ESP and other area in boiler. Mechanical erections of hoist components such as runway beams, hoist carriage, drive unit, etc. shall be done by other agency. The scope of work covered in this tender specification for erection & commissioning is installation of DSL system and associated accessories. The scope of work for the contract in this package is as under:

1. **TEE IRON TYPE DSL SYSTEM** -It consists of tee iron guide for cable trolley and associated supporting structural members, trailing cable, cable guide trolley, dog chain, switch fuse unit, limit switch etc.
2. **TAUT WIRE TYPE DSL SYSTEM**:-It consists of end bracket, Galvanised wire rope , turn buckle/ straining bolt, real insulator,/cable guide trolley ,cable, switch fuse unit, rope clamps, leather bands, dog chain, limit switch etc.
3. DSL system shall have to be erected at higher elevation. Contractor shall take all safety measures while carrying out the work.
4. Installation of tee iron & other structural steel member, unit rate for fabrication & installation shall be applicable and other items unit rate shall be paid, however cable dressing, fixing of leather bands, rope clamps and any incidental work such making approaches for executing the work, scaffolding etc. shall be part of work.
5. Commissioning & testing of electrical hoists shall includes panel wiring check, IR measurement, functional check, over load relay testing, trial run, providing assistance during load test, replacement of component if required etc. However, preparatory work for load test and arrangement of load etc. shall be done by other agency.

4.6.13 415V MOTOR CONTROL CENTERS (MCC) & DC/AC DISTRIBUTION BOARDS

Motor control centres are double front draw –out/non-draw type consisting of circuit breakers units, contractor/starter, switch fuse units, MCC, Protection & metering

Bharat Heavy Electricals limited, PSWR, Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

relays/ instruments etc. arranged in multi tier construction. These PCC and MCC are mainly supplied to cater to the requirements of drives, valve actuators etc.

DC distribution Boards is single front non-draw out type consisting of circuit breakers, contactors, starters, fuse units, MCB etc arranged in multi-tier construction. Shall be located in LT switchgear room to cater the dc supply requirement.

The scope of work for the LT switch board and DCDB covers receipt of materials from stores, transportation to the respective location, erection, testing, commissioning and handing over.

Rubber mats shall be supplied by BHEL for HT/LT switchgear and the same shall be laid wherever required as part of work.

4.6.14 ELECTRICAL LAB EQUIPMENT ; The lab equipments are to be mounted in electrical lab and electrical connections are to be made. Normally supervision of equipments during erection & commissioning shall be done by supplier. Indicative details are given in section 16.

4.6.15 BELOW GROUND EARTHING :Treated test pits, Test Links, Earth Electrodes, Column earth connections for various areas : Earth rod 40 mm shall be issued from BHEL stores. Work shall be done as per drawing given at site. **Supply of all other items including charcoal, salt, civil items is also in the scope of the contractor. Civil works are also to be carried out by the contractor.** The contractor shall also connect this pit to the earth grid (by other agency) at nominal distances of 3 to 5 meters by 40 mm rods, Details are given elsewhere in tender.

4.6.16 PAINTING

Colour Banding, Legend and Identification Marking, Direction Marking etc. shall be in scope of the contractor for all items (Erection or Commissioning) in the scope of the contractor.

4.6.16.1 TRANSFORMERS & BUS DUCTS

Exposed metal surfaces of Transformers and Bus Ducts erected by the contractor shall be painted with two coats of Finish Paint after thoroughly cleaning the surface from dust, rust, greases, oils, scales, etc, by wire brush, scrapping, machine buffing, water washing and any other appropriate method as specified in relevant erection documents. Bus Ducts shall first be coated with two coats of Primer before application of Finish Paint. Touch-up primer coat shall also be applied on Transformers as and where necessary. Supply of paints, etc for the above is in the scope of the contractor.

4.6.16.2 STRUCTURALS

Structural components may be supplied without any primer/paint coat from shop. The surface of such items shall be cleaned as per specifications and then coated with two

coats of ROZC (IS:2074) Primer. Supply of Primer, etc is included in the scope of the contractor.

4.6.16.3 PANELS, JUNCTION BOXES

Panels and Junction Boxes shall be Touch-up painted as and where original shop paint is peeled off. Necessary surface cleaning and preparation shall be done by the contractor as per relevant painting codes followed by two coats of Primer and two coats of Finish Paint. All necessary paints, primers, etc are to be arranged by the contractor within the quoted rates.

4.6.17 Troubleshooting during plant operation

During pre-commissioning / commissioning stages when the plant will be under various stages of operation, it will be necessary to have continuous (day and night) presence of suitable manpower along with required tools to attend to any defects etc that may arise during such operation. The contractor will be required to put such personnel in shifts in both electrical and C&I area. The bidder must also take this aspect into consideration.

4.6.18

Equipments/instruments etc., under the above scope of erection and commissioning are generally despatched from BHEL's manufacturing units / vendor's works at site well before start of erection. Sometimes, such despatched materials may get stuck up with transporters/railways. The contractor shall provide support / manpower for necessary chase up for removal of such bottlenecks in transportation. Also, for smaller items, it could be necessary to depute his person to personally carry certain items from works to site. Requirement of such activities which will be decided by BHEL engineer and chase up activities, if required, shall be performed under authorization by BHEL. The above services shall be provided without any additional price to BHEL.

4.7 EXCLUSIONS

The following are specific exclusions from this work.

1. Erection of dampers, valves, electrical actuators, pneumatic actuators.
2. Erection of ESP rectifier transformer, electrical heaters, rapping motors, mechanical interlocks.
3. Erection and Commissioning of HT/LT motors (except those specified herein)
4. Erection, testing and commissioning of elevators and DG sets.

Note:

The aforesaid exclusions should not be construed as exhaustive. They are meant for general guideline. BHEL reserves the right to include or exclude any item which is required for completing the job as per rates indicated in rate schedule. Contractor should carry out all such jobs as per the instructions of BHEL engineer.

Section-5

Special Conditions of Contract

5.0 Obligations of the Contractor (Tools, Tackles, Consumables etc.)

5.1 Labour Colony

BHEL'S customer will provide the open land with single point for drinking water and electricity. Contractor shall make further arrangements for constructing the labour colony and including lighting, water distribution and suitable provisions of drainage/sanitation.

5.2 Tools & Plants and MMD

5.2.1

The contractor shall provide all required Tools and Plants, inspection, Measuring and Monitoring Devices (MMD), Handling & Transportation Equipments for the scope of work covered under these specifications. An indicative list of major T&P and MMD to be deployed by the Contractor is given in the **Appendix-III**. It may be noted that this list does not intend to exhaustively cover the contractor's responsibility with regard to T&P to be deployed by him. BHEL will provide the services of their T & P listed in relevant Appendix, free of charge, on sharing basis. Refer section-7 for further details in this regard.

5.2.2

All tools and tackles to be deployed by the contractor for the work shall have the prior approval of BHEL engineer with regard to brand, quality and specification.

5.2.3

Timely deployment of adequate quantity of T&P is the responsibility of the contractor. The contractor shall be prepared to augment the T&P at short notice to match the planned targets and to achieve the milestones.

5.2.4

Contractor shall maintain and operate his tools and plants in such a way that major breakdowns are avoided. In the event of major breakdown, contractor shall make alternate arrangements expeditiously so that the progress of work is not hampered.

5.2.5

In the event of contractor failing to arrange the required tools, plants, machinery, equipment, material or non-availability of the same owing to breakdown, BHEL will make the alternate arrangement at the risk and cost of the contractor.

5.2.6

The T&P to be arranged by the contractor shall be in proper working condition. The operation shall not lead to unsafe condition. The movements of cranes, and other equipment should be such that no damage/breaking occur to foundation, equipment, material and men. All arrangements for the movement of his T&P etc, shall be the contractor's responsibility.

5.2.7

Normally, for welding only the use of welding generators/rectifiers will be permitted. The use of welding transformers will be subject to the approval of BHEL engineer.

5.2.8

The contractor at his cost shall carry out periodical testing of his construction equipments and calibration of measuring instruments (MMD) and tests. Test/ calibration certificates shall be furnished to BHEL. MMD shall be calibrated only at accredited laboratory as per the list available with BHEL or any other laboratory approved by BHEL.

The contractor shall provide all the necessary steel scaffolding materials, temporary structures and necessary safety devices etc. during preassembly, calibration, erection, testing and commissioning of the equipment.

Contractor shall maintain and operate his tools, plants, calibrating instruments etc. in such a way that major breakdowns are avoided. In the event of major breakdown, the contractor shall make alternate arrangements expeditiously so that the progress of the work is not hampered.

5.3 Consumables

5.3.1

The contractor shall provide all consumables required for carrying out the work covered under these specifications excepting those, which are specifically indicated as BHEL scope.

5.3.2

All consumables to be used for the work shall have prior approval of BHEL engineer with regard to brand and quality specifications. Test reports/ certificates in respect of these consumables, wherever applicable, shall be submitted to BHEL engineer.

5.3.3 Primers, Paints etc.

The contractor shall provide Primer (ROZC as per IS:2074), Synthetic Enamel Paint (IS:2932) and Aluminum Paint – as necessary for respective painting area for the scope of painting work indicated in Section-4 as well as for protection of site weld joints and gas cut locations. Contractor shall also arrange to provide the required thinner and other consumables, T&P and implements etc. required for application of Primer and Paints. All primers, paints and thinners shall be sourced by contractor only from BHEL approved manufacturers. Some of them are as listed under.

- 1) M/s Asian Paints
- 2) M/s Berger paints
- 3) M/s Jenson & Nicholson
- 4) M/s Shalimar Paints
- 5) Any other BHEL approved manufacturers.

5.4 Welding Electrodes, Filler Wires for MIG/TIG Welding and Gases

5.4.1

Contractor at his cost shall arrange all the required welding electrodes as approved by BHEL. It shall be the responsibility of the contractor to obtain prior approval of BHEL, regarding manufacturer, type and brand name of welding electrodes etc. On receipt of the electrodes at site, it shall be subject to inspection and approval by BHEL regarding type of electrodes, batch number, date of expiry etc. Batch test certificates shall be made available to BHEL for verification & records.

BHEL reserves the right to reject the use of any electrodes, if found non-acceptable because of bad quality, deterioration in quality due to improper storage, shelf-life expiry, unapproved type/brand etc

5.4.2

All the required gases for welding and gas cutting like Oxygen, Acetylene, Argon (welding quality), Nitrogen etc. shall be arranged by the contractor at his cost.

5.4.3

If at any time during the execution of work, it is noticed that the work is suffering on account of non-availability of consumables from the contractor's side BHEL will make alternate arrangements at the risk and cost of contractor. The expenditure incurred with overheads will be recovered from the contractor.

5.4.4 TEST PIECES FOR WELDERS QUALIFICATION TEST.

Materials for Test Pieces for qualification of structural welders shall be supplied by the Contractor. Contractor shall also prepare the test coupons from such materials. All expenses in respect of **welders' qualification test and Welding Process Qualification test** shall be to the contractors account.

5.5 Field Office

5.5.1

The contractor shall make his own arrangements for field office and stores for accommodating necessary equipments, tools room for execution of the work. Only open space will be provided by BHEL's customer free of charges within the project premises as per the availability of space.

The work under this scope being quite sophisticated and also quite extensive, for proper planning, monitoring, reporting, etc of ongoing works, the contractor shall establish his own computer(s) and printer(s) at his site office, along with suitable operator(s), consumables, etc. *Non-establishment of above equipment will attract penalty @ Rs 10000 (Rs Ten thousand only) per month.*

BHEL uses its own software SOMS (Site Operation and Management System) for total project execution and billing. The contractor shall also provide adequate and suitable manpower for updating / entries into SOMS in BHEL computers at site.

5.5.2

On completion of work, all the temporary buildings, structures, pipelines, cables, etc shall be dismantled and leveled and debris shall be removed as per instruction of BHEL by the contractor at his cost. In the event of his failure to do so, the same will be arranged to be removed and expenditure thereof will be recovered from the contractor. The decision of BHEL engineer in this regard shall be final. However, the scope of dismantling and leveling the area is limited only to the contractor's site office, yard and other spaces occupied by the contractor.

5.6 Area Lighting

Contractor shall arrange adequate floodlights, hand lamps and area lighting. Provision of distribution lines for lighting from the single point to the required place with proper distribution boards, observing the safety rules laid down by the electrical authorities of the state shall be done by the contractor including all the materials like cables, fuses, switch boards etc

5.7 CONSTRUCTION POWER & WATER

5.7.1

Construction power (three phase, 415v / 440v, 200 amps, 4-wire) will be provided at one point near the site approximately 500 Meters from erection site free of charge. However all taxes, duties, levies, charges etc, as applicable, shall also be born by the contractor. Presently no such charges are applicable. Accordingly, required energy meter, all cables, fuses, distribution boards, switches, switchboards, bus bars, earthing arrangements, protection devices e.g. ELCB, if any, and any other installation as specified by Statutory Authority, Client in this regard, for drawl of construction power shall be arranged by the contractor. Obtaining approvals, payment of necessary fees, duties etc towards the clearance of such installations, if any, prior to these being put to use or as may be specified, shall be the responsibility of the contractor.

5.7.2

It shall be the responsibility of the contractor to provide, maintain the complete installation on the load side of the supply with due regard to the safety requirements at site. All cabling and installations shall comply in all respects with the appropriate statutory requirements. The installation and maintenance of this shall be done by licensed and experienced Electrician.

5.7.3

The contractor shall install necessary Capacitor Bank etc. with appropriate control mechanism to maintain the Power Factor as per the guidelines in vogue from time to time in this regard. Any levy imposed by the customer / authority for any deviation in power factor shall be passed on to the contractor.

5.7.4

Contractor shall be equipped with back-up power supply arrangement like DG set and diesel operated welding machine etc. to tackle situations arising due to failure of customer supplied power, so as to ensure continuity and completion of critical process that are underway at the time of power failure or important activities planned in immediate future.

5.7.5

BHEL is not responsible for any loss or damage to the contractor's equipment as a result of variations in voltage or frequency or interruptions in power supply. Contractor shall take suitable insurance policy for such accidental loss/ damages.

5.7.6

Water for Drinking and Construction purposes shall be provided at one point. Further drawing and distribution is to be done by the contractor, including cost of materials and laying/installation

5.8 Contract Labour

5.8.1

The contractor in the event of his engaging 10 or more workmen will obtain independent license under the Contract Labour (regulations and abolition) Act 1970 from the concerned authorities based on the certificate (form –V) issued by the principal employer/customer.

5.8.2 Provident Fund

Contractor will deduct the necessary amount from his employees towards provident fund and contribute equal amount as per government of India labour laws. Contractor regularly to the provident fund commissioner and get the account code will deposit this amount. Contractor shall submit the account code duly certified by pf commissioner to BHEL project in-charge.

5.8.3

Contractor shall also comply with the provisions of ESIS act in vogue and submit evidence thereof to BHEL site in-charge. All other expenses such as employees' benefits to be borne by the contractor as per the labour laws. Contractor shall produce necessary certificates towards their compliance with such statutes and payment of all statutory dues.

5.8.4

Contractor shall also comply with the requirements of local authorities/ project authorities calling for police verification of antecedents of the workmen, staff etc

5.8.5

Where applicable, provisions of workman compensation act shall be adhered to.

5.8.6

BHEL/customer may insist upon witnessing the regular payment to the labour. They may also like to verify the relevant records for compliance with statutory requirements. Contractor shall enable such facilities to BHEL/ Customer.

5.9 Taxes, Duties, Levies

Refer to Clause 2.8.4 of General Conditions of Contract. Notwithstanding anything contained therein, the following provisions shall be applicable for this contract.

5.9.1

The contractor shall pay all (save the specific exclusions as enumerated in this contract) taxes, fees, license charges, deposits, duties, tools, royalty, commissions or other charges which may be levied on the input goods & services consumed and output goods & services delivered in course of his operations in executing the contract. In case BHEL is forced to pay any of such taxes, BHEL shall have the right to recover the same from his bills or otherwise as deemed fit.

However, provisions regarding Service Tax and Value Added Tax (VAT) on output services and goods shall be as per following clauses.

5.9.2

Service Tax & Cess on Service Tax:-

Service Tax and Cess on Service Tax as applicable on output Services are excluded from contractor's scope; therefore contractor's price/rates shall be exclusive of Service Tax and Cess on Output Services. In case, it becomes mandatory for the contractor under provisions of relevant act/law to collect the Service Tax & Cess from BHEL and deposit the same with the concerned tax authorities, such applicable amount will be paid by BHEL. Contractor shall submit to BHEL documentary evidence of Service Tax registration and remittance record of such tax immediately after depositing the tax with concerned authorities. Contractor shall obtain prior written consent from BHEL before billing the amount towards such taxes.

With introduction of Cenvat Credit Rules 2004, which came into force w.e.f. 10.09.2004, Excise Duty paid on Input Goods including Capital Goods and Service Tax paid on Input Services that are used for providing the output services can be taken credit of against the Service Tax payable on output services. However BHEL may opt for availing the abatement provision in which case cenvat credit may not be available on input duty.

5.9.3

VAT (Sales Tax /WCT)

As regards Value Added Tax (VAT) on transfer of property in goods involved in Works Contract (previously known as Works Contract Tax) applicable as per local laws, the price quoted by the contractor shall be exclusive of the same. Where such taxes are required to be paid by the contractor, this will be reimbursed on production of proof of payment made to the authorities by the Contractor. In any case the Contractor shall register himself with the respective Sales Tax authorities of the state and submit proof of such registration to BHEL along with the first RA bill. The contractor has to take all necessary steps to minimize tax on input goods by purchasing the materials from any registered dealer of the concerned state only. In case contractor opts for composition, it will be with the prior express consent of BHEL. Deduction of tax at source shall be made as per the provisions of law unless otherwise found exempted. In case tax is deducted at source as per the provisions of law, this is to be construed as an advance tax paid by the contractor and no reimbursement thereof will be made unless specifically agreed to.

5.9.4

Modalities of Tax Incidence on BHEL

Wherever the relevant tax laws permit more than one option or methodology for discharging the liability of tax/levy/duty, BHEL will have the right to adopt the appropriate one considering the amount of tax liability on BHEL/Client as well as

procedural simplicity with regard to assessment of the liability. The option chosen by BHEL shall be binding on the Contractor for discharging the obligation of BHEL in respect of the tax liability to the Contractor.

5.9.5

New Taxes/Levies

In case the Government imposes any new levy/tax on the output service/ goods/work after award of the contract, the same shall be reimbursed by BHEL at actual.

In case any new tax/levy/duty etc. becomes applicable after the date of Bidder's offer, the Bidder/Contractor must convey its impact on his price duly substantiated by documentary evidence in support of the same before opening of Price Bid. Claim for any such impact after opening the Price Bid will not be considered by BHEL for reimbursement of tax or reassessment of offer.

No reimbursement/recovery on account of increase/reduction in the rate of taxes, levies, duties etc. on input goods/services/work shall be made. Such impact shall be taken care of by the Price Variation/Adjustment Clause (PVC) if any. In case PVC is not applicable for the contract, Bidder has to make his own assessment of the impact of future variation if any, in rates of taxes/duties/ levies etc. in his price bid.

5.10 Submission of Periodical Reports

Contractor shall submit periodical reports in respect of following aspects of operation:

- 1) Consumption of welding electrodes and gases
- 2) Consumption of construction power
- 3) Manpower reports
- 4) Progress reports – periodically
- 5) Field calibration reports

BHEL at site will inform formats for these reports.

5.11

It is the responsibility of the contractor to arrange gate pass for all his employees, T&P etc. Necessary coordination with customer officials is the responsibility of the contractor. Contractor to follow all the procedures laid down by the customer for making gate passes. Where permitted, by customer/ BHEL, to work beyond normal working hours, the contractor shall arrange necessary work permit for working beyond normal working hours.

5.12 ELECTRICAL INSPECTORATE'S APPROVAL /STATUTORY INSPECTION

5.12.1 Contractor shall have/obtain valid Electrical Contractors License to carry out the Erection, Testing & Commissioning work on High/Low Voltage Electrical Equipments from the appropriate statutory authority of the concerned state or Central Electricity Authority, as the case may be. All fees and expenses in this regard shall be in the contractor's account.

5.12.2 The contractor has to arrange electrical licence to work in the state of Maharastra within a 6 weeks of mobilisation at site for carrying out the works

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

covered under this contract. Failure to arrange the requisite licence shall invite levy of non refundable penalty at the rate of Rs 1.0 lakh per month deductible from running bills till it is obtained

5.12.3 Contractor shall arrange inspection of concerned Statutory Authority for the installation, testing & commissioning of High / Low voltage equipments covered under the scope of work in this tender specification and obtain their approval in appropriate format prior to charging of the equipments.

5.12.4 Contractor shall be responsible for all necessary liaisoning work with Statutory Authority towards the certification of installation / works. BHEL will pay Statutory Fees in respect of inspection of installations as per demand note/challan issued by the statutory authority. All other expenses shall be borne by the Contractor. BHEL/ BHEL's Customer shall be providing technical assistance, drawing & document for submission to Statutory Authority. Contractor shall provide all logistics services in this regard.

Section-6

Special Conditions of Contract

6.1 Contractor's Obligation with Regard to Employment of Supervisory Staff and Workmen

The contractor shall deploy all the skilled/semiskilled/ unskilled labour including highly skilled workmen like high-pressure welders etc. These workmen should have previous experience on similar job. They shall hold valid certificates wherever necessary. BHEL reserves the right to insist on removal of any employee of the contractor at any time if he is found to be unsuitable and the contractor shall forthwith remove him. Contractor should furnish a tentative deployment plan of his manpower as required vide appendix-IV. Also the actual deployment will be so as to satisfy the erection and commissioning targets set by BHEL.

6.2

It is the responsibility of the contractor to engage his workmen in shifts and or on overtime basis for achieving the targets set by BHEL. This target may be set to suit BHEL's commitments to its customer or to advance date of completion of events or due to other reasons. The decision of BHEL in regard to setting the erection and commissioning targets will be final and binding on the contractor.

6.3

Contractor shall deploy only qualified and experienced engineers/ supervisors. They shall have professional approach in executing the work.

6.4

The contractor's supervisory staff shall execute the work in the most professional manner in the stipulated time. Accuracy of work and aesthetic finish are essential part of this contract. They shall be responsible to ensure that the assembly and workmanship conform to dimensions and tolerances given in the drawings/instructions given by BHEL engineer from time to time.

6.5

The supervisory staff employed by the contractor shall ensure proper outturn of work and discipline on the part of the labour put on the job by the contractor. Also in general they should see that the works are carried out in a safe and proper manner and in coordination with other labour and staff employed directly by BHEL or other contractors of BHEL /customer.

6.6 WATCH AND WARD

Contractor has to arrange and provide watch and ward round the clock. Any theft or damage of component due to negligence of the contractor will have to be replaced/repared by the contractor. The areas are unit control/ESP control room and field.

6.7 Industrial Relations and Labour Laws

An industrial relations supervisor shall coordinate for the implementation of local labour laws, maintenance of records as required by contract labour (regulation and

abolition) act and also coordinate with the local labour authorities and any other such authorities under whom this work falls.

6.8

If at any time, it is found that the contractor is not in a position to deploy the required engineers/supervisors/workmen due to any reason, BHEL shall have the option to make alternate arrangements at the contractor's risk and cost.

6.9 Site Organization.

Contractor shall employ only qualified and experienced engineers/supervisors for this job. They shall have professional approach in executing the work having adequate knowledge and experience in the fields of erection, erection methodology, calibration, testing and commissioning, quality control and quality assurance procedures, planning, safety etc., required to undertake the type of work as per this tender.

The contractor's supervisory staff shall execute the work in the most substantial and workmanlike manner in the stipulated time. Accuracy of work and aesthetic finish are essential part of this contract. They shall be responsible to ensure that the assembly and workmanship conform to dimensions and tolerances given in the drawings/instructions given by bhel engineer from time to time.

The supervisory staff employed by the contractor shall ensure proper outturn of work and discipline on the part of the labour put on the job by the contractor and in general, see that the works are carried out in a safe and proper manner in coordination with other labour and staff employed directly by BHEL or other contractors of BHEL or BHEL's client.

Contractor should provide a team of engineers with proven experience of erection, testing/ commissioning of electrical equipments as specified in tender specification. They shall be in a position to undertake specific assignments during the start up/ post start up/stabilization.

The contractor shall deploy adequate laboures and supervisory staff in the following areas.

- A) Overall planning, monitoring & control
- B) Equipments Erection
- C) Welding & NDT & Stress Relieving operators, induction.
- D) Testing & Commissioning
- E) Quality Control and Quality Assurance
- F) Materials Management
- G) Safety, Fire & Security
- H) Industrial Relations and Fulfillment of Labour Laws and Other Statutory Obligations.

Contractor shall furnish an organization chart indicating the staffing pattern for the above functions. Contractor shall provide the names and details of engineer/supervisors at the time of mobilization to BHEL as per the proposed organization chart.

Section-7

Special Conditions

7.0 Obligations Of BHEL

7.1 Facilities Provided By BHEL

7.2 Space For Field Office

Refer section-5 in this regard.

7.3 Construction Water

Refer section-5 in this regard.

7.4 Construction Power

Refer section-5 in this regard.

7.5 Other Materials and Consumables:

BHEL will supply consumables free of charges as listed in **Appendix-II B**.

7.6 Test Blanks (Plates & Pipes)

Test pieces for qualification of structural welders shall be supplied by the Contractor.

7.7 Filler Wire and Welding Electrodes

All the welding consumables shall be arranged by contractor.

7.8 Tools & Plants

BHEL will provide the Tools & Plants listed in **Appendix II A** free of charges on sharing basis.

BHEL will also provide any special tools that are supplied by BHEL manufacturing units/vendors/suppliers as special installation tools under regular DU/DESS numbers in various product groups free to contractor. Contractor shall return these tools after the completion of the specific task for which such tools are intended, in good working order after proper servicing/overhauling.

Section-8

Special Conditions of Contract

8.0 Inspection/Quality Assurance/Quality Control/ Statutory Inspection

- 8.1 Various inspection/quality control/quality assurance procedures/methods at various stages of erection and commissioning will be as per BHEL/customer quality control procedure/codes and other statutory provisions and as per BHEL engineer's instructions.
- 8.2 Preparation of quality assurance log sheets and protocols with customer/consultants/statutory authority, welding logs, NDE records, testing & calibration records and other quality control and quality assurance documentation as per BHEL engineer's instructions, is within the scope of work/specification. These records shall be submitted to BHEL/customer for approval from time to time.
- 8.3 A daily logbook of all measurements and testing/calibration should be maintained by contractor on the job for detailing inspection details of various equipments.
- 8.4 The performance of welders will be reviewed from time to time as per the BHEL standards. Welders' performance record shall be furnished periodically. Corrective action as informed by BHEL shall be taken in respect of those welders not conforming to these standards. This may include removal/ discontinuance of concerned welder(s). Contractor shall arrange for the alternate welders immediately.
- 8.5 All the welders shall carry identity cards as per the proforma prescribed by BHEL only welders duly authorized by BHEL/customer/consultant shall be engaged on the work.
- 8.6 Contractor shall provide all the measuring monitoring devices (MMDs) required for completion of the work satisfactorily. These MMDs shall conform to job requirement in respect of measurement range, accuracy level & any other specification. The indicative list of MMDs required for this work and to be made available by the contractor is given in appendix-III. The list will be reviewed by BHEL and the contractor shall meet any augmentation needed.
- 8.7 The MMDs deployed by the contractor shall, at all stages of work, have valid and current calibration. BHEL shall be done the calibration of these MMDs from the agencies accredited/ approved. Copy of calibration certificates in respect of these MMDs has to be submitted to BHEL. Periodical status report regarding validity of calibration has to be submitted to BHEL. Re-calibration/ re-validation shall be done periodically as per BHEL specifications. Contractor shall conform to the specifications of BHEL regarding storage of the MMDs.
- 8.8 Re-work necessitated on account of use of invalid MMDs shall be entirely to the contractor's account. He shall be responsible to take all corrective actions, including resource augmentation if any, as specified by BHEL to make-up for the loss of time.
- 8.9 In the course of work BHEL may counter/ finally check the measurements with their own MMDs. Contractor shall render all assistance in conduct of such counter/final measurements.
- 8.10 Total quality is the watchword of the work and contractor shall strive to achieve the quality standards, procedures laid down by BHEL. He shall follow all the instructions as per BHEL drawings and quality standards. Contractor shall provide for the services of quality assurance engineer.

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

8.11 Stage Inspection By FES/QA Engineers

Apart from day-to-day inspection by BHEL engineers stationed at site and also by customer's engineers, stage inspection of equipments under erection and commissioning at various stages of erection and commissioning by teams of engineers from field engineering services of BHEL's manufacturing units and quality assurance teams from field quality assurance factory quality assurance and commissioning engineers from technical services of BHEL will also be conducted. Contractor shall arrange all labour, tools and tackles etc, for such stage inspections as part of work.

8.12 Statutory Inspection of Work:

8.13 Statutory Inspection of Work

8.13.1

The work to be executed under these specifications has to be offered for inspection, at appropriate stages of work completion, to various statutory authorities for compliance with applicable regulations.

8.13.2

The work related statutory inspections, though not limited to, are as under:

- 1) Inspectorate of the Chief Electrical Inspector of Maharashtra OR Central Electricity Authority as per statute.
- 2) Any other authority connected to this work.

The scope includes getting the approval of the installations from the statutory authorities, which includes arranging for inspection visits of statutory authority periodically as per BHEL engineer's instructions, submitting documents, radiographs etc. and following up the matter with them. Contractor shall also make all arrangements for offering the products/systems for inspection, as applicable, to the concerned authority.

8.13.3

It shall be contractor's responsibility to obtain approval of statutory authorities, whenever applicable, for conducting any work which comes under the purview of these authorities.

8.13.4

BHEL will pay fees for visits, inspection fees etc. of these statutory authorities. Please refer Section-5 for working arrangement for payment of fees in this regard. All other expenses shall be borne by the contractor. In case these inspections have to be repeated due to reasons attributable to the contractor and fees have to be paid again, the contractor has to pay such additional charges.

8.13.5

It shall be the responsibility of contractor to obtain license from chief electrical inspector, Maharashtra for carrying out high voltage work. Contractor shall also

comply with the provisions of the latest Electricity Act, including the amendments thereof.

8.13.6

The contractors shall pay all fees connected with testing of his welders/workers and testing, inspection & calibration of his MMD and T&P.

8.14.0

The quality management system of BHEL, Power Sector – Western Region (PSWR) has already been certified and accredited under ISO 9002 standards in this regard. The basic philosophy of the quality management system is to define the organizational responsibility, work as per documented procedures, verify the output with respect to acceptance norms, identify the non-conforming product/ procedure and take corrective action for removal of non-conformance specifying the steps for avoiding recurrence of such non-conformities, & maintain the relevant quality records. The non-conformities are to be identified through the conduct of periodical audit of implementation of quality systems at various locations/stages of work. Suppliers/vendors of various products/services contributing in the work are also considered as part of the quality management system. .as such the contractor is expected not only to conform to the quality management system of BHEL but also it is desirable that they themselves are accredited under any quality management system standard.

8.15.0 Field Quality Assurance

Contractor shall carry out all activities conforming to the approved Field Quality Plan (FQP) as revised from time to time. Total quality shall be the watchword of the work and contractor shall strive to achieve the quality standards, procedures laid down by BHEL. He shall follow all the instructions as per BHEL drawings and quality standards. Contractor shall provide the services of quality assurance engineer as per the relevant clauses.

SECTION-9

SPECIAL CONDITIONS OF CONTRACT

Safety, Occupational Health and Environmental Management

BHEL PSWR has been certified for Environmental Management under ISO 14001:1996 standard and Occupational Health & Safety under OHSAS 18001 by DNV. In order to comply with the above standards, it shall be the endeavor of BHEL and all its subcontractors to meet and implement the requirements by following the guidelines issued under Environmental, Occupational Health and Safety Management (EHS) manual a copy of which will be available with the BHEL Site -in-charge.

Contractor shall also enter into a "Memorandum of Understanding" as given in clause 9.9 in case of award of contract.

9.0 Responsibility of the Contractor in Respect of Safety of Men, Equipment, Material and Environment.

9.1 The Contractor shall:

9.1.1

Abide by the Safety Regulations applicable for the Site/Project and in particular as mentioned in the booklet "Safe Work Practices" issued by BHEL. Contractors are also to ensure that their employees and workmen use safety equipments as stipulated in the Factories Act (Latest Revision) during the execution of the work. Failure to use safety equipment as required by BHEL Engineer will be a sufficient reason for issuance of memo, which shall become part of Safety evaluation of the contractor at the end of the Project. Also all site work may be suspended if it is found that the workmen are employing unsafe working practice and all the costs/losses incurred due to suspension of work shall be borne by contractor. A comprehensive list of National Standards from which the contractor can draw references for complying with various requirements under this section is given under 9.10

9.1.2

Hold BHEL harmless and indemnified from and against all claims, cost and charges under Workmen's Compensation Act 1923 and 1933 and any amendment thereof and the contractor shall be solely responsible for the same.

9.1.3

Abide by the Procedure governing entry/exit of the contractor's personnel within the Customer/Client premises. All the contractors employees shall be permitted to enter only on displaying of authorized Photo passes or any other documents as authorized by the Customer/Client.

9.1.4

Be fully responsible for the identity, conduct and integrity of the personnel/workers engaged by them for carrying out the contract work and ensure that none of them are ever engaged in any anti national activity

9.1.5

Prepare a signboard giving the following information and display it near work site:

- i) Name of Contractor
- ii) Name of Contractor Site -in-charge & Telephone number
- iii) Job Description in short
- iv) Date of start of job
- v) Date of expected completion
- vi) Name of BHEL Site -in-charge.

9.1.6

Abide by the rules and regulations existing during the contract period as applicable for the contractors at the Project premises.

9.1.7

Observe the timings of work as advised by BHEL Engineer-in-charge for carrying out the contract work.

9.2 **SPECIAL CONDITIONS**

9.2.1 **Safety**

9.2.1.1 **Safety Plan**

Before commencing the work, contractor shall submit a "safety plan" to the authorized BHEL official. The safety plan shall indicate in detail the measures that would be taken by the contractor to ensure safety to men, equipment, material and environment during execution of the work. The plan shall take care to satisfy all requirements specified hereunder.

The contractor shall submit "safety plan" before start of work. During negotiations, before placing of work order and during execution of the contract, BHEL shall have right to review and suggest modifications in the safety plan. Contractor shall abide by BHEL's decision in this respect.

9.2.1.2

The contractor shall take all necessary safety precautions and arrange for appropriate appliances and/or as per direction of BHEL or its authorized person to prevent loss of human lives, injuries to men engaged and damage to property and environment.

9.2.1.3

The contractor shall provide to his work force and also ensure the use of Personnel Protection Equipment (PPE) as found necessary and/or as directed and advised by BHEL officials without which permission is liable to be denied.

- Safety helmets conforming to IS 2925/1984 (1990)
- Safety belts conforming to IS 3521/1989
- Safety shoes conforming to IS 1989 part-II /1986(1992)
- Eye and face protection devices conforming to IS 2573/1986(1991), IS 6994 (1973), part-I (1991), IS 8807/1978 (1991), IS 8519/1977(1991).
- Other job specific PPEs of standard ISI make as may be prescribed

9.2.1.4

All tools, tackles, lifting appliances, material handling equipment, scaffolds, cradles, cages, safety nets, ladders, equipment, etc used by the contractor shall be of safe design and construction. These shall be tested and certificate of fitness obtained before putting them to use and from time to time as instructed by authorized BHEL official who shall have the right to ban the use of any item found to be unsafe.

9.2.1.5

All electrical equipment, connections and wiring for construction power, its distribution and use shall conform to the requirements of Indian Electricity Act and Rules. Only electricians licensed by the appropriate statutory authority shall be employed by the contractor to carry out all types of electrical works. All electrical appliances including portable electric tools used by the contractor shall have safe plugging system to source of power and be appropriately earthed.

9.2.1.6

The contractor shall not use any hand lamp energized by electric power with supply voltage of more than 24 volts. For work in confined spaces, lighting shall be arranged with power source of not more than 24 volts.

9.2.1.7

The contractor shall adopt all fire safety measures as per relevant Indian Standards

9.2.1.8

Where it becomes necessary to provide and/or store petroleum products, explosives, chemicals and liquid or gaseous fuel or any other substance that may cause fire or explosion, the contractor shall be responsible for carrying out such provisions and/or storage in accordance with the rules and regulations laid down by the relevant government acts, such as petroleum act, explosives act, petroleum and carbides of calcium manual of the chief controller of explosives, Government of India etc. The contractor in all such matters shall also take prior approval of the authorized BHEL official at the site.

9.2.1.9

Proper means of access must be used e.g. ladders, scaffolds, platforms etc. No makeshift access such as oil drums or pallets shall be used. Design of these will be in accordance with relevant standards and certified by competent persons before use.

9.2.1.10

Temporary arrangements made at Site for lifting , platforms, approach access etc should be properly designed and approved before being put to use.

9.2.1.11

All excavations and openings must be securely and adequately fenced/barricaded and warning signs erected when considered necessary as per relevant code of practice.

9.2.1.12

No persons shall remove guardrails, covers or protective devices unless authorized by a responsible supervisor and alternative precautions have been taken

9.2.1.13

Access ways, means of escape and fire exits shall be clearly marked, kept clear and unobstructed at all times

9.2.1.14

Only authorized persons holding relevant license will drive and operate site plant and equipments e.g. cranes, dumpers, excavators, transport vehicles etc

9.2.1.15

Only authorized personnel are allowed to repair, commission electrical equipments.

9.2.1.16

Gas Cylinders shall be handled and stored as per Gas Cylinders Rules and relevant safe working practices

9.2.1.17

All wastes generated at Site shall be segregated and collected in a designated place so as to prevent spillage/contamination/scattering at Site, until the waste is lifted for disposal to designated disposal area as advised by BHEL official.

9.2.1.18

The contractor shall arrange at his cost (wherever not specified) appropriate illumination at all work spots for safe working when natural day light is not adequate for clear visibility.

9.2.1.19

The contractor shall train adequate number of workers/supervisors for administering "FIRST AID". List of competent first aid administrators should be prominently displayed.

9.2.1.20

The contractor shall display at strategic places and in adequate numbers the following in fluorescent markings

- Emergency telephone numbers
- Exit, Walkways
- Safe working load charts for wire ropes, slings, D shackles etc
- Warning signs

9.2.1.21

The contractor shall be held responsible for any violation of statutory regulations (local, state or central) and BHEL instructions that may endanger safety of men, equipment, material and environment in his scope of work or other contractors or agencies. Cost of damage, if any, to life and property arising out of such violation of statutory regulations and BHEL instructions shall be borne by the contractor.

9.2.1.22

In case of a fatal or disabling injury/accident to any person at construction sites due to lapses by the contractor, the victim and/or his/her dependents shall be compensated by the contractor as per statutory requirements. However, if considered necessary, BHEL shall have the right to impose appropriate financial penalty on the contractor and recover the same from payments due to the contractor for suitably compensating the victim and/or his/her dependents. Before imposing any such penalty, appropriate enquiry shall be held by BHEL giving opportunity to the contractor to present his case.

9.2.1.23

In case of any damage to property due to lapses by the contractor, BHEL shall have the right to recover cost of such damages from payments due to the contractor after holding an appropriate enquiry.

9.2.1.24

In case of any delay in the completion of a job due to mishaps attributable to lapses by the contractor, BHEL shall have the right to recover cost of such delay from payments due to the contractor after notifying the contractor suitably and giving him opportunity to present his case.

9.2.1.25

If the contractor fails to improve the standards of safety in its operation to the satisfaction of BHEL after being given a reasonable opportunity to do so, and/or if the contractor fails to take appropriate safety precautions or to provide necessary safety devices and equipment or to carry out instructions regarding safety issued by the authorized BHEL official, BHEL shall have the right to take corrective steps at the risk and cost of the contractor after giving a notice of not less than seven days indicating the steps that would be taken by BHEL.

9.2.1.26

Emergency Response

BHEL will have an Emergency Response Plan for each Project Site in consultation with the Owner as the case may be, detailing the procedure for mobilization of personnel and

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

equipment, and defining the responsibilities of the personnel indicated, in order to prepare for any emergency that may arise in order to ensure the priorities of

- Safeguard of life
- Protect assets under construction or neighbouring
- Protect environment
- Resumption of normal operations as soon as the emergency condition is called off

All Contractors shall also be part of the Emergency response Plan and the personnel so nominated shall be aware of their duties and responsibilities in an emergency response situation.

9.2.1.27

At least 5% Contractors supervisors and workmen shall undergo training in administering 'First Aid'. The trained persons should represent for all categories of work and for all areas of work. Adequate number of trained persons should be available for each shift. These first aides shall be included in the emergency response team. Contractor employees and workmen are encouraged to participate in first aid training programmes whenever organized by BHEL.

9.2.2 OCCUPATIONAL HEALTH

9.2.2.1

Specific occupational health hazards will be identified through the hazard evaluation processes in consultation with BHEL engineers and the necessary prevention/reduction/elimination methods implemented.

9.2.2.2

All personnel working in an activity with a potential risk to health shall be made aware of all those risks and the actions they must take to reduce/control/eliminate the risk

9.2.2.3

Safety coordinator shall conduct periodic checks to ensure that every group of workers engaged in similar activities are aware of potential risks to health and the actions required to be taken to mitigate the risk

9.2.2.4

In order to protect personnel from associated health hazards, the following main areas will be focused

- Issue of approved Personnel Protective Equipment
- Verification that the PPE are adequate/maintained and worn by all staff involved in operations that are potentially hazardous to their health
- Ensure that the personnel deployed are physically fit for the operation/work concerned
- Provide hygienic and sanitary working conditions

9.2.2.5

Contractor workers employees engaged in noise risk areas shall be issued with hearing protection aids and the use of the same will be enforced. Further, these workers will be educated on the hazards of noise

9.2.2.6

Contractor workers engaged in dust environment shall be issued with necessary dust protection aids and the use of the same shall be enforced

9.2.2.7

Workers engaged in exposure to bright light/rays as in welding or radiation shall be issued with eye protection devices and the use of the same shall be enforced

9.2.2.8

Adequate arrangements shall be made to provide safe drinking water

9.2.2.9

Health monitoring records on at least sample basis for contractor employees & workmen shall be maintained for persons engaged in specified categories of work. These shall include

- Noise induced hearing loss
- Lung Function test
- Ergonomic Test
- Eye Test for Welders, Grinders, Drivers etc

9.2.3.0 HYGIENE and HOUSEKEEPING

9.2.3.1

Good house keeping and proper hygiene is one of the key requirements of Occupational Health Safety and Environment management. Towards this the contractor shall encourage his workers and supervisors to maintain cleanliness in their area of work.

9.2.3.2

The Contractor shall arrange to place waste bins/chutes at convenient locations for the collection of scrap and other wastes. The bins shall be clearly marked and segregated for metal, non-metal, hazardous and non hazardous wastes.

9.2.3.3

BHEL may take up appropriate remedial measures at the cost of the contractors if the contractors fail in good house keeping and if there is an imminent risk of pollution

9.2.4 ENVIRONMENT MANAGEMENT

9.2.4.1

BHEL has a sound environmental management system, which is to be maintained and implemented by all the contractors. The system allows for project specific objectives to be set and developed sensitive to client requirements, applicable environmental legislation and BHEL's own objectives and policy. BHEL engineers will assess and monitor the environmental impact of their work and lay out objectives for their minimization. The contractors shall implement the objectives for continual improvement of environmental performance. BHEL shall regularly audit environmental impacts and their improvements.

9.2.4.2 WASTE MANAGEMENT

9.2.4.3.1

The objective of waste management is to ensure the safe and responsible disposal of waste, ensuring that it is correctly disposed of and being able to audit the process to ensure compliance.

9.2.4.3.2

Chemical wastes if any shall be collected separately and disposed of to BHEL designated refuse yard as per BHEL advice.

9.2.4.3.3

No dangerous chemicals, noxious waste products or materials will be disposed off on or off site without approval obtained through BHEL.

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

9.2.4.3.4

All disposal of wastes generated during construction shall be in accordance with all relevant legislation.

9.2.4.3.5

Acid and alkali cleaning wastes shall be neutralized to acceptable norms before disposal to the designated area.

9.2.4.3.6

All necessary measures shall be taken to ensure safe collection and disposal of waste oils. In particular to ensure the prevention of their discharge into surface waters, ground waters, coastal waters or drainages

9.3 SUPERVISION

9.3.1

Contractor must provide at least one full time on site safety coordinator when the manpower engaged is in excess of 50 for the contract activities in the premises. If the manpower is less than 50, the on site safety coordination responsibilities shall be assumed by any one of the contractor's other supervisory staff; however in both the cases, the contractor must specify in writing the name of such persons to the BHEL Engineer in Charge.

9.3.2

Contractor's safety coordinator or his supervisor responsible for safety as the case may be shall conduct at his work site, and document formal safety inspection and audits at least once in a week. Such documents are to be submitted to BHEL Engineer in Charge for his review and record.

Contractor, supervisor must attend all schedule safety meetings as would be intimated to him by the BHEL Engineer in Charge.

9.3.3

Before starting work under any contract, the contractor must ensure that a job specific safety procedures/field practices as required over and above the safety permit conditions are prepared and followed .He should also ensure that all supervisors and workers involved understand and follow this procedures /field practices.

9.3.4

Contractor must ensure that in his work site appropriate display boards are put displaying signs for site safety, potential hazards and precautions required.

9.4.0 **TRAINING & AWARENESS**

9.4.1

Contractor shall deploy experienced supervisors and other manpower who are well conversant with the safety and environment regulations of the Project. The electricians to be deployed on the job should have wireman license.

9.4.2

All Supervisors & Workmen of the Contractor shall undergo Fire safety training/ demonstration whenever arranged by BHEL with the help of either Customer's Fire and Safety department or outside faculty so as to acquire knowledge of fire prevention and also to be able to make use of appropriate fire extinguishers.

9.4.3

Contractor must familiarize himself from BHEL Engineer in Charge about all known potential fire, explosion or toxic release hazards related to the contract. He in turn will ensure that same information has been passed to the supervisors and workmen

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

9.4.4

Contractor must ensure that all his supervisors are properly trained and each employee has received and understood from his supervisor necessary training and briefing about the safety requirement. Necessary document as a means to verify that employees have understood the training is to be maintained.

9.4.5

The contractor supervisors shall also give a small safety briefing to all the workmen under his charge before undertaking any new work and specially understand the safety requirements that are mandatory

9.5.0 **REPORTING**

9.5.1

The contractor shall submit report of all accidents, fires and property damage, dangerous occurrences to the authorized BHEL official immediately after such occurrence but in any case not later than twelve hours of the occurrence. Such report shall be furnished in the manner prescribed by BHEL and also to meet statutory requirement.

9.5.2

Any injury sustained by any of the contractor's employees within the Project premises must be reported to BHEL supervisor and FIRST AID should be immediately administered. The Contractor shall be responsible for keeping and maintaining proper records of Accidents to his personnel.

9.5.3

Contractor must arrange to immediately investigate, properly document and report any injury, accident or near miss involving any of his employees and take appropriate follow up action. He must furnish within 12 hours of the incident a written report to BHEL Engineer in charge and the Safety Section.

9.5.4

According to the Factory Act and the Employees state Insurance Act & regulation, any person sustaining any injury within the project premises and absenting himself from work for more than 46 hours, his accident report has to be sent to the respective Government Authorities. Therefore contractor shall inform the owner's representative such matter immediately for their needful action.

9.5.5

In addition, contractor shall submit periodic reports on safety to the authorised BHEL official from time to time as prescribed.

9.5.6

Before commencing the work, the contractor shall appoint/nominate a responsible officer to supervise implementation of all safety measures and liaison with his counterpart of BHEL.

9.6 **AUDIT REVIEW AND INSPECTION**

9.6.1

BHEL shall conduct audit on the contractor performance and compliance with the project specific requirements of the Environment and Occupational Health & Safety Management systems. The programme of audit shall cover all activities under the contract but will focus particularly on high-risk activities. The Construction Manager shall decide the schedule of

audit. The audit findings shall be communicated to the contractors and necessary remedial action as advised by BHEL Engineers shall be under taken within the stipulated time.

9.6.2

Inspections shall be carried out regularly by the contractors and by BHEL Engineers on activities, facilities, equipment, documentation, to cover the following aspects.

- Compliance with procedures and systems
- Availability, condition and use of PPE
- Condition of maintenance tools, equipments, facilities
- Availability of fire fighting equipments and its condition
- Use of fire fighting equipments and first aid kit
- Awareness of occupational health hazard
- Awareness of safe working practices
- Presence of quality supervision
- Housekeeping

The Safety coordinator shall visit and inspect work sites daily. All unsafe acts, unsafe conditions that have imminent potential for causing harm/injury/damage will be immediately corrected. He shall maintain a daily logbook giving details of unsafe acts or conditions observed and the corrective action taken and recommendations for preventing recurrence. Adequacy of corrective actions will be verified

The contractor shall take remedial measures as per the findings of each inspection
Besides the above, the contractor shall be required to carry out the following inspections

Sl no	Equipment	Scope of inspection	Inspection by	Schedule
1	Hand tools	To identify unsafe/defective tool	User	Daily
2	Power tools	To identify unsafe/defective tool	User	Daily
3	Fire Extinguishers	To check pressure and any defect	User / Safety Coordinator	Daily Every month
4	Lifting equipment/tackles	To check for defects and efficacy of brakes	User Third party	Daily Every Year
5	PPE	To check for defects	User	Daily

9.7 **NON COMPLIANCE**:-

9.7.1

NONCONFORMITY OF SAFETY RULES AND SAFETY APPLIANCES WILL BE VIEWED SERIOUSLY AND THE BHEL HAS RIGHT TO IMPOSE FINES ON THE CONTRACTOR AS UNDER **for every instance of violation noticed**:

Sl. No	Instance of Violation	Fine (in Rs)
01.	Not Wearing Safety Helmet	50/-
02.	Not wearing Safety Belt	100/-
03.	Grinding Without Goggles	50/-
04.	Not using 24 V Supply For Internal Work	500/-
05.	Electrical Plugs Not used for hand Machine	100/-

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

Sl. No	Instance of Violation	Fine (in Rs)
06.	Not Slings property	200/-
07.	Using Damaged Sling	200/-
08.	Lifting Cylinders Without Cage	500/-
09.	Not Using Proper Welding Cable With Lot of Joints And Not Insulated Property.	200/-
10.	Not Removing Small Scrap From Platforms	200/-
11.	Gas Cutting Without Taking Proper Precaution or Not Using Sheet Below Gas Cutting	200/-
12.	Not Maintaining Electric Winches Which are Operated Dangerously	500/-
13.	Improper Earthing Of Electrical T&P	500/-
	Major Accident or Accidents causing partial loss of earning to the victim	50,000/- per victim
14	Fatal Accident or Accidents causing permanent loss of earning to the victim	1,00,000/- per victim

Any other non-conformity noticed not listed above will also be fined as deemed fit by BHEL. The decision of BHEL engineer is final on the above. The amount will be deducted from running bills of the contractor. The amount collected above will be utilised for giving award to the employees who could avoid accident by following safety rules. Also the amount will be spent for purchasing the safety appliances and supporting the safety activity at site.

9.8

CITATION:- If safety record of the contractor in execution of the awarded job is to the satisfaction of safety department of BHEL, issue of an appropriate certificate to recognize the safety performance of the contractor may be considered by BHEL after completion of the job

9.9 Memorandum of Understanding

After Award Of Work, Contractors Are Required To Enter Into A Memorandum Of Understanding As Given Below:

Memorandum of Understanding

BHEL, PSWR is committed to Health, Safety and Environment Policy (EHS Policy) as given in the booklet titled “ Safe Working Practices” issued to all contractors.

M/s _____ do hereby also commit to the same EHS Policy while executing the Contract Number _____

M/s _____ shall ensure that safe work practices not limited to the above booklet are followed by all construction workers and supervisors. Spirit and content therein shall be reached to all workers and supervisors for compliance.

BHEL will be carrying out EHS audits twice a year and M/s _____ shall ensure to close any non-conformity observed/reported within fifteen days.

Signed by authorized representative of M/s-----

Bharat Heavy Electricals limited, PSWR, Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

Name :

Place & Date:

9.10

Comprehensive list of National Standards for reference and use wherever applicable in the execution of Civil, Erection and Commissioning Contracts.

IS No	YEAR	Amd upto	DESCRIPTION
IS 10204	1982		PORTABLE FIRE EXTINGUISHERS MECHANICAL FOAM TYPE
IS 10245	1994		SPECIFICATION FOR BREATHING APPARATUS
IS 10291	1982		SAFETY CODE FOR DRESS DRIVERS IN CIVIL ENGINEERING

Appendix-IVA

Month wise manpower deployment (number to be indicated category-wise in each month) by the Contractor .

S.N.	Category	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
01.	Resident manager															
02.	Engineers															
03.	Supervisors															
04.	A) Mechanical B) Electrical C) Instrumentation D) Industrial relation/safety															
05.	Riggers															
06.	Fitters															
07.	Aluminium welders															
08.	Struct. Welders															
09.	Tig welders															
10.	Electricians															
11.	Instrument technicians															
12.	Store keeper															
13.	Semiskilled & unskilled workers															
14.	Watchmen/security															

Note:

01. Minimum number of persons to be indicated monthwise.
02. Above deployment plan will be discussed prior to award of work and necessary changes will have to be made by contractor after discussion, if required. Any additional deployment required during execution of work will have to be made by contractor meeting various schedules/targets set by BHEL without any additional compensation.

Date:

Signature of bidder with s

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

Part I : Technical Bid Specification Tender Specification No BHE/PW/PUR/TRT-ELE/516 Page 138 of 142

Appendix-IVB

Deployment plan for major tools and plants/instruments (monthwise quantity to be indicated for each category) by the contractor.

SN	Category															
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
01	Mobile crane (8 MT)															
02	Oil Filtration Machines 6 kL															
03	Primary injection kits															
04	Secondary injection kits															
05	Welding generators / T/F															
06	Aluminium Wlding Machines															
07	Motorised Meggers (2.5/ 5 KV)															
08	Micro Ohm Meters															
09	HV Test kit															
10	Digital multimeters (3½ / 4½ Digit)															
11	Auto Transformer / Variac															
12	BDV TEST KIT															
13	TAN DELTA TEST KIT															
14	OSCILLOSCOPE															
15	DC POWER SUPPLY SOURCE															

Note:

Also, the list of other tools and plants to be deployed for this project may be indicated by the tenderers separately Above deployment plan will be discussed prior to award of work and necessary changes will have to be made by contractor as per discussion, if required. Any additional deployment required during execution of work will have to be made by contractor for meeting various schedules/targets set by BHEL without any additional compensation.

Date:

Signature of Bidders with seal

Bharat Heavy Electricals limited, PSWR,Nagpur
Tender Specification No BHE/PW/PUR/TRT-ELE/516

Appendix-V

Analysis of unit rate quoted

Sl. No.	Description	Percentage of unit rate quoted	Remarks if any
01	Site facilities viz., electricity, water, workshop and other infrastructure.		
02	Salary & wages		
03	Consumables		
04	Depreciation & maintenance for t&p/instruments and other items		
05	Establishment & administration expenses of site		
06	Retrenchment benefit		
07	Extra work incidental to erection		
08	Overheads		
09	Profit		
Total		100%	

Signature of the tenderer with seal

APPENDIX–VI

DETAILS OF SIMILAR WORK DONE DURING THE LAST SEVEN YEARS

BIDDERS SHALL ENCLOSE COPIES OF DETAILED WORK ORDER (GIVING BILL OF QUANTITIES AND SCOPE OF WORK) AND COMPLETION CERTIFICATE IN SUPPORT OF THIS STATEMENT.

SL. NO	FULL POSTAL ADDRESS OF CLIENT & NAME OF OFFICER IN CHARGE	DESCRIP- TION OF WORK	VALUE OF CONTRACT	DATE OF AWARD OF WORK	DATE OF COMMENCE MENT OF WORK	ACTUAL COMPLETION TIME (MONTHS)	DATE OF ACTUAL COMPLETION OF WORK	REMARKS
1								
2								
3								
4								
5								

DATE

SIGNATURE OF TENDERER WITH SEAL

APPENDIX –VII

CURRENT COMMITMENTS OF THE TENDERER

SN	FULL POSTAL ADDRESS OF CLINT & NAME OF OFFICER IN CHARGE	DESCRIPTION OF WORK	VALUE OF CONTRACT	DATE OF COMMENCEMENT OF WORK	SCHEDULE OF COMPLETION	% OF WORK COMPLETED AS ON DATE	EXPECTED DATE OF COMPLETION	REMARKS
1								
2								
3								
4								
5								
6								

DATE

SIGNATURE OF TENDERER WITH SEAL

Bharat Heavy Electricals Limited, PSWR : Nagpur
Tender Specification No. BHE/PW/PUR/TRT-ELE/516