

TENDER CHANGE NOTE 02 (TCN – 02) DT:27-09-2007

WITH REFERENCE TO THE NIT, PUBLISHED IN THE WEB SITES FOR COMPLETE MATERIALS MANAGEMENT, ERECTION, TESTING AND COMMISSIONING OF GAS TURBINE, GENERATOR & AUXILIARIES ETC FOR 1X 20 MW GTG PACKAGE (FRAME-5) AT IOCL, HALDIA. FOLLOWING CHANGES BASED ON THE PRE-BID CLARIFICATION MEETING AMAY PLEASE BE NOTED AND COMPLIED WHILE SUBMITTING THE OFFER FOR THE SUBJECT JOB.

REF: TENDER DOCUMENT NO-PSER:SCT:HLD-T797:07

FURTHER TO THE TCN-01 DATED 12/09/07, PUBLISHED IN THE WEB, PLEASE NOTE THAT THE PRE-BID MEETING TOOK PLACE ON 27/09/2007. THE ABOVE PRE-BID MEETING IS ENCLOSED HEREWITH FOR CONSIDERTION OF ALL BIDDERS.

ALL THE BIDDERS ARE REQUESTED TO SUBMIT THEIR QUOTATION ACCORDINGLY.

BIDDERS TO NOTE THAT ALL TCNS WILL FORM PART OF TECHNICAL SPECIFICATION AND SPECIAL CONDITIONS OF CONTRACT OF TENDER DOCUMENT.

ALL OTHER TERMS & CONDITIONS OF THE TENDER REMAIN NCHANGED.

BIDDERS ARE REQUESTED TO SUBMIT OFFER BY DUE DATE.

DGM (SCT)

ANNEXURE-I (TCN-01)

PREQUALIFYING REQUIREMENTS FOR BIDDERS FOR MATERIALS MANAGEMENT, ERECTION, TESTING AND COMMISSIONING OF GAS TURBINE, GENERATOR & AUXILIARIES FOR IOCL, HALDIA, 1 x 20 MW GTG PACKAGE AT IOCL HALDIA REFINARY, MIDNAPUR, WEST BENGAL

JOB : THE SCOPE INCLUDES ERECTION, TESTING AND COMMISSIONING, TRIAL RUN, PG TESTING AND HANDING OVER OF 1X 20 MW GAS TURBINE-GENERATOR PACKAGE AND ASSOCIATED AUXILIEIRES INCLUDING UNLOADING, LOADING, STACKING, STORAGE & PRESERVATION OF GTG & AUX., C&I, ETC MATERIALS FOR IOCL, HALDIA.REFINERY GAS TURBINE CO-GEN-III PLANT, MIDNAPUR, W.B.

CONTRACT PERIOD – 12 MONTHS

QUALIFYING REQUIREMENTS FOR BIDDERS

TECHNICAL

1. VENDOR SHOULD HAVE EXECUTED/EXECUTING SIMILAR JOB DURING LAST SEVEN YEARS ENDING 31/08/2007. VENDOR SHOULD PRODUCE CERTIFICATE IN SUPPORT OF SUCCESSFUL EXECUTION/EXECUTING SIMILAR PACKAGE FROM USER/END USER.

NOTE :- 1) SIMILAR JOB MEAN ERECTION, TESTING, COMMISSIONING ETC. OF AT LEAST ONE SET (20 MW) OF GAS TURBINE AND TURBOGENERATOR OR 20 MW STEAM TURBINE AND GENERATOR SET.

NOTE:- 2) EXECUTING SHALL MEAN FULL SPEED NO LOAD OPERATION OF GAS TURBINE OR BARRING GEAR OPERATION FOR STEAM TURBINE.

FINANCIAL

F-1 VENDOR SHOULD HAVE AVERAGE TURNOVER OF MINIMUM Rs. 60.0 LAKHS (RUPEES SIXTY LAKHS ONLY) PER ANNUM FOR LAST THREE FINANCIAL YEARS ENDING 31-03-2007.

F-2 VENDOR SHOULD HAVE EARNED PROFIT IN AT LEAST ONE YEAR DURING LAST THREE FINANCIAL YEARS ENDING 31-03-2007. VENDOR SHOULD POSSESS POSITIVE NET WORTH AS ON THE LAST FINANCIAL YEAR ENDING 31-03-2007.

VENDOR SHOULD SUBMIT AUDITED BALANCE SHEET AND PROFIT & LOSS ACCOUNT FOR THE ABOVE PERIOD IN SUPPORT OF POINT F-1 & F-2. IN CASE, AUDITED BALANCE SHEET AND PROFIT & LOSS ACCOUNT FOR THE FINANCIAL YEAR ENDING 31-03-2007 IS NOT AVAILABLE, THE BIDDER SHOULD SUBMIT THE SAME FOR THREE FINANCIAL YEARS ENDING 31-03-2006.

GENERAL

G-1 ACCEPTANCE OF CUSTOMER M/S IOCL, HALDIA IS A PRE-REQUISITE FOR CONSIDERATION OF THE BID.

G-2 PROOF OF VALID PAN AND P.F. ACCOUNT NEED TO BE PRODUCED.

G-3 VENDOR SHOULD BE REGISTERED / WORKED OR WORKING WITH BHEL /NTPC/CPSUS/POWER GENERATING COMPANIES AS ERECTION VENDOR.

PRE BID MEETING WITH THE BIDDERS ON 27/09/2007 -TCN-02

MATERIALS MANAGEMENT AND ERECTION, TESTING AND COMMISSIONING OF 1X20 MW FRAME-5, GTG SET & OTHER STATION AUXILIARIES INCLUDING PAINTING ETC AT IOCL , HALDIA, EAST MIDNAPUR, WEST BENGAL.

TENDER DOCUMENT NO : PSER:SCT:HLD-T797:07

S.N.	Reference clause of Tender document	Existing provision	Bidder's Query	BHEL's clarification
1	ANNEXURE-I		Generator weight & assembly	Generator weight is approximately 68 MT and shall reach site as single assembly
2	ANEEXURE-I		Whether insulation of bypass duct pieces shall have to be done at site or it will be supplied duly insulated	BHEL indicated that the same will be supplied duly insulated. However, joints got to insulated by the bidder as per procedure. This is based on the practices so far done. However, In case of any change, the same shall have to be carried out by the bidders without any financial implication to BHEL.
3	6.5	BHEL shall not provide any crane or hydra or truck, trailer including operator free of cost to the contractor. It is the prime responsibility of the contractor to arrange the same. List of T & P's are mentioned in details to be provided by the contractor in the later stage of this spec. However, if crane, hydra is available with BHEL, it can be given to the contractor on chargeable basis inclusive of operator charges.	As per annexure-II, it has been mentioned that all the cranes are in the scope of BHEL. This provision is contradictory to the provision with respect to clause no.6.5 of tender.	BHEL indicated that in regard to cranes, at least one hydra having capacity of 12T/14T shall have to be bought by the bidders. BHEL shall provide cranes free on sharing basis as per Annexure-II. In regard to other tools and plants, the tender terms shall hold good.
4	4.4	BHEL shall carry out the final finish grouting of all the equipment covered under the scope of this contract, final adjustment of foundation level, dressing of foundation surfaces and cementing of grouting the finished surfaces		BHEL indicates that the finish grouting along with supply of special grout materials like conbextra GP-2 or otherwise, as prescribed by the designer shall be in the scope of the bidder.
5	ANNEXURE-I	IBR PIPING	There is mention of IBR piping in the NIT in Annexure-I. Whether the same is in the scope of the bidder	BHEL indicated that the same is within the scope of the bidder.