



भारत हेवी इलेक्ट्रिकल्स लिमिटेड

Bharat Heavy Electricals Limited

(A Govt. of India Undertaking)

Power Sector, Western Region,
345, Kingsway, Nagpur - 440 001

PHONE:-3048600-604 FAX:-0712- 3048605/3048698/3048699

Ref: BHE/PW/PUR/SLT-CWP/522/Corrigendum-03

Date : 15.10.2007

To

ALL BIDDERS

SUB : Corrigendum-03 to Tender Specification No: BHE/PW/PUR/SLT-CWP/522

JOB : COLLECTION OF MATERIALS FROM BHEL/CLIENT'S STORES/STORAGE YARD INCLUDING LOADING; TRANSPORTATION TO SITE; ERECTION, TESTING, ASSISTANCE FOR COMMISSIONING, HANDING OVER ETC OF MAIN CIRCULATING WATER, CCW PIPING AND DRINKING WATER PIPELINES WITH FITTINGS, VALVES, SUPPORTS ETC AT 2 X 125MW SURAT LIGNITE POWER PLANT (EXPANSION UNIT 3 & 4) , GUJARAT INDUSTRIES POWER COMPANY LIMITED, SURAT LIGNITE POWER PLANT, VILLAGE-NANI NAROLI, TAL- MANGROL, DIST- SURAT, GUJARATE

Please refer Tender Specification for the subject detailed above.

The following clarification is hereby given to queries raised by some bidders

QUERY 1 :

Sec 4, SCC, 4.8.1 :- BHEL will supply pipes with internal surfaces cement concrete coated for pipes >1000mm dia. However, Sec 4, SCC, 4.9 states that internal surface for CW Buried piping of dia > 1000mm has to be blast clean to SA 2 1/2 & painted with Coal tar primer and finish paint with coal tar epoxy.

Please clarify whether this surface preparation for internal surface is required along with painting as indicated above.

CLARIFICATION TO QUERY 1:

Surface preparation for internal surface and painting of outside surface is not required .

QUERY 2 :

Sec 4, SCC, 4.8.2 & 4.8.3 :- The pipes will be supplied red oxide coated for protection both outside and inside. However, Sec 4, SCC, 4.9 states that external surface for CW over ground of dia > 1000mm & dia < 1000mm shall be blast cleaned to SA 2 1/2 and painted with epoxy polyamide resin based ROZP followed by intermediate coat.

Please clarify whether this surface preparation & painting of primer & intermediate coat is applicable for external surface of Over ground piping. Also, clarify whether the external surface for buried piping has to be power tool cleaned and painted with ROZP.

CLARIFICATION TO QUERY 2:

Pipes supplied will be with one coat of redoxide for protection during storage only. Surface preparation & painting of primer & intermediate coat is applicable for external surface of Over ground piping. External surface for buried piping has to be as per Sec 4 , 4.8.3

Last Date for Tender submission has been rescheduled to 12.00 hrs on **20/10/2007** and the Technical Bids shall be opened on the same day i.e.20/10/2007 @ 12.30 hrs

This letter is hosted as file titled "**Corrigendum-03 (Clarification & Time Extn-522)**" in BHEL web site (www.bhel.com→Tender Notifications → View Corrigendum).

All other Terms and conditions of the Tender Specification shall remain unaltered unless expressly amended by BHEL in writing.

Bidders are requested to submit as a part of Technical Bid, a copy of this corrigendum duly countersigned by the authorized signatory and stamped with the Official seal as a token of Bidder's unqualified acceptance of this corrigendum.

Thanking you,
Yours faithfully,

DGM (Purchase)