



# BHARAT HEAVY ELECTRICALS LIMITED

## Industrial Valves Plant



Goindwal Sahib –143 422 (TARN TARAN, PUNJAB, INDIA)

<b>ENQUIRY - Corrigendum 1</b>	Phone: +91 1859 223381 +91 1859 222002, 36, 39 Extn: 117 Fax : +91 1859 222 061 Email : srk@ivp.bhel.co.in
--------------------------------	---

<b>NIT No. 3589</b>	<b>Enquiry No:</b>  <b>78039</b>	<b>Enquiry Date:</b>  <b>12.10.2007</b>	<b>Due date for submission of quotation:</b>  <b>13.11.2007</b>
You are requested to quote the enquiry no date and due date in all your correspondences. This is only a request for quotation and not an order			

<b>Details of Corrigendum</b>	
Cl. No.	The following clauses of the Technical Specifications of ROTARY SREW COMPRESSOR have been amended and detailed as under
<b>4.2</b>	415V, 50Hz, 3 Phase, 3 wire supply will be provided at one point in/near compressor house. Control voltage requirements shall be derived by the supplier by providing suitable starter/control panels (the power supply may fluctuate + or – 10% from specified voltage and + or – 3% from specified frequency)
<b>6.1</b>	Electric motor suitable for 415V, 50 Hz, 3 Phase, 3 wire supply continuous rating, Squirrel cage induction type, Class F insulation and protection IP55.
<b>6.5</b>	Suitable LT motor star delta starter with motor protection controls to be included.
<b>The due date for submission of quotation has been extended from 13.11.2007 to 26.11.2007</b>	
<b>All other terms and conditions and specifications as published in the NIT 3589 remain unaltered</b>	

Tenders should reach us before 15:00 hours on the due date Tenders will be opened at 15:30 hours on the due date Tenders would be opened in the presence of the tenders who have submitted their offers and who may like to be present	Yours faithfully <b>For BHARAT HEAVY ELECTRICALS LTD</b>  Manager / MM
--	---