



## Bharat Heavy Electricals Limited

(A Government of India Undertaking)

### Power Sector – Eastern Region

Plot No. 9/1, Block-DJ, Salt Lake City,  
Kolkata – 700 091 (INDIA)

Phone no. 033 - 2321 1690 / 1691

Fax : 033 - 2321 1960

Web : [www.jantermanter.com](http://www.jantermanter.com) / [www.bhel.com](http://www.bhel.com)

REF : PSER: PUR: PMX: 164: 110:01:

DATE : 13-11-2007

M/s \_\_\_\_\_

\_\_\_\_\_

#### TCN (Tender Change Note) – 01

Dear Sir,

SUB : DESIGN, MANUFACTURING, SUPPLY, RECEIPT AT SITE, ERECTION, SITE PAINTING ETC. AND HANDING OVER OF THREE NOS. REMOVABLE/RE-ERECTABLE TYPE PREFABRICATED STEEL STORE SHED AS PER ENCLOSED PLAN AT 4X150 MW NEEPCO, KAMENG HEP PROJECT, ARUNACHAL PRADESH.

Ref: Tender specification no. **PSER: PUR: PMX: 164: 110**

With reference to above, it may please be noted that the due date of offer submission of above mentioned tender has been extended up to 21-11-2007 (15-00 Hrs). Also please find enclosed as Annexure-I -Clarification on technical points, which emerged out of Pre-Bid meeting to be considered for submission of offer. All other terms & conditions of the tender shall remain unchanged.

Thanking you

Yours faithfully,  
For & on behalf of BHEL,

Encl: Annexure-I

(Sr. Manager – PUR)

Contact Details : Tel. No. : 033-2321-6130  
(extn.-3228)  
033-2321-1690  
Fax No. : 033-2321-1960  
E-mail : [ppd@bhelsr.co.in](mailto:ppd@bhelsr.co.in)

**Annexure-I**

**TCN-01**

**AA)** Following points of Tender document no **PSER: PUR: PMX: 164:110** dated **22.10.2007**, which emerged out of Pre-Bid meeting held on 06/11/07 may please be considered while quoting:

- **All designs have to be carried out as per relevant IS code**
- **Wind Velocity to be considered as 47 meter per second.**
- **A seismic co-efficient of 0.10 to be considered in the design. ZONE - iv to be considered.**
- **Normal monthly rainfall to be considered as 1217 mm.**