



BHARAT HEAVY ELECTRICALS LIMITED
TIRUCHIRAPPALLI 620 014
OUTSOURCING DEPARTMENT

NIT: 2025OVM001

NIC TENDER ID: 2025_BHEL_47662_1

DUE DATE CORRIGENDUM & CLARIFICATIONS

1. **Due Date for Offer Submission is extended till 15.05.2025 – 11.00 A.M**

2. **Clarifications:**

1. **Project-wise Tank & Dished End Requirements shall be as below:**

RS	PROJECT	WT (MT)		RS	PROJECT	WT (MT)
RS01	Mirzapur	9.375		RS02	Talcher	9.000
RS01	Mirzapur	9.375		RS02	Lara	24.000
RS01	APL Kawai	9.375		RS02	Singrauli New	24.000
RS01	APL Kawai	9.375		RS02	Talabira	24.000
RS01	APL Kawai	9.375		RS02	Talabira	24.000
RS01	APL Kawai	9.375		RS02	Talabira	24.000
RS01	MEL Mahan-II	9.375		RS02	Yamunanagar	24.000
RS01	MEL Mahan-II	9.375		RS02	DVC Koderma	24.000
				RS02	DVC Koderma	24.000
				RS02	Sipat	24.000

2. **Clarification on PBG Scope (as per NIT 2025OVM001, Section 1 - T&C, Clause 18.9):**

Clause 18.9 under PERFORMANCE BANK GUARANTEE (PBG) shall be read as below:

“The Performance Bank Guarantee (PBG) shall remain valid to cover any liabilities arising from defects due to material, workmanship, or omissions attributable to the Vendor during the guarantee period. In the event that the Vendor fails to complete the required rework at the project site within the stipulated time, BHEL shall undertake the rework at its discretion. The associated costs shall be recovered from the PBG, from any amounts payable to the Vendor, or through both means.”

3. As per drawing **4-80-468-A0267**, the raw material thickness is specified as **25 mm**. Therefore, a minimum thickness of **20 mm** at the bend portion of the dished end shall be maintained.
4. Material specification for shell plate shall be **IS2062E250A** in line with the GMS – Section IID.
5. **SA516 Gr70** plates can be substituted in place of **SA515 Gr70**.

“All other Terms and Conditions of NIT remains unchanged”

“Participation in NIT 2025OVM001 by Vendor shall be construed as acceptance to all T&Cs including corrigendum”