


BHEL-PEM-MAUX
PRE-QUALIFICATION CRITERIA

	PACKAGE: HVAC FOR FGD SYSTEM PROJECT: 4 X 210MW + 3 X 500MW KAHALGAON STPP – FGD SYSTEM PRE-QUALIFICATION REQUIREMENT	PE-PQ-481-(571-13000-A)-A001	
		DATE	27/06/2023
		REV NO	00

1.	<p>Supplier should have designed, supplied, erected and commissioned at least one (1) number of either of the following systems: -</p> <ul style="list-style-type: none"> AC system: - Minimum installed capacity of AC system shall be 30 TR (Chiller/Precision package AC/Condensing unit/Package AC/ Ductable Split AC) along with associated ducting work etc. for complete Air Conditioning system. <p style="text-align: center;">or</p> <ul style="list-style-type: none"> Ventilation System: - Minimum installed capacity of single UAF / Air Washer / Fan Filtration Unit with Centrifugal Fan, shall be 50,000 CMH along with associated ducting work etc. for complete Ventilation system.
2.	<p>The supplier has to submit following supporting documents meeting above mentioned pre-qualifying requirement.</p> <p>Copy of minimum one(1) performance certificate (in English) from end user along with copy of related Purchase Order (PO) or Letter of Intent(LOI) or letter of Award(LOA) or Work Order (WO) specifying that the product is running successfully for one (1) year from date of commissioning as on date of bid opening in support of PQR clause at S. No. 1.0 above.</p>
3.	<p>Bidder shall submit design documents to substantiate technical parameters specified in PQR, if the same is not mentioned in performance certificate / purchase order.</p>
4.	<p>Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.</p>
5.	<p>Notwithstanding anything stated above, CUSTOMER/BHEL reserves the right to assess the capabilities and capacity of the Bidder to perform the contract, should the circumstances warrant such assessment in the overall interest of the Employer.</p>
6.	<p>Consideration of offer shall be subject to customer's approval of bidders, if applicable.</p>
7.	<p>After satisfactory fulfilment of all the above criteria / requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.</p>
8.	<p>The bidder shall meet PQR based on its own credentials. Bid from joint venture (JV) company / Consortium bid is not acceptable.</p>