


TDBT2 EPC / S	KARNATAKA POWER CORPORATION LTD	VOLUME C 1 - V
	TITLE PART E : OUTDOOR CIVIL WORKS	SECTION: D4.6 SHEET 6 OF 6
	<p>3.2.2 PCC paving of nominal mix 1:3:6, 100 mm thick shall be provided as paving inside fuel oil tank farm; The paving shall be laid over well compacted ground and laid to slope towards peripheral drain.</p> <p>3.3 Stone Aggregate paving</p> <p>3.3.1 Entire switch yard shall be provided with 75 mm paving of 40 mm size stone aggregate on top and 75 mm paving of 20 mm single size stone aggregate below. Before laying the paving, the ground surface shall be treated with anti weed chemicals as per manufacturer recommendations.</p> <p>3.3.2 For auxiliary transformer yard, paving of stone aggregate of 75 mm thick using 20 mm single size aggregate shall be provided after compacting the under bed and treating with anti-weed chemicals.</p>	
	BTPS Unit 2 071206	