

	PRE-QUALIFICATION REQUIREMENTS FOR TREFOIL CLAMPS	PE-PQ-999-507-E005
		REVISION NO. 03 DATE 03/06/2021
		Page 1 of 2

ITEMS: Trefoil Clamps

Vendor may be considered for evaluation for one or more of the following type of trefoil clamps:

Type 1 – Nylon – 6 material

Type 2 – Aluminium alloy




Type 3 – FRP

SCOPE: Supply: YES; Erection & Commissioning: NO;

1	Manufactured & supplied applicable type of trefoil clamps for single core cable of minimum overall dia. of 50 mm.
2	Availability of type test certificates (for short circuit at 125kA peak or above) for the applicable type of trefoil clamps.
3	Vendor should have in-house manufacturing & testing facility for applicable type of trefoil clamps.
4	Manufacturing capacity of 10000 nos. per month for the applicable type of trefoil clamps.
5	Manufactured & supplied at least 20000 nos. trefoil clamps of applicable type in one or more orders.
6	Minimum two (2) nos. purchase orders for trefoil clamps of applicable type shall be submitted which should not be more than five (5) years old from the date of application for registration or date of techno-commercial bid opening (as applicable) for establishing continuity in business.

Notes (General points of PQR):

1. Offers of the JV companies/ Joint Bidders/ bidders having collaboration/ licensing agreement/ MOU/ Indian subsidiaries shall be evaluated as follows:
 - a. If bidder happens to be an Indian subsidiaries of foreign OEM, then the credentials of the foreign OEM can also be considered for meeting PQR.
 - b. If bidder happens to be the Joint Venture Company, then the credentials of any of JV partners can be also considered for meeting PQR.
 - c. If bidder happens to bid jointly with their partner, then credentials of both the partners will be considered for meeting PQR as per distribution of the work. In all such cases, lead bidder as specified in bid documents shall be responsible for overall execution of the contract and all guarantee/ warranty.

PREPARED BY  Digitally signed by Sujit Kumar Sethy DN: cn=Sujit Kumar Sethy, o=BHEL, ou=PEM, email=sujitkumarsathy@bhel.in, c=IN Date: 2021.06.03 12:46:55 +05'30' SUJIT KUMAR SETHY, DY. MANAGER	REVIEWED BY  Digitally signed by okumar DN: cn=okumar, o=bhel, ou=bhel, email=okumar@bhel.in, c=IN Date: 2021.06.03 15:38:18 +05'30' OMKAR KUMAR, DGM	APPROVED BY  Digitally signed by Debasisa Rath DN: cn=Debasisa Rath, o=BHEL, ou=BHEL, email=debameena@gmail.com, c=IN Date: 2021.06.06 21:13:58 +05'30' DEBASISA RATH, AGM (DH)
---	---	---

	PRE-QUALIFICATION REQUIREMENTS FOR TREFOIL CLAMPS	PE-PQ-999-507-E005
		REVISION NO. 03 DATE 03/06/2021
		Page 2 of 2

- d. If bidder happens to be the having valid collaboration agreement/ MOU/ licensing agreement with some other company, then the credentials of collaborator/ MOU partner/ licensing company can also be considered for meeting PQR.

Note: If bidder(s) qualifies on the basis of credentials of his principal/ JV partner/ Collaborator/ joint bidder etc., then the principal/ JV partner/ Collaborator/ MOU partner/ joint bidder shall be responsible for overall design vetting and warranty/ guarantee of the package. The scope matrix clearly defining their respective roles including design vetting, manufacturing of critical component, E&C etc. etc. and warranty/ guarantee shall be submitted along with the offer.

- Bidder to note that the arrangement of bidding (joint bid partners/ collaborator/ MOU partner/ licensing company etc.) once offered to BHEL as a part of bidding documents cannot be changed till the execution of the project.
- Consideration of offer shall be subject to customer's approval of bidders, if applicable
- Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a self- attested English translated document should also be submitted.
- Any other project specific requirement shall be as per Annexure-I and bidder shall submit relevant supporting documents. Bidder to meet criteria as stated above and as per Annexure-I.
- Notwithstanding anything stated above, BHEL reserves the right to assess the capabilities and capacity of the bidder to perform the contract, should the circumstances warrant such assessment in the overall interest of BHEL.
- After satisfactory fulfilment of the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of tender.

<p>PREPARED BY</p> <p>Sujit Kumar Sethy</p> <p><small>Digitally signed by Sujit Kumar Sethy DN: cn=Sujit Kumar Sethy, o=BHEL, ou=PEM, email=sujitkumarsethy@bhel.in, c=IN Date: 2021.06.03 12:47:21 +05'30'</small></p> <p>SUJIT KUMAR SETHY, DY. MANAGER</p>	<p>REVIEWED BY</p> <p>okumar</p> <p><small>Digitally signed by okumar DN: cn=okumar, o=bhel, ou=bhel, email=okumar@bhel.in, c=IN Date: 2021.06.03 15:40:42 +05'30'</small></p> <p>OMKAR KUMAR, DGM</p>	<p>APPROVED BY</p> <p>Debasis a Rath</p> <p><small>Digitally signed by Debasis Rath DN: cn=Debasis Rath, o=BHEL, ou=bhel, email=debasisa@gmail.com, c=IN Date: 2021.06.06 21:14:38 +05'30'</small></p> <p>DEBASISA RATH, AGM (DH)</p>
--	---	--

**BHEL PEM ELECTRICAL
PRE-QUALIFYING REQUIREMENTS FOR TREFOIL CLAMPS
ANNEXURE – I
PROJECT SPECIFIC CRITERIA AGAINST ENQUIRY
PROJECT: 1X660 MW BHUSAWAL TPS UNIT 6**

-NIL-

Devendra Singh
[Dy. Manager]

Kavita Gupta
[Manager]

Omkar Kumar
[Section Head]

Debasisa Rath
[DH-Electrical]