


TECHNICAL PRE-QUALIFYING REQUIREMENT

Bidder should be manufacturer of 220kV class GIS. Bidder needs to meet the following technical requirements as stipulated here under:

1. The bidder or its Collaborator/Parent/Principal/JV Company/Technology Partner should have successful experience in designing, manufacturing, supply, supervision of installation, testing and commissioning of Gas Insulated Switchgear (GIS) having rated voltage of 220kV class or higher with current rating of 2000A or above and short circuit current rating of 40kA or above in last 10 years, as on 31.12.2019.
2. The GIS so manufactured should have been in **successful operation**# at least at three (3) power stations/ substations.


Successful operation means Performance Certificate issued by customer without any adverse remarks.


15/12/21

PREPARED BY


15.12.21.

REVIEWED BY


15/12/21

APPROVED BY