


Technical PQR
PRE-QUALIFICATION CRITERIA

	PROJECT: 5X800 MW YADADRI TPP (STAGE 2) PRE-QUALIFICATION REQUIREMENT- VENTILATION SYSTEM (PART-II)	PE-PQ-417-554-A002	
		DATE	Jun 2023
		REV NO	00

1	<p>Supplier should have completed at least one (1) number of each of the following works: -</p> <ul style="list-style-type: none"> i) Supplied and erected air distribution ducting of minimum 5000 Sqm. in single contract <li style="text-align: center;">and ii) Erected and commissioned at least one (1) number Air washer unit (AWU)/Unitary Air Filtration (UAF)/ Air handling unit (AHU) having minimum capacity of 80,000 Cum./Hr. or more. <p>Requirements mentioned at S. no. i) & ii) can be in different contracts</p>
2	<p>Supplier has to submit following supporting documents meeting above mentioned pre-qualifying requirement.</p> <ul style="list-style-type: none"> i) Copy of minimum one (1) work completion certificate/ commissioning certificate/ commissioning protocol (in English) from end user/ Contractor for requirement mentioned at S. No. 1 i) & ii) ii) Copy of related Purchase Order (PO) or Letter of Intent (LOI) or letter of Award (LOA) or Work Order (WO) for requirement mentioned at S. No. 1 i) & ii)
3	<p>Bidder shall submit relevant supporting documents to substantiate technical parameters specified in PQR, if the same is not mentioned in completion certificate / purchase order.</p>
4	<p>Bidder to submit all supporting documents in English. If documents submitted by bidder are in language other than English, a self-attested English translated document should also be submitted.</p>
5	<p>Notwithstanding anything stated above, CUSTOMER/BHEL reserves the right to assess the capabilities and capacity of the Bidder to perform the contract, should the circumstances warrant such assessment in the overall interest of the Employer.</p>
6	<p>Consideration of offer shall be subject to customer's approval of bidders, if applicable.</p>
7	<p>After satisfactory fulfilment of all the above criteria/ requirement, offer shall be considered for further evaluation as per NIT and all the other terms of the tender.</p>
8	<p>If the bidder is not able to meet the requirements at sl no 1 based on its own credentials, the bidder may also qualify provided that the bidder shall be required to furnish a letter of support (as per annexure I) from consortium partner who meets the qualification requirements stipulated in sl. no. 1 above. The type of bid (whether solo or consortium) to be declared at the time of bid submission and cannot be changed after bid opening.</p>



**Power Sector – PEM Noida
LETTER OF SUPPORT
(For Open Tender)**

Sheet 1 of 1

PROJECT: 5x800MW YADADRI STAGE II

PACKAGE: VENTILATION SYSTEM PART 2

DEPARTMENT:- MECHANICAL AUXILIARY

REVISION:- REV. 00

ANNEXURE - I

LETTER OF SUPPORT FOR SATISFACTORY PERFORMANCE OF VENTILATION SYSTEM

To:

Sub: Letter of Support submitted from..... (name of the Consortium Partner) undertaking the responsibility for satisfactory performance of VENTILATION SYSTEM

Dear Sirs,

1. In accordance with the Award of the Contract by BHEL, PEM, Noida-201301 to M/s.....(name of the vendor) , we the aforesaid Consortium Partner, (M/s.....) shall be fully responsible for the satisfactory performance of the VENTILATION SYSTEM of
2. Further, the manner of achieving the objective set forth in point 1 above shall be as follows, for VENTILATION SYSTEM
 - a) We shall be fully responsible for erection & commissioning and extending all necessary support for putting into satisfactory operation and carrying out the Guarantee Tests for VENTILATION SYSTEM to the satisfaction of the employer.
 - b) We shall assist in site erection, commissioning and final testing (as and when necessary) of the VENTILATION SYSTEM.
3. We, Consortium Partner do hereby undertake and confirm that this Letter of Support shall be valid shall be valid up to the end of the defect liability period of contract.

Signature of the Authorised Representative:

For M/s
(Consortium Partner)

Name

Designation

Date.....

Common Seal of the Company



PRE - QUALIFYING REQUIREMENTS
Financial PQR

PROJECT: 5 x 800 MW Yadadri TPS

PACKAGE: Ventilation System

CRITERIA FOR EVALUATION - FINANCIAL :

Average annual financial turnover during the last Three Financial Years should not be less than
Rs. One Crore Eighty Four Lakh only

Amount (in Rs.)
1,84,00,000.00

Notes:-

a) The bidder has to submit financial accounts (audited, if applicable comprising of Audit report, Balance Sheet, Profit & Loss A/c Statement and Notes/Schedules pertaining to Turnover/Sales/Revenue), for last three years (or from the date of incorporation, whichever is less) as on tender due date to review the above criteria. In case the incorporation of vendor is less than 3 years, average annual financial turnover shall be calculated based on available information as below:-

i) If the accounts are available for ≤ 1 Financial Year, the Average Annual Turnover shall be calculated based on available information divided by 1 (One).

ii) If the accounts are available for >1 but ≤ 2 Financial Years, the Average Annual Turnover shall be calculated based on available information divided by 2 (Two).

iii) If the accounts are available for >2 but ≤ 3 Financial Years, the Average Annual Turnover shall be calculated based on available information divided by 3 (Three).

b) Foreign bidder is to submit a latest report from reputed third party business rating agency like Dun & Bradstreet, Credit reform etc. in addition to the documents mentioned at point (a) above for review of above criteria.

c) Other Income shall not be considered for arriving at Annual Turnover/Sales. For evaluation purpose, turnover figure excluding taxes shall be considered.

d) For evaluation of foreign bidder, exchange rate (TT selling rate of SBI) as on scheduled date of tender opening (Part-I bid in case of two part bid) shall be considered.