

VENDOR QUALIFICATION REQUIREMENTS:**PRESSBOARD for 765 KV Transformer/ Reactors (for POWERGRID Projects)**


SL. No.	DESCRIPTION	VENDOR'S REMARKS (Y/N)
1.	i) Bidder must be approved by PGCIL QA & I for supply of the item for 765 kV Transformer/Reactor as on BID opening date ii) Vendor should have experience for successfully supplying of materials for minimum 2 nos. 765 kV class transformer/ reactor. Bidder to furnish valid Powergrid approval and valid un-priced Purchase orders and User certificates for same PO for successful use of pressboard or pressboard components in 765 kV & above class Transformer/ reactor. Purchase orders and user certificates should not be older than 5 years from bid opening date.	

Note-


1. Relevant documentary proof for above points must be furnished along with bid for scrutiny.
2. VQR shall be applicable for all suppliers.
3. All documents must be in Hindi or English only.
4. BHEL reserves the right to verify information and documents submitted by the vendor. In case the information is found to be false/ incorrect, the offer shall be rejected.




AGM (MRX)
MISCC
Member



AGM (TRM-P)
MISCC
Member



AGM (QTR)
MISCC
Member



AGM (TRE)
MISCC
Chairman