

1X125MW SENEGAL TPP


VOLUME – IIB

TECHNICAL SPECIFICATION FOR AIR TRAPS

SPECIFICATION NO: PE-TS-315-100-M011



**BHARAT HEAVY ELECTRICALS LIMITED, POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
NOIDA, INDIA**

	PREAMBLE		SPECIFICATION NO. PE-SS-999-100-Q001
			VOLUME
			SECTION
			REV. NO. DATE: 26/08/2011
	SHEET 1 OF 1		

1.0 The tender document contains three (3) volumes. The bidder shall meet the requirements of all the three volumes.

1.1 **Volume-I** (CONDITIONS OF CONTRACT)

This consists of four parts as below:-

- Volume-IA : This part contains instructions to bidders for making bids to BHEL.
- Volume-IB : This part contains general commercial conditions of the tender & includes provision that vendor is responsible for the quality of item supplied by their sub-vendors.
- Volume-IC : This part contains special conditions of contract.
- Volume-ID : This part contains commercial conditions for erection & commissioning site work, as applicable.

1.2 **Volume-II** TECHNICAL SPECIFICATIONS

Technical requirements are stipulated in Volume-II which comprises of :-

- Volume-IIA : General Technical Conditions
- Volume-IIB : Technical Specification including Drawings, if any.

1.2.1 **Volume-IIB**

This volume is sub-divided into following sections:-

- Section-A : This section outlines the scope of enquiry.
- Section-B : This section provides "Project Information".
- Section-C : This section indicates technical requirements specific to the contract, not covered in Section-D.
- Section-D : This section comprises of technical specifications of equipments complete with data sheet A, B and C.

Data Sheet - A Specifies data and other requirements pertaining to the Equipment.


Data Sheet - B Specifies data to be filled by the bidder (Data Sheet-B is contained in Volume-III).

Data Sheet -C Indicates data/documents to be furnished after the award of contract as per agreed schedule by the vendor (as applicable).

1.2.2 **Volume-III** (TECHNICAL SCHEDULES)


This volume contains technical schedules and Data Sheets-B, which are to be duly filled by the bidder and the same shall be furnished with the technical bid.

2.0 The requirements mentioned in Section-C / Data Sheets-A of section-D shall prevail and govern in case of conflict between the same and the corresponding requirements mentioned in the descriptive portion in Section-D

	TECHNICAL SPECIFICATION AIR TRAPS 1X125MW SENEGAL TPP		SPECIFICATION NO. PE-TS-315-100-M011
			VOLUME : IIB
			SECTION:
			REV. NO.: 00 DATE: 18.04.2014
	SHEET 1 OF 1		


CONTENTS

SECTION	TITLE
A	SCOPE OF ENQUIRY
B	PROJECT INFORMATION
C	SPECIFIC TECHNICAL REQUIREMENTS
D	STANDARD TECHNICAL SPECIFICATIONS
	AIR TRAPS
	<ul style="list-style-type: none"> ▪ STANDARD TECHNICAL SPECIFICATION FOR AIR TRAPS ▪ DATA SHEET – A ▪ QUALITY PLAN
	DATA SHEET – C

	TECHNICAL SPECIFICATION AIR TRAPS 1X125MW SENEGAL TPP		SPECIFICATION NO. PE-TS-315-100-M011	
			VOLUME : IIB	
			SECTION: A	
			REV. NO.: 00	DATE: 18.04.2014
			SHEET 1	OF 1

SECTION-A

SCOPE OF ENQUIRY

	TECHNICAL SPECIFICATION AIR TRAPS 1X125MW SENEGAL TPP	SPECIFICATION NO. PE-TS-315-100-M011	
		VOLUME : IIB	
		SECTION: A	
		REV. NO.: 00	DATE: 18.04.2014
		SHEET 1	OF 1


SCOPE OF ENQUIRY

1. SCOPE

This enquiry covers the Design, Manufacture, Inspection & Testing at vendor's and/or his sub-vendor's works, proper packing and delivery to site of air traps complete with all accessories as per the requirements mentioned in different sections of the specification for **1X125MW SENEGAL TPP**.


2. GENERAL TECHNICAL INSTRUCTIONS

- a) It is not the intent to specify herein all the details of design and manufacture. However the equipment shall conform in all respects to high standards of design, engineering and workmanship, and shall be capable of performing the required duties in a manner acceptable to Engineer/ Owner, who will interpret the meaning of drawing and specifications, and shall be entitled to reject any component or material, which in his judgement is not in full accordance herewith.
- b) The omission of specific reference to any component/ accessories necessary for the proper performance of air traps shall not relieve the bidder of the responsibility of providing such facilities to complete the supply of air traps at quoted prices.
- c) Design/ drawings/ data sheets etc. shall be subject to approval of BHEL as per specification, in the event of order.
- d) BHEL's / customer's representative shall be given access to the shop in which the equipment are being manufactured or tested and all test records shall be made available to him.
- e) The equipment covered under this specification shall not be despatched unless the same have been finally inspected, accepted and shipping release issued by BHEL.

	TECHNICAL SPECIFICATION 1X125MW SENEGAL TPP AIR TRAPS		SPECIFICATION NO. PE-TS-315-100-M011	
			VOLUME : IIB	
			SECTION: B	
			REV. NO.: 00	DATE: 18.04.2014
			SHEET 1	OF 1

SECTION-B


PROJECT INFORMATION

	TECHNICAL SPECIFICATION AIR TRAPS 1X125MW SENEGAL TPP		SPECIFICATION NO. PE-TS-315-100-M011	
			VOLUME : IIB	
			SECTION: B	
			REV. NO.: 00	DATE: 18.04.2014
			SHEET 1	OF 1

PROJECT INFORMATION

The bidder shall acquaint himself by a visit to the site, if felt necessary, with the conditions prevailing at site before submission of the bid. The information provided in this section will be for general guidance and shall not be contractually bidding on BHEL/OWNER. All relevant site data/information as may be necessary shall have to be obtained /collected by the bidder.

The proposed 1 x 125 MW Sendou Coal Fired Power Plant Senegal Project would be set up by COMPAGNIE D'ELECTRICITE DU SENEGAL, Senegal. The site, in Sendou ,which is about 30km from Dakar and 10km from Rufisque. Site is near a highway (2km approx from inside) and about 1 km from seashore.

	TECHNICAL SPECIFICATION 1X125MW SENEGAL TPP AIR TRAPS		SPECIFICATION NO. PE-TS-315-100-M011	
			VOLUME : IIB	
			SECTION: C	
			REV. NO.: 00	DATE: 18.04.2014
			SHEET 1	OF 1

SECTION-C

SPECIFIC TECHNICAL REQUIREMENTS

	SPECIFIC TECHNICAL REQUIREMENTS AIR TRAPS		SPECIFICATION NO. PE-TS-315-100-M011
			SECTION C
	REV. NO.: 00		DATE: 18.04.2014
	Sheet 1 of 2		

1. GENERAL

- 1.1 The air traps shall meet the technical requirements and conform to the standard technical specification and Data sheet A of Section D. In addition, the requirements of this Section-C shall also be complied with. However, wherever the details given in standard technical specification of Section-D and Data sheet- A are different, the requirements of Data sheet- A shall prevail. Similarly in the event of contradictions between Section –C & Section –D/ Data sheet A, Section –C will prevail.
- 1.2 The technical requirements for air traps shall, in general, be as per the attached standard technical specification for Air traps, and Data sheets A of Vol. II B Section D.

2. SCOPE OF SUPPLY

- 2.1 The air traps along with strainer shall be supplied as per Data sheets A of Section D. For detail refer the same.
- 2.2 Commissioning spares, if any.
- 2.3 Mandatory spares as applicable depending upon the project requirement.
- 2.4 Various drawings, datasheets, operation and maintenance manuals etc. as specified in Data Sheet-C.

3. EXCLUSIONS:


Erection & Commissioning of equipment at site.

4. QUALITY ASSURANCE

The Quality Plans enclosed with this specification specify minimum quality control requirement. During contract stage vendor shall furnish these Quality Plans duly signed & stamped for their compliance. Quality plans shall be approved by BHEL and customer (If necessary). All inspection and testing shall be carried out by BHEL and CUSTOMER (if necessary). In case inspection is by both BHEL and CUSTOMER, then the inspection can be carried out jointly or separately, which will be informed later.

5. GALVANIZING REQUIREMENT (FOR CARBON STEEL):

Carbon steel bodies and internals shall be thoroughly cleaned, pickled & rinsed as specified in IS: 2629. These shall then be hot dip galvanized as per IS: 2629. The minimum thickness of galvanizing shall be minimum 50 microns.

	SPECIFIC TECHNICAL REQUIREMENTS AIR TRAPS		SPECIFICATION NO. PE-TS-315-100-M011
			SECTION C
	REV. NO.: 00		DATE: 18.04.2014
	Sheet 2 of 2		

6 PACKING INSTRUCTIONS:

- Each trap shall be drained, cleaned, prepared and suitably protected in such a way so as to minimize the possibility of damage and deterioration during transit and storage.
- The trap shall be dispatched in total assembled form.
- Body ends shall be suitably sealed to protect them against damage during transit and storage.
- Trap Tag Nos. shall be incorporated in all the dispatch documents.
- Proper care shall be taken to avoid damage to the finished surface during transit.
- All the valves shall be as sea-worthy packed and of international standards. For more details please refer attached sea-worthy packing specification (PE-TS-888-100-A001).

7 SPARES


- Mandatory Spares:** ~~These shall be as per Data Sheet A.~~
- Recommended Spares:** ~~List of recommended spares for 3 year reliable operation along with the unit price shall be indicated in the schedule of prices for recommended spares enclosed in Volume III. Cost of Recommended spares shall not be included in the base price.~~
- Order for the spares may be placed simultaneously or otherwise at the option of purchaser.

8 DOCUMENTS TO BE SUBMITTED ALONG WITH OFFER

Bidder shall submit the following documents (enclosed in Vol III) duly filled, signed and stamped along with the bid:


- Compliance sheet
- Schedule of Deviations if any.
- Schedules of Price & Unit Price for each project.
- Schedule of declaration.

The above are the only documents which will be used for technical evaluation unless other documents are asked for during technical clarifications. Any other technical document enclosed with the bid shall be ignored for the purpose of technical evaluation. All other documents attached with the specification are for information of the vendor and no comments shall be marked on these.

	TECHNICAL SPECIFICATION 1X125MW SENEGAL TPP AIR TRAPS		SPECIFICATION NO. PE-TS-315-100-M011	
			VOLUME : IIB	
			SECTION: D	
			REV. NO.: 00	DATE: 18.04.2014
			SHEET 1	OF 1

SECTION-D

STANDARD TECHNICAL SPECIFICATION DATA SHEET – A QUALITY PLAN DATA SHEET – C

	STANDARD TECHNICAL SPECIFICATION FOR AIR TRAPS		SPECIFICATION NO. PE-SS-999-555-M011
			VOLUME . II B
			SECTION D
			REV. NO. 02
	DATE. 19-06-2012		SHEET 1 OF 2

1 GENERAL

This specification covers the design, materials, construction features, manufacture and testing of Air Traps along with Integral/External Strainers at Vendor's or/ and sub-Vendor's works inclusive of painting and packing requirements.

2 DESIGN REQUIREMENTS

All traps shall be suitable for removal of water from compressed air piping and shall be suitable for the service conditions i.e. flow, temperature and pressure under which they are required to operate. Those performing similar duties shall be interchangeable with each other unless otherwise specified.

3 CONSTRUCTION FEATURES:


- 3.1 The traps covered in the specification shall be of Ball Float Type/ Inverted Bucket Type with auto-drain arrangement conforming to supplier's own proven design and shall be with Integral/External Strainer designed suitably to prevent the internals of the trap from damage due to dirt etc.
- 3.2 The traps should be with internals easily accessible and replaceable.
- 3.3 Arrow showing inlet should be cast on the body of traps.
- 3.4 For ball float type traps, a balancing line connection shall also be provided at the top of the body.
- 3.5 A metallic (stainless steel plate 2mm thick) nameplate shall be fitted on each trap. Nameplate inscription required for each trap shall be indicated at the contract stage. Inscriptions shall be engraved 1 mm deep filled with enamel paint.

4 MATERIALS

- 4.1 The materials of construction of main parts of traps shall be specified in Data sheet-A.
- 4.2 The materials of construction of the remaining parts shall be suitable for the service conditions shall be subject to approval of the purchaser.
- 4.3 Materials used in manufacture of traps shall be of tested quality.

5 INSPECTION AND TESTS:

- 5.1 The items covered under this contract shall be subjected to inspection, testing and quality surveillance. The Inspection Agency shall, at all reasonable times have access to Vendor's works, Quality Control records and all facilities as reasonably required for carrying out the inspection and testing efficiently, and these shall be provided by the vendor free of cost.
- 5.2 The minimum NDT/testing and inspection requirements for traps shall be as per the attached Quality Plan. However, in case of order, final inspection and testing shall be carried out as per the final approved quality plan without any price implications.


	STANDARD TECHNICAL SPECIFICATION FOR AIR TRAPS		SPECIFICATION NO. PE-SS-999-555-M011	
			VOLUME . II B	
			SECTION D	
			REV. NO. 02	DATE. 19-06-2012
			SHEET 2 OF 2	

6 SURFACE PREPARATION AND GALVANIZING:

- 6.1 The surfaces of equipment to be galvanised shall be thoroughly cleaned of all grease, oil, loose mill scale, dirt, rust and any other foreign materials as mentioned in IS:2629.
- 6.2 Traps & Strainers bodies shall be hot dip galvanised as per IS:2629 after the necessary testing has been carried out. The minimum thickness of coating shall be 40 ~ 70 microns.

7 PROTECTION FOR DESPATCH


- 7.1 Traps shall be protected from external damage and sealed against the ingress of dirt.
 - 7.2 Ends of the traps shall be protected by means of polythene caps/rubber end protectors.
 - 7.3 All the traps shall be suitably packed in wooden cases in order to avoid damage during transit and also during storage at site.
- 8 Trap Tag Nos. shall also be incorporated in all the despatch documents.

	DATA SHEET-A AIR TRAPS 1X125MW SENEGAL TPP		SPECIFICATION NO. PE-TS-315-100-M011	
			VOLUME-IIB	
			SECTION : D	
			REV. NO.: 00	DATE: 18.04.2014
			Sheet 1 of 1	

S.NO.	UNITS	DATA/PARTICULARS
1	Type	Ball Float With External Y-Type Strainer
2	Size	25 NB
3	Quantity Of Traps (Along with Y-Type Strainer) Required Per Unit	17 NOS.
4	Total Quantity Required	17 NOS.
5	Max. Working Temp.	50 Deg. Cent.
6	Max. Working Pressure	10 KG/SQ.CM(g)
7	End Connections	Screwed BSP/IS554 Female Parallel
8	Mounting	Horizontal Pipeline
9	Matching Pipe	33.4x4.55


MATERIAL OF CONSTRUCTION

S.NO.	PART NAME	MATERIAL REQUIRED
1	Body and cover	Cast Carbon Steel as per ASTM A216 Gr.WCB
2	Valve, Valve seat	AISI 431(furnace hardened to 50 RC). Differential hardness Shall be maintained between seats
3	Float unit assembly, valve seat gasket, pivot frame, support frame and pivot pin	AISI 304
4	Bolts/Nuts	ASTM A193 Gr.B7/ASTM A194 Gr.2H
5	External Strainer	Body & cap-ASTM A216 Gr.WCB screen - SS to AISI 304- 20 mesh

		QUALITY PLAN		CUSTOMER: COMPAGNIE D'ELECTRICITE DU SENEGAL		PROJECT: 1x125 MW SENEGAL TPP		SPEC. NO : PE-SS-999-555-M011			
				BIDDER/VENDOR:		QP NO. PE-QP-999-555-M001		REV.01 DT.15.03.2014		SPEC. TITLE AIR TRAPS	
				SYSTEM		SERVICE AIR/ INSTRUMENT AIR		ITEM: BALL FLOAT AIR TRAP		SECTION VOLUME	
S.NO.	COMPONENT/ OPERATION	CHARACTERISTICS CHECKED	CATE- GORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY	REMARKS	
					CHECK				P	W	V


1.0	MATERIALS											
1.1	BODY, COVER	1.PHYSICAL & CHEM. PROPERTIES	MA	PHYS.&CHEM. TEST	ONE /HEAT / HEAT BATCH	APPROVED DRAWING / TECH. SPEC.	APPROVED DRAWING/ TECH. SPEC.	TEST CERT.	3/2	2	1	- CO-RELATED TCs SHALL BE FURNISHED. - FOR CAST IRON ONLY PHYSICAL TEST.
		2.SURFACE DEFECTS	MA	VISUAL	100%	MSS-SP-55	MSS-SP-55	LOG BOOK	3/2	2	1	
1.2	FLOAT UNIT ASSEMBLY, VALVE SEAT, PIVOT FRAME, SUPPORT FRAME, PIVOT PIN, VALVE SEAT, GASKET	1. PHYS., CHEM. PROPERTIES	MA	PHYS., CHEM. TEST	ONE /HEAT / HEAT BATCH	APPD. DRG	APPD. DRG	TEST CERT	3/2	2	1	
		2. SURFACE DEFECTS	MA	VISUAL	100%	MSS-SP-55	MSS-SP-55	INSPN. REPORT	3/2	2	1	
1.3	FASTENERS	1. PHYS., CHEM. PROPERTIES	MA	PHYS., CHEM. TEST	ONE PER TYPE	APPD. DRG	APPD. DRG	TEST CERT	3/2	2	1	
2.0	IN-PROCESS											
2.1	ALL COMPONENTS	1.DIMENSIONS	MA	MEASUREMENT	100%	MFG. DRAWING	MFG. DRAWING	INT. INSPN. REPORT	3/2	-	2	
		2. SURFACE DEFECTS	MA	VISUAL	100%	-DO-	-DO-	INSPN. REPORT	3/2	-	2	
2.2	VALVE, VALVE SEAT	1.SURFACE DEFECTS	CR	PENETRANT TEST	100%	ASTME-165	NO DEFECTS	INT. INSPN. REPORT	2	2	1	
		2. HARDNESS	MA	TESTING	100%	APPD. DRG.	APPD. DRG.	INT. INSPN. REPORT	2	2	1	
		3. BALL IMPRES	MA	BY AIR	100%	SEAT SURFACE SHALL HAVE METAL TO METAL CONTACT		INT. INSPN. REPORT	2	2	1	
3.0	SUB-ASSEMBLY											
3.1	VALVE & VALVE	1. LEAK TIGHTNESS	CR	AIR/HYDRO	100%	APPD. DRG	APPD. DRG.	INT. INSPN.	2	2	1	

BHEL		PARTICULARS		BIDDER/VENDOR	
		NAME			
		SIGNATURE			
		DATE			
				BIDDER'S/ VENDOR'S COMPANY SEAL	

<div><div>श्री राट्टी एंजिनीयर्स</div><div></div></div>	QUALITY PLAN			CUSTOMER: COMPAGNIE D'ELECTRICITE DU SENEGAL		PROJECT: 1x125 MW SENEGAL TPP			SPEC. NO : PE-SS-999-555-M011				
	SHEET 2 OF 3	BIDDER/VENDOR:	SYSTEM	SERVICE AIR/ INSTRUMENT AIR	CATE- GORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	QP NO. PE-QP-999-555-M001	REV.01	DT.15.03.2014	SPEC. TITLE AIR TRAPS		
								ITEM: BALL FLOAT AIR TRAP		SECTION VOLUME			
S.NO.	COMPONENT/ OPERATION	CHARACTERISTICS CHECKED						REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY P W V		REMARKS

SEAT								REPORT			
3.2	COVER	1. ALIGNMENT	MA	VISUAL	100%	--DO--	PROPER FITTING	INT. INSPN. REPORT	2	2	1
4.0	HYDRAULIC TEST (BEFORE GALVANISING)										
4.1	BODY COVER SHELL TEST (BEFORE GALVANISING)	LEAK TIGHTNESS	CR	HYDRO. TEST AT 2 TIMES OF DESIGN PR.	100%	APPD. DRG./TECH. SPEC./DATA SHEET	NO LEAKAGE	TEST CERT	2	2	1
5.0	GALVANISING										
5.1	HOT DIP GALVANISING OF BODY, COVER	1. SURFACE PREPARATION & THICKNESS OF GALVANISING & UNIFORMITY.	MA	VISUAL & MEASURE-MENT	100%	IS:2629	IS:2629	INSPN REPORT	2	2,1*	-
6.0	ASSEMBLY (AFTER GALVANISING)										
6.1	COMPLETE ASSEMBLY	1. CLEANLINESS & COMPLETENESS, DIMENSIONS, THREADING ENDS, ARROW MARKING ETC.	MA	VISUAL & MEASURE-MENT	100%	APPROVED DRAWING	APPROVED DRAWING	INSPN REPORT	2	2,1*	-
		2. LEAK TIGHTNESS OF BODY	CR	HYDRO. TEST AT 2 TIMES OF DESIGN PR.	100%	APPD. DRG./TECH. SPEC./DATA SHEET	NO LEAKAGE	TEST CERT	2	1*	-
		3. FUNCTIONAL TEST	CR	FUNCTION-AL TEST AT MAXIMUM WORKING PRESSURE	100 %	APPD DRG./ GIVEN PROCEDURE ON PAGE 3/3 OF THIS QP.	NO AIR LEAKAGE	TEST CERT.	2	1*	-

BHEL		PARTICULARS		BIDDER/VENDOR	
		NAME			
		SIGNATURE			
		DATE			
				BIDDER'S/ VENDOR'S COMPANY SEAL	

		QUALITY PLAN		CUSTOMER: COMPAGNIE D'ELECTRICITE DU SENEGAL		PROJECT: 1x125 MW SENEGAL TPP		SPEC. NO : PE-SS-999-555-M011	
		SHEET 3 OF 3		BIDDER/VENDOR:		QP NO. PE-QP-999-555-M001		REV.01 DT.15.03.2014	
COMPONENT/ OPERATION		CHARACTERISTICS CHECKED	CATEGORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	SYSTEM SERVICE AIR/ INSTRUMENT AIR		ITEM: BALL FLOAT AIR TRAP	
S.NO.						REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY
									P W V
									REMARKS

		(VISUAL DISCHARGE OF CONDENSATE)							
6.2	FLOW CAPACITY TEST (TYPE TEST)	CONDENSATE DISCHARGE	CR	DISCHARGE FLOW	1 PER PRESSURE RATING & ORIFICE SIZE TRAP	APPD. FLOW CAPACITY	APPD. FLOW CAPACITY	TYPE TEST CERTIFICATE	2 1
7.0	END CONN.	DIMENSIONS	CR	MEASUREMENT	100%	APPD. DRG./ TECH. SPEC.	APPD. DRG./ TECH. SPEC.	INSPN REPORT	2,1* -
8.0	VERIFICATION OF ALL PREVIOUS TEST CERTIFICATES	REVIEW OF ALL TEST CERTIFICATES/ INSP. REPORTS AS PER TECH. SPEC.	MA	VISUAL	100%	TECH. SPEC.	TECH. SPEC.	INSPN REPORT	2 1 -
9.0	PROVISION OF NAME PLATE WITH PURCHASER'S TRAP TAG NOS. & PACKING IN WOODEN CASES	AS PER TECHNICAL SPECIFICATION	MA	VISUAL	100%	--DO--	--DO--	INSPN REPORT	2 2,1 1

FUNCTIONAL TEST PROCEDURE: 1. COMPRESSED AIR AT MAXIMUM WORKING PRESSURE IS SUPPLIED IN A MIXING CHAMBER.

2. WATER IS ADDED IN THE SAME CHAMBER SO THAT AIR IN THE CHAMBER HAS SUFFICIENT MOISTURE


3. TRAP IS INSTALLED AT THE BOTTOM OF THIS CHAMBER AND ITS PERFORMANCE IS CHECKED.

A GOOD PERFORMING TRAP DRAINS OUT ONLY WATER DROPLETS AND RETAINS COMPRESSED AIR BACK IN THE SYSTEM.

NOTE:- CR- MEANS CRITICAL ACTIVITY MA- MEANS MAJOR ACTIVITY MI- MEANS MINOR ACTIVITY
1 = PURCHASER (BHEL) 2 = VENDOR 3 = SUB VENDOR OF THE VENDOR
P = PERFORMED BY W = WITNESSED BY V = VERIFIED BY


* The Quantum of check to be witnessed is 10% or Min. 2 Nos. at random by **BHEL/Customer & 100 % by Vendor for each type, Size & Rating.**

BHEL		PARTICULARS	BIDDER/VENDOR
		NAME	
		SIGNATURE	
		DATE	
			BIDDER'S/ VENDOR'S COMPANY SEAL

				QUALITY PLAN		CUSTOMER: COMPAGNIE D'ELECTRICITE DU SENEGAL BIDDER/VENDOR:		PROJECT: 1x125 MW SENEGAL TPP		SPEC. NO :PE-SS-999-555-M011	
SHEET 1 OF 2				SYSTEM		SERVICE/ INSTRUMENT AIR		QP NO. PE-QP-999-555-M016 REV.01 DT. DTD. 15.03.2014		SPEC. TITLE AIR TRAPS	
CHARACTERISTICS CHECKED				CATE-GORY		TYPE/METHOD OF CHECK		EXTENT OF CHECK		REFERENCE DOCUMENT	
COMPONENT/ OPERATION				MA		PHYS TESTS CHEM TESTS		ONE/HEAT/ BATCH		APPD. DATA SHEET/ TECH.SPEC.	
1.1 BODY, CAP				MA		VISUAL		100%		APPD. DATA SHEET/ TECH.SPEC.	
1.2 MESH				MA		CHEM. TESTS		1/SHEET		APPD. DATA SHEET/ TECH.SPEC.	
2.0 IN PROCESS CONTROL				MA		MEASUREMENT		SAMPLE PIECE		APPD. DATA SHEET/ TECH.SPEC.	
2.1 ALL COMPONENTS				MA		VISUAL		100%		MFG DRG	
3.0 HYDRAULIC TEST (BEFORE GALVANISING)				MA		MEASUREMENT		100%		MFG DRG	
3.1 BODY CAP (BEFORE GALVANIZING)				CR		LEAK TIGHTNESS		100%		TEST CERT	
4.0 GALVANISING				MA		VISUAL & MEASURE-MENT		100%		INSPN REPORT	
4.1 HOT DIP GALVANISING OF BODY, COVER				MA		PREPARATION & THICKNESS OF GALVANISING & UNIFORMITY.		100%		INSPN REPORT	

S.NO.	COMPONENT/ OPERATION	CHARACTERISTICS CHECKED	CATE-GORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY	REMARKS
									P W V	
1.0	MATERIAL CONTROL									
1.1	BODY, CAP	1. PHYS & CHEM PROPERTIES	MA	PHYS TESTS CHEM TESTS	ONE/HEAT/ BATCH	APPD. DATA SHEET/ TECH.SPEC.	APPD. DATA SHEET/ TECH.SPEC.	TEST CERT.	3/2	2
		2. SURFACE DEFECTS	MA	VISUAL	100%	--DO--	--DO--	INSPN. REPORT	3/2	2
1.2	MESH	1. CHEM PROPERTIES	MA	CHEM. TESTS	1/SHEET	APPD. DATA SHEET/ TECH.SPEC.	APPD. DATA SHEET/ TECH.SPEC.	TEST CERT	3/2	2
		2. MESH SIZE/ PERFORATION DIA	MA	MEASUREMENT	SAMPLE PIECE	--DO--	--DO--	INSPN REPORT	3/2	2
2.0	IN PROCESS CONTROL									
2.1	ALL COMPONENTS	1. WORKMANSHIP & FINISH	MA	VISUAL	100%	MFG DRG	MFG DRG	INSP REPORT	2	2
		2. DIMENSIONS	MA	MEASUREMENT	100%	MFG DRG	MFG DRG	MFG DRG	2	2
3.0	HYDRAULIC TEST (BEFORE GALVANISING)									
3.1	BODY CAP (BEFORE GALVANIZING)	LEAK TIGHTNESS	CR	HYDROTEST AT 2 TIMES THE DESIGN PRESSURE	100%	APPD.DRG/T ECH. SPEC	NO LEAKAGE	TEST CERT	2	2
										100% inspection/check to be done by manufacturer & 10% or min. 2 to be done by BHEL/Customer.
4.0	GALVANISING									
4.1	HOT DIP GALVANISING OF BODY, COVER	1. SURFACE PREPARATION & THICKNESS OF GALVANISING & UNIFORMITY.	MA	VISUAL & MEASURE-MENT	100%	IS:2629	IS:2629	INSPN REPORT	2	2,1 *
										THICKNESS MIN.40 MICRONS CHECKED WITH ELCOMETER

BHEL		PARTICULARS		BIDDER/VENDOR	
		NAME			
		SIGNATURE			
		DATE			
				BIDDER'S/ VENDOR'S COMPANY SEAL	

	QUALITY PLAN		CUSTOMER: COMPAGNIE D'ELECTRICITE DU SENEGAL		PROJECT: 1x125 MW SENEGAL TPP		SPEC. NO : PE-SS-999-555-M011			
			BIDDER/VENDOR:		QP NO. PE-QP-999-555-M016		REV.01 DT. DTD. 15.03.2014			
	SHEET 2 OF 2		SYSTEM SERVICE/INSTRUMENT AIR		ITEM: CARBON STEEL/CAST IRON Y-TYPE AIR STRAINER		SECTION VOLUME			
S.NO.	COMPONENT/ OPERATION	CHARACTERISTICS CHECKED	CATE- GORY	TYPE/METHOD OF CHECK	EXTENT OF CHECK	REFERENCE DOCUMENT	ACCEPTANCE NORMS	FORMAT OF RECORD	AGENCY P W V	REMARKS

5.0	ASSEMBLY CONTROL (AFTER GALVANISING)										
5.1	COMPLETE STRAINER	1. WORKMANSHIP AND FINISH	MA	VISUAL	100%	APPD.DRG	APPD.DRG	INSPN. REPORT	2	2	1
		2. OVERALL DIMENSIONS	CR	MEASUREMENT	100%	---DO---	DO---	--DO--	2	* 2,1	1
		3. LEAK TIGHTNESS,	CR	HYDROTEST AT 2 TIMES THE DESIGN PRESSURE	100%	APPD.DRG/T ECH. SPEC	NO LEAKAGE	TEST CERT	2	* 2,1	1
6.0	END CONN.	DIMENSIONS	CR	MEASUREMENT	100%	APPD DRG/ TECH SPEC.	APPD DRG/ TECH SPEC	INSPN REPORT	2	* 2,1	-
7.0	VERIFICATION OF ALL PREVIOUS TEST CERTIFICATES/ INSPN REPORTS	REVIEW OF ALL TEST CERTIFICATES/ INSPN. REPORTS OF PREVIOUS STAGES	MA	VISUAL	100%	TECH SPEC	TECH SPEC	INSPN REPORT	2	1	-
8.0	PROVISION OF NAME PLATE WITH PURCHADER'S STRAINER TAG NOS IF ANY & PACKING IN WOODEN CASES	AS PER TECH. SPEC	MA	VISUAL	100%	TECH. SPEC	TECH. SPEC	INSPN REPORT	3/2	2,1	1


NOTE: CR = CRITICAL ACTIVITY MA = MAJOR ACTIVITY MI = MINOR ACTIVITY

1 = PURCHASER (BHEL) 2 = VENDOR 3 = SUB VENDOR OF THE VENDOR

P = PERFORMED BY W = WITNESSED BY V = VERIFIED BY

* The Quantum of check to be witnessed is 10% or Min. 2 Nos. at random by BHEL/Customer & 100 % by Vendor for each type, Size& Rating.

BHEL	PARTICULARS	BIDDER/VENDOR
	NAME	
	SIGNATURE	
	DATE	
		BIDDER'S/ VENDOR'S COMPANY SEAL

	TECHNICAL SPECIFICATION AIR TRAPS PROJECT NAME	SPECIFICATION NO. PE-TS-315-100-M011	
		VOLUME : IIB	
		SECTION: D	
		REV. NO.: 00	DATE: 18.04.2014
		SHEET 1	OF 1

DATASHEET - C

Drawings/documents distribution schedule to be followed by the successful bidder:

1.0 The successful bidder shall submit the following drawings/documents within two weeks after award of contract.

- 1.1 Relevant drawings/leaflets for the traps showing following information.
 - i) Complete cross sectional arrangement of the traps.
 - ii) Binding dimensions, dismantling clearances & weights.
 - iii) Bill of material incorporating all the materials of construction of various parts along with BS/ASTM/IS standards to which the materials conform to.
 - iv) Special features, if any, as called for in the specific requirement
 - v) Type of oil/Grease wherever required and its annual consumption.
- 1.2 Quality Plan duly signed & stamped with bidder's seal.
- 2.0 Within the stipulated time period as per vendor's drawings/ documents schedule, the following shall be submitted but not later than one month before first dispatch.
 - a) Drawings of components & details as deemed necessary.
 - b) Instruction manual for erection, operation and maintenance.
 - c) Storage instructions.
- 3.0 Before dispatch of the equipment the vendor shall furnish the following.
 - a) Material Test certificates.
 - b) Shop test reports and certificates.
- 4.0 Distribution of drawings / documents for all projects:
After award of the contract the successful bidder shall furnish drawings/ documents as per following distribution schedule.

Sl. No.	Type of Document	No of Hard copies	No. of Soft copies
1	Documents submitted for Approval	2 Nos.	1 Nos.
2	Final Distribution(Approved Documents)	12 Nos.	1 Nos.
3	O&M Manuals	12 Nos.	2 Nos.

1X125MW SENEGAL TPP

VOLUME – III

TECHNICAL SCHEDULES


FOR

AIR TRAPS

SPECIFICATION NO: PE-TS-315-100-M011




BHARAT HEAVY ELECTRICALS LIMITED, POWER SECTOR
PROJECT ENGINEERING MANAGEMENT
NOIDA, INDIA

	AIR TRAPS 1X125MW SENEGAL TPP		SPECIFICATION NO. PE-TS-315-100-M011	
			VOLUME : III	
			SECTION:	
			REV. NO.: 00	DATE: 18.04.2014
			SHEET 1	OF 1

CONTENTS

SL.NO	TITLE
1	COMPLIANCE SHEET
2	SCHEDULE OF DEVIATIONS
3	SCHEDULE OF DECLARATIONS
4	SCHEDULE OF PRICES

	COMPLIANCE SHEET AIR TRAPS 1X125MW SENEGAL TPP	SPECIFICATION NO.:PE-TS-315-100-M011	
		VOLUME : III	
		SECTION:	
		REV. NO. 00	DATE : 18.04.2014
		SHEET 1 OF 2	


The bidder shall sign and return a copy of this compliance sheet along with his offer, indicating his compliance to the points specified herein:

A) Technical Details: Bidder to tick whichever is applicable.

1.	Technical requirements as per Data sheet-A & Standard Technical Specification of Vol IIB Section-D	Accepted	Not Accepted
2.	Quality Plan	Accepted	Not Accepted
3.	Specific Technical requirements of Vol IIB Section-C	Accepted	Not Accepted
4.	Documentation requirement as per Data sheet-C of Vol IIB Section-D	Accepted	Not Accepted
5.	Sea-Worthy Packing Specification no. PE-TS-888-100-A001	Accepted	Not Accepted

- B) Deviations to the technical specification are not acceptable. However, if there are any deviations due to unavoidable reasons then the same to be clearly specified in the schedule of deviation. In case of no deviations, schedule of deviations to be filled as NIL by bidder.
- C) The offered materials should be either equivalent or superior to those specified. Also for components where material is not specified, the material used shall be suitable for intended duty.
- D) QP/ test procedures shall be submitted in the event of order based on the guidelines given in the specification & QP enclosed therein. QP will be subject to BHEL/Customer approval in the event of order & customer hold points for inspection/ testing shall be marked in the QP at the contract stage. All Inspection/ testing shall be as per approved QP. The charges for 3rd party inspection (Lloyds, TUV or equivalent) for foreign bidders shall be included in the base price of the equipment by the bidder. This 3rd party inspection agency shall be approved by BHEL and will be decided in contract stage.
- E) All drawings/data – sheets etc. to be submitted during contract shall be subject to BHEL/Customer review/ approval.
- F) GA drawings, as submitted with offer at tender stage are for reference purpose only and shall be subject to approval during contract stage.
- G) The commissioning spares (if any) are supplied on 'As Required Basis' & prices for same shall be quoted in the price bid format. If the bidder has not quoted for commissioning spares at tender

PARTICULARS OF BIDDER / AUTHORISED REPRESENTATIVE				
NAME	DESIGNATION	SIGNATURE	DATE	
				COMPANY SEAL

	COMPLIANCE SHEET AIR TRAPS 1X125MW SENEGAL TPP		SPECIFICATION NO.:PE-TS-315-100-M011	
			VOLUME : III	
			SECTION:	
			REV. NO. 00	DATE : 18.04.2014
			SHEET 2 OF 2	

- H) All drawings/documents in soft as well as hard copy shall be submitted within 2 weeks from placement of Purchase orders in the event of order. A technical representative of bidder shall come for meeting with BHEL along with revised documents within one week of receipt of BHEL comments to resolve all issues and incorporate all comments in the soft copy for further submission to customer if required. Further, on receipt of customer comments on the documents a technical representative from bidder shall come for meeting to resolve all issues and incorporate all comments in the soft copy at BHEL and resubmit the drawings /documents for CAT I approval and shall visit customer/customer's consultant if required for across the table approval of documents.
- I) Any special tools & tackles, if required, shall be in bidder's scope.
- J) Prices for recommended spares (if any) for three year operation shall be furnished separately and not to be included in the base price.
- K) The offered model design should be of bidder's proven model and they should have designed, manufactured, supplied and tested the equipment of similar type and rating in at least Two (2) projects and be in satisfactory operation for last two (2) years.

PARTICULARS OF BIDDER / AUTHORISED REPRESENTATIVE				
NAME	DESIGNATION	SIGNATURE	DATE	COMPANY SEAL



TITLE

*** SCHEDULE OF DEVIATIONS**

() From Technical Specifications (Volume –II B)

SPECIFICATION NO
PE-TS-315-100-M011

VOL III

SHEET..... OF.....

We the undersigned hereby certify that the above mentioned are the only deviations.

PARTICULARS OF BIDDER / AUTHORISED REPRESENTATIVE

NAME	DESIGNATION	SIGNATURE	DATE	COMPANY SEAL
------	-------------	-----------	------	--------------

	TITLE *SCHEDULE OF DECLARATIONS	SPECIFICATION NO PE-TS-315-100-M011
		VOL III
		SHEET..... OF.....

* Bidder shall include this schedule both in technical and Price offers

DECLARATION

Icertify that all the technical data and information pertaining to this specification are correct and are true representation of the equipment/system covered by our format proposal number Dated and there is no deviation to the specification other than those listed in "Schedule of deviations" of this Vol III.

I hereby certify that I am duly authorized representative of the Bidder's company whose name appears above my signature.

Bidder's Company Name

.....

Authorised representative's
Signature

.....

Name

.....

Bidder's Name

The bidder hereby agrees to fully comply with the requirements and intent of this specification for the price indicated

PARTICULARS OF BIDDER / AUTHORISED REPRESENTATIVE				
NAME	DESIGNATION	SIGNATURE	DATE	
				COMPANY SEAL