

**TITLE****2X660 MW SEZ ENNORE STPP****FOR CW PUMP HOUSE ABOVE 50T UPTO 150T****Pre-bid Clarification Schedule**

SPECIFICATION NO. PE-TS-412-501-001

VOLUME: II B

REV 00

Section III

Page 1 of 1

ENQ NO: PE/PG/EN1/E-5418/2016 Dtd.29.12.2016**PRE-BID CLARIFICATION REPLY**

S. No.	Section/Clause/Page No.	Statement of the referred clause	Clarification Required	BHEL Reply
1.	Clause no 16.1 and 16.2, data sheet A Clause no. 3.4.2.2	AS per data sheet clause no 16.1 and 16.2 motor margin 25% and as per specification clause no. 3.4.2.2 Margin is 10 % over the calculated rating of motor.	Kindly clarify which is to be considered.	Motor margin of at least 25% over the maximum power requirement in the duty condition specified is to be considered.