

Annexure -V

PI 140610603 (WO 72602A17400)					
Sl. no.	Item Description	Qty.	Unit	Unit Rate	Value (in Rs.)
1	Supply of NIFPES System for Power Transformer along with FEC, CB & conservator isolation valve	1	No.		
2	Heat Sensor or Fire detector or LHD (25 meter)	8 / 25	No./Mtr.		
3	Supply of Fire survival cable	50	mtr.		
4	Supply of FRLS Armoured cable along with accessories for connection between Trs.- CB – FEC	300	mtr.		
5	Supply of FRLS Armoured cable along with accessories for connection between Relay panels to control box, DC source etc.	100	mtr.		
6	Supply of 6 mtrs. ERW Class 'C' pipes with support and fittings etc. for connections between Trs. and FEC	1	No.		
7	Supply of 10 mtrs pipes with fittings for connection between FEC and Oil pit	1	No.		
8	1 No. Spare Nitroigen cylinder (10 m3 at 150 Bar)	1	No		
9	1 set Spare Fire Detector (1 set means quantity required for 1 No. transformer)	1	Set		
Sub total (Total Supply portion Value)					
1	Installation & commissioning at any Customer site in India	1	No.		
Sub total (Total Service Portion Value)					

Total (Supply+I&C+ ~~Civil work~~)

Note:-

- 1 Minimum quantity indicated for Item 2 is for evaluation purpose. If actual quantity required as per the tank cover surface indicated in the OGA and as per RDSO Specifacaiton TI/SPC/PSI/TRNPWR/3200 is higher, then higher quantity shall be provided.
- 2 Length indicated against item 3, 4, 5 & 6 are only for evaluation purpose. For additional length of item 3, 4, 5 & 6, if required, at site to be provided on producing certificate from customer on pro-rata basis.
- 3 Supplier to comply RDSO specification for NIFPS (Annxure-1 of TI/SPC/PSI/TRNPWR/3200) with no technical deviation. Supplier may add items and accessories to meet specification criteria.
- 4 Gaurantee period for NIFPS system shall be 30 months from date of receipt or 24 months from date of commissioning of NIFPS at site, whichever is earlier.

Vendor to Quote for total (supply + I&C).

- Supply portion ^{value} shall be 80% of total value.
- I&C portion value shall be 20% of total value.

(Signature)